

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM
 REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8810070342 DOC. DATE: 88/09/29 NOTARIZED: NO DOCKET #
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296

AUTH. NAME RAY, M.J. AUTHOR AFFILIATION Tennessee Valley Authority
 RECIP. NAME Document Control Branch (Document Control Desk)
 RECIPIENT AFFILIATION

SUBJECT: Application for amends to Licenses DPR-33, DPR-52 & DPR-68 to change Browns Ferry Nuclear Tech Specs for Units 1, 2, & 3.

DISTRIBUTION CODE: D030D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+9
 TITLE: TVA Facilities - Routine Correspondence

NOTES: 1 Copy each to: F. McCoy, J.G. Partlow, S. Richardson, S. Black, 05000259
 B.D. Liaw.
 1 Copy each to: S. Black, J.G. Partlow, S. Richardson 05000260
 B.D. Liaw, F. McCoy.
 1 Copy each to: S. Black, J.G. Partlow, S. Richardson 05000296
 B.D. Liaw, F. McCoy.

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	SIMMS, M		1	1	PD		1	1	
	GEARS, G		1	1					
INTERNAL:	ACRS		1	1	ADM/LFMB		1	0	
	AEOD		1	1	NUDOCS-ABSTRACT		1	1	
	OGC/HDS2		1	0	<u>REG FILE</u> 01		1	1	
EXTERNAL:	LPDR		1	1	NRC PDR		1	1	
	NSIC		1	1					
NOTES:			5	5					

w/chodc
 \$150
 # 33684

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 15

R
I
D
S
/
A
D
D
S

R
I
D
S
/
A
D
D
S

ALA 2
8

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

SEP 29 1988

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

)
)
)

Docket Nos. 50-259
50-260
50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - UNITS 1, 2, AND 3 - TVA BFN TECHNICAL SPECIFICATION NO. 257 - SEISMIC MONITORING TABLES 3.2.J/4.2.J

In accordance with the provisions of 10 CFR 50.4 and 50.90, we are submitting a request for amendment to licenses DPR-33, DPR-52, an DPR-68 to change the BFN Technical Specifications of units 1, 2, and 3 (enclosure 1).

The proposed changes revise tables 3.2.J and 4.2.J for seismic monitoring to reflect the manufacturer's suggested testing frequency for triaxial peak accelerographs and to correct typographical errors in these tables.

The description, reason for change, and justification in support of the proposed changes are enclosed (enclosure 2). A proposed determination of no significant hazards consideration is provided in enclosure 3.

Enclosed is a check for the \$150 amendment fee required by 10 CFR Part 170.12. We request that these specifications be made effective 60 days after issuance in order to update the appropriate procedures.

8810070342 880929
PDR ADDCK 05000259
P PNU



Very truly yours,

TENNESSEE VALLEY AUTHORITY

M. J. Ray, Manager
Site Licensing Staff

Subscribed and sworn to before me on this 29th day of Sept 1988.

Mission Parker
Notary Public

My Commission Expires 2/7/90

Enclosures
cc: See page 2

1030
11
w/ check
\$150
33684



THE UNIVERSITY OF
MICHIGAN LIBRARY
ANN ARBOR, MICHIGAN

U.S. Nuclear Regulatory Commission

SEP 29 1988

cc (Enclosures):

Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Charles R. Christopher
Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Dr. C. E. Fox
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. J. E. Jones
General Electric Company
No. 1 Union Square
808 Krystal Building
Chattanooga, Tennessee 37402

Mr. F. R. McCoy, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Browns Ferry Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35611

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

1944

1944

ENCLOSURE 1

PROPOSED TECHNICAL SPECIFICATION REVISION

BROWNS FERRY NUCLEAR PLANT

UNITS 1, 2, AND 3

(TVA BFN TS 257)