

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8905240319 DOC. DATE: 89/05/15 NOTARIZED: YES DOCKET #
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296

AUTH. NAME RAY, M.J. AUTHOR AFFILIATION Tennessee Valley Authority
 RECIP. NAME RECIPIENT AFFILIATION Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-33, DPR-52 & DPR-68, updating Tech Spec Section 4.11.B.3.A.3.

DISTRIBUTION CODE: D030D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 2+11
 TITLE: TVA Facilities - Routine Correspondence

NOTES: 1 Copy each to: B. Wilson, D.M. Crutchfield, B.D. Liaw, S. Black 05000259/
 R. Pierson,
 1 Copy each to: S. Black, D.M. Crutchfield, B.D. Liaw, 05000260A
 R. Pierson, B. Wilson
 1 Copy each to: S. Black, D.M. Crutchfield, B.D. Liaw, 05000296D
 R. Pierson, B. Wilson

	RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
	SIMMS, M	1 1	PD	1 1
	GEARS, G	1 1		
INTERNAL:	ACRS	1 1	NUDOCS-ABSTRACT	1 1
	OC/LFMB	1 0	OGC/HDS2	1 0
	<u>REG FILE 01</u>	1 1		
EXTERNAL:	LPDR	1 1	NRC PDR	1 1
	NSIC	1 1		

NOTES: 5 5

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 16 ENCL 14

R
I
D
S
/
A
D
D
S

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

6N 38A Lookout Place

MAY 15 1989

TVA-BFN-TS-269

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket Nos. 50-259
50-260
50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - TVA BFN TECHNICAL SPECIFICATION NO. 269

In accordance with the provisions of 10 CFR 50.4 and 50.90, we are submitting a request for an amendment to licenses DPR-33, DPR-52, and DPR-68 to change the BFN Technical Specifications for units 1, 2, and 3 (enclosure 1). This proposed amendment updates technical specification section 4.11.B.3.A.3 to correct the pilot cell voltage for the diesel-driven high-pressure fire pump starting battery. In addition, this change adds damper FCO 150 G to TS 4.7.E.4 which was installed by a plant modification.

Description, reason for change, and justification in support of the proposed changes are enclosed (enclosure 2). A proposed determination of no significant hazards consideration is provided in enclosure 3. We request that these specifications be made effective 30 days after issuance.

If there are any questions, please telephone Patrick P. Carrier at (205) 729-3570.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

M. J. Ray
M. J. Ray, Manager,
Licensing Project Management

Subscribed and sworn to before
me on this 15th day of May 1989

Paulette H. White
Notary Public

My Commission Expires 11-4-92

Enclosures
cc: See page 2

8905240319 890515
PDR ADOCK 05000259
P PDC



0030
1/1

U.S. Nuclear Regulatory Commission

MAY 15 1989

cc (Enclosures):

Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Charles R. Christopher
Chairman, Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Dr. C. E. Fox
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36104

Mr. J. E. Jones
General Electric Company
No. 1 Union Square
808 Krystal Building
Chattanooga, Tennessee 37402

Mr. B. A. Wilson, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Browns Ferry Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35609-2000

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032



Small, faint, illegible marks or characters in the top right corner.

Faint, illegible text or markings in the upper middle section of the page.

Small, faint, illegible marks or characters in the middle section of the page.

Small, faint, illegible mark or character in the lower left section of the page.

Small, faint, illegible mark or character in the lower right section of the page.