

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9005240169 DOC. DATE: 90/05/18 NOTARIZED: NO DOCKET #
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296

AUTH. NAME AUTHOR AFFILIATION
 WALLACE, E.G. Tennessee Valley Authority
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-33, DPR-52 & DPR-68, revising Table 3.2.B & LCO for Operation 3.5.B.11.

DISTRIBUTION CODE: DF03D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+55
 TITLE: Direct Flow Distribution: Subject Files & 40,70,71 Dkts w/out LPDRs

NOTES: 1 Copy each to: B. Wilson, D.M. Crutchfield, B.D. Liaw, S. Black 05000259
 R. Pierson,
 1 Copy each to: S. Black, D.M. Crutchfield, B.D. Liaw, 05000260
 R. Pierson, B. Wilson
 1 Copy each to: S. Black, D.M. Crutchfield, B.D. Liaw, 05000296
 R. Pierson, B. Wilson

	RECIPIENT		COPIES		RECIPIENT	COPIES		
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR
INTERNAL:	NUDOCS-	ABSTRACT	1	1	REG FILE	01	1	1
EXTERNAL:	NRC	PDR	1	1				
NOTES:			5	5				

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTTR 8 ENCL 8

*AA-2
wfb*

R
I
D
S
/
A
D
D
S

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

MAY 18 1990

TVA-BFN-TS-280

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-259
Tennessee Valley Authority)	50-260
		50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - TVA BFN TECHNICAL SPECIFICATION (TS)
NO. 280 - CLARIFICATION FOR VESSEL HYDRO/INTEGRATED LEAK RATE TESTING (ILRT)
AND RECIRCULATION PUMP TRIP (RPT) INOPERABILITY

In accordance with the provisions of 10 CFR 50.4 and 50.90, TVA is submitting a request for an amendment to licenses DPR-33, DPR-52, and DPR-68 to change the BFN (TSs) for Units 1, 2, and 3 (Enclosure 1). This proposed amendment will: (1) revise Table 3.2.B and Limiting Conditions for Operation 3.5.B.11, 3.5.E.1, 3.5.F.1, 3.5.G.1, and 3.6.D.1 to clarify equipment operability requirements when the reactor is in the cold shutdown condition or during performance of inservice hydrostatic or leakage tests; (2) correct the maximum operating power level allowed with an inoperable RPT system(s) from 85 percent to 30 percent power; and (3) correct two typographical errors in Table 3.2.B.

Description, reason for change, and justification in support of the proposed changes are provided in Enclosure 2. A proposed determination of no significant hazards consideration is provided in Enclosure 3.

Change 1 above clarifies equipment operability during inservice hydrostatic testing, inservice leakage testing, and ILRT. TVA currently plans to perform this testing in August 1990. Therefore, NRC is requested to approve these changes by July 18, 1990, and make the issued amendments effective 15 days after issuance.

9005240169	900518
PDR	ADOCK
P	05000259
	PDC



D030
4/1



1944

U.S. Nuclear Regulatory Commission

MAY 18 1990


If there are any questions about these changes, please telephone Patrick P. Carier at (205) 729-3570.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs



Subscribed and sworn to before me on this 18th day of May, 1990.

Sandra D. Beal
Notary Public

My Commission Expires 11/4/92

Enclosures
cc: See page 3

1944



1944

1

2

3

4

5

6

7

8

9

U.S. Nuclear Regulatory Commission

MAY 18 1990

cc (Enclosures):

Ms. S. C. Black, Assistant Director
for Projects
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. Charles R. Christopher, Chairman
Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Dr. C. E. Fox
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36194

Mr. J. E. Jones
General Electric Company
No. 1 Union Square
808 Krystal Building
Chattanooga, Tennessee 37402

Mr. B. A. Wilson, Assistant Director
for Inspection Programs
TVA Projects Division
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35609-2000

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

0001 11 1951