

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9007100087 DOC. DATE: 90/07/03 NOTARIZED: YES DOCKET #
 FACIL: 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 AUTH. NAME AUTHOR AFFILIATION
 WALLACE, E.G. Tennessee Valley Authority
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for TS Change 284 to License DPR-52, updating
 Table 3.7.A, "Primary Containment Isolation Valves:"

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 22
 TITLE: OR Submittal: General Distribution

NOTES: 1 Copy each to: S.Black, B.WILSON 05000260

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID	CODE/NAME	LTTR	ENCL		ID	CODE/NAME	LTTR	ENCL
		KREBS, M.	1	1		PD	1	1	
		ROSS, T.	5	5					
INTERNAL:	ACRS		6	6		NRR/DET/ECMB 9H	1	1	
	NRR/DOEA/OTSB11		1	1		NRR/DST 8E2	1	1	
	NRR/DST/SELB 8D		1	1		NRR/DST/SICB 7E	1	1	
	NRR/DST/SRXB 8E		1	1		NUDOCS-ABSTRACT	1	1	
	OC/LFMB		1	0		OGC/HDS2	1	0	
	REG-FEE 01		1	1		RES/DSIR/EIB	1	1	
EXTERNAL:	LPDR		1	1		NRC PDR	1	1	
	NSIC		1	1					

NOTES: 5 5

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
 ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
 LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 32 ENCL 30

AA/12
 wb



Small, illegible handwritten marks in the top right corner.

Small, illegible handwritten marks on the left side of the page.

Two small, illegible handwritten marks in the center of the page.

Small, illegible handwritten mark in the middle right area.

Small, illegible handwritten marks on the left side, lower down.

Small, illegible handwritten marks in the lower center area.

Small, illegible handwritten mark in the lower right area.

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

5N 157B Lookout Place

TVA-BFN-TS-284

JUL 03 1990

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

)
)

Docket No. 50-260

BROWNS FERRY NUCLEAR PLANT (BFN) - TECHNICAL SPECIFICATION (TS) NO. 284 -
POST-ACCIDENT SAMPLING SYSTEM (PASS) AND AUTOMATIC DEPRESSURIZATION SYSTEM
(ADS) - UNIT 2

Reference: TVA letter to NRC, dated December 28, 1989, regarding BFN Nuclear
Performance Plan, Attachment IV-4, response to request for
additional information

In accordance with the provisions of 10 CFR 50.4 and 50.90, TVA is submitting
a request for an amendment to license DPR-52 to change the BFN TSs for unit 2
(Enclosure 1). Table 3.7.A, "Primary Containment Isolation Valves," is being
updated to reflect changes due to plant modifications. Section 6.0,
"Administrative Controls," is being revised to add requirements to maintain
post-accident sampling capabilities in accordance with the guidance of Generic
Letter 83-36, NUREG-0737 Technical Specifications. TVA committed to submit
this TS Amendment prior to restart in the above reference.

A summary of the proposed changes is provided in Enclosure 2. The reason and
justification for the proposed changes is provided in Enclosure 3. A proposed
determination of no significant hazards consideration is provided in
Enclosure 4.

9007100087 900703
PDR ADOCK 05000260
P PDC

D

An Equal Opportunity Employer

Adol
11

U.S. Nuclear Regulatory Commission

JUL 03 1990

TVA requests that these changes be made effective 30 days after NRC approval. If there are any questions about these changes, please telephone Patrick P. Carrier at (205) 729-3570.

Very truly yours,

TENNESSEE VALLEY AUTHORITY



E. G. Wallace, Manager
Nuclear Licensing and
Regulatory Affairs



Subscribed and sworn to before me
on this 3rd day of July 1990

Sandra D. Brook
Notary Public

My Commission Expires 11/4/92

Enclosures
cc: See page 3

1970



U.S. Nuclear Regulatory Commission

JUL 03 1990

cc (Enclosures):

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

Ms. S. C. Black, Project Chief
I-IV
TVA Projects Division
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike, MS 13H2
Rockville, Maryland 20852

Mr. Charles R. Christopher, Chairman
Limestone County Commission
P.O. Box 188
Athens, Alabama 35611

Dr. C. E. Fox
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36194

Mr. J. E. Jones
General Electric Company
735 Broad Street
Suite 1108 James Bldg.
Chattanooga, Tennessee 37402

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35609-2000

Mr. B. A. Wilson, Chief
of TVA Projects
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

100

100