

ACCELERATED DISTRIBUTION DEMONSTRATION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9109240394 DOC. DATE: 91/09/13 NOTARIZED: YES DOCKET #
 FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259
 50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260
 50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296

AUTH. NAME AUTHOR AFFILIATION
 ZERINGUE, O.J. Tennessee Valley Authority
 RECIPIENT NAME RECIPIENT AFFILIATION
 Document Control Branch (Document Control Desk)

SUBJECT: Application for amends to Licenses DPR-33, DPR-52 & DPR-63, extending logic sys functional testing surveillance interval for accident signal logic.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3 + 19
 TITLE: OR Submittal: General Distribution

NOTES:

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTTR	ENCL		ID CODE/NAME		LTTR	ENCL
	SANDERS, M.		1	1		HEBDON, F		1	1
	ROSS, T.		2	2		WILLIAMS, J.		2	2
INTERNAL:	ACRS		6	6		NRR/DET/ECMB 7D		1	1
	NRR/DET/ESGB		1	1		NRR/DOEA/OTSB11		1	1
	NRR/DST 8E2		1	1		NRR/DST/SELB 7E		1	1
	NRR/DST/SICB8H7		1	1		NRR/DST/SRXB 8E		1	1
	NUDOCS-ABSTRACT		1	1		OC/LFMB		1	0
	OGC/HDS3		1	0		REG FILE 01		1	1
	RES/DSIR/EIB		1	1					
EXTERNAL:	NRC PDR		1	1		NSIC		1	1


NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM P1-37 (EXT. 20079) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 26 ENCL 24

AA2

R
I
D
S
/
A
D
D
S
/
A
D
D
S





Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

SEP 13 1991

TVA-BFN-TS-299

10 CFR 50.90

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)
Tennessee Valley Authority)

Docket Nos. 50-259
50-260
59-296

BROWNS FERRY NUCLEAR PLANT (BFN) - UNITS 1, 2, AND 3 - TVA BFN TECHNICAL SPECIFICATION (TS) NO. 299 - LOGIC SYSTEM FUNCTIONAL TESTING (LSFT) SURVEILLANCE INTERVAL REVISION

In accordance with the provisions of 10 CFR 50.4 and 50.90, we are submitting a request for an amendment to licenses DPR-33, DPR-52, and DPR-68 to change the BFN Technical Specifications for Units 1, 2, and 3 (Enclosure 1). This proposed amendment will extend the LSFT surveillance interval for the Common Accident Signal Logic, 4 kV Shutdown Board Undervoltage Start of the Diesel Generator, 480V Load Shedding Logic, the Residual Heat Removal Service Water Initiation Logic, Control Room Isolation Logic, Reactor Building Isolation Logic, and the Standby Gas Treatment System Logic.

A description, reason for change, and justification in support of the proposed changes are enclosed (Enclosure 2). A proposed determination of no significant hazards considerations is provided in Enclosure 3. These changes are similar to the changes which were issued by NRC on February 12, 1988 as Amendments 144, 140, and 115 for Units 1, 2, and 3, respectively. TVA considers the changes requested by this application to be bounded by the NRC's Safety Evaluation supporting the previous amendments. We request that these changes be made effective by November 6, 1991 when the first of these tests is due for performance.

9109240394 910913
PDR ADOCK 05000259
PDR



ADOCK 1/1



23

2

.

U.S. Nuclear Regulatory Commission

SEP 13 1991

cc (Enclosures):

American Nuclear Insurers
Attention: Librarian
The Exchange, Suite 245
270 Farmington Avenue
Farmington, Connecticut 06032

Mr. Johnny Black, Chairman
Limestone County Commission
310 Washington Street
Athens, Alabama 35611

Dr. C. E. Fox
State Health Officer
State Department of Public Health
State Office Building
Montgomery, Alabama 36194

Mr. J. E. Jones
General Electric Company
735 Broad Street
Suite 1108 James Building
Chattanooga, Tennessee 37402

NRC Resident Inspector
Brown's Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35609-2000

Mr. Thierry M. Ross, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

U.S. Nuclear Regulatory Commission

SEP 13 1991

If you have any questions, please contact Patrick P. Carrier, at (205) 729-3566.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

Patrick P. Carrier

O. J. Zeringue

for

Enclosures

cc: See page 3

Subscribed and sworn to before me on this 13th day of Sept. 1991.

Barbara A. Blanton

Notary Public

My Commission Expires 10-30-84

My Commission Expires _____

