

ACCELERATED DOCUMENT DISTRIBUTION SYSTEM

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9303180239 DOC. DATE: 92/12/31 NOTARIZED: NO DOCKET #

FACIL: 50-259 Browns Ferry Nuclear Power Station, Unit 1, Tennessee 05000259

50-260 Browns Ferry Nuclear Power Station, Unit 2, Tennessee 05000260

50-296 Browns Ferry Nuclear Power Station, Unit 3, Tennessee 05000296

AUTH. NAME AUTHOR AFFILIATION *See Reports*

PIERCE, G.D. Tennessee Valley Authority

RECIP. NAME RECIPIENT AFFILIATION

SUBJECT: "Browns Ferry Nuclear Plant Semiannual Radiological Effluent Release Rept, Jul-Dec 1992." W/930301 ltr.

DISTRIBUTION CODE: IE48D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 275

TITLE: 50.36a(a)(2) Semiannual Effluent Release Reports

NOTES:

	RECIPIENT	COPIES	RECIPIENT	COPIES
	ID CODE/NAME	LTR ENCL	ID CODE/NAME	LTR ENCL
	PD2-4	3 3	HEBDON, F	1 1
	ROSS, T.	1 1	WILLIAMS, J.	1 1
INTERNAL:	ACRS	1 1	NRR/DRSS/PRPB11	2 2
	REG FILE 01	1 1	RGN2 DRSS/RPB	2 2
	RGN2 FILE 02	1 1		
EXTERNAL:	BNL TICHLER, J03	1 1	EG&G SIMPSON, F	2 2
	NRC PDR	1 1		


NOTE TO ALL "RIDS" RECIPIENTS:

ER-1

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM P1-37 (EXT. 504-2065) TO ELIMINATE YOUR NAME FROM DISTRIBUTION
LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 17

R
I
D
S
/
A
D
D
S
/
A
D
D
S





Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

MAR 01 1993

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of)	Docket Nos. 50-259
Tennessee Valley Authority)	50-260
		50-296

**BROWNS FERRY NUCLEAR PLANT (BFN) - SEMIANNUAL RADIOACTIVE EFFLUENT
RELEASE REPORT - JULY THROUGH DECEMBER 1992**

In accordance with the BFN Radiological Effluent Manual, Section F.2, and Regulatory Guide 1.21, Revision 1, two copies of the Semiannual Radioactive Effluent Release Report are provided. The report consists of the following:

1. The Radiological Impact Report (Enclosure 1)
2. Effluent and Waste Disposal Semiannual Report (Enclosure 2)
3. The Inoperable Radiological Effluent Instrumentation Report (Enclosure 3)
4. Changes to the Offsite Dose Calculation Manual (Enclosure 4)

BFN Technical Specifications 3.2.D.2, 3.2.K.2, and 6.12.2 require the Inoperable Radioactive Effluent Instrumentation Report and changes to the Offsite Dose Calculation Manual to be included with the Semiannual Radioactive Effluent Release Report.

180071

IEA 8
11


9303180239	921231
PDR	ADDOCK
R	05000259
	PDR

U.S. Nuclear Regulatory Commission

MAR 01 1993

Please refer any questions or comments to me at (205) 729-7566.

Sincerely,



G. D. Pierce
Interim Manager of Site Licensing
PAB 1G-BFN


Enclosure

cc (Enclosure):

NRC Resident Inspector
Browns Ferry Nuclear Plant
Route 12, Box 637
Athens, Alabama 35611

Mr. Thierry M. Ross, Project Manager
U.S. Nuclear Regulatory Commission
One White Flint, North
11555 Rockville Pike
Rockville, Maryland 20852

Mr. B. A. Wilson, Project Chief
U.S. Nuclear Regulatory Commission
Region II
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323



9303/80239

ENCLOSURE 1

TENNESSEE VALLEY AUTHORITY
SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
BROWNS FERRY NUCLEAR PLANT (BFN)

"THE RADIOLOGICAL IMPACT ASSESSMENT REPORT"

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

INTRODUCTION

Potential doses to maximum individuals and the population around Browns Ferry are calculated for each quarter as required in Section 5.2 of the Offsite Dose Calculation Manual (ODCM). Measured plant releases for the reporting period are used to estimate these doses. Dispersion of radioactive effluents in the environment is estimated using meteorological data and riverflow data measured during the period. In this report, the doses resulting from releases are described and compared to limits established for Browns Ferry.

DOSE LIMITS

The ODCM specifies limits for the release of radioactive effluents, as well as limits for doses to the general public from the release of radioactive effluents. These limits are set well below the NRC 10CFR20 limits which govern the concentrations of radioactivity and exposures permissible in unrestricted areas. This ensures that radioactive effluent releases are as low as reasonably achievable (ALARA).

The limits for doses at or beyond the site boundary from airborne noble gases releases are:

Less than or equal to 5 mrad per quarter and 10 mrad per year (per reactor unit) for gamma radiation,

- and -

Less than or equal to 10 mrad per quarter and 20 mrad per year (per reactor unit) for beta radiation.

The limit for the dose to a member of the general public at or beyond the site boundary from iodines and particulates released in airborne effluents is:

Less than or equal to 7.5 mrem per quarter and 15 mrem per year (per reactor unit) to any organ.

The limit for doses to a member of the general public from radioactive material in liquid effluents released to unrestricted areas, is:

Less than or equal to 1.5 mrem per quarter and 3 mrem per year (per reactor unit) to the total body,

- and -

Less than or equal to 5 mrem per quarter and 10 mrem per year (per reactor unit) to any organ



Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

The Environmental Protection Agency (EPA) limits for total dose to the public in the vicinity of a nuclear power plant, established in the Environmental Dose Standard of 40 CFR 190, are:

Less than or equal to 25 mrem per year to the total body,

Less than or equal to 75 mrem per year to the thyroid,

- and -

Less than or equal to 25 mrem per year to any other organ.

DOSE CALCULATIONS

Estimated doses to the public are determined using computer models (the Gaseous Effluent Licensing Code, GELC, and the Quarterly Water Dose Assessment Code, QWATA). These models are based on guidance provided by the NRC (in Regulatory Guides 1.109, 1.111 and 1.113) for determining the potential dose to individuals and populations living in the vicinity of the plant. The area around the plant is analyzed to determine the pathways through which the public may receive a dose. The doses calculated are a representation of the dose to a "maximum exposed individual." Some of the factors used in these calculations (such as ingestion rates) are maximum values. Many of these factors are obtained from NUREG/CR-1004. The values chosen will tend to overestimate the dose to this "maximum" person. The expected dose to actual individuals is lower. The calculated doses are presented in Tables 1A through 3.

DOSES FROM AIRBORNE EFFLUENTS

For airborne effluents, the public can be exposed to radiation from several sources: direct radiation from the radioactivity in the air, direct radiation from radioactivity deposited on the ground, inhalation of airborne radioactivity, ingestion of vegetation which contains radioactivity deposited from the atmosphere, and ingestion of milk and beef which contains radioactivity deposited from the atmosphere onto vegetation which is then eaten by milk and beef animals.

Airborne Release Points

There are four routine release points from Browns Ferry Nuclear Plant: the turbine building, the radwaste building, the reactor building, and the stack.

Releases from the turbine building are considered ground-level releases. The ground-level joint frequency distribution (JFD) is derived from windspeeds and directions measured 10 meters above ground and from the vertical temperature difference between 10 and 46 meters, and is presented in Table 4A and 4B.



Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

Releases from the radwaste and reactor buildings are considered split-level releases. Portions of the release are treated as elevated while other portions are considered ground-level depending on the ratio of the vertical exit velocity to the horizontal wind speed. The split-level dispersion approach is implemented using a model that requires two complete quarterly JFDs for each effluent vent, one for the elevated releases and one for the ground-level releases. The ground-level portion of the split-level JFD is based on wind speeds and directions measured 10 meters above ground-level and from the vertical temperature difference between 10 and 46 meters. The elevated portion of the split-level JFD is based on wind speeds and direction measurements at the 46-meter level and the vertical temperature difference between 46 and 91 meters. Both of these JFDs are given in Tables 5A, 5B, 5C and 5H.

Releases from the stack are considered to be elevated-level releases. The JFDs for elevated releases are based on wind directions and wind speeds measured at 91 meters and the vertical temperature difference between 46 and 91 meters, and are given in Tables 6A and 6B.

Meteorological Data

Meteorological variables at Browns Ferry are measured continuously. Measurements collected include wind speed, wind direction, and temperature at heights of 10, 46 and 91 meters above the ground. Quarterly joint frequency distributions (JFDs) are calculated for each release point using the appropriate levels of meteorological data. A joint frequency distribution gives the percentage of the time in a quarter that the wind is blowing out of a particular upwind compass sector in a particular range of wind speeds for a given stability class A through G. The wind speeds are divided into nine wind speed ranges. Calms are distributed by direction in proportion to the distribution of noncalm wind directions less than 0.7 m/s (1.5 mph). Stability classes are determined from the vertical temperature difference between two measurement levels. The JFDs are given in Tables 4A, 4B, 5A, 5B, 5C, 5H, 6A and 6B.

The generally open terrain around BFN is not believed to cause any significant effects on the transport and dispersion of gaseous effluents from the plant. Within 30 kilometers of BFN, the terrain is mostly gently rolling hills (30-60 meters). Between 30 and 80 kilometers the hills become larger to the north and south, and mountainous to the east and northeast. The Tennessee River/Wheeler Lake may have a minor effect on transport and dispersion in the immediate vicinity of BFN during periods of winds with a southerly component, overcast skies, and relatively high wind speeds. Then, the lower layer (10-46 meters) stability class tends to be more stable than would be expected. However, during this infrequent condition, dose estimates will be conservative.

External Exposure Dose

Dose estimates for maximum external air exposures (gamma-air and beta-air doses) are made for points at and beyond the site boundary as described in the BFN ODCM.

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

Submersion Dose

External doses to the skin and total body, due to submersion in a cloud of noble gases, are estimated for the nearest residence in each sector.

Organ Dose

Doses to organs due to releases of airborne effluents are estimated for the inhalation, ground contamination, and ingestion pathways. The ingestion pathway is further divided into four possible contributing pathways: ingestion of cow/goat milk, ingestion of beef, and ingestion of vegetables. Doses from applicable pathways are calculated for each real receptor location identified in the most recent land use survey. To determine the maximum organ dose, the doses from the pathways are summed for each receptor. For the ingestion dose, however, only those pathways that exist for each receptor are considered in the sum, i.e., milk ingestion doses are included only for locations where milk is consumed without commercial preparation and vegetable ingestion is included only for those locations where a garden is identified. To conservatively account for beef ingestion, a beef ingestion dose equal to that for the highest site boundary location is added to each identified receptor. For ground contamination, the dose added to the organ dose being calculated is the total body dose calculated for that location, i.e., it is assumed that the dose to an individual organ is equal to the total body dose.

Doses from airborne effluents are presented in Table 1A and 1B.

DOSES FROM LIQUID EFFLUENTS

For liquid effluents, the public can be exposed to radiation from three sources: the ingestion of water from the Tennessee River, the ingestion of fish caught in the Tennessee River, and direct exposure from radioactive material deposited on the river shoreline sediment (recreation).

The concentrations of radioactivity in the Tennessee River are estimated by a computer model which uses measured hydraulic data downstream of Browns Ferry. Parameters used to determine the doses are based on guidance given by the NRC (in Regulatory Guides 1.109) for maximum ingestion rates, exposure times, etc. Wherever possible, parameters used in the dose calculation are site specific use factors determined by TVA. The models that are used to estimate doses, as well as the parameters input to the models, are described in detail in the Browns Ferry Nuclear Plant ODCM.

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

Liquid Release Points and River Data

Radioactivity concentrations in the Tennessee River are calculated assuming that releases in liquid effluents are continuous. All routine liquid releases from Browns Ferry, located at Tennessee River Mile 294, are made through diffusers which extend into the Tennessee River. It is assumed that releases to the river through these diffusers will initially be entrained in one-fifth of the water which flows past the plant. The QWATA code makes the assumption that this mixing condition holds true until the water is completely mixed at the first downstream dam, at Tennessee River Mile 283.0.

Doses are calculated for locations between the plant site and the mouth of the Tennessee River. The maximum potential recreation dose is calculated for a location immediately downstream from the plant outfall. The maximum individual dose from ingestion of fish is assumed to be that calculated for the consumption of fish caught anywhere between the plant and the first downstream dam (Wheeler Dam). The maximum individual dose from drinking water is assumed to be that calculated at the nearest downstream public water supply (Champion Paper Company). This could be interpreted as indicating that the maximum individual, as assumed for liquid releases from Browns Ferry, is an individual who obtains all of his drinking water at the Champion Paper Company, consumes fish caught from the Tennessee River between BFN and Wheeler Dam, and spends 500 hours per year on the shoreline just below the outfall from Browns Ferry. Dose estimates for the maximum individual due to liquid effluents for each quarter in the period are presented in Tables 2A and 2B, along with the average river flows past the plant site for the periods.

POPULATION DOSES

Population doses for highest exposed organ due to airborne effluents are calculated for an estimated 627,000 persons living within a 50-mile radius of the plant site. Ingestion population doses are calculated assuming that each individual consumes milk, vegetables, and meat produced with the sector annulus in which he resides. Doses from external pathways and inhalation are based on the 50-mile human population distribution.

Population doses for total body and the maximum exposed organ due to liquid effluents are calculated for the entire downstream Tennessee River Population. Water ingestion population doses are calculated using actual population figures for downstream public water supplies. Fish ingestion population doses are calculated assuming that all sport fish caught in the Tennessee River are consumed by the Tennessee River population. Recreation population doses are calculated using actual recreational data on the number of shoreline visits at downstream locations.

Population dose estimates for airborne and liquid effluents are presented in Tables 1A, 1B, 2A and 2B.



Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

DIRECT RADIATION

External gamma radiation levels were measured by thermoluminescent dosimeters (TLDs) deployed around BFN. The quarterly gamma radiation levels determined from these TLDs during this reporting period averaged approximately 15.6 mR/quarter at onsite stations and approximately 13.8 mR/quarter at offsite stations, or approximately 1.8 mR/quarter higher onsite than at offsite stations. This is consistent with levels reported at TVA's nonoperating nuclear power plant construction sites where the average radiation levels onsite are generally 2-6 mR/quarter higher than the levels offsite. This may be attributable to natural variations in environmental radiation levels, earth moving activities onsite, the mass of concrete employed in the construction of the plants, or other undetermined influences. Fluctuations in natural background dose rates and in TLD readings tend to mask any small increments which may be due to plant operations. Thus, there was no identifiable increase in dose rate levels attributable to direct radiation from plant equipment and/or gaseous effluents.

DOSE TO MEMBERS OF THE PUBLIC INSIDE THE SITE BOUNDARY

No routine activities within the site boundary by members of the public have been identified which would lead to their radiation exposure.

TOTAL DOSE

To determine compliance with 40 CFR 190, annual total dose contributions to the maximum individual from BFN radioactive effluents and all other nearby uranium fuel cycle sources are considered.

The annual dose to any organ other than thyroid for the maximum individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the critical organ dose (for any organ other than the thyroid) from airborne effluents for each quarter from ground contamination, inhalation and ingestion, the total body dose from liquid effluents for each quarter, the maximum organ dose (for any organ other than the thyroid) from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the environmental monitoring program. This dose is compared to the 40 CFR 190 limit for total body or any organ dose (other than thyroid) to determine compliance.

The annual thyroid dose to the maximum individual is conservatively estimated by summing the following doses: the total body air submersion dose for each quarter, the thyroid dose from airborne effluents for each quarter, the total body dose from liquid effluents for each quarter, the thyroid dose from liquid effluents for each quarter, and any identifiable increase in direct radiation dose levels as measured by the environmental monitoring program. This dose is compared to the 40 CFR 190 limit for thyroid dose to determine compliance.

Cumulative annual total doses are presented in Table 3.

Radiological Impact Assessment
 Browns Ferry Nuclear Plant
 July - December 1992

TABLE 1A

Doses from Airborne Effluents
 Third Quarter 1992

Individual Doses

<u>Pathway</u>	<u>Dose</u>	<u>Quarterly Limit</u>	<u>Percent of Limit</u>	<u>Location</u>
External				
Gamma air	6.9E-03 mrad	5 mrad	< 1 %	NW/7400 meters
Beta air	3.4E-03 mrad	10 mrad	< 1 %	NW/7400 meters
Submersion				
Total Body	8.5E-03 mrem	10 mrad	< 1 %	NE/3772 meters
Skin	1.3E-02 mrem	10 mrad	< 1 %	NE/3772 meters
Organ Doses				
Child/Liver	5.9E-02 mrem	7.5 mrem	1 %	NNW/1791 meters
Child/Thyroid	2.5E-02 mrem	7.5 mrem	< 1 %	NNW/1791 meters
Child/Total Body	7.6E-03 mrem	7.5 mrem	< 1 %	NNW/1791 meters

Population Doses

<u>Total Body Dose</u>	1.7E-01 man-rem
<u>Maximum Organ Dose (organ)</u>	1.9E-01 man-rem (bone)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 56,430 man-rem/yr (based on 90 mrem/year for natural background).

Radiological Impact Assessment
 Browns Ferry Nuclear Plant
 July - December 1992

TABLE 1B

Doses from Airborne Effluents
 Fourth Quarter 1992

Individual Doses

<u>Pathway</u>	<u>Dose</u>	<u>Quarterly Limit</u>	<u>Percent of Limit</u>	<u>Location</u>
External				
Gamma air	1.4E-02 mrad	5 mrad	< 1 %	NW/7600 meters
Beta air	6.8E-03 mrad	10 mrad	< 1 %	NW/7600 meters
Submersion				
Total Body	1.7E-02 mrem	10 mrad	< 1 %	SSE/6706 meters
Skin	2.6E-02 mrem	10 mrad	< 1 %	SSE/6706 meters
Organ Doses				
Child/Liver	4.9E-02 mrem	7.5 mrem	< 1 %	NNW/1791 meters
Child/Thyroid	4.6E-02 mrem	7.5 mrem	< 1 %	NNW/1791 meters
Child/Total Body	4.4E-02 mrem	7.5 mrem	< 1 %	NNW/1791 meters

Population Doses

<u>Total Body Dose</u>	4.7E-01 man-rem
<u>Maximum Organ Dose (organ)</u>	4.8E-01 man-rem (liver)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 56,430 man-rem/yr (based on 90 mrem/year for natural background).

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 2A

Doses from Liquid Effluents
Third Quarter 1992

Individual Dose (mrem)

<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>	<u>Quarterly Limit</u>	<u>Percent of Limit</u>
Adult	Total Body	4.8E-02	1.5 mrem	3.2%
Teen	Liver	7.2E-02	5 mrem	1.5%
Child	Thyroid	5.8E-03	5 mrem	< 1.0%

Average Riverflow past BFN (cubic feet per second): 35,275

Population Doses

Total Body Dose 4.3E-01 man-rem

Maximum Organ Dose (organ) 6.4E-01 man-rem (liver)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 56,430 man-rem/yr (based on 90 mrem/year for natural background).

Radiological Impact Assessment
 Browns Ferry Nuclear Plant
 July - December 1992

TABLE 2B

Doses from Liquid Effluents
 Fourth Quarter 1992

Individual Dose (mrem)

<u>Age Group</u>	<u>Organ</u>	<u>Dose (mrem)</u>	<u>Quarterly Limit</u>	<u>Percent of Limit</u>
Adult	Total Body	2.4E-02	1.5 mrem	2 %
Teen	Liver	3.5E-02	5 mrem	< 1 %
Child	Thyroid	3.5E-03	5 mrem	< 1 %

Average Riverflow past BFN (cubic feet per second): 61,988

Population Doses

Total Body Dose 1.7E-01 man-rem

Maximum Organ Dose (organ) 2.8E-01 man-rem (liver)

Population doses can be compared to the natural background dose for the entire 50-mile population of about 56,430 man-rem/yr (based on 90 mrem/year for natural background).



Radiological Impact Assessment
 Browns Ferry Nuclear Plant
 July - December 1992

TABLE 3

Total Dose from Fuel Cycle

<u>Dose</u>	<u>First</u> <u>Quarter</u>	<u>Second</u> <u>Quarter</u>	<u>Third</u> <u>Quarter</u>	<u>Fourth</u> <u>Quarter</u>
Total Body or any Organ (except thyroid)				
Total body air submersion	1.2E-03	6.4E-03	8.5E-03	1.7E-02
Critical organ dose (air)	6.0E-03	1.6E-02	5.9E-02	4.9E-02
Total body dose (liquid)	1.2E-02	4.7E-02	4.8E-02	2.3E-02
Maximum organ dose (liquid)	1.7E-02	6.8E-02	7.2E-02	3.4E-02
Direct radiation dose	0.0E-00	0.0E-00	0.0E-00	0.0E-00
Total	3.6E-02	1.4E-01	1.9E-01	1.2E-01
Cumulative Total Dose (Total Body or other organ) mrem				4.9E-01
Annual Limit mrem				2.5E+01
Percentage of Limit				2 %

Thyroid Dose (mrem)

Total body air submersion	1.2E-03	6.4E-03	8.5E-03	1.7E-02
Thyroid dose (airborne)	6.0E-03	1.6E-02	2.5E-02	4.6E-02
Total body dose (liquid)	1.2E-02	4.7E-02	4.8E-02	2.3E-02
Thyroid dose (liquid)	3.9E-03	4.9E-03	5.8E-03	3.5E-03
Direct radiation dose	0.0E-00	0.0E-00	0.0E-00	0.0E-00
Total (Thyroid)	2.3E-02	7.4E-02	8.7E-02	9.0E-02
Cumulative Total Dose (Thyroid) mrem				2.7E-01
Annual Limit mrem				7.5E+01
Percentage of Limit				< 1 %

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 4A.

Joint Frequency Distribution in Percent
for Ground Level Releases
Third Quarter 1992

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (D₀ = 0.5 T₀ ≤ -1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥24.5	
N	0.0	0.0	0.0	0.0	0.0	0.187	0.0	0.0	0.0	0.187
NNE	0.0	0.0	0.0	0.0	0.0	0.890	0.094	0.0	0.0	0.984
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.609	0.094	0.0	0.0	0.0	0.0	0.703
SE	0.0	0.0	0.187	0.797	0.0	0.0	0.0	0.0	0.0	0.984
SSE	0.0	0.0	0.984	0.187	0.0	0.0	0.0	0.0	0.0	1.172
S	0.0	0.047	0.328	0.375	0.0	0.0	0.0	0.0	0.0	0.750
SSW	0.0	0.0	0.047	0.281	0.0	0.0	0.0	0.0	0.0	0.328
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.0	0.0	0.047
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.047
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.047	1.546	2.296	0.094	1.125	0.094	0.0	0.0	5.201

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2167
 TOTAL HOURS OF STABILITY CLASS A 112
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 111
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 5.3 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B ($-\Delta T \leq -1.7$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥ 24.5	
N	0.0	0.0	0.0	0.0	0.0	0.094	0.0	0.0	0.0	0.094
NNE	0.0	0.0	0.0	0.0	0.094	0.234	0.0	0.0	0.0	0.328
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.047	0.0	0.047	0.0	0.0	0.0	0.0	0.094
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.047	0.187	0.047	0.0	0.0	0.0	0.0	0.281
SE	0.0	0.0	0.515	0.187	0.0	0.0	0.0	0.0	0.0	0.703
SSE	0.0	0.0	0.375	0.094	0.0	0.0	0.0	0.0	0.0	0.469
S	0.0	0.0	0.562	0.047	0.0	0.0	0.0	0.0	0.0	0.609
SSW	0.0	0.0	0.094	0.141	0.0	0.0	0.0	0.0	0.0	0.234
SW	0.0	0.0	0.094	0.187	0.047	0.0	0.0	0.0	0.0	0.328
WSW	0.0	0.0	0.0	0.0	0.094	0.0	0.0	0.0	0.0	0.094
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.047	0.047	0.047	0.0	0.0	0.0	0.141
NNW	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.0	0.047
SUBTOTAL	0.0	0.0	1.734	0.890	0.422	0.375	0.0	0.0	0.0	3.421

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2167
TOTAL HOURS OF STABILITY CLASS B	74
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B	73
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2134
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 4.3 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (-1 DELTA-T<=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.234	0.047	0.047	0.0	0.0	0.0	0.328
NNE	0.0	0.0	0.0	0.141	0.234	0.187	0.047	0.0	0.0	0.609
NE	0.0	0.0	0.0	0.234	0.047	0.047	0.0	0.0	0.0	0.328
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.047	0.141	0.0	0.0	0.0	0.0	0.0	0.187
SE	0.0	0.0	0.515	0.187	0.047	0.0	0.0	0.0	0.0	0.750
SSE	0.0	0.0	0.797	0.047	0.0	0.0	0.0	0.0	0.0	0.843
S	0.0	0.0	0.656	0.094	0.0	0.0	0.0	0.0	0.0	0.750
SSW	0.0	0.0	0.187	0.234	0.0	0.0	0.0	0.0	0.0	0.422
SW	0.0	0.0	0.094	0.187	0.0	0.0	0.0	0.0	0.0	0.281
WSW	0.0	0.0	0.047	0.187	0.141	0.094	0.0	0.0	0.0	0.469
W	0.0	0.0	0.0	0.328	0.187	0.234	0.0	0.0	0.0	0.750
WNW	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.047
NW	0.0	0.0	0.0	0.0	0.281	0.422	0.0	0.0	0.0	0.703
NNW	0.0	0.0	0.0	0.0	0.0	0.094	0.047	0.0	0.0	0.141
SUBTOTAL	0.0	0.0	2.343	2.015	0.984	1.172	0.094	0.0	0.0	6.607

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2167
 TOTAL HOURS OF STABILITY CLASS C 142
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C 141
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 5.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D ($\Delta T \leq -0.5$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.002	0.047	0.422	0.562	0.469	0.609	0.0	0.0	0.0	2.111
NNE	0.002	0.0	0.469	0.375	0.328	0.890	0.0	0.0	0.0	2.064
NE	0.003	0.0	0.562	0.234	0.515	0.187	0.0	0.0	0.0	1.502
ENE	0.003	0.047	0.656	0.375	0.047	0.047	0.0	0.0	0.0	1.175
E	0.002	0.047	0.469	1.172	0.562	0.187	0.047	0.0	0.0	2.486
ESE	0.005	0.141	0.984	0.843	0.937	0.0	0.0	0.0	0.0	2.910
SE	0.010	0.094	2.109	0.984	0.047	0.047	0.0	0.0	0.0	3.290
SSE	0.013	0.187	2.671	0.187	0.0	0.0	0.0	0.0	0.0	3.059
S	0.019	0.422	3.796	0.890	0.0	0.0	0.0	0.0	0.0	5.127
SSW	0.013	0.281	2.577	1.125	0.0	0.0	0.0	0.0	0.0	3.996
SW	0.008	0.375	1.453	0.375	0.0	0.0	0.0	0.0	0.0	2.211
WSW	0.007	0.187	1.359	1.593	0.843	0.234	0.0	0.0	0.0	4.224
W	0.003	0.094	0.469	1.125	1.265	0.187	0.0	0.0	0.0	3.142
WNW	0.001	0.047	0.187	0.281	0.375	0.469	0.0	0.0	0.0	1.360
NW	0.001	0.047	0.187	0.422	0.281	0.703	0.234	0.0	0.0	1.875
NNW	0.002	0.141	0.234	0.515	0.094	0.094	0.094	0.047	0.0	1.220
SUBTOTAL	0.094	2.156	18.604	11.059	5.764	3.655	0.375	0.047	0.0	41.752

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2167
 TOTAL HOURS OF STABILITY CLASS D 897
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D 891
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 2

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 4.2 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (-0.5 DELTA-T<= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.052	0.094	0.750	0.937	0.234	0.187	0.0	0.0	0.0	2.254
NNE	0.043	0.187	0.515	0.422	0.141	0.0	0.0	0.0	0.0	1.308
NE	0.040	0.141	0.515	0.141	0.141	0.0	0.0	0.0	0.0	0.977
ENE	0.106	0.656	1.078	0.281	0.047	0.0	0.0	0.0	0.0	2.168
E	0.126	0.375	1.687	1.687	0.094	0.094	0.047	0.0	0.0	4.109
ESE	0.129	0.515	1.593	0.797	0.047	0.047	0.0	0.0	0.0	3.128
SE	0.109	0.562	1.218	0.234	0.0	0.0	0.0	0.0	0.0	2.124
SSE	0.097	0.797	0.797	0.047	0.0	0.0	0.0	0.0	0.0	1.737
S	0.100	0.562	1.078	0.141	0.0	0.0	0.0	0.0	0.0	1.881
SSW	0.077	0.750	0.515	0.047	0.0	0.0	0.0	0.0	0.0	1.389
SW	0.052	0.328	0.515	0.047	0.047	0.0	0.0	0.0	0.0	0.989
WSW	0.072	0.281	0.890	0.141	0.0	0.047	0.0	0.0	0.0	1.430
W	0.040	0.141	0.515	0.0	0.094	0.0	0.0	0.0	0.0	0.790
WNW	0.014	0.047	0.187	0.047	0.0	0.0	0.0	0.0	0.0	0.295
NW	0.023	0.141	0.234	0.047	0.094	0.0	0.0	0.0	0.0	0.538
NNW	0.046	0.047	0.703	0.375	0.0	0.094	0.0	0.0	0.0	1.264
SUBTOTAL	1.125	5.623	12.793	5.389	0.937	0.469	0.047	0.0	0.0	26.382

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2167
TOTAL HOURS OF STABILITY CLASS E	574
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E	563
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2134
TOTAL HOURS CALM	24

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 2.7 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($\Delta T \leq 4.0 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.106	0.234	0.890	0.562	0.0	0.0	0.0	0.0	0.0	1.793
NNE	0.098	0.281	0.750	0.609	0.047	0.047	0.0	0.0	0.0	1.831
NE	0.035	0.047	0.328	0.047	0.047	0.0	0.0	0.0	0.0	0.504
ENE	0.071	0.141	0.609	0.562	0.0	0.0	0.0	0.0	0.0	1.383
E	0.124	0.328	0.984	0.375	0.0	0.0	0.0	0.0	0.0	1.811
ESE	0.022	0.094	0.141	0.0	0.0	0.0	0.0	0.0	0.0	0.256
SE	0.022	0.141	0.094	0.0	0.0	0.0	0.0	0.0	0.0	0.256
SSE	0.022	0.187	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.256
S	0.018	0.141	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.205
SSW	0.031	0.187	0.141	0.0	0.0	0.0	0.0	0.0	0.0	0.359
SW	0.004	0.0	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.051
WSW	0.013	0.094	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.154
W	0.004	0.0	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.051
WNW	0.004	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.051
NW	0.035	0.141	0.234	0.0	0.0	0.0	0.0	0.0	0.0	0.410
NNW	0.044	0.141	0.328	0.094	0.0	0.0	0.0	0.0	0.0	0.607
SUBTOTAL	0.656	2.202	4.733	2.249	0.094	0.047	0.0	0.0	0.0	9.981

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2167
 TOTAL HOURS OF STABILITY CLASS F 219
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 213
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 14

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 2.4 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DISPERST > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.342	0.656	1.172	0.281	0.0	0.0	0.0	0.0	0.0	2.450
NNE	0.289	0.609	0.937	0.141	0.141	0.0	0.0	0.0	0.0	2.117
NE	0.088	0.328	0.141	0.0	0.0	0.0	0.0	0.0	0.0	0.556
ENE	0.123	0.141	0.515	0.141	0.0	0.0	0.0	0.0	0.0	0.919
E	0.035	0.141	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.222
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.009	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.056
NNW	0.053	0.234	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.334
SUBTOTAL	0.937	2.156	2.858	0.562	0.141	0.0	0.0	0.0	0.0	6.654

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2167
 TOTAL HOURS OF STABILITY CLASS G 149
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G 142
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2134
 TOTAL HOURS CALM 20

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 1.9 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 4B

Joint Frequency Distribution in Percent
for Ground Level Releases
Fourth Quarter 1992

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DISPERST<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.046
NNE	0.0	0.0	0.0	0.0	0.046	0.463	0.0	0.0	0.0	0.509
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.046	0.231	0.324	0.0	0.0	0.0	0.0	0.601
SE	0.0	0.0	0.139	1.156	0.278	0.0	0.0	0.0	0.0	1.573
SSE	0.0	0.0	0.278	0.463	0.046	0.0	0.0	0.0	0.0	0.786
S	0.0	0.0	0.046	0.463	0.0	0.0	0.0	0.0	0.0	0.509
SSW	0.0	0.0	0.046	0.093	0.0	0.0	0.0	0.0	0.0	0.139
SW	0.0	0.0	0.046	0.046	0.0	0.0	0.0	0.0	0.0	0.093
WSW	0.0	0.0	0.0	0.0	0.046	0.046	0.0	0.0	0.0	0.093
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.046	0.093	0.0	0.0	0.139
NNW	0.0	0.0	0.0	0.0	0.0	0.046	0.046	0.0	0.0	0.093
SUBTOTAL	0.0	0.0	0.601	2.451	0.740	0.648	0.139	0.0	0.0	4.579

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS A 99
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 99
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 5.5 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B ($-\Delta T \leq -1.7$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.046	0.093	0.139	0.046	0.0	0.0	0.324
NNE	0.0	0.0	0.0	0.0	0.093	0.278	0.0	0.0	0.0	0.370
NE	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.046
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.231	0.0	0.0	0.0	0.0	0.0	0.231
SE	0.0	0.0	0.093	0.185	0.139	0.046	0.0	0.0	0.0	0.463
SSE	0.0	0.0	0.0	0.093	0.0	0.0	0.0	0.0	0.0	0.093
S	0.0	0.0	0.278	0.046	0.0	0.0	0.0	0.0	0.0	0.324
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.093	0.093	0.0	0.0	0.0	0.0	0.0	0.185
WSW	0.0	0.0	0.0	0.093	0.0	0.093	0.0	0.0	0.0	0.185
W	0.0	0.0	0.0	0.0	0.185	0.0	0.0	0.0	0.0	0.185
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.093	0.0	0.0	0.093
NW	0.0	0.0	0.0	0.0	0.0	0.093	0.046	0.0	0.0	0.139
NNW	0.0	0.0	0.0	0.0	0.0	0.093	0.0	0.0	0.0	0.093
SUBTOTAL	0.0	0.0	0.463	0.786	0.509	0.786	0.185	0.0	0.0	2.729

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS B 59
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B 59
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 6.8 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C ($-\Delta T \leq -1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.093	0.139	0.231	0.0	0.0	0.0	0.463
NNE	0.0	0.0	0.0	0.046	0.093	0.324	0.0	0.0	0.0	0.463
NE	0.0	0.0	0.0	0.093	0.046	0.093	0.0	0.0	0.0	0.231
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.139	0.0	0.0	0.0	0.0	0.0	0.139
SE	0.0	0.0	0.278	0.093	0.139	0.093	0.0	0.0	0.0	0.601
SSE	0.0	0.0	0.231	0.093	0.046	0.0	0.0	0.0	0.0	0.370
S	0.0	0.046	0.093	0.0	0.046	0.0	0.0	0.0	0.0	0.185
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.139	0.0	0.0	0.0	0.0	0.0	0.139
WSW	0.0	0.0	0.0	0.185	0.139	0.093	0.0	0.0	0.0	0.416
W	0.0	0.0	0.0	0.093	0.046	0.0	0.0	0.0	0.0	0.139
WNW	0.0	0.0	0.0	0.046	0.139	0.093	0.046	0.0	0.0	0.324
NW	0.0	0.0	0.0	0.046	0.046	0.278	0.046	0.0	0.0	0.416
NNW	0.0	0.0	0.0	0.093	0.046	0.093	0.0	0.0	0.0	0.231
SUBTOTAL	0.0	0.046	0.601	1.156	0.925	1.295	0.093	0.0	0.0	4.117

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS C 89
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C 89
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 6.3 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (-1 DELTA-T<=-0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.324	0.971	1.434	1.804	0.324	0.046	0.0	4.903
NNE	0.0	0.0	0.185	0.648	0.601	0.879	0.139	0.0	0.0	2.451
NE	0.0	0.0	0.185	0.278	0.786	0.786	0.0	0.0	0.0	2.035
ENE	0.0	0.093	0.278	0.370	0.324	0.139	0.0	0.0	0.0	1.203
E	0.0	0.093	0.648	0.463	0.0	0.0	0.0	0.0	0.0	1.203
ESE	0.0	0.093	0.694	1.203	0.416	0.046	0.046	0.0	0.0	2.498
SE	0.0	0.093	1.619	0.971	1.434	0.833	0.0	0.0	0.0	4.949
SSE	0.0	0.231	1.758	0.833	0.185	0.139	0.0	0.0	0.0	3.145
S	0.0	0.370	0.925	0.694	0.231	0.046	0.0	0.0	0.0	2.266
SSW	0.0	0.185	0.648	0.278	0.046	0.093	0.0	0.0	0.0	1.249
SW	0.0	0.0	0.324	0.093	0.046	0.046	0.0	0.0	0.0	0.509
WSW	0.0	0.0	0.509	0.416	0.231	0.324	0.0	0.0	0.0	1.480
W	0.0	0.046	0.231	0.740	0.601	0.740	0.0	0.0	0.0	2.359
WNW	0.0	0.0	0.185	0.463	0.231	0.971	0.324	0.093	0.0	2.266
NW	0.0	0.0	0.555	0.555	0.463	0.786	0.463	0.093	0.0	2.914
NNW	0.0	0.0	0.185	1.064	1.665	2.498	0.185	0.0	0.0	5.597
SUBTOTAL	0.0	1.203	9.251	10.037	8.696	10.130	1.480	0.231	0.0	41.027

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS D 890
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D 887
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 6.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E ($-\infty < \Delta T \leq 1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.002	0.046	0.278	0.971	0.324	0.185	0.0	0.0	0.0	1.806
NNE	0.002	0.046	0.278	0.324	0.231	0.093	0.0	0.0	0.0	0.974
NE	0.004	0.185	0.324	0.694	0.648	0.185	0.0	0.0	0.0	2.039
ENE	0.005	0.139	0.601	0.185	0.139	0.046	0.0	0.0	0.0	1.115
E	0.006	0.231	0.555	0.555	0.093	0.0	0.0	0.0	0.0	1.439
ESE	0.008	0.139	0.925	1.388	0.324	0.093	0.0	0.0	0.0	2.875
SE	0.016	0.509	1.758	0.971	0.648	0.509	0.0	0.0	0.0	4.410
SSE	0.022	0.278	2.821	0.740	0.463	0.093	0.0	0.0	0.0	4.416
S	0.009	0.139	1.064	0.833	0.324	0.046	0.0	0.0	0.0	2.414
SSW	0.003	0.139	0.324	0.185	0.093	0.0	0.0	0.0	0.0	0.743
SW	0.004	0.093	0.416	0.0	0.093	0.0	0.0	0.0	0.0	0.605
WSW	0.004	0.231	0.324	0.416	0.185	0.046	0.0	0.0	0.0	1.207
W	0.002	0.046	0.185	0.231	0.0	0.093	0.0	0.0	0.0	0.557
WNW	0.001	0.046	0.093	0.278	0.185	0.0	0.0	0.0	0.0	0.602
NW	0.002	0.046	0.231	0.324	0.370	0.185	0.0	0.0	0.0	1.158
NNW	0.004	0.185	0.370	0.555	0.694	0.370	0.046	0.0	0.0	2.224
SUBTOTAL	0.093	2.498	10.546	8.649	4.810	1.943	0.046	0.0	0.0	28.585

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS E 623
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E 618
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 2

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 4.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($\Delta T \leq 4.0$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥ 24.5	
N	0.009	0.0	0.324	0.601	0.046	0.0	0.0	0.0	0.0	0.980
NNE	0.006	0.046	0.185	0.601	0.231	0.0	0.0	0.0	0.0	1.070
NE	0.008	0.093	0.185	0.093	0.046	0.0	0.0	0.0	0.0	0.424
ENE	0.013	0.139	0.324	0.324	0.139	0.0	0.0	0.0	0.0	0.938
E	0.031	0.185	0.925	0.509	0.0	0.0	0.0	0.0	0.0	1.650
ESE	0.026	0.231	0.694	0.463	0.0	0.0	0.0	0.0	0.0	1.413
SE	0.027	0.231	0.740	0.139	0.093	0.0	0.0	0.0	0.0	1.230
SSE	0.039	0.278	1.110	0.231	0.093	0.046	0.0	0.0	0.0	1.796
S	0.006	0.093	0.139	0.185	0.046	0.046	0.0	0.0	0.0	0.515
SSW	0.005	0.0	0.185	0.0	0.0	0.0	0.0	0.0	0.0	0.190
SW	0.003	0.046	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.095
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.001	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.048
NW	0.004	0.0	0.139	0.324	0.0	0.0	0.0	0.0	0.0	0.466
NNW	0.006	0.046	0.185	0.324	0.0	0.0	0.0	0.0	0.0	0.562
SUBTOTAL	0.185	1.388	5.227	3.793	0.694	0.093	0.0	0.0	0.0	11.378

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS F 252
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 246
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 4

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 3.1 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DISPERST > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.154	0.324	0.740	0.278	0.0	0.0	0.0	0.0	0.0	1.496
NNE	0.134	0.370	0.555	0.324	0.0	0.0	0.0	0.0	0.0	1.383
NE	0.107	0.231	0.509	0.046	0.0	0.0	0.0	0.0	0.0	0.894
ENE	0.114	0.093	0.694	0.046	0.0	0.0	0.0	0.0	0.0	0.947
E	0.107	0.278	0.463	0.278	0.0	0.0	0.0	0.0	0.0	1.125
ESE	0.013	0.046	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.106
SE	0.034	0.139	0.093	0.0	0.0	0.0	0.0	0.0	0.0	0.265
SSE	0.074	0.324	0.185	0.0	0.0	0.0	0.0	0.0	0.0	0.583
S	0.034	0.231	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.265
SSW	0.013	0.093	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.106
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.013	0.093	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.106
NNW	0.034	0.185	0.046	0.046	0.0	0.0	0.0	0.0	0.0	0.311
SUBTOTAL	0.833	2.405	3.330	1.018	0.0	0.0	0.0	0.0	0.0	7.586

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS G 183
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G 164
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2162
 TOTAL HOURS CALM 18

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 10.03 AND 45.30 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 10.42 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 1.9 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 5A

Joint Frequency Distribution in Percent
for Split-Level Releases
Ground Level Portion
Third Quarter 1992

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (A T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.035	0.0	0.0	0.0	0.035
NNE	0.0	0.0	0.0	0.0	0.0	0.157	0.019	0.0	0.0	0.176
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.042	0.010	0.0	0.0	0.0	0.0	0.052
SE	0.0	0.0	0.005	0.043	0.0	0.0	0.0	0.0	0.0	0.048
SSE	0.0	0.0	0.045	0.009	0.0	0.0	0.0	0.0	0.0	0.054
S	0.0	0.0	0.029	0.055	0.0	0.0	0.0	0.0	0.0	0.084
SSW	0.0	0.0	0.007	0.015	0.0	0.0	0.0	0.0	0.0	0.021
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.007	0.0	0.0	0.0	0.0	0.0	0.007
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.008	0.0	0.0	0.0	0.008
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.085	0.171	0.010	0.200	0.019	0.0	0.0	0.485

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF GROUND LEVEL RELEASE	128.630
TOTAL HOURS OF STABILITY CLASS A	10.200
TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A	10.200

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B ($\Delta T \leq -1.7$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.012	0.0	0.0	0.0	0.012
NNE	0.0	0.0	0.0	0.0	0.007	0.037	0.0	0.0	0.0	0.044
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.003	0.0	0.0	0.0	0.0	0.003
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.015	0.004	0.0	0.0	0.0	0.0	0.019
SE	0.0	0.0	0.008	0.005	0.0	0.0	0.0	0.0	0.0	0.013
SSE	0.0	0.0	0.012	0.0	0.0	0.0	0.0	0.0	0.0	0.012
S	0.0	0.0	0.015	0.0	0.0	0.0	0.0	0.0	0.0	0.015
SSW	0.0	0.0	0.0	0.007	0.0	0.0	0.0	0.0	0.0	0.007
SW	0.0	0.0	0.002	0.0	0.007	0.0	0.0	0.0	0.0	0.009
WSW	0.0	0.0	0.0	0.0	0.012	0.0	0.0	0.0	0.0	0.012
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.001	0.003	0.007	0.0	0.0	0.0	0.011
NNW	0.0	0.0	0.0	0.0	0.003	0.0	0.0	0.0	0.0	0.003
SUBTOTAL	0.0	0.0	0.038	0.028	0.040	0.056	0.0	0.0	0.0	0.161

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS B 3.380
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B 3.380

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (DELTA T<=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.000	0.005	0.009	0.0	0.0	0.0	0.014
NNE	0.0	0.0	0.0	0.004	0.020	0.030	0.010	0.0	0.0	0.065
NE	0.0	0.0	0.0	0.002	0.003	0.006	0.0	0.0	0.0	0.011
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.010	0.0	0.0	0.0	0.0	0.0	0.010
SE	0.0	0.0	0.019	0.017	0.007	0.0	0.0	0.0	0.0	0.043
SSE	0.0	0.0	0.029	0.0	0.0	0.0	0.0	0.0	0.0	0.029
S	0.0	0.0	0.004	0.011	0.0	0.0	0.0	0.0	0.0	0.015
SSW	0.0	0.0	0.0	0.005	0.0	0.0	0.0	0.0	0.0	0.005
SW	0.0	0.0	0.0	0.009	0.0	0.0	0.0	0.0	0.0	0.009
WSW	0.0	0.0	0.0	0.008	0.018	0.016	0.0	0.0	0.0	0.041
W	0.0	0.0	0.0	0.003	0.019	0.036	0.0	0.0	0.0	0.059
WNW	0.0	0.0	0.0	0.0	0.0	0.005	0.0	0.0	0.0	0.005
NW	0.0	0.0	0.0	0.0	0.019	0.062	0.0	0.0	0.0	0.081
NNW	0.0	0.0	0.0	0.0	0.0	0.014	0.017	0.0	0.0	0.030
SUBTOTAL	0.0	0.0	0.052	0.070	0.091	0.179	0.027	0.0	0.0	0.419

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS C 13.810
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C 8.810

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D ($\Delta T \leq -0.5$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.011	0.050	0.112	0.0	0.0	0.0	0.173
NNE	0.0	0.0	0.000	0.011	0.040	0.165	0.0	0.0	0.0	0.217
NE	0.0	0.0	0.0	0.004	0.047	0.026	0.0	0.0	0.0	0.077
ENE	0.0	0.0	0.0	0.015	0.005	0.008	0.0	0.0	0.0	0.028
E	0.0	0.0	0.0	0.066	0.076	0.034	0.012	0.0	0.0	0.188
ESE	0.0	0.0	0.007	0.078	0.155	0.0	0.0	0.0	0.0	0.241
SE	0.0	0.0	0.053	0.136	0.009	0.010	0.0	0.0	0.0	0.208
SSE	0.0	0.0	0.133	0.026	0.0	0.0	0.0	0.0	0.0	0.158
S	0.0	0.0	0.229	0.136	0.0	0.0	0.0	0.0	0.0	0.366
SSW	0.0	0.001	0.074	0.144	0.0	0.0	0.0	0.0	0.0	0.219
SW	0.0	0.0	0.027	0.024	0.0	0.0	0.0	0.0	0.0	0.050
WSW	0.0	0.0	0.028	0.079	0.124	0.040	0.0	0.0	0.0	0.271
W	0.0	0.0	0.0	0.028	0.129	0.029	0.0	0.0	0.0	0.187
WNW	0.0	0.0	0.0	0.002	0.027	0.066	0.0	0.0	0.0	0.095
NW	0.0	0.0	0.0	0.007	0.020	0.105	0.090	0.0	0.0	0.221
NNW	0.0	0.0	0.0	0.010	0.011	0.014	0.037	0.048	0.0	0.119
SUBTOTAL	0.0	0.001	0.551	0.778	0.695	0.608	0.139	0.048	0.0	2.818

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS D 1241.070
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D 59.320

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (< DELTA T<= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.0	0.040	0.095	0.027	0.036	0.0	0.0	0.0	0.198
NNE	0.000	0.0	0.022	0.046	0.021	0.0	0.0	0.0	0.0	0.089
NE	0.000	0.005	0.009	0.016	0.020	0.0	0.0	0.0	0.0	0.050
ENE	0.000	0.011	0.025	0.019	0.007	0.0	0.0	0.0	0.0	0.063
E	0.001	0.004	0.070	0.153	0.013	0.025	0.032	0.0	0.0	0.298
ESE	0.001	0.004	0.084	0.090	0.008	0.010	0.0	0.0	0.0	0.197
SE	0.001	0.030	0.085	0.039	0.0	0.0	0.0	0.0	0.0	0.156
SSE	0.001	0.030	0.077	0.009	0.0	0.0	0.0	0.0	0.0	0.117
S	0.001	0.028	0.072	0.026	0.0	0.0	0.0	0.0	0.0	0.127
SSW	0.000	0.015	0.019	0.008	0.0	0.0	0.0	0.0	0.0	0.043
SW	0.000	0.0	0.005	0.005	0.0	0.0	0.0	0.0	0.0	0.010
WSW	0.000	0.0	0.016	0.010	0.0	0.009	0.0	0.0	0.0	0.034
W	0.000	0.002	0.002	0.0	0.011	0.0	0.0	0.0	0.0	0.015
WNW	0.0	0.0	0.0	0.001	0.0	0.0	0.0	0.0	0.0	0.001
NW	0.0	0.0	0.0	0.0	0.013	0.0	0.0	0.0	0.0	0.013
NNW	0.000	0.0	0.019	0.027	0.0	0.007	0.0	0.0	0.0	0.053
SUBTOTAL	0.007	0.129	0.545	0.543	0.119	0.086	0.032	0.0	0.0	1.461

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS E 636.080
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E 30.760

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (DELTA T<= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.0	0.057	0.065	0.0	0.0	0.0	0.0	0.0	0.122
NNE	0.000	0.0	0.048	0.091	0.009	0.010	0.0	0.0	0.0	0.157
NE	0.000	0.0	0.021	0.007	0.009	0.0	0.0	0.0	0.0	0.036
ENE	0.000	0.006	0.015	0.060	0.0	0.0	0.0	0.0	0.0	0.082
E	0.000	0.011	0.025	0.029	0.0	0.0	0.0	0.0	0.0	0.065
ESE	0.000	0.0	0.011	0.0	0.0	0.0	0.0	0.0	0.0	0.011
SE	0.000	0.005	0.002	0.0	0.0	0.0	0.0	0.0	0.0	0.008
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.000	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.000
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.000	0.0	0.000	0.0	0.0	0.0	0.0	0.0	0.0	0.000
NNW	0.000	0.001	0.010	0.013	0.0	0.0	0.0	0.0	0.0	0.024
SUBTOTAL	0.001	0.024	0.190	0.265	0.018	0.010	0.0	0.0	0.0	0.506

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS F 170.900
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F 10.660

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCY WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.003	0.079	0.042	0.0	0.0	0.0	0.0	0.0	0.124
NNE	0.0	0.0	0.058	0.022	0.025	0.0	0.0	0.0	0.0	0.105
NE	0.0	0.0	0.005	0.0	0.0	0.0	0.0	0.0	0.0	0.005
ENE	0.0	0.0	0.011	0.008	0.0	0.0	0.0	0.0	0.0	0.019
E	0.0	0.0	0.002	0.0	0.0	0.0	0.0	0.0	0.0	0.002
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.006	0.0	0.0	0.0	0.0	0.0	0.0	0.006
SUBTOTAL	0.0	0.003	0.161	0.072	0.025	0.0	0.0	0.0	0.0	0.261

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 128.630
 TOTAL HOURS OF STABILITY CLASS G 29.560
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G 5.500

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 5B

Joint Frequency Distribution in Percent
for Split-Level Releases
Elevated Portion
Third Quarter 1992

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (A T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS A	10.200
TOTAL HOURS OF ELEVATED STABILITY CLASS A	0.0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B < DELTA T(<=-1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS B	3.380
TOTAL HOURS OF ELEVATED STABILITY CLASS B	0.0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EPFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C ($\Delta T \leq -1.5$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.048	0.0	0.0	0.0	0.0	0.0	0.048
SW	0.0	0.0	0.0	0.190	0.0	0.0	0.0	0.0	0.0	0.190
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.238	0.0	0.0	0.0	0.0	0.0	0.238

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS C	13.810
TOTAL HOURS OF ELEVATED STABILITY CLASS C	5.000

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (DELTA T < -0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.002	0.095	0.285	0.523	0.512	0.583	0.462	0.0	0.0	2.461
NNE	0.001	0.0	0.190	0.285	0.459	1.449	1.431	0.038	0.0	3.852
NE	0.001	0.0	0.238	0.143	0.460	0.509	0.039	0.0	0.0	1.390
ENE	0.002	0.0	0.333	0.285	0.274	0.043	0.039	0.0	0.0	0.975
E	0.001	0.0	0.190	0.475	0.370	0.172	0.116	0.0	0.0	1.324
ESE	0.002	0.0	0.428	0.713	0.861	1.552	0.0	0.0	0.0	3.555
SE	0.010	0.0	2.090	1.758	1.195	1.993	0.661	0.0	0.0	7.707
SSE	0.005	0.0	1.093	1.188	1.605	1.979	0.468	0.0	0.0	6.337
S	0.008	0.190	1.378	1.283	1.144	2.452	0.856	0.0	0.0	7.310
SSW	0.005	0.0	1.093	1.615	1.053	1.590	0.118	0.0	0.0	5.474
SW	0.004	0.238	0.665	0.950	0.958	0.957	0.274	0.0	0.0	4.046
WSW	0.002	0.095	0.333	1.140	0.820	0.879	0.158	0.0	0.0	3.427
W	0.001	0.0	0.238	0.808	0.873	1.218	0.117	0.0	0.0	3.254
WNW	0.001	0.0	0.238	0.143	0.417	0.625	0.039	0.0	0.0	1.462
NW	0.001	0.0	0.190	0.333	0.733	0.713	0.429	0.106	0.0	2.505
NNW	0.002	0.095	0.238	0.190	0.235	0.208	0.039	0.054	0.0	1.060
SUBTOTAL	0.048	0.713	9.216	11.829	11.969	16.920	5.248	0.198	0.0	56.140

TOTAL HOURS OF VALID OBSERVATIONS 2105.000
 TOTAL HOURS OF ELEVATED RELEASES 1976.370
 TOTAL HOURS OF STABILITY CLASS D 1241.070
 TOTAL HOURS OF ELEVATED STABILITY CLASS D 1181.750

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (DELTA T<= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.005	0.0	0.190	0.475	0.683	0.804	0.116	0.0	0.0	2.273
NNE	0.006	0.095	0.143	0.475	0.677	1.380	0.273	0.0	0.0	3.048
NE	0.009	0.0	0.333	0.333	0.135	0.544	0.0	0.0	0.0	1.354
ENE	0.005	0.095	0.095	0.570	0.319	0.210	0.0	0.0	0.0	1.294
E	0.009	0.048	0.285	0.190	0.582	0.681	0.038	0.050	0.0	1.883
ESE	0.012	0.0	0.475	0.475	1.460	0.980	0.038	0.032	0.0	3.472
SE	0.022	0.190	0.665	0.855	0.550	0.086	0.0	0.0	0.0	2.369
SSE	0.020	0.190	0.570	0.570	0.187	0.505	0.194	0.0	0.0	2.236
S	0.017	0.095	0.570	0.475	0.373	0.873	0.157	0.0	0.0	2.561
SSW	0.027	0.143	0.903	0.523	0.187	0.380	0.0	0.0	0.0	2.162
SW	0.019	0.190	0.523	0.665	0.231	0.215	0.0	0.0	0.0	1.842
WSW	0.012	0.048	0.428	0.570	0.229	0.166	0.0	0.0	0.0	1.453
W	0.010	0.095	0.285	0.285	0.0	0.0	0.0	0.0	0.0	0.675
WNW	0.004	0.0	0.143	0.380	0.047	0.082	0.0	0.0	0.0	0.655
NW	0.006	0.0	0.238	0.143	0.048	0.170	0.0	0.0	0.0	0.604
NNW	0.006	0.095	0.143	0.190	0.314	0.127	0.0	0.0	0.0	0.875
SUBTOTAL	0.190	1.283	5.986	7.173	6.023	7.203	0.816	0.083	0.0	28.756

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS E	636.080
TOTAL HOURS OF ELEVATED STABILITY CLASS E	605.320

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (DELTA T <= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.007	0.0	0.095	0.190	0.092	0.418	0.0	0.0	0.0	0.802
NNE	0.007	0.0	0.095	0.0	0.188	0.839	0.157	0.0	0.0	1.286
NE	0.010	0.0	0.143	0.190	0.228	0.379	0.117	0.0	0.0	1.066
ENE	0.003	0.048	0.0	0.143	0.093	0.084	0.0	0.0	0.0	0.370
E	0.0	0.0	0.0	0.190	0.0	0.587	0.0	0.0	0.0	0.777
ESE	0.010	0.0	0.143	0.0	0.183	0.129	0.0	0.0	0.0	0.465
SE	0.014	0.0	0.190	0.095	0.0	0.0	0.0	0.0	0.0	0.299
SSE	0.010	0.048	0.095	0.048	0.048	0.0	0.0	0.0	0.0	0.248
S	0.003	0.0	0.048	0.143	0.093	0.165	0.0	0.0	0.0	0.451
SSW	0.014	0.0	0.190	0.238	0.228	0.0	0.0	0.0	0.0	0.669
SW	0.010	0.0	0.143	0.285	0.092	0.0	0.039	0.0	0.0	0.569
WSW	0.0	0.0	0.0	0.095	0.090	0.0	0.0	0.0	0.0	0.185
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.003	0.0	0.048	0.095	0.0	0.0	0.0	0.0	0.0	0.146
NNW	0.003	0.048	0.0	0.095	0.091	0.044	0.0	0.0	0.0	0.280
SUBTOTAL	0.095	0.143	1.188	1.805	1.424	2.645	0.314	0.0	0.0	7.612

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS F	170.900
TOTAL HOURS OF ELEVATED STABILITY CLASS F	160.240

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (A T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.143	0.134	0.339	0.0	0.0	0.0	0.615
NE	0.0	0.0	0.048	0.095	0.0	0.168	0.0	0.0	0.0	0.310
ENE	0.0	0.0	0.0	0.0	0.0	0.040	0.0	0.0	0.0	0.040
E	0.0	0.0	0.0	0.0	0.0	0.083	0.0	0.0	0.0	0.083
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.0	0.047
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.048	0.0	0.0	0.0	0.0	0.0	0.048
SUBTOTAL	0.0	0.0	0.048	0.285	0.181	0.629	0.0	0.0	0.0	1.143

TOTAL HOURS OF VALID OBSERVATIONS	2105.000
TOTAL HOURS OF ELEVATED RELEASES	1976.370
TOTAL HOURS OF STABILITY CLASS G	29.560
TOTAL HOURS OF ELEVATED STABILITY CLASS G	24.060

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 10/22/92

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 5C.

Joint Frequency Distribution in Percent
for Split-Level Releases
Ground Level Portion
Fourth Quarter 1992

SPLIT JOINT PERCENTAGE FREQUENCY WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (ΔT ≤ -1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.006	0.0	0.0	0.0	0.006
NNE	0.0	0.0	0.0	0.0	0.005	0.072	0.0	0.0	0.0	0.077
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.008	0.047	0.0	0.0	0.0	0.0	0.056
SE	0.0	0.0	0.006	0.026	0.043	0.0	0.0	0.0	0.0	0.076
SSE	0.0	0.0	0.007	0.033	0.009	0.0	0.0	0.0	0.0	0.050
S	0.0	0.0	0.0	0.062	0.0	0.0	0.0	0.0	0.0	0.062
SSW	0.0	0.0	0.006	0.012	0.0	0.0	0.0	0.0	0.0	0.018
SW	0.0	0.0	0.0	0.001	0.0	0.0	0.0	0.0	0.0	0.001
WSW	0.0	0.0	0.0	0.0	0.007	0.009	0.0	0.0	0.0	0.016
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.008	0.018	0.0	0.0	0.026
NNW	0.0	0.0	0.0	0.0	0.0	0.008	0.009	0.0	0.0	0.017
SUBTOTAL	0.0	0.0	0.020	0.143	0.111	0.104	0.027	0.0	0.0	0.405

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS A 8.820
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS A 8.820

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (DELTA T <= -1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.007	0.023	0.024	0.0	0.0	0.055
NNE	0.0	0.0	0.0	0.0	0.009	0.038	0.0	0.0	0.0	0.047
NE	0.0	0.0	0.0	0.0	0.0	0.006	0.0	0.0	0.0	0.006
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.008	0.0	0.0	0.0	0.0	0.0	0.008
SE	0.0	0.0	0.0	0.011	0.022	0.028	0.0	0.0	0.0	0.062
SSE	0.0	0.0	0.0	0.012	0.0	0.0	0.0	0.0	0.0	0.012
S	0.0	0.0	0.007	0.008	0.0	0.0	0.0	0.0	0.0	0.015
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.008	0.0	0.0	0.0	0.0	0.0	0.008
WSW	0.0	0.0	0.0	0.001	0.0	0.029	0.0	0.0	0.0	0.030
W	0.0	0.0	0.0	0.0	0.018	0.0	0.0	0.0	0.0	0.018
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.018	0.0	0.0	0.018
NW	0.0	0.0	0.0	0.0	0.0	0.016	0.011	0.0	0.0	0.027
NNW	0.0	0.0	0.0	0.0	0.0	0.015	0.0	0.0	0.0	0.015
SUBTOTAL	0.0	0.0	0.007	0.049	0.056	0.156	0.054	0.0	0.0	0.322

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS B 8.830
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS B 7.020

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C ($\Delta T < -1.5$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.001	0.007	0.032	0.0	0.0	0.0	0.040
NNE	0.0	0.0	0.0	0.0	0.006	0.046	0.0	0.0	0.0	0.052
NE	0.0	0.0	0.0	0.000	0.004	0.011	0.0	0.0	0.0	0.016
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.005	0.0	0.0	0.0	0.0	0.0	0.005
SE	0.0	0.0	0.003	0.0	0.026	0.019	0.0	0.0	0.0	0.048
SSE	0.0	0.0	0.010	0.017	0.008	0.0	0.0	0.0	0.0	0.035
S	0.0	0.0	0.006	0.0	0.028	0.0	0.0	0.0	0.0	0.034
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.006	0.0	0.0	0.0	0.0	0.0	0.006
WSW	0.0	0.0	0.0	0.006	0.017	0.017	0.0	0.0	0.0	0.041
W	0.0	0.0	0.0	0.001	0.003	0.0	0.0	0.0	0.0	0.004
WNW	0.0	0.0	0.0	0.0	0.005	0.013	0.009	0.0	0.0	0.027
NW	0.0	0.0	0.0	0.001	0.002	0.040	0.020	0.0	0.0	0.063
NNW	0.0	0.0	0.0	0.0	0.001	0.012	0.0	0.0	0.0	0.014
SUBTOTAL	0.0	0.0	0.018	0.037	0.108	0.191	0.029	0.0	0.0	0.384

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS C 22.320
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS C 8.360

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D (< DELTA T<=-0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.030	0.148	0.297	0.111	0.042	0.0	0.628
NNE	0.0	0.0	0.0	0.027	0.056	0.144	0.029	0.0	0.0	0.257
NE	0.0	0.0	0.0	0.006	0.074	0.108	0.0	0.0	0.0	0.189
ENE	0.0	0.0	0.0	0.011	0.028	0.022	0.0	0.0	0.0	0.060
E	0.0	0.0	0.004	0.022	0.0	0.0	0.0	0.0	0.0	0.026
ESE	0.0	0.0	0.002	0.090	0.061	0.009	0.036	0.0	0.0	0.198
SE	0.0	0.0	0.030	0.116	0.330	0.332	0.0	0.0	0.0	0.809
SSE	0.0	0.0	0.108	0.113	0.026	0.106	0.0	0.0	0.0	0.353
S	0.0	0.0	0.025	0.104	0.078	0.017	0.0	0.0	0.0	0.229
SSW	0.0	0.001	0.023	0.034	0.013	0.069	0.0	0.0	0.0	0.141
SW	0.0	0.0	0.0	0.012	0.009	0.033	0.0	0.0	0.0	0.054
WSW	0.0	0.0	0.002	0.022	0.033	0.066	0.0	0.0	0.0	0.122
W	0.0	0.0	0.0	0.039	0.069	0.124	0.0	0.0	0.0	0.233
WNW	0.0	0.0	0.0	0.004	0.019	0.152	0.107	0.069	0.0	0.352
NW	0.0	0.0	0.0	0.001	0.033	0.121	0.189	0.081	0.0	0.424
NNW	0.0	0.0	0.0	0.029	0.165	0.391	0.062	0.0	0.0	0.646
SUBTOTAL	0.0	0.001	0.198	0.662	1.143	1.992	0.534	0.192	0.0	4.721

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS D 1219.920
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS D 102.870

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (< DELTA T(<= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.011	0.085	0.041	0.034	0.0	0.0	0.0	0.171
NNE	0.0	0.0	0.006	0.034	0.034	0.015	0.0	0.0	0.0	0.089
NE	0.0	0.0	0.006	0.071	0.087	0.030	0.0	0.0	0.0	0.194
ENE	0.0	0.0	0.009	0.014	0.017	0.008	0.0	0.0	0.0	0.048
E	0.0	0.002	0.008	0.066	0.013	0.0	0.0	0.0	0.0	0.089
ESE	0.0	0.004	0.031	0.167	0.049	0.017	0.0	0.0	0.0	0.269
SE	0.0	0.017	0.133	0.150	0.120	0.307	0.0	0.0	0.0	0.726
SSE	0.0	0.001	0.319	0.192	0.308	0.092	0.0	0.0	0.0	0.913
S	0.0	0.0	0.095	0.145	0.107	0.016	0.0	0.0	0.0	0.363
SSW	0.0	0.0	0.023	0.030	0.031	0.0	0.0	0.0	0.0	0.084
SW	0.0	0.0	0.011	0.0	0.017	0.0	0.0	0.0	0.0	0.028
WSW	0.0	0.0	0.004	0.048	0.029	0.009	0.0	0.0	0.0	0.090
W	0.0	0.0	0.001	0.013	0.0	0.018	0.0	0.0	0.0	0.032
WNW	0.0	0.0	0.0	0.017	0.025	0.0	0.0	0.0	0.0	0.042
NW	0.0	0.0	0.003	0.021	0.047	0.033	0.0	0.0	0.0	0.104
NNW	0.0	0.0	0.003	0.050	0.098	0.066	0.010	0.0	0.0	0.227
SUBTOTAL	0.0	0.024	0.665	1.103	1.025	0.644	0.010	0.0	0.0	3.470

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS E 713.330
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS E 75.620

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F (DELTA T<= 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.000	0.0	0.022	0.076	0.006	0.0	0.0	0.0	0.0	0.104
NNE	0.0	0.0	0.0	0.084	0.038	0.0	0.0	0.0	0.0	0.122
NE	0.000	0.0	0.010	0.012	0.007	0.0	0.0	0.0	0.0	0.030
ENE	0.000	0.010	0.008	0.043	0.023	0.0	0.0	0.0	0.0	0.085
E	0.001	0.004	0.048	0.053	0.0	0.0	0.0	0.0	0.0	0.105
ESE	0.001	0.010	0.029	0.055	0.0	0.0	0.0	0.0	0.0	0.095
SE	0.001	0.019	0.048	0.017	0.018	0.0	0.0	0.0	0.0	0.104
SSE	0.002	0.019	0.127	0.067	0.059	0.044	0.0	0.0	0.0	0.318
S	0.000	0.011	0.014	0.031	0.009	0.011	0.0	0.0	0.0	0.077
SSW	0.000	0.0	0.028	0.0	0.0	0.0	0.0	0.0	0.0	0.028
SW	0.000	0.0	0.006	0.0	0.0	0.0	0.0	0.0	0.0	0.007
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.000	0.0	0.011	0.035	0.0	0.0	0.0	0.0	0.0	0.047
NNW	0.000	0.0	0.012	0.041	0.0	0.0	0.0	0.0	0.0	0.053
SUBTOTAL	0.006	0.074	0.363	0.514	0.162	0.055	0.0	0.0	0.0	1.173

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS F 160.210
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS F 25.570

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 1 OF 2 GROUND LEVEL RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	TOTAL
N	0.000	0.0	0.023	0.038	0.0	0.0	0.0	0.0	0.0	0.061
NNE	0.000	0.0	0.028	0.037	0.0	0.0	0.0	0.0	0.0	0.064
NE	0.000	0.0	0.020	0.007	0.0	0.0	0.0	0.0	0.0	0.027
ENE	0.000	0.000	0.026	0.000	0.0	0.0	0.0	0.0	0.0	0.027
E	0.000	0.024	0.020	0.017	0.0	0.0	0.0	0.0	0.0	0.061
ESE	0.000	0.0	0.005	0.0	0.0	0.0	0.0	0.0	0.0	0.005
SE	0.000	0.010	0.005	0.0	0.0	0.0	0.0	0.0	0.0	0.014
SSE	0.000	0.027	0.031	0.0	0.0	0.0	0.0	0.0	0.0	0.059
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.000	0.002	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.002
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.000	0.0	0.004	0.006	0.0	0.0	0.0	0.0	0.0	0.009
SUBTOTAL	0.002	0.063	0.161	0.104	0.0	0.0	0.0	0.0	0.0	0.330

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF GROUND LEVEL RELEASE 235.440
 TOTAL HOURS OF STABILITY CLASS G 45.570
 TOTAL HOURS OF GROUND LEVEL STABILITY CLASS G 7.180

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 10.03 AND 45.30 METERS
 WIND DIRECTION MEASURED AT 10.42 METER LEVEL
 WIND SPEED MEASURED AT 10.42 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 5D

Joint Frequency Distribution in Percent
for Split-Level Releases
Elevated Portion
Fourth Quarter 1992

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DELTA T <= -1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS A 8.820
 TOTAL HOURS OF ELEVATED STABILITY CLASS A 0.0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B (DELTA T < -1.7 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.039	0.0	0.0	0.0	0.039
WSW	0.0	0.0	0.0	0.0	0.044	0.0	0.0	0.0	0.0	0.044
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.044	0.039	0.0	0.0	0.0	0.083

TOTAL HOURS OF VALID OBSERVATIONS	2179.000
TOTAL HOURS OF ELEVATED RELEASES	1943.559
TOTAL HOURS OF STABILITY CLASS B	8.830
TOTAL HOURS OF ELEVATED STABILITY CLASS B	1.810

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS



SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C (< DELTA T<=-1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.087	0.039	0.0	0.0	0.0	0.126
SE	0.0	0.0	0.0	0.046	0.134	0.042	0.0	0.0	0.0	0.222
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.040	0.0	0.0	0.0	0.040
SW	0.0	0.0	0.0	0.0	0.045	0.0	0.037	0.0	0.0	0.081
WSW	0.0	0.0	0.0	0.0	0.088	0.083	0.0	0.0	0.0	0.171
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.046	0.353	0.205	0.037	0.0	0.0	0.641

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS C 22.320
 TOTAL HOURS OF ELEVATED STABILITY CLASS C 13.960

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D < DELTA T(<=-0.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.092	0.597	1.183	2.828	0.934	0.159	0.004	5.797
NNE	0.0	0.046	0.092	0.321	0.832	1.836	0.751	0.072	0.0	3.949
NE	0.0	0.0	0.138	0.321	0.263	1.061	0.038	0.0	0.0	1.821
ENE	0.0	0.046	0.184	0.229	0.175	0.163	0.076	0.0	0.0	0.874
E	0.0	0.092	0.092	0.413	0.535	0.083	0.0	0.0	0.0	1.214
ESE	0.0	0.0	0.229	0.597	0.714	1.007	0.076	0.0	0.010	2.633
SE	0.0	0.092	0.734	1.239	0.943	1.847	1.789	0.603	0.008	7.256
SSE	0.0	0.0	0.505	0.321	0.754	1.883	1.162	0.144	0.038	4.807
S	0.0	0.138	0.275	0.577	0.579	0.888	0.670	0.172	0.0	3.319
SSW	0.0	0.046	0.413	0.275	0.132	0.757	0.298	0.094	0.011	2.027
SW	0.0	0.046	0.275	0.413	0.133	0.403	0.299	0.104	0.0	1.673
WSW	0.0	0.046	0.321	0.321	0.355	0.442	0.297	0.073	0.0	1.855
W	0.0	0.0	0.092	0.551	0.436	0.963	0.414	0.0	0.010	2.466
WNW	0.0	0.0	0.046	0.275	0.486	0.679	0.557	0.095	0.010	2.148
NW	0.0	0.0	0.413	0.734	0.358	1.080	0.673	0.223	0.021	3.503
NNW	0.0	0.046	0.229	0.597	0.830	3.012	1.122	0.085	0.0	5.922
SUBTOTAL	0.0	0.597	4.130	7.802	8.709	18.933	9.157	1.825	0.112	51.264

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS D 1219.920
 TOTAL HOURS OF ELEVATED STABILITY CLASS D 1117.050

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E ($\Delta T \leq 1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.001	0.0	0.092	0.046	0.087	0.682	0.076	0.0	0.0	0.984
NNE	0.001	0.0	0.046	0.275	0.264	0.801	0.265	0.0	0.0	1.652
NE	0.001	0.0	0.046	0.0	0.175	1.436	0.076	0.0	0.0	1.733
ENE	0.001	0.0	0.046	0.138	0.175	0.484	0.076	0.0	0.0	0.920
E	0.006	0.092	0.321	0.184	0.441	0.372	0.0	0.0	0.0	1.416
ESE	0.006	0.046	0.367	0.597	0.535	1.574	0.0	0.0	0.0	3.124
SE	0.009	0.138	0.551	0.780	1.063	2.302	0.486	0.245	0.0	5.574
SSE	0.006	0.0	0.459	0.597	0.793	1.493	0.597	0.217	0.004	4.165
S	0.004	0.092	0.181	0.229	0.570	1.062	0.225	0.035	0.0	2.401
SSW	0.001	0.0	0.092	0.367	0.308	0.360	0.226	0.0	0.0	1.355
SW	0.004	0.046	0.275	0.321	0.043	0.279	0.038	0.0	0.0	1.007
WSW	0.001	0.0	0.046	0.413	0.0	0.320	0.076	0.0	0.0	0.855
W	0.001	0.046	0.046	0.229	0.090	0.121	0.038	0.0	0.0	0.572
WNW	0.001	0.046	0.046	0.184	0.090	0.122	0.0	0.0	0.0	0.489
NW	0.003	0.0	0.229	0.229	0.353	0.608	0.037	0.0	0.0	1.461
NNW	0.001	0.0	0.046	0.046	0.264	1.166	0.037	0.0	0.0	1.559
SUBTOTAL	0.046	0.505	2.891	4.635	5.252	13.184	2.253	0.497	0.004	29.266

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS E 713.330
 TOTAL HOURS OF ELEVATED STABILITY CLASS E 637.710

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($\Delta T \leq 4.0 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥ 24.5	
N	0.0	0.0	0.0	0.0	0.0	0.123	0.0	0.0	0.0	0.123
NNE	0.009	0.0	0.046	0.0	0.045	0.165	0.038	0.0	0.0	0.303
NE	0.009	0.046	0.0	0.0	0.046	0.328	0.0	0.0	0.0	0.429
ENE	0.018	0.092	0.0	0.092	0.0	0.201	0.152	0.0	0.0	0.555
E	0.028	0.0	0.138	0.092	0.175	0.244	0.0	0.0	0.0	0.676
ESE	0.046	0.046	0.184	0.184	0.217	0.366	0.0	0.0	0.0	1.042
SE	0.009	0.0	0.046	0.229	0.267	0.124	0.0	0.0	0.0	0.676
SSE	0.028	0.092	0.046	0.046	0.134	0.123	0.0	0.0	0.0	0.469
S	0.0	0.0	0.0	0.092	0.044	0.202	0.038	0.0	0.0	0.375
SSW	0.037	0.046	0.138	0.046	0.0	0.0	0.0	0.0	0.0	0.266
SW	0.028	0.046	0.092	0.229	0.044	0.0	0.0	0.0	0.0	0.439
WSW	0.028	0.0	0.138	0.092	0.0	0.0	0.0	0.0	0.0	0.257
W	0.018	0.046	0.046	0.138	0.0	0.0	0.0	0.0	0.0	0.248
WNW	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.046
NW	0.0	0.0	0.0	0.0	0.0	0.041	0.0	0.0	0.0	0.041
NNW	0.018	0.092	0.0	0.0	0.0	0.125	0.0	0.0	0.0	0.235
SUBTOTAL	0.275	0.505	0.872	1.285	0.972	2.042	0.228	0.0	0.0	6.179

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS F 160.210
 TOTAL HOURS OF ELEVATED STABILITY CLASS F 134.640

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

SPLIT JOINT PERCENTAGE FREQUENCY OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DELTA T > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

PART 2 OF 2 ELEVATED RELEASE MODE

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	CALM	WIND SPEED(MPH)								TOTAL
		0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.046	0.0	0.0	0.046	0.042	0.0	0.0	0.0	0.134
NNE	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.046
NE	0.0	0.0	0.0	0.0	0.089	0.156	0.0	0.0	0.0	0.245
ENE	0.0	0.0	0.0	0.046	0.0	0.080	0.0	0.0	0.0	0.126
E	0.0	0.0	0.0	0.0	0.046	0.041	0.0	0.0	0.0	0.087
ESE	0.0	0.0	0.092	0.092	0.262	0.084	0.0	0.0	0.0	0.529
SE	0.0	0.0	0.092	0.138	0.044	0.0	0.0	0.0	0.0	0.274
SSE	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.046
S	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.046
SSW	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.046
SW	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.046
WSW	0.0	0.0	0.0	0.092	0.0	0.0	0.0	0.0	0.0	0.092
W	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.046
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.092	0.275	0.505	0.487	0.403	0.0	0.0	0.0	1.762

TOTAL HOURS OF VALID OBSERVATIONS 2179.000
 TOTAL HOURS OF ELEVATED RELEASES 1943.559
 TOTAL HOURS OF STABILITY CLASS G 45.570
 TOTAL HOURS OF ELEVATED STABILITY CLASS G 38.390

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON DELTA-T BETWEEN 45.30 AND 89.59 METERS
 WIND DIRECTION MEASURED AT 45.67 METER LEVEL
 WIND SPEED MEASURED AT 45.67 METER LEVEL
 EFFLUENT VELOCITY = 12.60 M/S

DATE PRINTED: 01/14/93

NOTE: TOTALS AND SUBTOTALS ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 6A

Joint Frequency Distribution in Percent
for Stack Releases
Third Quarter 1992

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (D-----T<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL	
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2119
TOTAL HOURS OF STABILITY CLASS A	0
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A	0
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2110
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 0.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B ($\Delta T \leq -1.7$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL	
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2119
 TOTAL HOURS OF STABILITY CLASS B 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2110
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 0.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C ($-\Delta T \leq -1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL	
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.047
SW	0.0	0.0	0.0	0.095	0.0	0.0	0.0	0.0	0.0	0.0	0.095
WSW	0.0	0.0	0.0	0.095	0.0	0.0	0.0	0.0	0.0	0.0	0.095
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.237	0.0	0.0	0.0	0.0	0.0	0.0	0.237

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2119
TOTAL HOURS OF STABILITY CLASS C	5
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C	5
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2110
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 4.9 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D ($\Delta T \leq -0.5$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.284	0.474	0.474	0.948	0.995	0.190	0.0	3.365
NNE	0.0	0.0	0.142	0.142	0.474	0.948	1.374	0.474	0.0	3.554
NE	0.0	0.047	0.190	0.142	0.284	0.664	0.190	0.0	0.0	1.517
ENE	0.0	0.047	0.142	0.379	0.190	0.095	0.047	0.0	0.0	0.900
E	0.0	0.0	0.142	0.332	0.190	0.190	0.047	0.047	0.0	0.948
ESE	0.0	0.0	0.474	0.521	0.427	1.801	1.043	0.190	0.0	4.455
SE	0.0	0.0	1.280	1.564	0.995	1.991	2.180	0.569	0.0	8.578
SSE	0.0	0.0	0.900	0.900	0.995	1.659	1.043	0.047	0.0	5.545
S	0.0	0.047	0.853	0.948	0.853	2.607	1.659	0.047	0.0	7.014
SSW	0.0	0.0	0.474	0.758	1.043	1.896	1.232	0.047	0.0	5.450
SW	0.0	0.095	0.995	0.711	0.474	1.659	0.948	0.095	0.0	4.976
WSW	0.0	0.0	0.427	0.664	0.616	1.327	0.711	0.095	0.0	3.839
W	0.0	0.0	0.190	0.711	0.758	1.659	0.569	0.047	0.0	3.934
WNW	0.0	0.095	0.142	0.190	0.521	0.948	0.142	0.0	0.0	2.038
NW	0.0	0.047	0.237	0.190	0.664	0.900	0.474	0.237	0.047	2.796
NNW	0.0	0.047	0.332	0.284	0.190	0.142	0.095	0.047	0.095	1.232
SUBTOTAL	0.0	0.427	7.204	8.910	9.147	19.431	12.749	2.133	0.142	60.142

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2119
 TOTAL HOURS OF STABILITY CLASS D 1276
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D 1269
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2110
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 9.2 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E (~~-----~~ DELTA-T<= 1.5 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.001	0.047	0.0	0.190	0.284	0.995	0.758	0.190	0.0	2.466
NNE	0.005	0.0	0.190	0.284	0.237	1.043	1.043	0.284	0.0	3.086
NE	0.003	0.047	0.047	0.190	0.190	0.379	0.427	0.047	0.0	1.330
ENE	0.003	0.0	0.095	0.095	0.142	0.521	0.047	0.0	0.0	0.903
E	0.008	0.095	0.190	0.0	0.047	0.474	0.190	0.095	0.047	1.145
ESE	0.007	0.047	0.190	0.190	0.095	0.995	1.280	0.0	0.095	2.898
SE	0.012	0.0	0.427	0.569	0.474	2.085	0.379	0.047	0.0	3.993
SSE	0.011	0.095	0.284	0.664	0.332	0.711	0.237	0.0	0.0	2.333
S	0.013	0.095	0.379	0.332	0.190	0.758	0.711	0.0	0.0	2.478
SSW	0.007	0.095	0.142	0.332	0.332	0.711	0.616	0.095	0.0	2.329
SW	0.003	0.0	0.095	0.569	0.664	0.948	0.427	0.0	0.0	2.704
WSW	0.005	0.0	0.190	0.284	0.142	0.521	0.142	0.0	0.0	1.285
W	0.005	0.0	0.190	0.142	0.284	0.569	0.0	0.0	0.0	1.190
WNW	0.001	0.0	0.047	0.095	0.190	0.142	0.0	0.0	0.0	0.475
NW	0.008	0.047	0.237	0.190	0.190	0.047	0.095	0.0	0.0	0.814
NNW	0.004	0.0	0.142	0.142	0.190	0.332	0.095	0.0	0.0	0.904
SUBTOTAL	0.095	0.569	2.844	4.265	3.981	11.232	6.445	0.758	0.142	30.332

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2119
 TOTAL HOURS OF STABILITY CLASS E 642
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E 640
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2110
 TOTAL HOURS CALM 2

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 9.2 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($\Delta T \leq 4.0$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥ 24.5	
N	0.007	0.047	0.0	0.047	0.047	0.237	0.237	0.095	0.0	0.718
NNE	0.007	0.0	0.047	0.047	0.0	0.142	0.474	0.047	0.0	0.766
NE	0.007	0.0	0.047	0.0	0.0	0.474	0.379	0.474	0.0	1.382
ENE	0.0	0.0	0.0	0.0	0.142	0.332	0.0	0.0	0.0	0.474
E	0.0	0.0	0.0	0.190	0.095	0.237	0.0	0.0	0.0	0.521
ESE	0.015	0.0	0.095	0.095	0.0	0.284	0.427	0.0	0.0	0.915
SE	0.022	0.047	0.095	0.0	0.095	0.237	0.047	0.0	0.0	0.543
SSE	0.007	0.0	0.047	0.0	0.047	0.095	0.0	0.0	0.0	0.197
S	0.0	0.0	0.0	0.0	0.0	0.095	0.190	0.047	0.0	0.332
SSW	0.0	0.0	0.0	0.095	0.095	0.190	0.0	0.0	0.0	0.379
SW	0.0	0.0	0.0	0.190	0.095	0.379	0.379	0.047	0.0	1.090
WSW	0.0	0.0	0.0	0.095	0.0	0.142	0.047	0.0	0.0	0.284
W	0.007	0.0	0.047	0.0	0.0	0.0	0.0	0.0	0.0	0.055
WNW	0.015	0.0	0.095	0.047	0.0	0.0	0.0	0.0	0.0	0.157
NW	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.047
NNW	0.007	0.0	0.047	0.0	0.0	0.047	0.095	0.0	0.0	0.197
SUBTOTAL	0.095	0.095	0.521	0.806	0.616	2.938	2.275	0.711	0.0	8.057

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2119
 TOTAL HOURS OF STABILITY CLASS F 170
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 170
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2110
 TOTAL HOURS CALM 2

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 11.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS G (DISPERST > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

JUL 1, 92 - SEP 30, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.047
NNE	0.0	0.0	0.0	0.0	0.0	0.284	0.047	0.0	0.0	0.332
NE	0.0	0.0	0.0	0.0	0.0	0.237	0.237	0.0	0.0	0.474
ENE	0.0	0.0	0.0	0.0	0.0	0.142	0.047	0.0	0.0	0.190
E	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.0	0.047
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.095	0.0	0.0	0.095
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.047	0.0	0.0	0.047
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.758	0.474	0.0	0.0	1.232

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2119
TOTAL HOURS OF STABILITY CLASS G	26
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	26
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2110
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 10/22/92

MEAN WIND SPEED = 12.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

Radiological Impact Assessment
Browns Ferry Nuclear Plant
July - December 1992

TABLE 6B

Joint Frequency Distribution in Percent
for Stack Releases
Fourth Quarter 1992

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS A (DISPERST<=-1.9 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS A 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS A 0
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 0.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS B ($\Delta T \leq -1.7$ C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL	
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.046
WSW	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.046
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.0	0.046	0.046	0.0	0.0	0.0	0.091

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS B 2
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS B 2
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 11.8 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS C ($-\Delta T \leq -1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL	
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5		
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.183	0.046	0.0	0.0	0.0	0.229
SE	0.0	0.0	0.0	0.0	0.046	0.091	0.0	0.0	0.0	0.0	0.137
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.046
SW	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.046	0.0	0.0	0.091
WSW	0.0	0.0	0.0	0.0	0.0	0.137	0.0	0.0	0.0	0.0	0.137
W	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.046
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.0	0.0	0.091	0.503	0.046	0.046	0.0	0.0	0.686

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS C 15
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS C 15
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 10.8 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS D ($-\Delta T \leq -0.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	≥ 24.5	
N	0.0	0.0	0.091	0.411	0.686	2.971	1.782	0.548	0.091	6.581
NNE	0.0	0.0	0.091	0.183	0.274	1.645	1.188	0.091	0.0	3.473
NE	0.0	0.0	0.091	0.137	0.274	1.188	0.274	0.0	0.0	1.965
ENE	0.0	0.0	0.091	0.183	0.183	0.320	0.046	0.046	0.0	0.868
E	0.0	0.0	0.091	0.366	0.320	0.457	0.0	0.0	0.0	1.234
ESE	0.0	0.0	0.091	0.503	0.686	0.960	1.005	0.137	0.046	3.428
SE	0.0	0.0	0.183	0.548	0.777	0.914	2.057	1.645	1.828	7.952
SSE	0.0	0.0	0.137	0.320	0.503	1.554	1.463	0.457	0.366	4.799
S	0.0	0.0	0.274	0.320	0.731	1.371	0.868	0.457	0.046	4.068
SSW	0.0	0.0	0.183	0.366	0.274	0.457	0.640	0.274	0.137	2.331
SW	0.0	0.046	0.366	0.320	0.229	0.274	0.503	0.229	0.229	2.194
WSW	0.0	0.0	0.229	0.274	0.274	0.503	0.457	0.366	0.0	2.102
W	0.0	0.0	0.046	0.457	0.411	0.960	0.777	0.274	0.046	2.971
WNW	0.0	0.0	0.366	0.274	0.320	0.731	0.640	0.548	0.183	3.062
NW	0.0	0.046	0.229	0.594	0.457	1.051	1.097	0.503	0.229	4.205
NNW	0.0	0.046	0.137	0.274	0.594	3.291	2.148	0.548	0.0	7.038
SUBTOTAL	0.0	0.137	2.697	5.530	6.993	18.647	14.945	6.124	3.199	58.272

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS D 1281
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS D 1275
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 12.2 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS



JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS E ($\Delta T \leq 1.5 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.046	0.091	0.0	0.411	0.777	0.091	0.0	1.417
NNE	0.0	0.0	0.137	0.137	0.137	0.366	0.731	0.320	0.0	1.828
NE	0.0	0.046	0.091	0.137	0.0	0.457	1.051	0.183	0.0	1.965
ENE	0.0	0.0	0.091	0.046	0.046	0.274	0.686	0.137	0.0	1.280
E	0.0	0.0	0.183	0.091	0.137	0.320	0.091	0.0	0.0	0.823
ESE	0.0	0.0	0.137	0.137	0.229	0.594	0.640	0.274	0.0	2.011
SE	0.0	0.0	0.274	0.320	0.503	1.143	1.737	1.325	0.868	6.170
SSE	0.0	0.091	0.137	0.274	0.548	1.417	1.280	0.594	0.183	4.525
S	0.0	0.046	0.091	0.229	0.503	1.782	1.005	0.091	0.0	3.748
SSW	0.0	0.0	0.091	0.091	0.229	0.640	0.777	0.274	0.0	2.102
SW	0.0	0.0	0.137	0.046	0.137	0.320	0.457	0.0	0.0	1.097
WSW	0.0	0.046	0.137	0.091	0.183	0.229	0.366	0.091	0.0	1.143
W	0.0	0.0	0.137	0.274	0.183	0.137	0.091	0.046	0.0	0.868
WNW	0.0	0.0	0.046	0.183	0.091	0.046	0.091	0.0	0.0	0.457
NW	0.0	0.0	0.046	0.137	0.183	0.594	0.274	0.046	0.0	1.280
NNW	0.0	0.046	0.0	0.046	0.0	0.594	0.960	0.046	0.0	1.691
SUBTOTAL	0.0	0.274	1.782	2.331	3.108	9.324	11.015	3.519	1.051	32.404

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS E 709
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS E 709
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 12.4 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS F ($\Delta T \leq 4.0 \text{ C}/100 \text{ M}$)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.0	0.0	0.0	0.091	0.091	0.0	0.0	0.183
NNE	0.0	0.0	0.0	0.0	0.0	0.091	0.046	0.046	0.0	0.183
NE	0.003	0.0	0.046	0.0	0.0	0.183	0.137	0.0	0.0	0.368
ENE	0.006	0.0	0.091	0.0	0.046	0.366	0.274	0.0	0.0	0.783
E	0.003	0.0	0.046	0.0	0.046	0.229	0.091	0.0	0.0	0.414
ESE	0.009	0.0	0.137	0.091	0.183	0.229	0.366	0.091	0.0	1.105
SE	0.003	0.0	0.046	0.091	0.046	0.137	0.320	0.046	0.0	0.688
SSE	0.003	0.0	0.046	0.0	0.046	0.411	0.046	0.0	0.0	0.551
S	0.003	0.046	0.0	0.091	0.091	0.091	0.274	0.091	0.0	0.688
SSW	0.003	0.0	0.046	0.0	0.046	0.091	0.137	0.0	0.0	0.229
SW	0.0	0.0	0.0	0.0	0.137	0.091	0.0	0.0	0.0	0.323
WSW	0.003	0.046	0.0	0.0	0.091	0.183	0.0	0.0	0.0	0.229
W	0.0	0.0	0.0	0.0	0.0	0.137	0.0	0.0	0.0	0.137
WNW	0.003	0.0	0.046	0.046	0.0	0.0	0.0	0.0	0.0	0.094
NW	0.006	0.046	0.046	0.229	0.046	0.0	0.0	0.0	0.0	0.371
NNW	0.003	0.0	0.046	0.046	0.0	0.046	0.0	0.0	0.0	0.140
SUBTOTAL	0.046	0.137	0.594	0.594	0.777	2.377	1.782	0.274	0.0	6.581

TOTAL HOURS OF VALID STABILITY OBSERVATIONS 2195
 TOTAL HOURS OF STABILITY CLASS F 144
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS F 144
 TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS 2188
 TOTAL HOURS CALM 1

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
 STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
 WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 10.0 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION FOR

STABILITY CLASS-G (DISPERST > 4.0 C/100 M)

BROWNS FERRY NUCLEAR PLANT

OCT 1, 92 - DEC 31, 92

WIND DIRECTION	WIND SPEED(MPH)									TOTAL
	CALM	0.6-1.4	1.5-3.4	3.5-5.4	5.5-7.4	7.5-12.4	12.5-18.4	18.5-24.4	>=24.5	
N	0.0	0.0	0.046	0.0	0.0	0.0	0.046	0.0	0.0	0.091
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.046
NE	0.0	0.0	0.046	0.0	0.0	0.0	0.091	0.091	0.0	0.229
ENE	0.0	0.0	0.0	0.0	0.0	0.091	0.091	0.0	0.0	0.183
E	0.0	0.0	0.0	0.046	0.0	0.091	0.0	0.0	0.0	0.137
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.046
SE	0.0	0.0	0.091	0.046	0.091	0.274	0.274	0.0	0.0	0.777
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.046
S	0.0	0.0	0.0	0.0	0.0	0.0	0.137	0.0	0.0	0.137
SSW	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.046
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.046
W	0.0	0.0	0.0	0.0	0.0	0.137	0.0	0.0	0.0	0.137
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.046	0.0	0.0	0.0	0.0	0.0	0.0	0.046
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SUBTOTAL	0.0	0.0	0.229	0.091	0.183	0.594	0.777	0.091	0.0	1.965

TOTAL HOURS OF VALID STABILITY OBSERVATIONS	2195
TOTAL HOURS OF STABILITY CLASS G	44
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY CLASS G	43
TOTAL HOURS OF VALID WIND DIRECTION-WIND SPEED-STABILITY OBSERVATIONS	2188
TOTAL HOURS CALM	0

METEOROLOGICAL FACILITY: MET FACILITY LOCATED 1.3 KM ESE OF BROWNS FERRY NUCLEAR PLANT
STABILITY BASED ON LAPSE RATE MEASURED BETWEEN 45.30 AND 89.59 METERS
WIND SPEED AND DIRECTION MEASURED AT THE 92.63 METER LEVEL

DATE PRINTED: 01/14/93

MEAN WIND SPEED = 11.3 MPH

NOTE: TOTALS AND SUBTOTALS ABOVE ARE OBTAINED FROM UNROUNDED NUMBERS

ENCLOSURE 2

TENNESSEE VALLEY AUTHORITY
SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
BROWNS FERRY NUCLEAR PLANT (BFN)

EFFLUENT AND WASTE DISPOSAL
SEMIANNUAL REPORT

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT

SUMMARY

SECOND HALF 1992

The radioactive effluents for the second half of 1992 were normal for a three unit boiling water reactor plant with one unit operating and the other two in extended outage.

The release of radioactive material to the environment from Browns Ferry has been a small fraction of the 10 CFR 20 Appendix B and 10 CFR 50 Appendix I limits.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
SUPPLEMENTAL INFORMATION
SECOND HALF 1992

I. Regulatory Limits

A. Fission and Activation Gases in Gaseous Effluent:

The release of fission and activation gases is regulated by the dose limits of 10 CFR 50 Appendix I. The air dose, to areas at and beyond the site boundary due to noble gases released in gaseous effluents per unit, shall be limited during any calendar quarter to ≤ 5 millirad (mrad) for gamma radiation and ≤ 10 mrad for beta radiation; and during any calendar year to ≤ 10 mrad for gamma radiation and ≤ 20 mrad for beta radiation.

B. and C. Iodines and Particulates with Half-Lives Greater than Eight Days in Gaseous Effluents.

The release of iodines and particulates in gaseous effluent is regulated by the dose limits of 10 CFR 50 Appendix I. The dose to a member of the public from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than eight days in gaseous effluent released per unit to areas at and beyond the site boundary shall be limited to any organ during any calendar quarter to ≤ 7.5 millirem (mrem), and during any calendar year to ≤ 15 mrem.

D. Liquid Effluents

The release of radioactive liquid effluents is regulated by the dose limits of 10 CFR 50 Appendix I. The doses or dose commitment to a member of the public from radioactive materials in liquid effluents released from each unit to unrestricted areas shall be limited during any calendar quarter to ≤ 1.5 mrem to the total body and < 5 mrem to any organ and during any calendar year to < 3 mrem to the total body and < 10 mrem to any organ.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
SUPPLEMENTAL INFORMATION
SECOND HALF 1992

II. Maximum Permissible Concentrations

A. Fission and Activation Gases in Gaseous Effluent:

1. The instantaneous release rate of fission and activation gases is regulated by the dose rate limit of 10 CFR 20 Appendix B. The dose rate at any time to areas at and beyond the site boundary due to noble gases released in gaseous effluents from the site shall be limited to < 500 mrem per year to the total body and < 3000 mrem per year to the skin.
2. The BFN Offsite Dose Calculation Manual (ODCM) determines the maximum noble gas release rate based upon the dose rate limits in Section III. The instantaneous noble gas release rates are limited by the following equation:

$$\frac{Q_1}{0.15} + \frac{Q_2}{14.4} < 1$$

Q1 = The release rate from the building exhaust vents in Ci per second.

Q2 = The release rate from the main stack in Ci per second.

B. and C. Iodines and Particulates with Half-Lives Greater than Eight Days in Gaseous Effluents

1. The instantaneous release rate of particulates and iodines is regulated by the dose rate limit of 10 CFR 20 Appendix B. The dose rate at any time to areas at and beyond the site boundary, due to I-131, H-3 and particulates with greater than eight days half-lives released in gaseous effluents from the site, shall be limited to < 1500 mrem per year to any organ.
2. The BFN ODCM determines the maximum particulate and iodine release rate based upon the dose rate limit in Section III. The instantaneous iodine and particulate release rates are limited by the following equation:

$$\frac{Q_3}{2.19} + \frac{Q_4}{35.7} < 1$$

Q3 = The release rate from the building exhaust vents in μ Ci per second.

Q4 = The release rate from the main stack in μ Ci per second.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
SUPPLEMENTAL INFORMATION
SECOND HALF 1992

II. Maximum Permissible Concentrations (Continued)

D. Liquid Effluents

1. The concentration of radionuclides in liquid effluents released at any time from the site to unrestricted areas shall be limited to the concentrations specified in 10 CFR 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases.
2. For dissolved or entrained noble gases, the concentration shall be limited to $2E-4$ μ Ci per milliliter (ml) total activity.

III. Average Energy - Not applicable

IV. Measurements and Approximations of Total Radioactivity

A. Fission and Activation Gases:

1. Noble gases in the building vent and stack gaseous effluent are continuously monitored. The flow rate of the stack is continuously monitored and the building vent effluent flow rates are calculated once a shift based on the configuration of operating exhaust fans. The flow rate data is consolidated weekly to determine the volume of airborne effluent released from the plant. The noble gas monitor data is consolidated monthly to determine the total curies of noble gases released during the month.
2. Gas grab samples are taken and analyzed monthly to determine the relative noble gas activity concentrations. This information is used to apportion the total curies of noble gases released among different noble gas radionuclides.
3. The tritium concentration is determined by the analysis of a monthly grab sample for each release point.

B. and C. Iodines and Particulates

1. Iodines and particulates are continuously sampled on impregnated charcoal filters and particulate filters, respectively. The charcoal and particulate samples are replaced at least weekly and analyzed to determine specific activity concentrations. The specific activity concentrations and vent flow rate data are used weekly to verify that release rate limits were not exceeded. The specific activity concentrations and total volume of gaseous effluent are used on a monthly basis to determine the total curies of each particulate and iodine released during the month.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SUPPLEMENTAL INFORMATION
 SECOND HALF 1992

IV. Measurements and Approximations of Total Radioactivity (Continued)

2. The gross alpha concentration is determined by analysis of a monthly particulate filter composite sample and strontium -89 and -90 are determined by analysis of a quarterly particulate filter composite sample for each release point.

D. Liquid Effluents

1. The gamma ray emitting radionuclide concentrations are determined for each batch by gamma ray spectroscopy analysis of a grab sample. The allowable release rate is calculated for each batch based upon the known dilution flow. The flow rate of the liquid effluent is continuously monitored and the total volume released in each batch is determined. The total gamma activity released in each batch is determined by multiplying the radionuclide concentrations by the total volume discharged. The total gamma activity released during the month is then determined by summing the gamma activity content of each batch discharged during the month.
2. The gross alpha and tritium concentrations are measured on a monthly composite sample. The strontium -89 and -90 and iron -55 are measured on a quarterly composite sample.

V. Batch

	<u>Third Quarter</u>	<u>Fourth Quarter</u>	Units
A. Liquid			
1. Number of batches released	75	117	Each
2. Total time period for batch releases	19400	32088	Minutes
3. Maximum time period for a batch release	355	365	Minutes
4. Average time period for batch releases	258	274	Minutes
5. Minimum time period for a batch release	140	165	Minutes
6. Average stream flow during period of release of effluent into a flowing stream	36172	62842	cfs
B. Gaseous None			

VI. ABNORMAL/UNPLANNED RELEASES (1)

	NUMBER OF RELEASES	TOTAL ACTIVITY
A. Liquid	None	None
B. Gaseous	None	None

- (1) All abnormal/unplanned releases shall be discussed in the summary.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992
 LIQUID EFFLUENTS - SUMMATION OF ALL RELEASES

	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>	<u>% Error</u>
A. Fission and Activation Products				
1. Total Releases	Curies	4.91E-01	1.04E+00	9
2. Average Diluted Concentration Released During Period	µCi/ml	1.12E-08	1.43E-08	
3. Percent of Applicable Limit (1.00E-07 µCi/ml)	%	1.12E+01	1.43E+01	
B. Tritium				
1. Total Releases	Curies	7.75E+00	9.54E+00	6
2. Average Diluted Concentration Released During Period	µCi/ml	1.76E-07	1.31E-07	
3. Percent of Applicable Limit (3E-03 µCi/ml)	%	5.87E-03	4.36E-03	
C. Dissolved and Entrained Noble Gases ¹				
1. Total Releases	Curies	1.17E-02	1.63E-01	8
2. Average Diluted Concentration Released During Period	µCi/ml	2.66E-10	2.23E-09	
3. Percent of Applicable Limit (2E-04 µCi/ml)	%	1.33E-04	1.11E-03	
D. Gross Alpha Radioactivity				
1. Total Releases	Curies	ND	3.51E-03	48
2. Average Diluted Concentration Released During Period	µCi/ml	ND	4.81E-11	
E. Volume of Liquid Waste to Discharge Canal (Before dilution)				
	Liters	8.55E+06	1.40E+07	3
F. Volume of Dilution Water for Period				
	Liters	4.40E+10	7.29E+10	10
G. Total CCW flow for Six Months				
	Gigagallons		153.6	

¹ Includes Xe-133, Xe-135, and others

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
LIQUID RELEASES FOR SECOND HALF 1992 - BATCH MODE

<u>Isotope</u> (Required by Regulation (REG) Guide 1.21)	<u>Third Quarter</u> <u>Unit Curies</u>	<u>Fourth Quarter</u> <u>Unit Curies</u>
1. Cr-51	2.32E-02	5.72E-02
2. Mn-54	4.07E-03	1.23E-02
3. Co-58	1.50E-03	4.59E-03
4. Fe-59	ND	ND
5. Co-60	1.95E-02	1.71E-02
6. Zn-65	2.84E-03	2.15E-02
7. Nb-95	ND	ND
8. Zr-95	ND	ND
9. Mo-Tc-99m	3.55E-02	1.79E-01
10. I-131	1.35E-02	1.50E-02
11. Xe-133	4.37E-03	2.45E-02
12. Cs-134	1.11E-02	1.23E-02
13. Xe-135	7.35E-03	3.91E-02
14. Cs-137	1.28E-01	1.05E-01
15. Ba-140	2.74E-04	7.47E-05
16. La-140	1.29E-04	ND
17. Ce-141	ND	ND
18. Sr-89	2.96E-02	8.03E-03
19. Sr-90	2.14E-03	1.07E-03

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
LIQUID RELEASES FOR SECOND HALF 1992 - BATCH MODE

<u>Isotope</u> (Not Required by Regulation (REG) Guide 1.21)	<u>Third Quarter</u> <u>Unit Curies</u>	<u>Fourth Quarter</u> <u>Unit Curies</u>
1. Fe-55	1.86E-03	1.25E-02
2. Na-24	2.05E-01	5.40E-01
3. Sr-91	ND	1.05E-03
4. I-132	1.08E-04	8.42E-04
5. I-133	1.07E-02	3.69E-02
6. I-135	ND	1.56E-02
7. Xe-133m	ND	1.79E-04
8. Xe-135m	8.41E-11	2.38E-07
9. Y-91m	1.25E-05	5.43E-04
10. Sr-92	7.49E-05	2.54E-04
11. Ag-110m	8.62E-04	3.97E-04
12. Ru-103	4.13E-04	1.74E-04
13. Sb-124	5.97E-05	ND
14. Cs-136	2.75E-04	7.61E-04
15. Tc-104	ND	4.57E-10
16. I-134	ND	5.68E-06



EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992¹
 GASEOUS EFFLUENTS - SUMMATION OF ALL RELEASES

Summation of All Releases	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>	<u>% Error</u>
A. Fission and Activation Gases				
1. Total Releases	Curies	3.59E+03	1.01E+04	45
2. Average Release Rate for Period	µCi/sec	4.56E+02	1.29E+03	
3. Percent of Technical Specification (TS) limit ¹	%	5.52E-03	8.93E-03	
B. Iodines				
1. Total Iodine-131 & I-133	Ci	4.52E-02	2.99E-02	36
2. Average Release Rate for Period	µCi/sec	5.76E-03	3.80E-03	
3. Percent of TS limit ²	%	2.43E-01	1.60E-01	
C. Particulates				
1. Particulates with half-lives > eight days	Ci	9.20E-03	2.06E-02	35
2. Average release rate for period	µCi/sec	1.17E-03	2.62E-03	
3. Percent of TS limit ²	%	5.23E-02	1.18E-01	
4. Gross alpha radioactivity	Ci	ND.	7.01E-07	
D. Tritium				
1. Total release	Ci	7.53E+00	3.96E+00	21
2. Average release rate for period	µCi/sec	9.58E-01	5.04E-01	
3. Ground level release	Ci	7.23E+00	3.89E+00	
4. Elevated release	Ci	2.99E-01	7.25E-02	

¹ Reporting period - 182 days.

² The dose rate limit for Noble gases shall be < 500 mrem per year to the total body and < 3000 mrem per year to the skin and the dose rate limit for I-131, I-133, H-3, and particulates with ≥ eight day half-lives shall be < 1500 mrem per year to any organ.



EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992¹
 GASEOUS EFFLUENTS - ELEVATED RELEASE

	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>
1. Fission Gases			
Kr-85m	Ci	6.18E+02	1.56E+03
Kr-85	Ci	ND	ND
Kr-87	Ci	2.24E+02	8.52E+02
Kr-88	Ci	9.64E+02	2.82E+03
Xe-133	Ci	1.65E+03	4.40E+03
Xe-135m	Ci	ND	ND
Xe-135	Ci	3.51E+01	2.73E+02
Xe-138	Ci	ND	ND
Others (specify)			
Ar-41	Ci	1.15E+01	1.15E+01
Xe-133m	Ci	5.35E+01	1.95E+02
<u>Total for Period</u>	Ci	3.56E+03	1.01E+04
2. Iodines			
I-131	Ci	8.35E-04	5.56E-04
I-132	Ci	2.09E-03	2.10E-03
I-133	Ci	2.89E-03	1.99E-03
I-134	Ci	ND	ND
I-135	Ci	5.47E-03	3.00E-03
<u>Total for Period</u>	Ci	1.13E-02	7.65E-03

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992¹
 GASEOUS EFFLUENTS - ELEVATED RELEASE

	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>
3. Particulates ²			
Sr-89 ¹	Ci	3.27E-05	5.69E-05
Sr-90 ¹	Ci	6.60E-08	1.80E-07
Cs-134	Ci	ND	ND
Cs-137	Ci	ND	ND
Ba-140	Ci	1.12E-04	8.34E-05
La-140	Ci	5.71E-05	8.00E-05
Others (specify)			
Ag-110m	Ci	ND	ND
Ba-139	Ci	1.10E-01	5.56E-02
Co-58	Ci	ND	ND
Co-60	Ci	ND	ND
Cr-51	Ci	ND	ND
Na-24	Ci	ND	ND
Mn-54	Ci	ND	7.99E-05
Mn-56	Ci	ND	ND
MoTc-99m	Ci	ND	ND
Zn-65	Ci	ND	ND
Sr-91	Ci	3.94E-03	5.59E-03
Y-92	Ci	ND	ND
Rb-88	Ci	ND	1.82E+00
Y-91m	Ci	ND	1.95E-03
Ru-103	Ci	ND	ND
Cs-136	Ci	ND	ND
<u>Total for Period</u>	Ci	1.14E-01	1.88E+00
4. Tritium	Ci	2.99E-01	7.25E-02

¹Predicted estimation of releases.

²Include all particulate nuclides (even those with half-lives < 8 days)

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992¹
 GASEOUS EFFLUENTS - GROUND LEVEL RELEASE

	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>
1. Fission Gases.			
Kr-85m	Ci	ND	ND
Kr-85	Ci	ND	ND
Kr-87	Ci	ND	ND
Kr-88	Ci	ND	ND
Xe-133	Ci	ND	ND
Xe-135m	Ci	ND	ND
Xe-135	Ci	2.80E+01	ND
Xe-138	Ci	ND	ND
Others (specify)			
Ar-41	Ci	ND	ND
Xe-133m	Ci	ND	ND
<u>Total for Period</u>	Ci	2.80E+01	ND
2. Iodines			
I-131	Ci	3.69E-03	2.79E-03
I-132	Ci	1.81E-02	2.34E-02
I-133	Ci	3.78E-02	2.46E-02
I-134	Ci	2.06E-02	ND
I-135	Ci	4.68E-02	ND
<u>Total for Period</u>	Ci	1.27E-01	5.07E-02

¹Predicted estimation of releases.

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992¹
 GASEOUS EFFLUENTS - GROUND LEVEL RELEASE

	<u>Unit</u>	<u>Third Quarter</u>	<u>Fourth Quarter</u>
3. Particulates²			
Sr-89 ¹	Ci	1.69E-03	2.25E-05
Sr-90 ¹	Ci	4.09E-07	ND
Cs-134	Ci	3.14E-05	1.72E-04
Cs-137	Ci	6.53E-04	4.80E-04
Ba-140	Ci	4.98E-04	5.59E-04
La-140	Ci	3.62E-04	3.97E-04
Others (specify)			
Ag-110m	Ci	3.67E-04	8.54E-04
Ba-139	Ci	9.38E-01	5.02E-01
Co-58	Ci	1.82E-04	3.07E-04
Cr-51	Ci	3.95E-03	9.93E-03
Co-60	Ci	3.49E-04	5.22E-03
Mn-54	Ci	2.34E-04	3.25E-04
Mn-56	Ci	1.41E-02	ND
MoTc-99m	Ci	4.49E-03	1.77E-03
Na-24	Ci	1.36E-01	9.48E-02
Zn-65	Ci	6.78E-04	1.83E-03
Sr-91	Ci	5.91E-03	9.98E-03
Y-92	Ci	3.80E-02	ND
Rb-88	Ci	ND	ND
Y-91m	Ci	ND	4.63E-02
Ru-103	Ci	ND	9.63E-05
Cs-136	Ci	ND	1.47E-04
<u>Total for Period</u>	Ci	1.15E+00	6.75E-01
4. Tritium	Ci	7.23E+00	3.89E+00

¹Predicted estimation of releases.

²Include all particulate nuclides (even those with half-lives < 8 days)

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS

A. Solid Waste Shipped Offsite For Burial Or Disposal (Not Irradiated Fuel)

1.	Type of Waste	Units	Amount	Error %
a.	Spent resins, filter sludges, evaporator bottoms, etc.	m3 Ci	8.75E+01 5.91E+01	1.50E+01
*b.	Dry compressible waste contaminated equip., etc.	m3 Ci	5.71E+01 3.45E+00	1.50E+01
c.	Irradiated components, control rods, etc.	m3 Ci	0.00E+00 0.00E+00	1.50E+01
d.	Other	m3 Ci	0.00E+00 0.00E+00	N/A

* Dry compressible waste shipped from processor to the burial ground.

2. Estimate of major nuclide composition (by waste type)

a. Spent resins, filter sludge, evaporator bottoms, etc.

	Nuclide	Percentage	Ci
1.	Iron - 55 (2)	4.35E+00	2.53E+00
2.	Cobalt-60 (1)	1.98E+01	1.15E+01
3.	Cesium-134 (1)	1.72E+00	1.02E+00
4.	Cesium-137 (1)	2.65E+01	1.54E+01
5.	Nickel-63 (1)	3.20E+01	1.86E+01
6.	Manganese-54 (1)	1.00E+00	5.85E-01
7.	Iodine-131 (1)	4.00E+00	2.35E+00
8.	Barium/Lanthanum-140 (1)	3.95E+00	2.30E+00
9.	Zinc-65 (1)	2.70E+00	1.57E+00
10.	Chromium-51(1)	4.00E+00	2.32E+00

(1) Measured
 (2) Calculated

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 (Continued)

A. Solid Waste Shipped Offsite For Burial Or Disposal
 (Not Irradiated Fuel) (Continued)

2. Estimate of major nuclide composition (by waste type) (Continued)

b. Dry compressible waste, contaminated equipment, etc.

	<u>Nuclide</u>	<u>Percentage</u>	<u>Ci</u>
1.	Iron-55 (2)	2.50E+01	8.63E-01
2.	Cobalt-60 (2)	6.52E+01	2.25E+00
3.	Nickel-63 (2)	2.59E+00	8.94E-02
4.	Cesium-137 (2)	6.99E+00	2.42E-01

(1) Measured
 (2) Calculated

c. Irradiated components, control rods, etc.

None

d. Other

None

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
15	Sole Use Truck	Barnwell, SC
29	Sole Use Truck	Quadrex, Oak Ridge, TN
8	Sole Truck	SEG, Oak Ridge, TN

EFFLUENT AND WASTE DISPOSAL SEMIANNUAL REPORT
 SECOND HALF 1992
 SOLID WASTE AND IRRADIATED FUEL SHIPMENTS
 (Continued)

B. Irradiated Fuel Disposition

<u>Number of Shipments</u>	<u>Mode of Transportation</u>	<u>Destination</u>
None	N/A	N/A

C. Description of Shipments

<u>Number of Shipments</u>	<u>Type Container</u>	<u>Type Quantity</u>	<u>Number of Containers</u>	<u>Container Volume</u>	<u>Type Waste</u>
37	Strong Tight Container (STC)	A-LSA	See Note	See Note	DAW
14	High Integrity Container (HIC)	A-LSA	14	5.83m3	Dewatered Resin
1	HIC	B-LSA	1	5.83m3	Dewatered Resin

Solidification agents used: None

Absorbents used: None

NOTE: 37 shipments to waste processor contained the following:

<u>Type of Package</u>	<u>Number of Packages</u>	<u>Volume Each Package (m3)</u>
40' Sealand (STC)	6	72.50
20' Sealand (STC)	2	36.25
"FR" Box (STC)	12	06.40
"B" Box (STC)	28	02.66
"7A/55 Gallon" Drums (STC)	1211	00.21
Leaded Box (STC)	6	12.90
"Waltz Mill" Fuel Rack Box (STC)	3	36.25

ENCLOSURE 3

TENNESSEE VALLEY AUTHORITY
SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
BROWNS FERRY NUCLEAR PLANT (BFN)

INOPERABLE RADIOLOGICAL EFFLUENT
INSTRUMENTATION REPORT

INOPERABLE RADIOLOGICAL EFFLUENT INSTRUMENTATION REPORT

This report is to comply with Browns Ferry Nuclear Plant Technical Specifications (TSs), Sections 3.2.D.2, 3.2.K.2 and Offsite Dose Calculation Manual (ODCM), Sections 1/2.1.1 and 1/2.1.2. The BFN TS and ODCM require the exertion of best efforts to return inoperable radiological effluent monitoring instrumentation to an operable status within 30 days. Failure to return the inoperable instruments to an operable status requires a description in the next Semiannual Radioactive Effluent Release Report.

During the reporting period, July 1 through December 31, 1992, there was no airborne or liquid radiological effluent instrumentation inoperable for periods greater than 30 days.

The Effluent Monitors, which have been placed in "out-of-service" status with their effluent streams isolated, are not applicable for this report.

During this period, Units 1 and 3 were defueled and Unit 2 operating.

ENCLOSURE 4

TENNESSEE VALLEY AUTHORITY
SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT
BROWNS FERRY NUCLEAR PLANT (BFN)


CHANGES TO THE BFN OFFSITE DOSE CALCULATION MANUAL
JULY THROUGH DECEMBER 1992



CHANGES TO THE ODCM

BFN Technical Specification 6.12.2 requires that changes to the Offsite Dose Calculation Manual (ODCM) be submitted to the commission with the semiannual Radioactive Effluent Release Report for the period in which the changes were made. This report covers the period between July through December 1992.

During this period, two revisions have been made to the ODCM. Revision 12 was a general revision and is submitted in its entirety. Revision 13, only the pages affected by the changes are submitted. Reference the attached notebook which contains the above changes.



SITE STANDARD PRACTICE	ADMINISTRATION OF SITE PROCEDURES	SSP-2.3 NOV 04 1991
------------------------------	--------------------------------------	------------------------

FORM SSP-2
Page 1 of 2
SAFETY ASSESSMENT FORM

Procedure No. RETS Manual Tracking No. 12

Does a previous safety assessment adequately address this change? YES NO
 If yes, go to page 2, and state in the summary section which previous assessment is applicable. X

List the specific Tech Spec requirements (by number) associated with this procedure:
1.0 LL, 4.5.3, and 6.8.1

	<u>YES</u>	<u>NO</u>	<u>NA</u>
A. Does this procedure (or source notes) specify the Tech Spec requirements it implements? (If a procedure does <u>not</u> fully satisfy a Tech Spec requirement, it must state what <u>part</u> of the requirements it <u>does</u> fulfill.)	<u>X</u>	<u> </u>	<u> </u>
B. Does this procedure satisfy all associated Tech Spec requirements?	<u>X</u>	<u> </u>	<u> </u>
C. Is this procedure consistent with the <u>basis</u> for the applicable Tech Spec requirements?	<u>X</u>	<u> </u>	<u> </u>

If any of the preceding questions A through C are answered "NO", then

- 1) Change the procedure to achieve a "YES" answer, or
- 2) Obtain a License Amendment from NRC before proceeding.

List the SAR sections and documents related to this procedure:
13.6 and Appendix G

D. Does the procedure require system operation consistent with the SAR?	<u> </u>	<u> </u>	<u>X</u>
E. Are setpoints and acceptance criteria consistent with the SAR?	<u>X</u>	<u> </u>	<u> </u>
F. Is the procedure consistent with personnel duties and responsibilities specified in the SAR?	<u>X</u>	<u> </u>	<u> </u>
G. Are prerequisites for plant systems status and equipment condition adequate and consistent with safe operation?	<u>X</u>	<u> </u>	<u> </u>

SITE STANDARD PRACTICE	ADMINISTRATION OF SITE PROCEDURES	SSP-2.3 NOV 04 1991
------------------------------	--------------------------------------	----------------------------

FORM SSP-2
Page 2 of 2

- | | <u>YES</u> | <u>NO</u> | <u>NA</u> |
|--|------------|-----------|-----------|
| H. Does the procedure fulfill the requirements of all applicable SAR sections? | <u>X</u> | ___ | ___ |
| I. If the procedure is a test that could impact nuclear safety, has the test been authorized by NRC? | ___ | ___ | <u>X</u> |

If any of the preceding questions D through I are answered "NO", then

- 1) Change the procedure to achieve a "YES" answer, or
- 2) Complete a Safety Evaluation per SSP-12.13.

J. Does the procedure make a temporary alteration to a Radwaste System? If YES, complete a Safety Evaluation per SSP-12.13.

___ X

K. Is this procedure change safe from a Nuclear Safety standpoint? If NO, revise or cancel the procedure.

X ___

Provide a summary of why this procedure is safe: This change is being made to implement Technical Specification change 311.
TS change 311 deletes the 3.25 times limitation on extension of three consecutive SI intervals consistent with the guidance from NRC Generic Letter 89-14.
Since this change is to implement TS, it is safe from a nuclear safety standpoint.

Prepared by: Beth Lind-Lew 11/6/92
 50.59 Level I Reviewer Date

Dale W. King 11/6/92 Steve Bennett 11/6/92
 Safety Assessment Reviewer Date Sponsoring Manager Date

(Must be a 50.59 Level I Reviewer and also be IQR qualified or be a 50.59 Level II Reviewer)



SITE STANDARD PRACTICE	ADMINISTRATION OF SITE PROCEDURES	SSP-2.3 Page 26 of 46 REV 0005
------------------------------	--------------------------------------	--------------------------------------

APPENDIX C (Continued)

TYPICAL COVERSHEET AND REVISION LOG

The detailed description of change will only be issued to controlled copies for the latest revision. DCRM or Site Procedure maintains a complete history of all revisions.

REVISION LOG

Procedure Number: RETS Manual TR#12 Revision Number: _____
(Site Procedures completes)

Pages Affected: 49, 54, 59

Description of Change: This change makes the

ODCRM consistent with TS change
311. This change removes the
provision in control/surveillance
requirement 2.0.2 that limits the
combined time interval for three
consecutive surveillance tests to
less than 3.25 times the interval
specified in the ODCRM for the
surveillance test. The 3.25 time
interval is removed from two notes
(pp. 54, 59).

Please type on an urgent basis. PORC Friday
11/13/92.

Parallel Procedure Changes (including tracking number): Issue with
TS change 311, 1-SI-1 TR#4, 2-SI-1 TR#12
813p SSP 8.2 TR#4

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT

RETS MANUAL

RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATION (RETS)

REVISION 12

PREPARED BY: DALE W. NIX

PHONE: 2682

RESPONSIBLE ORGANIZATION: CHEMICAL TECHNICAL SUPPORT

APPROVED BY: A. W. SORRELL

DATE: 11/17/92

EFFECTIVE DATE: 11/18/92

VALIDATION DATE: NOT REQUIRED

QUALITY-RELATED

CONTROLLED



(1496)

REVISION LOG

Procedure Number: RETS MANUAL

Revision Number: 12

Pages Affected: 49, 54, 59

Pagination Pages: 1-48, 50-53, 55-58, 60-266

Description of Change:

- The change makes the ODCM consistent with TS change 311. This change removes the provision in control/surveillance requirement 2.0.2 that limits the combined time interval for three consecutive surveillance tests to less than 3.25 time the interval specified in the ODCM for the surveillance test. The 3.25 time interval is removed from two notes (pp. 54, 59).

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.0 APPLICABILITY

SURVEILLANCE REQUIREMENTS

- 2.0.1 Surveillance Requirements shall be met during the conditions specified for individual Controls unless otherwise stated in the individual Surveillance Requirement.
- 2.0.2 Each Surveillance Requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the surveillance interval.
- 2.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance and OPERABILITY requirements for a Control and associated action statements unless otherwise required by these Controls. Surveillance Requirements do not have to be performed on inoperable equipment.

Table 2.1-1 (Page 2 of 2)
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS
TABLE NOTATION

NOTE: Each requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the interval given.

- 1 The CHANNEL FUNCTIONAL TEST shall demonstrate that automatic isolation of this pathway and control room alarm annunciation occurs if any of the following conditions exists:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates an inoperative/downscale failure.
 - c. Instrument controls not set in operate mode.
- 2 The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates an inoperative/downscale failure.
 - c. Instrument controls not set in operate mode.
- 3 This functional test shall consist of measuring rate of tank decrease over a period of time and comparing this value with flow rate instrument reading.
- 4 INSTRUMENT CHECK shall consist of verifying indication during periods of release. INSTRUMENT CHECK shall be made at least once per 24 hours on days which continuous, periodic, or batch releases are made.
- 5 The CHANNEL CALIBRATION shall include the use of a known (traceable to the National Institute of Standards and Technology (NIST)) radioactive source(s) positioned in a reproducible geometry with respect to the sensor or using standards that have been obtained from suppliers that participate in measurement assurance activities with the NIST.

Table 2.1-2 (Page 2 of 2)
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

NOTE: Each requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the interval given.

- 1 The CHANNEL CALIBRATION shall include the use of a known (traceable to the National Institute of Standards and Technology (NIST)) radioactive source(s) positioned in a reproducible geometry with respect to the sensor or using standards that have been obtained from suppliers that participate in measurement assurance activities with the NIST.
- 2 The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:
 1. Instrument indicates measured levels above the alarm/trip setpoint.
 2. Instrument indicates an inoperative/downscale failure.
 3. Instrument controls not set in operate mode (stack only).
- 3 The CHANNEL FUNCTIONAL TEST shall demonstrate that automatic isolation of this pathway and control room alarm annunciation occurs if any of the following conditions exists:
 1. Instrument indicates measured levels above the alarm/trip setpoint.
 2. Instrument indicates an inoperative/downscale failure.
 3. Instrument controls not set in operate mode (stack only).

The two channels are arranged in a coincidence logic such that 2 upscale, or 1 downscale and 1 upscale or 2 downscale will isolate the offgas line. ,
- 4 The noble gas monitor shall have a LLD of 1E-5 (Xe-133 Equivalent)
- 5 The noble gas monitor shall have a LLD of 1E-6 (Xe-133 Equivalent)

SITE STANDARD PRACTICE	ADMINISTRATION OF SITE PROCEDURES	SSP-2.3 NOV 04 1991
------------------------------	--------------------------------------	------------------------

FORM SSP-2
Page 1 of 2
SAFETY ASSESSMENT FORM

Procedure No. RETS Manual Tracking No. 13

Does a previous safety assessment adequately address this change?
If yes, go to page 2, and state in the summary section which previous assessment is applicable.

YES NO
_____ X

List the specific Tech Spec requirements (by number) associated with this procedure:

See attached

- | | <u>YES</u> | <u>NO</u> | <u>NA</u> |
|---|------------|-----------|-----------|
| A. Does this procedure (or source notes) specify the Tech Spec requirements it implements? (If a procedure does <u>not</u> fully satisfy a Tech Spec requirement, it must state what <u>part</u> of the requirements it <u>does</u> fulfill.) | <u>X</u> | _____ | _____ |
| B. Does this procedure satisfy all associated Tech Spec requirements? | <u>X</u> | _____ | _____ |
| C. Is this procedure consistent with the <u>basis</u> for the applicable Tech Spec requirements? | <u>X</u> | _____ | _____ |

If any of the preceding questions A through C are answered "NO", then

- 1) Change the procedure to achieve a "YES" answer, or
- 2) Obtain a License Amendment from NRC before proceeding.

List the SAR sections and documents related to this procedure:

See attached.

- | | | | |
|--|----------|-------|----------|
| D. Does the procedure require system operation consistent with the SAR? | _____ | _____ | <u>X</u> |
| E. Are setpoints and acceptance criteria consistent with the SAR? | <u>X</u> | _____ | _____ |
| F. Is the procedure consistent with personnel duties and responsibilities specified in the SAR? | <u>X</u> | _____ | _____ |
| G. Are prerequisites for plant systems status and equipment condition adequate and consistent with safe operation? | <u>X</u> | _____ | _____ |

SITE STANDARD PRACTICE	ADMINISTRATION OF SITE PROCEDURES	SSP-2.3 NOV 04 1991
------------------------------	--------------------------------------	------------------------

FORM SSP-2
Page 2 of 2

- | | <u>YES</u> | <u>NO</u> | <u>NA</u> |
|--|------------|-----------|-----------|
| H. Does the procedure fulfill the requirements of all applicable SAR sections? | <u>X</u> | _____ | _____ |
| I. If the procedure is a test that could impact nuclear safety, has the test been authorized by NRC? | _____ | _____ | <u>X</u> |

If any of the preceding questions D through I are answered "NO", then

- 1) Change the procedure to achieve a "YES" answer, or
- 2) Complete a Safety Evaluation per SSP-12.13.

- | | | | |
|---|----------|----------|--|
| J. Does the procedure make a temporary alteration to a Radwaste System? If YES, complete a Safety Evaluation per <u>SSP-12.13</u> . | _____ | <u>X</u> | |
| K. Is this procedure change safe from a Nuclear Safety standpoint? If NO, revise or cancel the procedure. | <u>X</u> | _____ | |

Provide a summary of why this procedure is safe: _____

see attached.

Prepared by: Dale W. King 11/24/92
 50.59 Level I Reviewer Date

Roger Shuman 11/25/92 Stan Z. Oles 12/4/92
 Safety Assessment Reviewer Date Sponsoring Manager Date

(Must be a 50.59 Level I Reviewer and also be IQR qualified or be a 50.59 Level II Reviewer)

RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATIONS MANUAL

Revision 13 - Tracking No. 13

Technical Specification (TS) References:

Sections 1.0 BB, 1.0 EE, 3/4.8, 6.5.1.6 g, 6.5.1.6 h, 6.5.2.8 n, 6.5.2.8 o, 6.5.2.8 p, 6.8.1.1 g, 6.8.1.1 h, 6.8.1.1 i, 6.11, 6.12, and 6.13.

Final Safety Analysis Report (FSAR) References:

Sections 1.6.1.6, 2.6.2, 7.12, 9.0, 10.12.5.2, 10.12.5.4, and 10.17.

Provide a summary of why this procedure is safe:

Several typographical errors were corrected. This includes corrections to the stack monitor designation, units in equations, number of pumps available for minimum dilution flow, and values in the tables.

A station was added to collect drinking water (public water) from the Florence, Alabama municipal water supply. The city of Florence, Alabama has recently built a second water treatment plant. This plant draws water from the Tennessee River at river mile 259.8. Since this is a new water supply taken from the river downstream from BFN, the station will be added to the BFN radiological environmental monitoring program.

The only systems potentially affected by a change to the ODCM will be the liquid and gaseous effluent and process monitoring systems described in the BFN FSAR. The typographical changes and the addition of a monitoring station do not affect any system. This change is safe from a nuclear safety standpoint.

TENNESSEE VALLEY AUTHORITY

BROWNS FERRY NUCLEAR PLANT

RETS MANUAL

RADIOLOGICAL EFFLUENT TECHNICAL SPECIFICATION (RETS)

REVISION 13

PREPARED BY: DALE W. NIX

PHONE: 2682

RESPONSIBLE ORGANIZATION: CHEMICAL TECHNICAL SUPPORT

APPROVED BY: J. SCALICE

DATE: 12/22/92

EFFECTIVE DATE: 12/29/92

VALIDATION DATE: NOT REQUIRED

QUALITY-RELATED



(1496)

REVISION LOG

Procedure Number: RETS MANUAL

Revision Number: 13

Pages Affected: 56, 103, 111, 115, 118-120, 202, 204, 215, 217, 234, 237, 241

Pagination Pages: 1-55, 57-102, 104-110, 112-114, 116, 117, 121-201, 203,
205-214, 216, 218-233, 235, 236, 238-240, 242-266

Description of Change:

- Several typographical errors were corrected. This includes corrections to the stack monitor designation, units in equations, number of pumps available for minimum dilution flow, and values in tables. Add the collection of drinking water (public water) from the Florence, Alabama municipal water supply.

Browns Ferry Nuclear Plant

Radiological Effluent

Technical Specification

(RETS)

Manual

INDEX

Section

- I. Introduction
- II. Radiological Effluent Manual (REM)
- III. Offsite Dose Calculation Manual (ODCM)
- IV. Process Control Program (PCP)

RETS Manual

Section I

Introduction

RETS Manual

Section I

INTRODUCTION

The Radiological Effluent Technical Specification (RETS) Manual contains three documents; the Radiological Effluent Manual (REM), the Offsite Dose Calculation Manual (ODCM), and the Process Control Program (PCP). All three documents are referenced by the Radiological Effluent Technical Specifications which were issued on February 5, 1987 as Technical Specification Amendments Nos. 132, 128, and 103 to unit 1, 2, and 3, respectively.

The REM and the ODCM were approved by the NRC when they issued the RETS. The REM is controlled by the NRC, so changes to the REM must be approved by the NRC before they are put in this manual. The ODCM and PCP are controlled by TVA, so changes to the ODCM and the PCP must be approved by PORC. Initial NRC approval of the PCP is required and has been requested.



RETS MANUAL

Section II

RADIOLOGICAL EFFLUENT MANUAL (REM)

For the Browns Ferry Nuclear Plant

Limestone County, Alabama

Tennessee Valley Authority

RADIOLOGICAL EFFLUENT MANUAL

TABLE OF CONTENTS

<u>SECTION</u>	<u>PAGE NO.</u>	<u>REV. NO.</u>
A. INTRODUCTION	A-1	0
B. RESPONSIBILITIES	B-1	0
C. 1. LIQUID EFFLUENTS SAMPLING AND ANALYSIS PROGRAM	C-1	0
2. LIQUID WASTE TREATMENT	C-5	0
D. 1. GASEOUS EFFLUENTS SAMPLING AND ANALYSIS PROGRAM	D-1	0
2. GASEOUS WASTE TREATMENT	D-5	0
E. RADIOLOGICAL ENVIRONMENTAL MONITORING		
1. SAMPLING AND ANALYSIS	E-1	0
2. LAND USE CENSUS	E-3	0
3. INTERLABORATORY COMPARISON PROGRAM	E-5	0
F. REPORT CONTENT		
1. ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT	F-1	0
2. SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT	F-2	0
3. SPECIAL REPORTS (RADIOLOGICAL ENVIRONMENTAL MONITORING)	F-3	0

A. INTRODUCTION

The purpose of this manual is to provide the sampling and analysis programs which provide input to the ODCM for calculating liquid and gaseous effluent concentrations and offsite doses. Guidelines are provided for operating radioactive waste treatment systems in order that offsite doses are kept as-low-as-reasonable-achievable (ALARA).

The Radiological Environmental Monitoring Program outlined within this manual provides confirmation that the measurable concentrations of radioactive material released as a result of operations at the Browns Ferry Plant are not higher than expected.

In addition, this manual outlines the information required to be submitted to the NRC in both the Annual Radiological Environmental Operating Report and the Semiannual Radioactive Effluent Release Report.



B. RESPONSIBILITIES

All changes to this manual shall be reviewed by the Plant Operations Review Committee prior to implementation.

All changes to this manual shall be approved by the NRC prior to implementation.

It shall be the responsibility of the Plant Manager to ensure that this manual is used in performance of the surveillance requirements and administrative controls of the Technical Specifications.

C. LIQUID EFFLUENT SAMPLING AND ANALYSIS PROGRAM

- C.1 Radioactive liquid waste sampling and activity analysis of each liquid waste batch to be discharged shall be performed prior to release in accordance with Table C-1.

The results of the analysis of samples collected from release points shall be used with the calculational methodology in the ODCM to assure that the concentrations at the point of release are maintained within the limits of the Technical Specifications.

TABLE C-1
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

LIQUID RELEASE TYPE	SAMPLING FREQUENCY	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	SYSTEM DESIGN CAPABILITY LOWER LIMIT OF DETECTION (LLD) (dpm/ml)
Batch Waste Releases ⁽¹⁾	Each Batch	Each Batch Prior to Release	Principal Gamma Emitters ⁽⁴⁾	5E-7 ⁽³⁾
	One Batch per Month	Monthly	Dissolved and Entrained Gases ⁽⁵⁾	1 E-5 ⁽³⁾
	Monthly Proportional Composite ⁽²⁾	Monthly	Tritium	1 E-5
			Gross a	1 E-7
	Quarterly Proportional Composite ⁽²⁾	Quarterly	Sr-89, Sr-90	5 E-8
			Fe-55	1 E-6

TABLE NOTATION - TABLE C-1

- (1) A batch release is the discharge of liquid wastes of a discrete volume. The discharge shall be thoroughly mixed prior to sampling.
- (2) A proportional composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged from the plant and is representative of the liquid discharged.
- (3) The LLD is defined, for the purposes of these specifications as the smallest concentration of radioactive material in a sample that will yield a new count (above system background) that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 s_b}{E * V * 2.22 \times 10^6 * Y * \exp(-\lambda \Delta t)}$$

Where:

LLD is the "a priori" lower limit of detection as defined above (as microcuries per unit mass or volume),

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per disintegration),

V is the sample size (in units of mass or volume),

2.22×10^6 is the number of disintegrations per minute per microcurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt for plant effluents is the elapsed time between the midpoint of sample collection and time of counting.

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

TABLE NOTATION - TABLE C-1 (Continued)

- (4) The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Zn65, Co60, Cs137, Mn54, Co58, Cs134, Ce141, Ce144, Mo99, and Fe59 for liquid releases. This list does not mean that only these nuclides are to be detected and reported. Other nuclides detected within a $\approx 95\%$ confidence level, together with the above nuclides, shall also be identified and reported as being present. Nuclides which are below the LLD for the analysis may not be reported as being present at the LLD Level for that nuclide. I-131 shall have a LLD of $\leq 1 \text{ E-6}$.
- (5) Gamma Emitters Only.

C.2 LIQUID RADIOACTIVE WASTE TREATMENT

This section requires that the appropriate portions of the liquid radwaste treatment system be used when specified. This provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable". This specification implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50 and design objective Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the liquid radwaste treatment system were specified as a suitable fraction of the guide set forth in Section II.A of Appendix I, 10 CFR Part 50, for liquid effluents.

This section also requires submittal of a special report if the limiting values are exceeded and unexpected failures of non-redundant radwaste processing equipment halt waste treatment.

The liquid radwaste system shall be used to reduce the radioactive materials in liquid wastes prior to their discharge from the site when the projected monthly dose would exceed 0.06 mrem to the total body or 0.21 mrem to any organ per unit (see Figure 4.8-1b, Technical Specification).

Doses due to liquid releases to unrestricted areas shall be projected at least once per 31 days, in accordance with the ODCM.

With radioactive liquid waste being discharged for more than 31 days without treatment and when the projected dose is in excess of limits specified above prepare and submit the Special Report pursuant to Section 6.7.2 of the Technical Specifications.

D. GASEOUS EFFLUENTS SAMPLING AND ANALYSIS PROGRAM

- D.1 Radioactive gaseous waste sampling and activity analysis shall be performed in accordance with Table D-1. Dose rates shall be determined to be within limits of the Technical Specifications using methods contained in the ODCM.

Samples of offgas system effluents shall be analyzed at least weekly to determine the identity and quantity of the principal radionuclides being released.



TABLE D-1

RADIOACTIVE GASEOUS WASTE SAMPLING AND ANALYSIS PROGRAM

GASEOUS RELEASE TYPE	SAMPLING FREQUENCY	MINIMUM ANALYSIS FREQUENCY	TYPE OF ACTIVITY ANALYSIS	SYSTEM DESIGN CAPABILITY LOWER LIMIT OF DETECTION (g/ml)
A. Containment Purge	Prior to Each Purge Grab Sample	Prior to Each Purge	Principal Gamma Emitters ⁽³⁾ H-3	1E-4 ⁽¹⁾ 1E-6
B. 1. Stack	Grab Sample	Monthly ⁽⁴⁾	Principal Gamma Emitters ⁽³⁾	1E-4 ⁽¹⁾
2. Building Ventilation	Grab Sample	Monthly ⁽⁴⁾	H-3	1E-6
a. Reactor/Turbine				
b. Turbine Exhaust				
c. Radwaste				
C. All Release Points Listed in B. Above	Continuous Sampler	Charcoal Sample Weekly ⁽⁴⁾	I-131	1E-12 ⁽²⁾
	Continuous Sampler	Particulate Sample Weekly ⁽⁴⁾	Principal Gamma Emitters ⁽³⁾ and I-131	1E-11 ⁽²⁾ 1E-12 ⁽²⁾
	Continuous Sampler	Composite Particulate Sample Monthly	Gross Alpha	1E-11
	Continuous Sampler	Composite Particulate Sample Quarterly	Sr-89, Sr-90	1E-11

TABLE NOTATION - TABLE D-1

- (1) The LLD is defined, for the purposes of these specifications as the smallest concentration of radioactive material in a sample that will yield a new count (above system background) that will be detected with 95% probability with only 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 s_b}{E * V * 2.22 \times 10^6 * Y * \exp(-\lambda \Delta t)}$$

Where:

LLD is the "a priori" lower limit of detection as defined above (as microcuries per unit mass or volume),

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per disintegration),

V is the sample size (in units of mass or volume),

2.22×10^6 is the number of disintegrations per minute per microcurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt for plant effluents is the elapsed time between the midpoint of sample collection and time of counting.

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posterior (after the fact) limit for a particular measurement.

- (2) When samples are taken more often than that shown, the minimum detectable concentrations can be correspondingly higher.

TABLE NOTATION - TABLE D-1 (Continued)

- (3) The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141, and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level for that nuclide.
- (4) Analysis shall also be performed if the radiation monitor alarm exceeds the setpoint value.

D.2 GASEOUS RADIOACTIVE WASTE TREATMENT

Doses due to gaseous releases to areas at and beyond the site boundary shall be projected in accordance with the ODCM at least once per 31 days.



E. RADIOLOGICAL ENVIRONMENTAL MONITORING

E.1 SAMPLING AND ANALYSIS

The radiological monitoring program required by this section provides measurements of radiation and of radioactive materials in those exposure pathways and for those radionuclides, which lead to the highest potential radiation exposures of individuals resulting from the station operation. This monitoring program thereby supplements the radiological effluent monitoring program by verifying that the measureable concentrations of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways.

The radiological environmental monitoring program shall be conducted as specified in Table E-1.

The radiological environmental monitoring samples shall be collected pursuant to Table E-1 from the locations given in the table and figure in the ODCM and shall be analyzed pursuant to the requirement of Table E-1 and the detection capabilities required by Table E-2.

With the radiological environmental monitoring program not being conducted as specified in Table E-1, in lieu of a LER, prepare and submit to the Commission, in the Annual Radiological Operating Report, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.

Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability or malfunction of automatic sampling equipment. If the latter, every effort shall be made to complete corrective action prior to the end of the next sampling period. All deviations from the sampling schedule shall be reported in the Annual Radiological Environmental Operating Report.

With the level of radioactivity in an environmental sampling medium exceeding the reporting levels of Table E-3 when averaged over any calendar quarter, in lieu of a LER, prepare and submit to the Commission within 30 days from the end of the affected calendar quarter, a report which identifies the cause(s) for exceeding the limit(s) and defines the corrective action to be taken to reduce radioactive effluents so that the potential annual dose to a member of the public is less than the calendar year limits of the Technical Specifications. When more than one of the radionuclides in Table E-3 are detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{Conc}(1)}{\text{Limit}(1)} + \frac{\text{Conc}(2)}{\text{Limit}(2)} + \dots \geq 1.0$$

When radionuclides other than those in Table E-3 are detected and are result of plant effluents, this report shall be submitted if the potential annual dose to a member of the public is equal to or greater than the calendar year limits of the Technical Specification.

Such reports are not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Operating Report.

With milk or fresh leafy vegetable samples unavailable from one or more of the sample locations required by Table E-1 identify locations for obtaining replacement samples, if available, and add them to the radiological environmental monitoring program within 30 days. The specific locations from which samples were unavailable may then be deleted from the monitoring program.

In lieu of a LER, identify the cause of the unavailability of samples and identify the new location(s), if available, for obtaining replacement samples in the next Annual Radiological Environmental Operating Report and also include a revised figure(s) and table(s) for the ODCM reflecting the new locations.

The provisions of Technical Specification 1.0.C are not applicable.

The detection capabilities required by Table E-2 are state-of-the-art for routine environmental measurements in industrial laboratories. It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of the measurement system and not as an a posterior (after the fact) limit for particular measurement. Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing factors will be identified and described in the Annual Radiological Environmental Operating Report.

E.2 LAND USE CENSUS

A land use census shall be conducted and shall identify the location of the nearest milk animal, the nearest residence and the nearest garden* of greater than 500 square feet producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of five miles. (For elevated releases as defined in Regulatory Guide 1.111, Revision 1, July 1977, the land use census shall also identify the locations of all milk animals and all gardens of greater than 500 square feet producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of three miles).

With a land use census identifying a location(s) which yields a calculated dose or dose commitment greater than the maximum value currently being calculated in section D.2 of this manual, in lieu of a LER, identify the new locations in the next Annual Radiological Environmental Operating Report.

With a land use census identifying a location(s) that yields a calculated dose or dose commitment (via the same exposure pathway) 20 percent greater than at a location from which samples are currently being obtained in accordance with section E.1, add the new location(s) to the radiological environmental monitoring programs within 30 days if the owner consents. The sampling location(s), excluding the control station location, having the lowest calculated dose or dose commitment(s) (via the same exposure pathway) may be deleted from this monitoring program after October 31 of the year in which this land use census was conducted. In lieu of a LER, identify the new location(s) in the next Annual Radiological Environmental Operating Report and provide a revised figure(s) and table for the ODCM reflecting the new location(s).

*Broad leaf vegetation sampling may be performed at the site boundary in the direction section with the highest D/Q in lieu of the garden census.

The land use census shall be conducted at least once per calendar year between the dates of April 1 and October 1 using the following techniques:

- a. Within a 2 mile radius from the plant or within the 15 mrem per year isodose line, whichever is larger, enumeration by a door-to-door or equivalent counting technique.
- b. Within a 5 mile radius from the plan, enumeration by using appropriate techniques such as door-to-door survey, mail survey, telephone survey, aerial survey, or information from local agricultural authorities or other reliable sources.

This specification is provided to ensure that changes in the use of unrestricted areas are identified and that modifications to the monitoring program are made if required by the results of this census. The best survey information from the door-to-door, mail, telephone, aerial or consulting with local agricultural authorities shall be used. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR Part 50. Restricting the census to gardens of greater than 500 square feet provides assurance that significant exposure pathways via leafy vegetables will be identified and monitored since a garden of this size is the minimum required to produce the quantity (26 kg/year) of leafy vegetation assumed in Regulatory Guide 1.109 for consumption by a child. To determine this minimum garden size, the following assumptions were used: 1) that 20% of the garden was used for growing broad leaf vegetation (i.e., similar to lettuce and cabbage), and 2) a vegetation yield of 2 kg/square meter.

E.3 INTERLABORATORY COMPARISON PROGRAM

The requirement for participation in an Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive materials in environmental sample matrices are performed as part of the quality assurance program for environmental monitoring in order to demonstrate that the results are reasonably valid.

Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program which has been approved by the Commission.

A summary of the results obtained as part of the above required Interlaboratory Comparison Program and in accordance with the ODCM (or participants in the EPA cross check program shall provide the EPA program code designation for the unit) shall be included in the Annual Radiological Environmental Operating Report.

With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Operating Report.

TABLE E-1

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
1. AIRBORNE Radioiodine and Particulates	Minimum of 5 locations	Continuous operation of sampler with sample collection as required by dust loading but at least once per 7 days.	Radioiodine canister. Analyze at least once per 7 days for I-131. Particulate sampler. Analyze for gross beta radioactivity \geq 24 hours following filter change. Perform gamma isotopic analysis on each sample when gross beta activity is greater than 10 times the average of control samples. Perform gamma isotopic analysis on composite (by location) sample at least once per 92 days.
2. DIRECT RADIATION	At least 40 locations with \geq 2 dosimeters at each location.	At least once per 92 days.	Gamma dose. At least once per 92 days.

^aSample locations are given in the ODCM.

TABLE E-1 (Continued)

RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
3. WATERBORNE			
a. Surface	2 locations	Composite ^b sample collected over a period of ≤ 31 days.	Gamma isotopic analysis of each composite sample. Tritium analysis of composite sample at least once per 92 days.
b. Drinking	Minimum of 1 downstream location, or all water supplies within 10 miles downstream which are taken from the Tennessee River.	Composite ^b sample collected ^c over a period ≤ 31 days.	Gross beta and gamma isotopic analysis of each composite sample. Tritium analysis of composite sample at least once per 92 days.
c. Sediment	Minimum of 1 location	At least once per 184 days.	Gamma isotopic analysis of each sample.
d. Ground ^d			

^aSample locations are shown in the ODCM.

^bComposite samples shall be collected by collecting an aliquot at intervals not exceeding 2 hours.

^cComposite samples shall be collected over a period of ≤ 14 days for ¹³¹I if drinking water is obtained within 3 miles downstream of the plant.

^dGround water movement in the area has been determined to be from the plant site toward the Tennessee River. Since no drinking water wells exist between the plant and the river, ground water will not be monitored.



TABLE E-1 (Continued)
RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
4. INGESTION			
a. Milk	3 locations	At least once per 15 days when animals are on pasture; at least once per 31 days at other times.	I-131 analysis of each sample. Gamma isotopic analysis at least once per 31 days.
b. Fish	2 samples	One sample in season, or at least once per 184 days if not seasonal. One sample of commercial and game species.	Gamma isotopic analysis on edible portions.
c. Food Products ^e	2 locations	At least once per year at time of harvest.	Gamma isotopic analysis on edible portion.

^aSample locations are shown in the ODCM.

^eSince water from the Tennessee River in the immediate area downstream is not used for irrigation purposes, the sampling of food products (primarily broad leaf vegetation) is not required unless milk sampling is not performed.

TABLE E-2

MAXIMUM VALUES FOR THE LOWER LIMITS OF DETECTION (LLD)^{a,c}

Analysis	Water (pCi/l)	Airborne Particulate or Gas (pCi/m ³)	Fish (pCi/kg, wet)	Milk (pCi/l)	Food Products (pCi/kg, wet)	Sediment (pCi/kg, dry)
gross beta	4	1x10 ⁻²	N.A.	N.A.	N.A.	N.A.
H-3	2000	N.A.	N.A.	N.A.	N.A.	N.A.
Mn-54	15	N.A.	130	N.A.	N.A.	N.A.
Fe-59	30	N.A.	260	N.A.	N.A.	N.A.
Co-58, 60	15	N.A.	130	N.A.	N.A.	N.A.
Zn-65	30	N.A.	260	N.A.	N.A.	N.A.
Zr-95	30	N.A.	N.A.	N.A.	N.A.	N.A.
Nb-95	15	N.A.	N.A.	N.A.	N.A.	N.A.
I-131	1 ^b	7 x 10 ⁻²	N.A.	1	60	N.A.
Cs-134	15	5 x 10 ⁻²	130	15	60	150
Cs-137	18	6 x 10 ⁻²	150	18	80	180
Ba-140	60	N.A.	N.A.	60	N.A.	N.A.
La-140	15	N.A.	N.A.	15	N.A.	N.A.

TABLE E-2 (Continued)

TABLE NOTATION

- a. The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95% probability with 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66 s_b}{E * V * 2.22 * Y * \exp(-\lambda \Delta t)}$$

Where:

LLD is the "a priori" lower limit of detection as defined above (as picocurie per unit mass or volume),

s_b is the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (as counts per minute),

E is the counting efficiency (as counts per disintegration),

V is the sample size (in units of mass or volume),

2.22 is the number of disintegrations per minute per picocurie,

Y is the fractional radiochemical yield (when applicable),

λ is the radioactive decay constant for the particular radionuclide, and

Δt is the elapsed time between sample collection (or end of the sample collection period) and time of counting (for environmental samples, not plant effluent samples).

It should be recognized that the LLD is defined as a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

TABLE E-2 (Continued)

TABLE NOTATION

- b. The LLD for analysis of drinking water and surface water samples shall be performed by gamma spectroscopy at approximately 15 pCi/L. If levels greater than 15 pCi/L are identified in surface water samples downstream from the plant, or in the event of an unanticipated release of I-131, drinking water samples will be analyzed at an LLD of 1.0 pCi/L for I-131.
- c. Other peaks which are measurable and identifiable, together with the radionuclides in Table E-3, shall be identified and reported.

TABLE E-3

REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES

Reporting Levels

<u>Analysis</u>	<u>Water (pCi/l)</u>	<u>Airborne Particulate or Gases (pCi/m³)</u>	<u>Fish (pCi/Kg, wet)</u>	<u>Milk (pCi/l)</u>	<u>Food Products (pCi/Kg, wet)</u>
H-3	2 x 10 ⁴ (a)	N.A.	N.A.	N.A.	N.A.
Mn-54	1 x 10 ³	N.A.	3 x 10 ⁴	N.A.	N.A.
Fe-59	4 x 10 ²	N.A.	1 x 10 ⁴	N.A.	N.A.
Co-58	1 x 10 ³	N.A.	3 x 10 ⁴	N.A.	N.A.
Co-60	3 x 10 ²	N.A.	1 x 10 ⁴	N.A.	N.A.
Zn-65	3 x 10 ²	N.A.	2 x 10 ²	N.A.	N.A.
Zr-Nb-95	4 x 10 ²	N.A.	N.A.	N.A.	N.A.
I-131	2	0.9	N.A.	3	1 x 10 ²
Cs-134	30	10	1 x 10 ³	60	1 x 10 ³
Cs-137	50	20	2 x 10 ³	70	2 x 10 ³
Ba-La-140	2 x 10 ²	N.A.	N.A.	3 x 10 ²	N.A.

(a) For drinking water samples. This is 40 CFR Part 141 value.



F. REPORT CONTENT

F.1 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

Routine Annual Radiological Environmental Operating Reports covering operation of the plant during the previous calendar year shall be submitted prior to May 1 of each year.

The Annual Radiological Environmental Operating Reports shall include summaries, interpretations, and an analysis of trends of the results of the radiological environmental surveillance activities for the report period, including a comparison with preoperational studies, operational controls (as appropriate), and previous environmental surveillance reports and an assessment of the observed impacts of the plant operation on the environment. The reports shall also include the results of land use censuses required by section E.2 of this manual. If harmful effects or evidence of irreversible damage are detected by the monitoring, the report shall provide an analysis of the problems and a planned course of action to alleviate the problem.

The annual radiological environmental operating reports shall include summarized and tabulated results in the format of Regulatory Guide 4.8, December 1975 of all radiological environmental samples taken during the report period. In the event that some results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted as soon as possible in a supplementary report.

The reports shall also include the following: a summary description of the radiological environmental monitoring program; a map of all sampling locations keyed to a table giving distances and directions from one reactor; and the results of licensee participation in the Interlaboratory Comparison Program, required by section E.3 of this manual.



F.2 SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

A report on the radioactive discharges released from the site during the previous 6 months of operation shall be submitted to the Director of the Regional Office of Inspection and Enforcement within 60 days after January 1 and July 1 of each year. The report shall include summary of the quantities of radioactive liquid and gaseous effluents released and solid waste shipped from the plant as delineated in Regulatory Guide 1.21, Revision 1, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," with data summarized on a quarterly basis following the format of Appendix B thereof.

The report shall include a summary of the meteorological conditions concurrent with the release of gaseous effluents during each quarter as outlined in Regulatory Guide 1.21, Revision 1, with data summarized on a quarterly basis following the format of Appendix B thereof. Calculated offsite dose to members of the public resulting from the release of liquid and gaseous effluents and their subsequent dispersion in the river and atmosphere shall be reported as recommended in Regulatory Guide 1.21, Revision 1. The Radioactive Effluent Release Report shall include the following information for each type of solid waste shipped offsite during the report period (a) container volume, (b) total curie quantity, (specify whether determined by measurement or estimate), (c) principal radionuclides (specify whether determined by measurement or estimate), (d) sources of waste and processing employed (e.g. dewatered spent resins, compacted dry waste, etc.), (e) type of container (e.g., LSA, Type A, Type B, large quantity), and (f) solidification agent or absorbant (e.g. concrete, urea formaldehyde, etc.).

F.3 SPECIAL REPORTS (Radiological Environmental Monitoring)

If measured levels of radioactivity in an environmental sampling medium are determined to exceed the reporting level values of Table E-3 when averaged over any calendar quarter sampling period, a report shall be submitted to the Commission pursuant to Section E.1 of this Manual.

RETS MANUAL

Section III

OFFSITE DOSE CALCULATION
MANUAL (ODCM)

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 1 of 10)

Section	page
INTRODUCTION	46
1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS	48
1/2.0 APPLICABILITY	48
1/2.1 INSTRUMENTATION	50
1/2.1.1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION	50
1/2.1.2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION	55
1/2.2 RADIOACTIVE EFFLUENTS	60
1/2.2.1 LIQUID EFFLUENTS	60
1/2.2.1.1 CONCENTRATION	60
1/2.2.1.2 DOSE	64
1/2.2.1.3 LIQUID RADWASTE TREATMENT SYSTEM	65
1/2.2.2 GASEOUS EFFLUENTS	66
1/2.2.2.1 DOSE RATE	66
1/2.2.2.2 DOSE - NOBLE GASES	69
1/2.2.2.3 DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM WITH HALF-LIVES GREATER THAN EIGHT DAYS .	70
1/2.2.2.4 GASEOUS RADWASTE TREATMENT	71
1/2.2.3 TOTAL DOSE	72
1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING	73
1/2.3.1 MONITORING PROGRAM	73
1/2.3.2 LAND USE CENSUS	81
1/2.3.3 INTERLABORATORY COMPARISON PROGRAM	83

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 2 of 10)

Section	page
BASES	84
1/2.1.1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION	85
1/2.1.2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION	85
1/2.2 RADIOACTIVE EFFLUENTS	85
1/2.2.1.1 CONCENTRATION	85
1/2.2.1.2 DOSE	86
1/2.2.1.3 LIQUID WASTE TREATMENT	86
1/2.2.2.1 DOSE RATE	87
1/2.2.2.2 DOSE - NOBLE GASES	88
1/2.2.2.3 DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM	89
1/2.2.2.4 GASEOUS RADWASTE TREATMENT	90
1/2.2.3 TOTAL DOSE	90
1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING	90
1/2.3.1 MONITORING PROGRAM	90
1/2.3.2 LAND USE CENSUS	91
1/2.3.3 INTERLABORATORY COMPARISON PROGRAM	91
3.0 DEFINITIONS	92
3.0.A. CHANNEL CALIBRATION	93
3.0.B. CHANNEL FUNCTIONAL TEST	93
3.0.C. GASEOUS WASTE TREATMENT SYSTEM	93
3.0.D. DOSE EQUIVALENT I-131	93
3.0.E. MEMBER(S) OF THE PUBLIC	93
3.0.F. OPERABLE - OPERABILITY	94
3.0.G. PURGE - PURGING	94

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 3 of 10)

Section	page
3.0.H. RATED POWER	94
3.0.I. SITE BOUNDARY	94
3.0.J. SOURCE CHECK	94
3.0.K. UNRESTRICTED AREA	95
3.0.L. VENTING	95
4.0 (NOT USED)	98
5.0 ADMINISTRATIVE CONTROLS	99
5.1 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT	100
5.2 SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT	100
5.3 OFFSITE DOSE CALCULATION MANUAL CHANGES	101
5.4 SPECIAL REPORTS	101
6.0 LIQUID EFFLUENTS	102
RELEASE POINTS	103
6.1 LIQUID RELEASES	104
6.1.1 Pre-release Analysis/MPC - Sum of the Ratios	104
6.1.2 Release Flow Rate Calculations	104
6.1.3 Post-release Analysis	105
6.2 INSTRUMENT SETPOINTS	106
6.2.1 Radwaste Discharge Monitor	106
6.2.2 Raw Cooling Water and Residual Heat Removal Service Water Monitors	107
6.3 CUMULATIVE LIQUID EFFLUENT DOSE CALCULATION	108
6.3.1 Monthly Analysis	108
6.3.1.1 Water Ingestion	109

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 4 of 10)

Section	page
6.3.1.2 Fish Ingestion	110
6.3.1.3 Recreation	111
6.3.1.4 Monthly Summary	112
6.4 LIQUID RADWASTE TREATMENT SYSTEM	113
6.5 DOSE PROJECTIONS	114
6.6 DOSE CALCULATIONS FOR REPORTING PURPOSES	115
6.6.1 Water Ingestion	115
6.6.2 Fish Ingestion	116
6.6.3 Shoreline Recreation	116
6.6.4 Total Maximum Individual Dose	117
6.6.5 Population Doses	118
6.7 LIQUID DOSE FACTOR EQUATIONS	120
6.7.1 Water Ingestion Dose Factors	120
6.7.2 Fish Ingestion Dose Factors	120
6.7.3 Shoreline Recreation Dose Factors	120
7.0 GASEOUS EFFLUENTS	140
RELEASE POINTS DESCRIPTION	141
7.1 RELEASE RATE LIMIT METHODOLOGY	142
7.2 GASEOUS EFFLUENT MONITOR INSTRUMENT SETPOINTS	147
7.2.1 Alarm/Trip Setpoints	147
7.2.2 Allowable Values	147
7.3 GASEOUS EFFLUENTS - DOSE RATES	149
7.3.1 Noble Gas Dose Rates	149



Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 5 of 10)

Section	page
7.3.2 I-131, I-133, Tritium and all Radionuclides in Particulate Form with Half-lives of Greater than 8 days - Organ Dose Rate	150
7.4 DOSE - NOBLE GASES	151
7.4.1 Monthly Noble Gas Dose	151
7.4.1.1 Monthly Conservative Model - Gamma Air Dose	151
7.4.1.2 Monthly Conservative Model - Beta Air Dose	152
7.4.1.3 Cumulative Dose - Noble Gas	152
7.4.1.4 Comparison to Limits	152
7.5 CUMULATIVE DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM WITH HALF LIVES GREATER THAN 8 DAYS	153
7.5.1 Monthly Conservative Model - Infant Thyroid Dose from Milk Ingestion	154
7.5.2 Monthly Conservative Model - Child Bone Dose from Vegetable Ingestion	155
7.5.3 Monthly Conservative Model - Teen Gastrointestinal Tract (GIT) Dose from Vegetable Ingestion	156
7.5.4 Cumulative Doses	157
7.5.5 Total Monthly Dose - Comparison to Limits	157
7.6 GASEOUS RADWASTE TREATMENT	158
7.6.1 Dose Projections	158
7.6.2 System Description	158
7.7 DOSE CALCULATIONS FOR REPORTING PURPOSES	159
7.7.1 Noble Gas Dose	159
7.7.1.1 Gamma Dose to Air	160
7.7.1.2 Beta Dose to Air	160

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 6 of 10)

Section	page
7.7.2 Radioiodine, Particulate and Tritium - Maximum Organ Dose	161
7.7.3 Population Doses	163
7.7.4 Reporting of Doses	164
7.8 GASEOUS DOSE FACTOR EQUATIONS	165
7.8.1 Pasture Grass-Cow-Goat-Milk Ingestion Dose Factors	165
7.8.2 Stored Feed-Cow/Goat-Milk Ingestion Dose Factors	166
7.8.3 Pasture Grass-Beef Ingestion Dose Factors	167
7.8.4 Stored Feed-Beef Ingestion Dose Factors	168
7.8.5 Fresh Leafy Vegetable Ingestion Dose Factors	169
7.8.6 Stored Vegetable Ingestion Dose Factors	170
7.8.7 Tritium-Pasture Grass-Cow/Goat-Milk Dose Factor	171
7.8.8 Tritium-Stored Feed-Cow/Goat-Milk Dose Factor	172
7.8.9 Tritium-Pasture Grass-Beef Dose Factor	173
7.8.10 Tritium-Stored Feed-Beef Dose Factor	174
7.8.11 Tritium-Fresh Leafy Vegetable Dose Factor	175
7.8.12 Tritium-Stored Vegetables Dose Factor	176
7.8.13 Inhalation Dose Factors	177
7.8.14 Ground Plane Dose Factors	177
7.9 DISPERSION METHODOLOGY	178
7.9.1 Annual Average Air Concentration	179
7.9.2 Relative Concentration	180
7.9.3 Relative Dispersion	180
7.9.4 Effective Release Height	181



Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 7 of 10)

Section	page
8.0 TOTAL DOSE	228
9.0 ENVIRONMENTAL MONITORING PROGRAM	230
9.1 MONITORING PROGRAM DESCRIPTION	231
9.2 DETECTION CAPABILITIES	231
9.3 LAND USE CENSUS	231
9.4 INTERLABORATORY COMPARISON PROGRAM	231

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 8 of 10)

LIST OF TABLES

	page
Table 1.1-1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION ..	51
Table 2.1-1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS	53
Table 1.1-2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION .	56
Table 2.1-2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION SURVEILLANCE REQUIREMENTS	58
Table 2.2-1 RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM ..	61
Table 2.2-2 RADIOACTIVE GASEOUS WASTE MONITORING SAMPLING AND ANALYSIS PROGRAM	67
Table 2.3-1 MINIMUM REQUIRED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM	75
Table 2.3-2 MAXIMUM VALUES FOR THE LOWER LIMIT OF DETECTION (LLD) FOR ENVIRONMENTAL SAMPLES	78
Table 2.3-3 REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES	80
Table 3.1 FREQUENCY NOTATION	96
Table 6.1 RECEPTORS FOR LIQUID DOSE CALCULATIONS	121
Table 6.2 RADIONUCLIDE DECAY AND STABLE ELEMENT TRANSFER DATA	122
Table 6.3 DOSE CALCULATION FACTORS	125
Table 6.4 INGESTION DOSE FACTORS	127
Table 6.5 BIOACCUMULATION FACTORS FOR FRESHWATER FISH	135
Table 6.6 EXTERNAL DOSE FACTORS FOR STANDING ON CONTAMINATED GROUND..	136
Table 7.1 BFN - OFFSITE RECEPTOR LOCATION DATA	182
Table 7.2 EXPECTED ANNUAL ROUTINE ATMOSPHERIC RELEASES FROM ONE UNIT AT BFN	183
Table 7.3 JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION	184
Table 7.4 DOSE FACTORS FOR SUBMERSION IN NOBLE GASES	206



Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 9 of 10)

LIST OF TABLES

	page
Table 7.5 SECTOR ELEMENTS CONSIDERED FOR POPULATION DOSES	207
Table 7.6 BFN 50-MILE POPULATION WITHIN EACH SECTOR ELEMENT	208
Table 7.7 INHALATION DOSE FACTORS	209
Table 9.1 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM	232
Table 9.2 ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS	237
Table 9.3 THERMOLUMINESCENT DOSIMETRY LOCATIONS	238

Browns Ferry Nuclear Plant
Offsite Dose Calculation Manual
TABLE OF CONTENTS
(Page 10 of 10)

LIST OF FIGURES

	page
Figure 3.1 LAND SITE BOUNDARY	97
Figure 6.1 LIQUID RELEASE POINTS	138
Figure 6.2 LIQUID RADWASTE SYSTEM	139
Figure 7.1 OFFGAS SYSTEM AND SGTS EFFLUENT MONITORING	217
Figure 7.2 NORMAL BUILDING VENTILATION	218
Figure 7.3 PLUME DEPLETION EFFECT	219
Figure 7.4 VERTICAL STANDARD DEVIATION OF MATERIAL IN A PLUME	223
Figure 7.5 RELATIVE DEPOSITION	224
Figure 9.1 ENVIRONMENTAL RADIOLOGICAL SAMPLING LOCATIONS WITHIN 1 MILE OF THE PLANT	239
Figure 9.2 ENVIRONMENTAL RADIOLOGICAL SAMPLING LOCATIONS FROM 1 TO 5 MILES FROM THE PLANT	240
Figure 9.3 ENVIRONMENTAL RADIOLOGICAL SAMPLING LOCATIONS GREATER THAN 5 MILES FROM THE PLANT	241

SECTION 1.0 AND 2.0

CONTROLS AND SURVEILLANCE REQUIREMENTS



INTRODUCTION

The Browns Ferry Nuclear Plant (BFN) Offsite Dose Calculation Manual (ODCM) is a supporting document of the BFN Technical Specifications. The ODCM is divided into two major parts. The first part of the ODCM contains: 1) Radioactive Effluent Controls specified by the BFN Technical Specifications; 2) Radiological Environmental Monitoring Controls required by the BFN Technical Specifications; 3) descriptions of the information that should be included in the Annual Radiological Environmental Operating and Semiannual Radioactive Effluent Release Reports required by BFN Technical Specifications; and, 4) Administrative Controls for the ODCM requirements. The second part of the ODCM contains the methodologies used to: 1) calculate offsite doses resulting from radioactive gaseous and liquid effluents; 2) calculate gaseous and liquid effluent monitor Alarm/Trip setpoints; and, 3) conduct the Environmental Radiological Monitoring Program.

The BFN ODCM is maintained for use as a reference guide on accepted methodologies and calculations. Changes in the calculation methods or parameters will be incorporated into the ODCM in order to assure that the ODCM represents the present methodology in all applicable areas. Any licensee initiated ODCM changes will be implemented in accordance with BFN Technical Specifications.

Radioactive waste release levels to UNRESTRICTED AREAS should be kept "as low as reasonably achievable" and are not to exceed the concentration limits specified in 10 CFR Part 20, Appendix B, Table II. At the same time, the requirements specified in this manual permit the flexibility of operation, compatible with considerations of health and safety, to assure that the public is provided a dependable source of power under unusual operating conditions which may temporarily result in releases higher than design objectives but still within the concentration limits specified in 10 CFR Part 20. It is expected that by using this operational flexibility and exerting every effort to keep levels of radioactive releases "as low as reasonably achievable" in accordance with criteria established in 10 CFR Part 50, Appendix I, the annual releases will result in a small fraction of the annual average concentration limits specified in 10 CFR Part 20, Appendix B, Table II.

The surveillance/testing requirements given in this manual provide assurance that liquid and gaseous wastes are properly controlled and monitored during any release of radioactive materials in the liquid and gaseous effluents. These requirements provide the data for the licensee and the Commission to evaluate the station's performance relative to radioactive materials released to the environment. Reports on the quantities of radioactive materials released in effluents shall be furnished to the Commission on the basis of Section 5.0 of this manual. On the basis of such reports and any additional information the Commission may obtain from the licensee or others, the Commission may from time to time require the licensee to take such actions as the Commission deems appropriate.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.0 APPLICABILITY

CONTROLS

- 1.0.1 Compliance with the Controls contained in the succeeding sections is required during the conditions specified therein; except that upon failure to meet the Control, the associated ACTION requirements shall be met.
- 1.0.2 Noncompliance with a Control shall exist when the requirements of the Control and associated ACTION requirements are not met within the specified time intervals. If the Control is restored prior to the expiration of the specified intervals, completion of the ACTION requirements is not required.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.0 APPLICABILITY

SURVEILLANCE REQUIREMENTS

- 2.0.1 Surveillance Requirements shall be met during the conditions specified for individual Controls unless otherwise stated in the individual Surveillance Requirement.
- 2.0.2 Each Surveillance Requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the surveillance interval.
- 2.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance and OPERABILITY requirements for a Control and associated action statements unless otherwise required by these Controls. Surveillance Requirements do not have to be performed on inoperable equipment.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.1 INSTRUMENTATION

1/2.1.1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

CONTROLS

1.1.1 The radioactive liquid effluent monitoring instrumentation listed in Table 1.1-1 shall be OPERABLE with the applicability as shown in Tables 1.1-1 and 2.1-1. Alarm/trip setpoints will be set in accordance with guidance given in ODCM Section 6.2 to ensure that the limits of Control 1.2.1.1 are not exceeded.

APPLICABILITY: This requirement is applicable as shown in Table 1.1-1.

ACTION:

- a. With a radioactive liquid effluent monitoring channel alarm/trip setpoint less conservative than required by these requirements, suspend the release without delay, declare the channel inoperable, or adjust the alarm/trip setpoint to establish the conservatism required by these requirements.
- b. The action required when the number of OPERABLE channels is less than the minimum channels OPERABLE requirement is specified in the notes for Table 1.1-1. Exert best efforts to return the instrument(s) to OPERABLE status within 30 days and, if unsuccessful, explain in the next Semiannual Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner.

SURVEILLANCE REQUIREMENTS

2.1.1 Each of the radioactive liquid effluent monitoring instruments shall be demonstrated OPERABLE by performance of tests in accordance with Table 2.1-1.



Table 1.1-1 (Page 1 of 2)
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
Minimum Channels

<u>Instrument*</u>	<u>OPERABLE</u>	<u>Applicability</u>	<u>Action</u>
1. Liquid Radwaste Effluent Monitor (RM-90-130)	1	**	A/B
2. RHR Service Water Monitor (RM-90-133, -134)	1	***	C
3. Raw Cooling Water Monitor (RM-90-132)	1	**	D
4. Liquid Radwaste Effluent Flow Rate (77-60 loop)	1	**	E

* Alarm/trip setpoints will be calculated in accordance with the guidance given in Section 6.2.

** During Releases via this pathway.

*** During operation of an RHR loop and associated RHR service water system.

Table 1.1-1 (Page 2 of 2)
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
TABLE NOTATION

ACTION A

During release of radioactive wastes from the radwaste processing system, the following shall be met:

- (1) liquid waste activity and flowrate shall be continuously monitored and recorded during release and shall be set to alarm and automatically close the waste discharge valve before exceeding the limits specified in Control 1.2.1.1.
- (2) if this cannot be met, two independent samples of the tank being discharged shall be analyzed in accordance with the sampling and analysis program specified in Table 2.2.1 and two qualified station personnel shall independently verify the release rate calculations and check valving before the discharge. Otherwise, suspend releases via this pathway.

ACTION B

With a radioactive liquid effluent monitoring channel alarm/trip setpoint less conservative than required by these requirements, suspend release via this pathway without delay, declare the channel inoperable, or adjust the alarm/trip setpoint to establish the conservatism required by these requirements.

ACTION C

During operation of an RHR loop and associated RHR service water system, the effluent from that unit's service water shall be continuously monitored. If an installed monitoring system is not available, a temporary monitor or grab samples taken every 4 hours and an analysis with at least an LLD¹ of 1E-7 $\mu\text{Ci/ml}$ (gross) or < applicable MPC ratio (γ isotopic) shall be used to monitor the effluent.

ACTION D

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided that a temporary monitor is installed or, at least once per 8 hours, grab samples are collected and analyzed for radioactivity with an LLD¹ of 1E-7 $\mu\text{Ci/ml}$ (gross) or < applicable MPC ratio (γ isotopic).

ACTION E

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continued provided the flow rate is estimated at least once per 4 hours during actual releases. Pump curves may be used to estimate flow.

¹ See Table 2.2-1, Table Notation for the definition of LLD.

Table 2.1-1 (Page 1 of 2)
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>INSTRUMENT CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>FUNCTIONAL TEST</u>
a. Liquid Radwaste Effluent Monitor (RM-90-130)	D ⁴	M	R ⁵	Q ¹
b. RHR Service Water Monitor (RM-90-133,-134)	D ⁴	M	R ⁵	Q ²
c. Raw Cooling Water Monitor (RM-90-132)	D ⁴	M	R ⁵	Q ²
d. Liquid Radwaste Effluent Flow Rate (77-60 loop)	D ⁴	N/A	R	Q ³

Table 2.1-1 (Page 2 of 2)
RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS
TABLE NOTATION

NOTE: Each requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the interval given.

- 1 The CHANNEL FUNCTIONAL TEST shall demonstrate that automatic isolation of this pathway and control room alarm annunciation occurs if any of the following conditions exists:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates an inoperative/downscale failure.
 - c. Instrument controls not set in operate mode.
- 2 The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:
 - a. Instrument indicates measured levels above the alarm/trip setpoint.
 - b. Instrument indicates an inoperative/downscale failure.
 - c. Instrument controls not set in operate mode.
- 3 This functional test shall consist of measuring rate of tank decrease over a period of time and comparing this value with flow rate instrument reading.
- 4 INSTRUMENT CHECK shall consist of verifying indication during periods of release. INSTRUMENT CHECK shall be made at least once per 24 hours on days which continuous, periodic, or batch releases are made.
- 5 The CHANNEL CALIBRATION shall include the use of a known (traceable to the National Institute of Standards and Technology (NIST)) radioactive source(s) positioned in a reproducible geometry with respect to the sensor or using standards that have been obtained from suppliers that participate in measurement assurance activities with the NIST.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.1 INSTRUMENTATION

1/2.1.2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

CONTROLS

1.1.2 The radioactive gaseous effluent monitoring instruments listed in Table 1.1-2 shall be OPERABLE with the applicability as shown in Table 1.1-2. Alarm/trip setpoints will be set in accordance with guidance given in ODCM Section 7.2 to ensure that the limits of ODCM Control 1.2.2.1 are not exceeded.

APPLICABILITY: As shown in Table 1.1-2.

ACTION:

- a. With a radioactive gaseous effluent monitoring channel alarm/trip setpoint less conservative than required by these requirements, suspend the release without delay, declare the channel inoperable or adjust the alarm/trip setpoint to establish the conservatism required by these requirements.
- b. Both off-gas treatment monitors may be taken out of service for less than one hour for purging of monitors during SI performance.
- c. The action required when the number of operable channels is less than the minimum channels operable requirement is specified in the notes for Table 1.1-2. Exert best efforts to return the instrument(s) to operable status within 30 days and, if unsuccessful, explain in the next Semiannual Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner.

SURVEILLANCE REQUIREMENTS

2.1.2 Each of the radioactive gaseous effluent monitoring instruments shall be demonstrated OPERABLE by performance of tests in accordance with Table 2.1-2.

Table 1.1-2 (Page 1 of 2)
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

<u>Instrument</u>	<u>Minimum Channels/ Devices OPERABLE</u>	<u>Applicability</u>	<u>Action</u>
1. Stack (RM-90-147B & 148B)			
a. Noble Gas Monitor	1	*	A/C
b. Iodine Cartridge	1	*	B/C
c. Particulate Filter	1	*	B/C
d. Sampler Flow Abnormal	1	*	D
e. Stack Flow (FT, FM, FI-90-271)	1	*	D
2. Reactor/Turbine Building Ventilation (RM-90-250)			
a. Noble Gas Monitor	1	*	A/C
b. Iodine Sampler	1	*	B/C
c. Particulate Sampler	1	*	B/C
d. Sampler Flowmeter	1	*	D
3. Turbine Building Exhaust (RM-90-249, 251)			
a. Noble Gas Monitor	1	**	A/C
b. Iodine Sampler	1	**	B/C
c. Particulate Sampler	1	**	B/C
e. Sampler Flowmeter	1	**	D
4. Radwaste Building Vent (RM-90-252)			
a. Noble Gas Monitor	1	*	A/C
b. Iodine Sampler	1	*	B/C
c. Particulate Sampler	1	*	B/C
e. Sampler Flowmeter	1	*	D
5. Offgas Post Treatment			
a. Noble Gas Activity Monitor (RM-90-265, -266)	1	*	F
b. Sample Flow Abnormal (PA-90-262)	1	*	D

Table 1.1-2 (Page 2 of 2)
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
TABLE NOTATION

* At all times.

** During releases via this pathway

ACTION A

With the number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via the affected pathway may continue provided a temporary monitoring system is installed or grab samples are taken and analyzed at least once every 8 hours.

ACTION B

With a number of channels OPERABLE less than required by the Minimum Channels OPERABLE requirement, effluent releases via this pathway may continue provided samples are continuously collected with auxiliary sampling equipment for periods on the order of seven (7) days and analyzed in accordance with the sampling and analysis program specified in Table 2.2-2 within 48 hours after the end of the sampling period.

ACTION C

A monitoring system may be out of service for 4 hours for functional testing, calibration, or repair without providing or initiating grab sampling.

ACTION D

With the number of channels OPERABLE less than required by the Minimum Channels Operable requirement, effluent releases via this pathway may continue provided the flow rate is estimated at least once per 4 hours.

ACTION F

With the number of channels OPERABLE less than required by the Minimum Channels Operable requirement, effluent releases via this pathway may continue provided grab samples are taken at least once per 8 hours and these samples are analyzed for gross activity within 24 hours. Purging during SI performance is not considered a loss of monitoring capability.

Table 2.1-2 (Page 1 of 2)
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

<u>Instrument</u>	<u>INSTRUMENT CHECK</u>	<u>SOURCE CHECK</u>	<u>CHANNEL CALIBRATION</u>	<u>FUNCTIONAL TEST</u>
1. STACK				
a. Noble Gas Monitor ⁴	D	M	R ¹	Q ²
b. Iodine Cartridge	W	N/A	N/A	N/A
c. Particulate Filter	W	N/A	N/A	N/A
d. Sampler Flow Abnormal	D	N/A	R	Q
e. Stack Flowmeter	D	N/A	R	Q
2. REACTOR/TURBINE BUILDING VENT				
a. Noble Gas Monitor ⁵	D	M	R ¹	Q ²
b. Iodine Sampler	W	N/A	N/A	N/A
c. Particulate Sampler	W	N/A	N/A	N/A
b. Sampler Flowmeter	D	N/A	R	Q
3. TURBINE BUILDING EXHAUST				
a. Noble Gas Monitor ⁵	D	M	R ¹	Q ²
b. Iodine Sampler	W	N/A	N/A	N/A
c. Particulate Sampler	W	N/A	N/A	N/A
b. Sampler Flowmeter	D	N/A	R	Q
4. RADWASTE BUILDING VENT				
a. Noble Gas Monitor ⁵	D	M	R ¹	Q ²
b. Iodine Sampler	W	N/A	N/A	N/A
c. Particulate Sampler	W	N/A	N/A	N/A
b. Sampler Flowmeter	D	N/A	R	Q
5. OFF GAS POST TREATMENT⁴				
a. Noble Gas Activity Monitor	D	M	R ¹	Q ³
b. Sample Flow Abnormal	D	N/A	R	Q ²

Table 2.1-2 (Page 2 of 2)
RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION
SURVEILLANCE REQUIREMENTS

NOTE: Each requirement shall be performed within the specified time interval with a maximum allowable extension not to exceed 25% of the interval given.

- ¹ The CHANNEL CALIBRATION shall include the use of a known (traceable to the National Institute of Standards and Technology (NIST)) radioactive source(s) positioned in a reproducible geometry with respect to the sensor or using standards that have been obtained from suppliers that participate in measurement assurance activities with the NIST.
- ² The CHANNEL FUNCTIONAL TEST shall also demonstrate that control room alarm annunciation occurs if any of the following conditions exists:

 1. Instrument indicates measured levels above the alarm/trip setpoint.
 2. Instrument indicates an inoperative/downscale failure.
 3. Instrument controls not set in operate mode (stack only).
- ³ The CHANNEL FUNCTIONAL TEST shall demonstrate that automatic isolation of this pathway and control room alarm annunciation occurs if any of the following conditions exists:

 1. Instrument indicates measured levels above the alarm/trip setpoint.
 2. Instrument indicates an inoperative/downscale failure.
 3. Instrument controls not set in operate mode (stack only).

The two channels are arranged in a coincidence logic such that 2 upscale, or 1 downscale and 1 upscale or 2 downscale will isolate the offgas line.
- ⁴ The noble gas monitor shall have a LLD of $1E-5$ (Xe-133 Equivalent)
- ⁵ The noble gas monitor shall have a LLD of $1E-6$ (Xe-133 Equivalent)



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1 LIQUID EFFLUENTS

1/2.2.1.1 CONCENTRATION

CONTROLS

- 1.2.1.1 The concentration of radioactive material released at any time from the site to UNRESTRICTED AREAS (see Figure 3.1) shall be limited to the concentrations specified in 10 CFR Part 20, Appendix B, Table II, Column 2 for radionuclides other than dissolved or entrained noble gases. For dissolved or entrained noble gases, the concentration shall be limited to $2E-4$ $\mu\text{Ci/ml}$ total activity.

APPLICABILITY: At all times.

ACTION:

If the above limits are exceeded, appropriate action shall be initiated without delay to bring the release within limits. Provide prompt notification to the NRC pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

- 2.2.1.1.1 Facility records shall be maintained of radioactive concentrations and volume before dilution of each batch of liquid effluent released, and of the average dilution flow and the length of time over which each discharge occurred.
- 2.2.1.1.2 Radioactive liquid waste sampling and activity analysis of each liquid waste batch to be discharged shall be performed prior to release in accordance with the sampling and analysis program specified in Table 2.2-1.
- 2.2.1.1.3 The operation of the automatic isolation valves and discharge tank selection valves shall be checked annually.
- 2.2.1.1.4 The results of the analysis of samples collected from release points shall be used with the calculational methodology in ODCM Section 6.1 to assure that the concentrations at the point of discharge are maintained within the above limits.

Table 2.2-1 (Page 1 of 3)
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM

Liquid Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	System Design Capability Lower Limit of Detection (LLD) ($\mu\text{Ci/ml}$)
Batch Waste Releases ¹	Each Batch	Each Batch Prior to Release	Principal Gamma Emitters ⁴	5×10^{-7} ³
	One Batch per Month	Monthly	Dissolved and Entrained Gases ⁵	1×10^{-5} ³
	Monthly Proportional Composite ²	Monthly	Tritium	1×10^{-5}
			Gross Alpha	1×10^{-7}
	Quarterly Proportional Composite ²	Quarterly	Sr-89, Sr-90	5×10^{-8}
			Fe-55	1×10^{-6}

Table 2.2-1 (Page 2 of 3)
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM
TABLE NOTATION

- 1 A batch release is the discharge of liquid waste of a discrete volume. The discharge shall be thoroughly mixed prior to sampling.
- 2 A proportional composite sample is one in which the quantity of liquid sampled is proportional to the quantity of liquid waste discharged from the plant and is representative of the liquid discharged.
- 3 The LLD is defined for the purpose of these requirements as the smallest concentration of radioactive material in a sample that will yield a net count above system background that will be detected with 95% probability with only a 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66s_b}{E \quad V \quad 2.22E+06 \quad Y \quad \exp(-\lambda\Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection as defined above (microcurie per unit mass or volume)
- s_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute),
- E = the counting efficiency (counts per disintegration)
- V = the sample size (units of mass or volume)
- 2.22E+06 = the number of disintegrations per minute per microcurie,
- Y = the fractional radiochemical yield, when applicable,
- λ = the radioactive decay constant for the particular radionuclide (s^{-1}), and
- Δt = the elapsed time between midpoint of sample collection and time of counting (s).

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not an a posteriori (after the fact) limit for a particular measurement.

- 4 The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Zn-65, Co-60, Cs-137, Mn-54, Co-58, Cs-134, Ce-141, Ce-144, Mo-99 and Fe-59 for

Table 2.2-1 (Page 3 of 3)
RADIOACTIVE LIQUID WASTE SAMPLING AND ANALYSIS PROGRAM
TABLE NOTATION

liquid releases. This list does not mean that only these nuclides are to be detected and reported. Other nuclides detected within a $\approx 95\%$ confidence level, together with the above nuclides, shall also be identified and reported as being present. Nuclides which are below the LLD for the analysis may not be reported as being present at the LLD level for that nuclide. I-131 shall have a LLD of $\leq 1E-6$.

⁵ Gamma Emitters Only.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1 LIQUID EFFLUENTS

1/2.2.1.2 DOSE

CONTROLS

1.2.1.2 The doses or dose commitment to a MEMBER OF THE PUBLIC from radioactive materials in liquid effluents released from each unit to UNRESTRICTED AREAS shall be limited:

- a. During any calendar quarter to < 1.5 mrem to the total body and to < 5 mrem to any organ, and
- b. During any calendar year to < 3 mrem to the total body and to < 10 mrem to any organ.

APPLICABILITY: At all times.

ACTION:

If the limits specified above are exceeded, prepare and submit a Special Report pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

2.2.1.2 Cumulative quarterly and yearly dose contributions from liquid effluents shall be determined as specified in ODCM Section 6.3 at least once every 31 days.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1 LIQUID EFFLUENTS

1/2.2.1.3 LIQUID RADWASTE TREATMENT SYSTEM

CONTROLS

1.2.1.3 The liquid radwaste system shall be used to reduce the radioactive materials in liquid discharge from the site when the projected monthly dose would exceed 0.06 mrem to the total body or 0.21 mrem to any other organ per unit.

APPLICABILITY: At all times.

ACTION:

With radioactive liquid waste being discharged for more than 31 days without treatment and when the projected dose is in excess of limits specified above, prepare and submit the Special Report pursuant to Section 6.9.1.4 of the Technical Specifications.

SURVEILLANCE REQUIREMENTS

2.2.1.3 Doses due to liquid releases to UNRESTRICTED AREAS shall be projected at least once per 31 days, in accordance with ODCM Section 6.5.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2 GASEOUS EFFLUENTS

1/2.2.2.1 DOSE RATE

CONTROLS

- 1.2.2.1 The dose rate at any time to areas at and beyond the SITE BOUNDARY (see Figure 3.1) due to radioactivity released in gaseous effluents from the site shall be limited to the following values:
- a. The dose rate limit for noble gases shall be <500 mrem/yr to the total body and <3000 mrem/yr to the skin, and
 - b. The dose rate limit for I-131, I-133, H-3 and particulates with greater than eight day half-lives shall be <1500 mrem/yr to any organ.

APPLICABILITY: At all times.

ACTION: If the limits above are exceeded, appropriate corrective action shall be immediately initiated to bring the release within limits. Provide prompt notification to the NRC pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

- 2.2.2.1.1 The gross B/γ and particulate activity of gaseous wastes released to the environment shall be monitored and recorded.
- a. For effluent streams having continuous monitoring capability, the activity shall be monitored and flow rate evaluated and recorded to enable release rates of gross radioactivity to be determined at least once per shift using instruments specified in Table 1.1-2.
 - b. For effluent streams without continuous monitoring capability, the activity shall be monitored and recorded and the release through these streams controlled to within the limits specified above.
- 2.2.2.1.2 Radioactive gaseous waste sampling and activity analysis shall be performed in accordance with the sampling and analysis program specified in Table 2.2-2. Dose rates shall be determined to be within the above limits using methods contained in ODCM Section 7.3.
- 2.2.2.1.3 Samples of offgas system effluents shall be analyzed at least weekly to determine the identity and quantity of the principal radionuclides being released.

Table 2.2-2 (Page 1 of 2)
RADIOACTIVE GASEOUS WASTE MONITORING SAMPLING AND ANALYSIS PROGRAM

Gaseous Release Type	Sampling Frequency	Minimum Analysis Frequency	Type of Activity Analysis	System Design Capability Lower Limit of Detection (LLD) ($\mu\text{Ci/ml}$)
A. Containment Purge	Prior to Each PURGE Grab Sample	Prior to Each PURGE	Principal Gamma Emitters ³	1×10^{-4} ¹
			H-3	1×10^{-6}
B.1. Stack	Grab Sample	Monthly ⁴	Principal Gamma Emitters ³	1×10^{-4} ¹
2. Building Ventilation	Grab Sample	Monthly ⁴	H-3	1×10^{-6}
a. Reactor/Turbine				
b. Turbine Exhaust				
c. Radwaste				
C. All Release Points Listed in B. Above	Continuous Sampler	Charcoal Sample Weekly ⁴	I-131	1×10^{-12} ²
	Continuous Sampler	Particulate Sample Weekly ⁴	Principal Gamma Emitters ³	1×10^{-11} ²
			I-131	1×10^{-12} ²
	Continuous Sampler	Composite Particulate Sample Monthly	Gross Alpha	1×10^{-11}
	Continuous Sampler	Composite Particulate Sample Quarterly	Sr-89, Sr-90	1×10^{-11}

Table 2.2-2 (Page 2 of 2)
 RADIOACTIVE GASEOUS WASTE MONITORING SAMPLING AND ANALYSIS PROGRAM
 TABLE NOTATION

- ¹ The LLD is defined, for the purpose of this requirement, as the smallest concentration of radioactive material in a sample that will yield a net count above system background that will be detected with 95% probability with only a 5% probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system (which may include radiochemical separation):

$$LLD = \frac{4.66s_b}{E \quad V \quad 2.22E+06 \quad Y \quad \exp(-\lambda \Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection (microcurie per unit mass or volume)
 s_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate (counts per minute),
 E = the counting efficiency (counts per disintegration)
 V = the sample size (units of mass or volume)
 2.22E+06 = the number of disintegrations per minute per microcurie,
 Y = the fractional radiochemical yield, when applicable,
 λ = the radioactive decay constant for the particular radionuclide (s^{-1}), and
 Δt = the elapsed time between midpoint of sample collection and time of counting (s).

Typical values of E, V, Y, and Δt should be used in the calculation

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not an a posteriori (after the fact) limit for a particular measurement.

- ² When samples are taken more often than that shown, the minimum detectable concentrations can be correspondingly higher.
- ³ The principal gamma emitters for which the LLD specification will apply are exclusively the following radionuclides: Kr-87, Kr-88, Xe-133, Xe-133m, Xe-135, and Xe-138 for gaseous emissions and Mn-54, Fe-59, Co-58, Co-60, Zn-65, Mo-99, Cs-134, Cs-137, Ce-141 and Ce-144 for particulate emissions. This list does not mean that only these nuclides are to be detected and reported. Other peaks which are measurable and identifiable, together with the above nuclides, shall also be identified and reported. Nuclides which are below the LLD for the analyses should not be reported as being present at the LLD level for that nuclide.
- ⁴ Analysis shall also be performed if the radiation monitor alarm exceeds the setpoint value.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2 GASEOUS EFFLUENTS

1/2.2.2.2 DOSE - NOBLE GASES

CONTROLS

1.2.2.2 The air dose to areas at and beyond the SITE BOUNDARY (see Figure 3.1) due to noble gases released in gaseous effluents per unit shall be limited to the following:

- a. During any calendar quarter, to ≤ 5 mrad for gamma radiation and ≤ 10 mrad for beta radiation;
- b. During any calendar year, to ≤ 10 mrad for gamma radiation and ≤ 20 mrad for beta radiation.

APPLICABILITY: At all times.

ACTION:

If the calculated air dose exceeds the limits specified above, prepare and submit a special report pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

2.2.2.2 Cumulative quarterly and yearly dose contributions from gaseous releases shall be determined using methods contained in ODCM Section 7.3 at least once every 31 days.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2 GASEOUS EFFLUENTS

1/2.2.2.3 DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN PARTICULATE FORM
WITH HALF-LIVES GREATER THAN EIGHT DAYS

CONTROLS

1.2.2.3 The dose to a MEMBER OF THE PUBLIC from radioiodines, radioactive materials in particulate form, and radionuclides other than noble gases with half-lives greater than 8 days in gaseous effluent released per unit to areas at and beyond the SITE BOUNDARY (see Figure 3.1) shall be limited to the following:

- a. To any organ during any calendar quarter to ≤ 7.5 mrem;
- b. To any organ during any calendar year to ≤ 15 mrem.

APPLICABILITY: At all times.

ACTION:

If the calculated doses exceed the limits specified above, prepare and submit a special report pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

2.2.2.3 Cumulative quarterly and yearly dose contributions from gaseous releases shall be determined using methods contained in ODCM Section 7.4 at least once every 31 days.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2 GASEOUS EFFLUENTS

1/2.2.2.4 GASEOUS RADWASTE TREATMENT

CONTROLS

- 1.2.2.4 During operation above 25% power, the discharge of the SJAE must be routed through the charcoal adsorbers.

The GASEOUS RADWASTE TREATMENT SYSTEM shall be operable and appropriate portions of the system shall be used to reduce releases of radioactivity when the projected doses in 31 days due to gaseous effluents from each unit, to areas at and beyond the site boundary, would exceed:

- a. 0.2 mrad to air from gamma radiation, or
- b. 0.4 mrad to air from beta radiation, or
- c. 0.3 mrem to any organ of a MEMBER OF THE PUBLIC.

APPLICABILITY: At all times.

ACTION:

With the gaseous waste being discharged for more than 7 days without treatment through the charcoal adsorbers and in excess of the above limits, prepare and submit a special report pursuant to Technical Specification 6.9.1.4.

SURVEILLANCE REQUIREMENTS

- 2.2.2.4.1 During operation above 25% power, the position of the charcoal bed bypass valve will be verified daily.
- 2.2.2.4.2 Doses due to gaseous releases to areas at and beyond the SITE BOUNDARY shall be projected in accordance with Section 7.5 at least once per 31 days.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.3 TOTAL DOSE

CONTROLS

1.2.3 The dose or dose commitment to a real individual from all uranium fuel cycle sources is limited to ≤ 25 mrem to the total body or any organ (except the thyroid, which is limited to ≤ 75 mrem) over a period of one calendar year.

APPLICABILITY: At all times.

ACTION:

With the calculated dose from the release of radioactive materials in liquid or gaseous effluents exceeding twice the limits of ODCM Control 1.2.1.2, 1.2.2.2, or 1.2.2.3, prepare and submit a Special Report to the Commission pursuant to Technical Specification 6.9.1.4 and limit the subsequent releases such that the above limits are not exceeded.

SURVEILLANCE REQUIREMENTS

2.2.3 Cumulative dose contributions from liquid and gaseous effluents shall be determined in accordance with ODCM Sections 6.3, 7.3, and 7.4 and the methods in ODCM Section 8.0.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.1 MONITORING PROGRAM

CONTROLS

1.3.1 The radiological environmental monitoring program shall be conducted as specified in Table 2.3-1.

APPLICABILITY: At all times.

ACTION:

- a. With the radiological environmental monitoring program not being conducted as specified in Table 2.3-1, prepare and submit to the Commission, in the Annual Radiological Environmental Operating Report, a description of the reasons for not conducting the program as required and the plans for preventing a recurrence.

Deviations are permitted from the required sampling schedule if specimens are unobtainable due to hazardous conditions, seasonal unavailability or malfunction of automatic sampling equipment. If the latter, every effort shall be made to complete corrective action prior to the end of the next sampling period. All deviations from the sampling schedule shall be reported in the Annual Radiological Environmental Operating Report.

- b. With the level of radioactivity in an environmental sampling medium exceeding the reporting levels of Table 2.3-3 when averaged over any calendar quarter, prepare and submit to the Commission within 30 days from the end of the affected quarter a report which identifies the cause(s) for exceeding the limit(s) and defines the corrective actions to be taken to reduce radioactive effluents so that the potential annual dose to a member of the public is less than the calendar year limits of ODCM Controls 1.2.1.2, 1.2.2.2, and 1.2.2.3. When one or more of the radionuclides in Table 2.3-2 is detected in the sampling medium, this report shall be submitted if:

$$\frac{\text{concentration}(1)}{\text{limit level}(1)} + \frac{\text{concentration}(2)}{\text{limit level}(2)} + \dots \geq 1.0$$

When radionuclides other than those in Table 2.3-3 are detected and are the result of plant effluents, this report shall be submitted if the potential annual dose to a MEMBER OF THE PUBLIC is equal to or greater than the calendar year limits of ODCM Controls 1.2.1.2, 1.2.2.2, and 1.2.2.3. This report is not required if the measured level of radioactivity was not the result of plant effluents; however, in such an event, the condition shall be reported and described in the Annual Radiological Environmental Operating Report.

1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.1 MONITORING PROGRAM

CONTROLS

ACTION (CONTINUED):

- c. With milk or fresh leafy vegetable samples unavailable from one or more of the sample locations required by Table 2.3-1, identify locations for obtaining replacement samples, if available, and add them to the radiological environmental monitoring program within 30 days. The specific locations from which samples were unavailable may then be deleted from the monitoring program.

Pursuant to Control 1.3.1.b, identify the cause of the unavailability of samples and identify the new location(s), if available, for obtaining replacement samples in the next Annual Radiological Environmental Operating Report and also include a revised figure(s) and table(s) for the ODCM reflecting the new location(s).

The detection capabilities required by Table 2.3-2 are state-of-the-art for routine environmental measurements in industrial laboratories. It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as a posteriori (after the fact) limit for a particular measurement. Analyses shall be performed in such a manner that the stated LLDs will be achieved under routine conditions. Occasionally background fluctuations, unavoidably small sample sizes, the presence of interfering nuclides, or other uncontrollable circumstances may render these LLDs unachievable. In such cases, the contributing circumstances will be identified and described in the Annual Radiological Environmental Operating Report.

SURVEILLANCE REQUIREMENTS

- 2.3.1.1 The radiological environmental monitoring samples shall be collected pursuant to Table 2.3-1 from the locations given in the tables and figures listed below and shall be analyzed pursuant to the requirements of Table 2.3-1 and the detection capabilities required by Table 2.3-2.
- 2.3.1.2 If measured levels of radioactivity in an environmental sampling medium are determined to exceed the reporting level values of Table 2.3-3 when averaged over any calendar quarter sampling period, a report shall be submitted to the Commission pursuant to Control 1.3.1.b.



Table 2.3-1 (1 of 3)
MINIMUM REQUIRED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
1. AIRBORNE			
Radioiodine/ Particulates	Minimum of 5 locations	Continuous operation of sampler with sample collection as required by dust loading but at least once per 7 days.	Radioiodine canister: Analyze at least once per 7 days for I-131. Particulate sampler: Analyze for gross beta radioactivity \geq 24 hours following filter change. Perform gamma isotopic analysis on each sample when gross beta activity is $>$ 10 times the average of control samples. Perform gamma isotopic analysis on composite (by location) sample at least once per 92 days.
2. DIRECT RADIATION	At least 40 locations with \geq 2 dosimeters at each location.	At least once per 92 days.	Gamma Dose. At least once per 92 days.

^a Sample locations are given in ODCM Section 9.0.

Table 2.3-1 (2 of 3)
MINIMUM REQUIRED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
3. WATERBORNE			
a. Surface	2 locations	Composite sample collected over a period of \leq 31 days. ^b	Gamma isotopic analysis of each composite sample. Tritium analysis of composite sample at least once per 92 days.
b. Drinking	Minimum of 1 downstream location, or all water supplies within 10 miles downstream which are taken from the Tennessee River	Composite sample collected ^c over a period of \leq 31 days. ^{b,c}	Gross beta and gamma isotopic analysis of each composite sample. Tritium analysis of composite sample at least once per 92 days.
c. Sediment	Minimum of 1 location.	At least once per 184 days	Gamma isotopic analysis of each sample.
d. Ground ^d			

^a Sample locations are given in ODCM Section 9.0.

^b Composite samples shall be collected by collecting an aliquot at intervals not exceeding 2 hours.

^c Composite samples shall be collected over a period of \leq 14 days for I-131 if drinking water is obtained within 3 miles downstream of the plant.

^d Ground water movement in the area has been determined to be from the plant site toward the Tennessee River. Since no drinking water wells exist between the plant and the river, ground water will not be monitored.



Table 2.3-1 (3 of 3)
MINIMUM REQUIRED RADIOLOGICAL ENVIRONMENTAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations^a</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
4. INGESTION			
a. Milk	3 locations	At least once per 15 days when animals are on pasture; at least once per 31 days at other times.	I-131 analysis of each sample. Gamma isotopic analysis at least once per 31 days
b. Fish	2 samples	One sample in season, or at least once per 184 days if not seasonal. One sample of commercial and game species.	Gamma isotopic analysis on edible portions.
c. Food Products ^e	2 locations	At least once per year at time of harvest	Gamma isotopic analysis on edible portion.

^a Sample locations are given in ODCM Section 9.0.

^e Since water from the Tennessee River in the immediate area downstream is not used for irrigation purposes, the sampling of food products (primarily broad leaf vegetation) is not required unless milk sampling is not performed.




Table 2.3-2 (1 of 2)
MAXIMUM VALUES FOR THE LOWER LIMIT OF DETECTION (LLD)^{a,c}
FOR ENVIRONMENTAL SAMPLES

<u>Analysis</u>	<u>Water (pCi/L)</u>	<u>Airborne Particulate or Gases (pCi/m3)</u>	<u>Fish (pCi/kg, wet)</u>	<u>Milk (pCi/L)</u>	<u>Food Products (pCi/kg, wet)</u>	<u>Sediment (pCi/kg, dry)</u>
gross beta	4	0.01	N/A	N/A	N/A	N/A
H-3	2000	N/A	N/A	N/A	N/A	N/A
Mn-54	15	N/A	130	N/A	N/A	N/A
Fe-59	30	N/A	260	N/A	N/A	N/A
Co-58, 60	15	N/A	130	N/A	N/A	N/A
Zn-65	30	N/A	260	N/A	N/A	N/A
Zr-95	30	N/A	N/A	N/A	N/A	N/A
Nb-95	15	N/A	N/A	N/A	N/A	N/A
I-131	1 ^b	0.07	N/A	1	60	N/A
Cs-134	15	0.05	130	15	60	150
Cs-137	18	0.06	150	18	80	180
Ba-140	60	N/A	N/A	60	N/A	N/A
La-140	15	N/A	N/A	15	N/A	N/A



Table 2.3-2 (2 of 2)
MAXIMUM VALUES FOR THE LOWER LIMIT OF DETECTION (LLD)^{a,c}
FOR ENVIRONMENTAL SAMPLES
TABLE NOTATION

^a The LLD is the smallest concentration of radioactive material in a sample that will be detected with 95 percent probability with 5 percent probability of falsely concluding that a blank observation represents a "real" signal.

For a particular measurement system, which may include radiochemical separation:

$$LLD = \frac{4.66 s_b}{E V 2.22 Y \exp(-\lambda \Delta t)}$$

Where:

- LLD = the "a priori" lower limit of detection as defined above, (as picocuries per unit mass or volume).
 s_b = the standard deviation of the background counting rate or of the counting rate of a blank sample as appropriate, (as counts per minute).
E = the counting efficiency, (as counts per disintegration).
V = the sample size (in units of mass or volume).
2.22 = the number of disintegrations per minute per picocurie.
Y = the fractional radiochemical yield, (when applicable).
 λ = the radioactive decay constant for the particular radionuclide, seconds⁻¹ and
 Δt = for environmental samples is the elapsed time between sample collection, (or end of the sample collection period), and time of counting (for environmental samples, not plant effluent samples), seconds.

Typical values of E, V, Y, and Δt should be used in the calculation.

It should be recognized that the LLD is defined as an a priori (before the fact) limit representing the capability of a measurement system and not as an a posteriori (after the fact) limit for a particular measurement.

- ^b LLD for analysis of drinking water and surface water samples shall be performed by gamma spectroscopy at approximately 15 pCi/L. If levels greater than 15 pCi/L are identified in surface water samples downstream from the plant, or in the event of an unanticipated release of I-131, drinking water samples will be analyzed at an LLD of 1.0 pCi/L for I-131.
- ^c Other peaks which are measurable and identifiable shall be identified and reported.



Table 2.3-3
REPORTING LEVELS FOR RADIOACTIVITY CONCENTRATIONS IN ENVIRONMENTAL SAMPLES

<u>Analysis</u>	<u>Water (pCi/L)</u>	<u>Airborne Particulate or gases (pCi/m3)</u>	<u>Fish (pCi/Kg, wet)</u>	<u>Milk (pCi/L)</u>	<u>Food Products (pCi/Kg, wet)</u>
H-3	2 x 10 ⁴ (a)	N.A.	N.A.	N.A.	N.A.
Mn-54	1 x 10 ³	N.A.	3 x 10 ⁴	N.A.	N.A.
Fe-59	4 x 10 ²	N.A.	1 x 10 ⁴	N.A.	N.A.
Co-58	1 x 10 ³	N.A.	3 x 10 ⁴	N.A.	N.A.
Co-60	3 x 10 ²	N.A.	1 x 10 ⁴	N.A.	N.A.
Zn-65	3 x 10 ²	N.A.	2 x 10 ⁴	N.A.	N.A.
Zr-Nb-95	4 x 10 ²	N.A.	N.A.	N.A.	N.A.
I-131	2	0.9	N.A.	3	1 x 10 ²
Cs-134	30	10	1 x 10 ³	60	1 x 10 ³
Cs-137	50	20	2 x 10 ³	70	2 x 10 ³
Ba-La-140	2 x 10 ²	N.A.	N.A.	3 x 10 ²	N.A.

(a) For drinking water samples. This is 40 CFR Part 141 value.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.2 LAND USE CENSUS

CONTROLS

1.3.2 A land use census shall be conducted and shall identify the location of the nearest milk animal, the nearest residence and the nearest garden¹ of greater than 500 square feet producing vegetables in each of the 16 meteorological sectors within a distance of 5 miles. (For elevated releases as defined in Regulatory Guide 1.111, Revision 1, July 1977, the land use census shall also identify the locations of all milk animals and gardens of greater than 500 square feet producing fresh leafy vegetables in each of the 16 meteorological sectors within a distance of three miles.)

¹ Broad leaf vegetation sampling may be performed at the SITE BOUNDARY in the direction sector with the highest D/Q in lieu of the garden census.

APPLICABILITY: At all times.

ACTION:

With a land use census identifying a location(s) which yields a calculated dose or dose commitment greater than the maximum value currently being calculated in Section 7.5, identify the new location(s) in the next Annual Radiological Environmental Operating Report.

With a land use census identifying a location(s) that yields a calculated dose or dose commitment (via the same exposure pathway) 20 percent greater than at a location from which samples are currently being obtained in accordance with ODCM Control 1.3.1, add the new location(s) to the radiological environmental monitoring program within 30 days if the owner consents. The sampling location(s), excluding the control station location, having the lowest calculated dose or dose commitment(s) (via the same exposure pathway) may be deleted from this monitoring program after October 31 of the year in which this land use census was conducted. Identify the new location(s) in the next Annual Radiological Environmental Operating Report and provide a revised figure(s) and table(s) reflecting the new location(s).

SURVEILLANCE REQUIREMENTS

(see next page)



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.2 LAND USE CENSUS

SURVEILLANCE REQUIREMENTS

2.3.2 The land use census shall be conducted at least once per calendar year between the dates of April 1 and October 1 using the following techniques:

1. Within a 2-mile radius from the plant or within the 15 mrem per year isodose line, whichever is larger, enumeration by a door-to-door or equivalent counting technique.
2. Within a 5-mile radius from the plant, enumeration by using appropriate techniques such as door-to-door survey, mail survey, telephone survey, aerial survey, or information from local agricultural authorities or other reliable sources.



1/2 CONTROLS AND SURVEILLANCE REQUIREMENTS

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.3 INTERLABORATORY COMPARISON PROGRAM

CONTROLS

1.3.3 Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program which has been approved by the Commission.


APPLICABILITY: At all times.

ACTION:

With analyses not being performed as required above, report the corrective actions taken to prevent a recurrence to the Commission in the Annual Radiological Environmental Operating Report.

SURVEILLANCE REQUIREMENTS

2.3.3 A summary of the results obtained as part of the above required Interlaboratory Comparison Program (or participants in the Environmental Protection Agency (EPA) cross check program shall provide the EPA program code designation for the unit) shall be included in the Annual Radiological Environmental Operating Report.



BASES FOR
SECTIONS 1.0 AND 2.0
CONTROLS
AND
SURVEILLANCE REQUIREMENTS

NOTE

The BASES contained in succeeding pages summarize the reasons for the Controls in Sections 1.0 and 2.0, but are not part of these Controls.



BASES

1/2.1 EFFLUENT MONITORING INSTRUMENTATION

1/2.1.1 RADIOACTIVE LIQUID EFFLUENT MONITORING INSTRUMENTATION

The radioactive liquid effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in liquid effluents during actual or potential releases of liquid effluents. The alarm/trip setpoints for these instruments shall be calculated in accordance with guidance provided in the ODCM to ensure that the alarm/trip will occur prior to exceeding the limits or 10 CFR Part 20 Appendix B, Table II, Column 2. The OPERABILITY and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

1/2.1.2 RADIOACTIVE GASEOUS EFFLUENT MONITORING INSTRUMENTATION

The radioactive gaseous effluent instrumentation is provided to monitor and control, as applicable, the releases of radioactive materials in gaseous effluents during actual or potential releases of gaseous effluents. The alarm/trip setpoints for these instruments will be calculated in accordance with Section 7.2.1 to ensure that the alarm/trip will occur prior to exceeding the limits of 10 CFR Part 20. The operability and use of this instrumentation is consistent with the requirements of General Design Criteria 60, 63, and 64 of Appendix A to 10 CFR Part 50.

The action required when the number of OPERABLE channels is less than the Minimum Channels Operable requirement is specified in the notes for Table 1.1-2. Exert best efforts to return the instruments to OPERABLE status within 30 days and, if unsuccessful, explain in the next Semiannual Radioactive Effluent Release Report why the inoperability was not corrected in a timely manner.

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1.1 CONCENTRATION

This requirement is provided to ensure that the concentration of radioactive materials released in liquid waste effluents from the site to UNRESTRICTED AREAS will be less than the concentration levels specified in 10 CFR Part 20, Appendix B, Table II, Column 2. This limitation provides additional assurance that the levels of radioactive materials in bodies of water outside the site will result in exposures within (1) the Section II.A limits of Appendix I to 10 CFR Part 50 to the population. The concentration limit for noble gases is based upon the assumption that Xe-135 is the

BASES

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1.1 CONCENTRATION (continued)

controlling radioisotope and its Maximum Permissible Concentration in air (submersion) was converted to an equivalent concentration in water using the methods described in International Commission of Radiological Protection (ICRP) Publication 2.

1/2.2.1.2 DOSE

This requirement is provided to implement the dose requirements of Section II.A, III.A, and IV.A of Appendix I, 10 CFR Part 50. The requirement implements the guides set forth in Section II.A of Appendix I.

This action provides the required operating flexibility and at the same time implements the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in liquid effluents will be kept "as low as is reasonable achievable". Also, for fresh water sites with drinking water supplies which can potentially be affected by plant operations, there is reasonable assurance that the operation of the facility will not result in radionuclide concentrations in the finished drinking water that are in excess of the requirements of 40 CFR 141. The dose calculations in Section 6.0 implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. The equations specified in Section 6.0 for calculating the doses due to the actual release rates of radioactive materials in liquid effluents will be consistent with the methodology provided in Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purpose of Implementing Appendix I," October 1977 and Regulatory Guide 1.113, "Estimating Aquatic Dispersion of Effluents from Accidental and Routine Reactor Releases for the Purpose of Implementing Appendix I" April 1977. NUREG-0133 provides methods for dose calculations consistent with Regulatory Guides 1.109 and 1.113.

1/2.2.1.3 LIQUID WASTE TREATMENT

This section requires that the appropriate portions of the liquid radwaste treatment system be used when specified. This provides assurance that the releases of radioactive materials in liquid effluents will be kept "as low as is reasonably achievable." This requirement implements the requirements of 10 CFR Part 50.36a,



BASES

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.1.3 LIQUID WASTE TREATMENT (continued)

General Design Criterion 60 of Appendix A to 10 CFR Part 50 and design objective Section II.D of Appendix I to 10 CFR 50. The specified limits governing the use of appropriate portions of the liquid radwaste treatment system were specified as a suitable fraction of the guide set forth in Section II.A of Appendix I, 10 CFR 50, for liquid effluents.

This section also requires submittal of a special report if the limiting values are exceeded and unexpected failures of non-redundant radwaste processing equipment halt waste treatment.

1/2.2.2.1 DOSE RATE

This requirement is provided to ensure that the dose rate at anytime at the SITE BOUNDARY from gaseous effluents from all units on the site will be within the annual dose limits of 10 CFR Part 20 for UNRESTRICTED AREAS. The annual dose limits are the doses associated with the concentrations of 10 CFR Part 20, Appendix B, Table II, Column 1. These limits provide reasonable assurance that radioactive material discharged in gaseous effluents will not result in the exposure of a MEMBER OF THE PUBLIC in an UNRESTRICTED AREA; either within or outside the SITE BOUNDARY, to annual average concentrations exceeding the limits specified in Appendix B, Table II of 10 CFR Part 20 (10 CFR Part 20.106(b)). For MEMBERS OF THE PUBLIC who may at times be within the SITE BOUNDARY, the occupancy of the MEMBER OF THE PUBLIC will be sufficiently low to compensate for any increase in the atmospheric diffusion factor above that for the SITE BOUNDARY.

The specified release rate limits restrict, at all times, the corresponding gamma and beta dose rates to an individual at or beyond the SITE BOUNDARY to < 500 mrem/year to the total body or < 3000 mrem/year to the skin. These release rates also restrict, at all times, the corresponding thyroid dose rate above background to an infant via the cow-milk-infant pathway to < 1500 mrem/year for the nearest cow to the plant.

The action for this requirement requires that appropriate corrective action(s) be taken to reduce gaseous effluent releases if the limits are exceeded.



BASES


1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2.2 DOSE - NOBLE GASES

This requirement is provided to implement the requirements of Section II.B, III.A, and IV.A of Appendix I, 10 CFR Part 50. The limits are the guides set forth in Section II.C of Appendix I.

The action to be taken for exceeding these limits provides the required operating flexibility and at the same time implements the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as reasonably achievable." Section 7.0 calculational methods implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. Section 7.0 calculational methods for calculating the doses due to the actual release rates of the subject materials are consistent with the methodologies provided in NUREG/CR-1004, "A Statistical Analysis of Selected Parameters for Predicting Food Chain Transport and Internal Dose of Radionuclides." October 1979 and Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10 CFR Part 50, "Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors," Revision 1, July 1977. These ODCM equations also provide for determining the air doses at the exclusion area boundary are based upon the historical average atmospheric conditions. NUREG-0133 provides methods for dose calculations consistent with Regulatory Guides 1.109 and 1.111.

If these limits are exceeded, this section requires that a special report be prepared and submitted to explain violations of the limiting doses contained in the section above.



BASES

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2.3 DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN
PARTICULATE FORM

This requirement is provided to implement the requirements of Section II.C, III.A, and IV of Appendix I, 10 CFR Part 50. The limits are the guides set forth in Section II.C of Appendix I.

The action to be taken for exceeding these limits provides the required operating flexibility and at the same time implements the guides set forth in Section IV.A of Appendix I to assure that the releases of radioactive material in gaseous effluents will be kept "as low as reasonably achievable." Section 7.0 calculational methods implement the requirements in Section III.A of Appendix I that conformance with the guides of Appendix I be shown by calculational procedures based on models and data such that the actual exposure of an individual through appropriate pathways is unlikely to be substantially underestimated. Section 7.0 calculational methods for calculating the doses due to the actual release rates of the subject materials are consistent with the methodologies provided in NUREG/CR-1004, "A Statistical Analysis of Selected Parameters for Predicting Food Chain Transport and Internal Dose of Radionuclides," October 1979 and Regulatory Guide 1.109, "Calculation of Annual Doses to Man from Routine Releases of Reactor Effluents for the Purposes of Evaluating Compliance with 10 CFR Part 50, Appendix I," Revision 1, October 1977 and Regulatory Guide 1.111, "Methods for Estimating Atmospheric Transport and Dispersion of Gaseous Effluents in Routine Releases from Light-Water Cooled Reactors," Revision 1, July 1977. These equations also provide for determining the actual doses based upon the historical average atmospheric conditions. The release rate specifications for iodines, radioactive material in particulate form and radionuclides other than noble gases are dependent on the existing radionuclide pathways to man in the UNRESTRICTED AREA. The pathways which were examined in the development of these calculations were: 1) individual inhalation of airborne radionuclides, 2) deposition of radionuclides onto green leafy vegetation with subsequent consumption by man, 3) deposition onto grassy areas where milk animals and meat producing animals graze with consumption of the milk and meat by man, and 4) deposition on the ground with subsequent exposure of man.

If these limits are exceeded, this section requires that a special report be prepared and submitted to explain violations of the limiting doses contained in the section above.



BASES

1/2.2 RADIOACTIVE EFFLUENTS

1/2.2.2.4 GASEOUS RADWASTE TREATMENT

This requires that the offgas charcoal adsorber beds be used when specified to treat gaseous effluents prior their release to the environment. This provides reasonable assurance that the release of radioactive materials in gaseous effluents will be kept "as low as is reasonable achievable". This requirement implements the requirements of 10 CFR Part 50.36a, General Design Criterion 60 of Appendix A to 10 CFR Part 50, and design objective Section II.D of Appendix I to 10 CFR Part 50. The specified limits governing the use of appropriate portions of the systems were specified as a suitable fraction of the guide set forth in Sections II.B and II.C of Appendix I, 10 CFR Part 50, for gaseous effluents.

This action requires that a special report be prepared and submitted to explain reasons for any failure to comply with the above requirements.

1/2.2.3 TOTAL DOSE

This requirement is provided to meet the dose limitations of 40 CFR 190. This requirement requires the preparation and submittal of a Special Report whenever the calculated doses from plant radioactive effluents exceed twice the design objective doses of Appendix I. For sites containing up to four reactors, it is highly unlikely that the resultant dose to a MEMBER OF THE PUBLIC will exceed the dose limits of 40 CFR 190 if the individual reactors remain within the reporting requirement level. The Special Report will describe a course of action which should result in the limitation of dose to a member of the public for the calendar year to be within 40 CFR 190 limits. For the purposes of the Special Report, it may be assumed that the dose commitment to the MEMBER OF THE PUBLIC from other fuel cycle sources is negligible, with the exception that dose contributions from other nuclear fuel cycle facilities within a radius of five miles must be considered.

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.1 MONITORING PROGRAM

The radiological environmental monitoring program required by this section provides measurements of radiation and radioactive materials in those exposure pathways and for those radionuclides, which lead to the highest potential radiation exposures of individuals resulting from the station operation. This monitoring program thereby supplements the radiological effluent monitoring



BASES

1/2.3 RADIOLOGICAL ENVIRONMENTAL MONITORING

1/2.3.1 MONITORING PROGRAM (continued)

program by verifying that the measurable concentration of radioactive materials and levels of radiation are not higher than expected on the basis of the effluent measurements and modeling of the environmental exposure pathways.

1/2.3.2 LAND USE CENSUS

This requirement is provided to ensure that changes in the use of UNRESTRICTED AREAS are identified and that modifications to the monitoring program are made if required by the results of this census. The best survey information from the door-to-door, mail, telephone, aerial or consulting with local authorities shall be used. This census satisfies the requirements of Section IV.B.3 of Appendix I to 10 CFR Part 50. Restricting the census to gardens of greater than 500 square feet provides assurance that significant exposure pathways via the leafy vegetables will be identified and monitored since a garden of this size is the minimum required to produce the quantity (26 kg/year) of leafy vegetation assumed in Regulatory Guide 1.109 for consumption by a child. To determine this minimum garden size, the following assumptions were used: 1) that 20% of the garden was used for growing broad leaf vegetation (i.e., similar to lettuce and cabbage), and 2) a vegetation yield of 2 kg/square meter.

1/2.3.3 INTERLABORATORY COMPARISON PROGRAM

The requirement for participation in an Interlaboratory Comparison Program is provided to ensure that independent checks on the precision and accuracy of the measurements of radioactive materials in environmental sample matrices are performed as part of the quality assurance program for environmental monitoring in order to demonstrate that the results are reasonably valid.



3.0 DEFINITIONS

The defined terms in this section appear in capitalized type in the text and are applicable throughout these controls.

3.0.A. CHANNEL CALIBRATION

A CHANNEL CALIBRATION shall be the adjustment, as necessary, of the channel output such that it responds with the necessary range and accuracy to known values of the parameter which the channel monitors. The CHANNEL CALIBRATION shall encompass the entire channel including alarm and/or trip functions, and shall include the CHANNEL FUNCTIONAL TEST. The CHANNEL CALIBRATION may be performed by any series of sequential, overlapping, or total channel steps such that the entire channel is calibrated. Non-calibratable components shall be excluded from this requirement, but will be included in CHANNEL FUNCTIONAL TEST and SOURCE CHECK.

3.0.B. CHANNEL FUNCTIONAL TEST

A CHANNEL FUNCTIONAL TEST shall be:

- a. Analog channels - the injection of a simulated signal into the channel as close to the sensor as practicable to verify OPERABILITY including alarm and/or trip functions.
- b. Bistable channel - the injection of a simulated signal into the sensor to verify OPERABILITY including alarm and/or trip function.

3.0.C. GASEOUS WASTE TREATMENT SYSTEM

The GASEOUS WASTE TREATMENT SYSTEM consists of the charcoal adsorber vessels installed in the discharge of the steam jet air ejector to provide delay to a unit's offgas activity prior to release.

3.0.D. DOSE EQUIVALENT I-131

DOSE EQUIVALENT I-131 shall be that concentration of I-131 ($\mu\text{Ci}/\text{gram}$) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factors used for this calculation shall be those listed in Table III of TID-14844, "Calculation of Distance Factors for Power and Test Reactor Sites."

3.0.E. MEMBER(S) OF THE PUBLIC

MEMBER(S) OF THE PUBLIC shall include all individuals who by virtue of their occupational status have no formal association with the plant.



DEFINITIONS

This category shall include non-employees of the licensee who are permitted to use portions of the site for recreational, occupational, or other purposes not associated with plant functions. This category shall not include non-employees such as vending machine servicemen or postmen who, as part of their formal job function, occasionally enter RESTRICTED AREAS.

3.0.F. OPERABLE - OPERABILITY

A system, subsystem, train, component, or device shall be OPERABLE or have OPERABILITY when it is capable of performing its specified function(s). Implicit in this definition shall be the assumption that all necessary attendant instrumentation, controls, normal and emergency electrical power sources, cooling or seal water, lubrication or other auxiliary equipment that are required for the system, subsystem, train, component, or device to perform its function(s) are also capable of performing their related support function(s).

3.0.G. PURGE - PURGING

PURGE or PURGING is the controlled process of discharging air or gas from the primary containment to maintain temperature, pressure, humidity, concentration or other operating condition, in such a manner that replacement air or gas is required to purify the containment.

3.0.H. RATED POWER

RATED POWER refers to operation at a reactor power of 3,293 MWt; this is also termed 100 percent power and is the maximum power level authorized by the operating license. Rated steam flow, rated coolant flow, rated neutron flux, and rated nuclear system pressure refer to the values of these parameters when the reactor is at rated power. Design power, the power to which the safety analysis applies, corresponds to 3,440 MWt.

3.0.I. SITE BOUNDARY

The SITE BOUNDARY shall be that line beyond which the land is not owned, leased, or otherwise controlled by TVA (see Figure 3.1).

3.0.J. SOURCE CHECK

A SOURCE CHECK shall be the qualitative assessment of channel response when the channel sensor is exposed to a radioactive source or multiple of sources.



DEFINITIONS

3.0.K. UNRESTRICTED AREA

An UNRESTRICTED AREA shall be any area, at or beyond the SITE BOUNDARY to which access is not controlled by the licensee for purposed of protection of individuals from exposure to radiation and radioactive materials or any area within the SITE BOUNDARY used for residential quarters or industrial, commercial, institutional, and/or recreational purposes (see Figure 3.1).

3.0.L. VENTING

VENTING is the controlled process of discharging air or gas from primary containment to maintain temperature, pressure, humidity, concentration, or other operating condition, in such a manner that replacement air or gas is not provided or required. Vent, used in system names, does not imply a VENTING process.





Table 3.1

FREQUENCY NOTATION

<u>Notation</u>	<u>Frequency</u>
S	At least once per 12 hours.
D	At least once per 24 hours.
W	At least once per 7 days.
M	At least once per 31 days.
Q	At least once per 92 days.
SA	At least once per 184 days.
R	At least once per 18 months.
S/U	Prior to each reactor startup.
N.A.	Not Applicable
P	Completed prior to each release



Figure 3.1
LAND SITE BOUNDARY



SECTION 5.0

ADMINISTRATIVE CONTROLS

5.0 ADMINISTRATIVE CONTROLS

5.1 ANNUAL RADIOLOGICAL ENVIRONMENTAL OPERATING REPORT

The Annual Radiological Environmental Operating Report shall include summaries, interpretations, and an analysis of trends of the results of the radiological environmental surveillance activities for the report period, including a comparison with preoperational studies, operational controls (as appropriate), and previous environmental surveillance reports and an assessment of the observed impacts of the plant operation on the environment. The report shall also include the results of land use censuses required by Control 1.3.2. If harmful effects or evidence of irreversible damage are detected by the monitoring, the report shall provide an analysis of the problems and a planned course of action to alleviate the problem.

The Annual Radiological Environmental Operating Report shall include summarized and tabulated results in the format of Regulatory Guide 4.8, December 1975 of all radiological environmental samples taken during the report period. In the event that some results are not available for inclusion with the report, the report shall be submitted noting and explaining the reasons for the missing results. The missing data shall be submitted as soon as possible in a supplementary report.

The report shall also include the following: a summary description of the radiological environmental monitoring program; a map of all sampling locations keyed to a table giving distances and directions from one reactor; and the results of licensee participation in the Interlaboratory Comparison Program required by Control 1.3.3.

5.2 SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT

Semiannual Radioactive Effluent Release Reports shall include a summary of the quantities of radioactive liquid and gaseous effluents and solid waste shipped from the plant as delineated in Regulatory Guide 1.21, "Measuring, Evaluating, and Reporting Radioactivity in Solid Wastes and Releases of Radioactive Materials in Liquid and Gaseous Effluents from Light-Water-Cooled Nuclear Power Plants," Revision 1, June 1974, with data summarized on a quarterly basis following the format of Appendix B thereof.

The report shall include a summary of the meteorological conditions concurrent with the release of gaseous effluents during each quarter as outlined in Regulatory Guide 1.21, Revision 1, with data summarized on a quarterly bases following the format of Appendix B thereof. Calculated offsite dose to members of the public resulting from the release of liquid and gaseous effluents and their subsequent dispersion in the river and atmosphere shall be reported as recommended in Regulatory Guide 1.21, Revision 1.

5.0 ADMINISTRATIVE CONTROLS

5.2 SEMIANNUAL RADIOACTIVE EFFLUENT RELEASE REPORT (continued)

The Semiannual Radioactive Effluent Release Report shall include the information regarding solid waste as specified in the Process Control Program.

5.3 OFFSITE DOSE CALCULATION MANUAL CHANGES

As required by BFN TS 6.12, changes to the ODCM:

1. Shall be documented and records of reviews performed shall be retained as required by BFN TS 6.10.1. This documentation shall contain:
 - a. Sufficient information to support the change together with the appropriate analyses or evaluations justifying the change(s) and
 - b. A determination that the change will maintain the level of radioactive effluent control required by 10 CFR 20.106, 40 CFR 190, 10 CFR 50.36a, and Appendix I to 10 CFR 50 and not adversely impact the accuracy or reliability of effluent, dose, or setpoint calculations.
2. Shall become effective after review and acceptance by the PORC.
3. Shall be submitted to the NRC in the form of a complete, legible copy of the entire ODCM as a part of or concurrent with the Semiannual Radioactive Effluent Report for the period of the report in which any change to the ODCM was made. Each change shall be identified by markings in the margin of the affected pages, clearly indicating the area of the page that was changed, and shall indicate the date (i.e., month/year) the change was implemented.


5.4 SPECIAL REPORTS

Special Reports shall be submitted to the NRC in accordance with Section 50.73 to 10 CFR 50.

6.0 - LIQUID EFFLUENTS

RELEASE POINTS

The minimum flows available for dilution of radwaste are shown below:



6.1 LIQUID RELEASES

6.1.1 Pre-release Analysis/MPC - Sum of the Ratios

Prior to release, a grab sample will be analyzed to determine the concentration (C_i) of each gamma emitting radionuclide i in the radwaste tank. The following equation is used to calculate MPC fractions (M_i).

$$M_i = \frac{C_i}{MPC_i} \quad (6.1)$$

where:

- M_i = MPC fraction of radionuclide i .
- C_i = concentration of radionuclide i in the radwaste tank, $\mu\text{Ci/ml}$.
- MPC_i = MPC of radionuclide i as specified in Control 1.2.1.1, $\mu\text{Ci/ml}$.

The sum of the ratios (R) will be calculated by the following relationship:

$$R = \sum_i M_i \quad (6.2)$$

where:

- R = the sum of the ratios.
- M_i = MPC fraction from equation 6.1.

6.1.2 Release Flow Rate Calculations

The sum of the ratios at the diffuser pipes must be ≤ 1 due to the releases from the above source. The following relationship will assure this criterion is met:

$$f (R-1) \leq F \quad (6.3)$$

where:

- f = the effluent flow rate (gallons/minute) before dilution.
- R = the sum of the ratios as determined by Equation 6.2.
- F = minimum dilution flow rate for prerelease analysis.

The allowable release rate is calculated before each release and the release rate is continuously monitored during the release so that the MPC limit is not exceeded.



6.1.3 Post-release Analysis

A post-release analysis will be done using actual release data to ensure that the limits specified in Control 1.2.1.1 were not exceeded.

A composite list of concentrations (C_i) by isotope, will be used with actual liquid radwaste (f) and dilution (F) flow rates (or volumes) during the release. The data will be substituted into Equations 6.1, 6.2 and 6.3 to demonstrate compliance with the limits in Control 1.2.1.1. This data and setpoints will be recorded in auditable records by plant personnel.



6.2 INSTRUMENT SETPOINTS

Alarm/trip setpoints for each liquid monitor will be established and set such that Equation 6.3 is satisfied. The locations and identification numbers for each liquid effluent radiation detector are shown in Figures 6.1 and 6.2. This section of the ODCM describes the methodology that will be used to determine allowable values. The allowable values are then used to determine the physical settings on the monitors. The physical settings are calculated in the applicable Scaling and Setpoint Document.

6.2.1 Radwaste Discharge Monitor

The allowable value for the radwaste discharge monitor (RM-90-130), shown in Figures 6.1 and 6.2, will be established using the methodology below. The alarm/trip allowable value will be set such that Equation 6.3 is satisfied. The trip allowable value for the monitor, which will automatically isolate the release, is set at less than or equal to the limit in Control 1.2.1.1. The alarm allowable value is set at 50% of the trip allowable value.

The maximum activity concentration¹ of liquid radwaste that can be discharged can be calculated as:

$$A = \frac{F + f}{f * \sum_i \frac{WF_i}{MPC_i}}$$

where:

- A = maximum batch activity concentration, $\mu\text{Ci/ml}$.
- MPC_i = Maximum Permissible Concentration, from 10 CFR 20 Appendix B for nuclide i , $\mu\text{Ci/ml}$.
- WF_i = weighting factor for nuclide i , defined as the fraction of the total concentration which is attributed to nuclide i .
- F = dilution water flow rate, gpm.
- f = maximum discharge flow rate, gpm.

¹ The maximum activity concentration is based on a selected isotopic mixture so that an allowable value can be calculated. The selected isotopic mixture will be documented in O-TI-45. If the actual batch MPC is less restrictive than the MPC for the selected isotopic mixture, then the actual activity concentration may be higher than the calculated maximum activity concentration.

The monitor isolation allowable value, in cps, for releases is calculated using the following equation:

$$\text{Monitor Isolation Allowable Value} = (A * \sum_i \text{WF}_i * \text{E}_i) + B$$

where:

- A = maximum batch activity concentration as calculated above, $\mu\text{Ci/ml}$
- WF_i = weighting factor for nuclide i , defined as the fraction of the total concentration which is attributed to nuclide i
- E_i = efficiency of the monitor for nuclide i , $\text{cps}/\mu\text{Ci/ml}$
- B = monitor background, cps

The calculation of these allowable values are documented further in TI 45, including the numerical values for each of the parameters described above.

6.2.2 Raw Cooling Water and Residual Heat Removal Service Water Monitors

The allowable value for the Raw Cooling Water (RCW) monitors and the Residual Heat Removal Service Water (RHRSW) monitors (RM-90-132 and RM-90-133,134 respectively), shown in Figure 6.1, will be established using the methodology below. The alarm/trip allowable values will be set such that Equation 6.3 is satisfied. The allowable values for these monitors, which will alarm in the control room, are based on the 10 CFR 20 Appendix B concentration limits. These allowable values are also based on a selected isotopic mixture.

The monitor alarm allowable values, in cpm, for the RCW and RHRSW effluent monitors are calculated using the following equation:

$$\text{Monitor Allowable Values} \leq (A * \sum_i \text{WF}_i * \text{E}_i) + B$$

where:

- A = total activity concentration, $\mu\text{Ci/ml}$.
- WF_i = weighting factor for nuclide i , defined as the fraction of the total concentration which is attributed to nuclide i .
- E_i = efficiency of the monitor for nuclide i , $\text{cpm}/\mu\text{Ci/ml}$.
- B = monitor background, cpm.

The calculation of these allowable values are documented further in TI 45, including the numerical values for each of the parameters described above.

6.3 CUMULATIVE LIQUID EFFLUENT DOSE CALCULATION

6.3.1 Monthly Analysis

Principal radionuclides will be used to conservatively estimate the monthly contribution to the cumulative dose. If the projected dose calculated by this monthly method exceeds the monthly fraction of the annual limits in Control 1.2.1.2, then the methodology in Section 6.6 will be implemented.

The 20 nuclides listed below, based on operational source terms, contribute more than 95 percent of the total estimated dose to the total body and the most critical organ for both the water and fish ingestion pathways. The organs considered for both water ingestion and fish ingestion are the gastrointestinal tract (GIT), bone, thyroid and liver.

H-3	Fe-59	Sr-90	I-131
Na-24	Co-58	Zr/Nb-95	I-133
Cr-51	Co-60	Mo/Tc-99m	Cs-134
Mn-54	Zn-65	Ag-110m	Cs-136
Fe-55	Sr-89	Sb-124	Cs-137

A conservative calculation of the monthly dose will be done according to the following procedure. First, the monthly operating report containing the release data will be obtained and the activities reported (if any) for each of the above 20 radionuclides will be noted. This information will then be used in the following calculations.

6.3.1.1 Water Ingestion

The dose to an individual from ingestion of water is described by the following equation.

$$D_{jk} = \frac{10^{12}}{0.95} \sum_{i=1}^{20} (DFL)_{ijk} I_{ik} \quad (6.4)$$

where:

- D_{jk} = dose for the j th organ and the k th age group from the 20 radionuclides, mrem.
- j = the organ of interest (bone, GIT, thyroid, liver or total body).
- k = the age group being considered, child or adult.
- 10^{12} = conversion factor, pCi/Ci.
- 0.95 = conservative correction factor, considering only 20 radionuclides.
- DFL_{ijk} = ingestion dose commitment factor for the i th radionuclide for the j th organ for the k th age group, mrem/pCi (Table 6.4)
- I_{ik} = monthly activity ingested of the i th radionuclide by the k th age group, Ci.

The activity ingested due to drinking water, I_{ik} , is described by:

$$I_{ik} = \frac{10^3 A_i U_{wa} (1/12)}{F d (7.34E+10)} \quad (6.5)$$

where:

- 10^3 = conversion factor, ml/L.
- A_i = activity released of i th radionuclide during the month, Ci.
- U_{wa} = maximum individual water consumption rate corresponding to the k th age group (Table 6.3), L/yr.
- $1/12$ = conversion factor, yr/month.
- F = average river flow rate for the month (cubic feet per second)
- d = fraction of river flow available for dilution (0.30)
- $7.34E+10$ = conversion from cubic feet per second to milliliters per month

Inserting this for I_{ik} in equation 6.4, the dose equation for water ingestion then becomes:

$$D_{jk} = \frac{3.98E+03}{F} \sum_{i=1}^{20} U_{wa} DFL_{ijk} A_i \quad (6.6)$$

6.3.1.2 Fish Ingestion

The dose to an individual from the consumption of fish is described by Equation 6.4. In this case, the activity ingested of the *i*th radionuclide due to eating fish (I_{ik}) is described by

$$I_{ik} = \frac{10^3 A_i B_i U_{fa} (1/12)}{F d (7.34E+10)} \quad (6.7)$$

where:

- 10^3 = conversion factor, g/kg.
- A_i = activity released of the *i*th radionuclide during the month, Ci
- B_i = bioaccumulation factor of *i*th radionuclide, $\mu\text{Ci/g}$ per $\mu\text{Ci/ml}$.
(Table 6.5)
- U_{fa} = amount of fish eaten yearly by the *k*th age group (Table 6.3),
kg/yr.
- 1/12 = conversion factor, yr/month.
- F = average river flow rate for the month, cubic feet per second.
- d = fraction of river flow available for dilution, 0.30.
- $7.34E+10$ = conversion from cubic feet per second to milliliters per month.

Inserting this for I_{ik} in equation 6.4, the dose equation for fish ingestion then becomes:

$$D_{jk} = \frac{3.98E+03}{F} \sum_{i=1}^{20} A_i B_i U_{fa} DFL_{ijk} \quad (6.8)$$

6.3.1.3 Recreation

For the recreation dose calculation, the total dose is estimated based on a calculation of the shoreline dose for Co-58, Co-60, Cs-134, and Cs-137. The shoreline dose due to these four nuclides is expected to contribute over 95 percent of the total recreation dose. The total body and maximum organ dose to an individual via the shoreline recreation pathway are assumed to be equal. The recreation dose is described by the following equation:

$$D_r = \frac{1012}{0.95} \sum_{i=1}^4 42 \text{ DFG}_i \xi_i \quad (6.9)$$

where:

- D_r = recreation dose from plant releases, mrem.
- 1012 = conversion factor, pCi/Ci.
- 0.95 = conservative correction factor for considering only 4 radionuclides.
- 42 = assumed monthly exposure time for maximum individual, hours
- DFG_i = dose commitment factor for standing on contaminated ground for the i th radionuclide, mrem/hr per pCi/m² (Table 6.6).
- ξ_i = concentration of i th radionuclide in shoreline sediment, Ci/m², as described by the following equation (based on equation A-5 in Regulatory Guide 1.109).
$$= 10^3 \cdot 6.94E-04 \cdot 100 \cdot \text{RHL}_i \cdot W [1 - \exp(-\lambda_i t_b)] C_i \quad (6.10)$$

where:

- 10^3 = conversion factor, ml/L.
- 6.94E-04 = conversion factor, d/min.
- RHL_i = radiological half-life of the i th radioisotope, minutes (Table 1.11).
- 100 = conversion factor, L/(M²d) (defined in Regulatory Guide 1.109).
- W = shoreline width factor (Table 6.3).
- λ_i = decay constant of the i th radionuclide, sec⁻¹ (Table 1.11).
- t_b = buildup time in sediment, seconds (Table 6.3)
- C_i = concentration of i th radionuclide in the Tennessee River, Ci/ml.
$$= A_i / (F \cdot d \cdot 7.34E+10)$$

where:

- A_i = activity released of i th radionuclide during the month, Ci/month.
- F = average river flow for the month, cfs.
- d = fraction of river flow available for dilution, 0.30.
- 7.34E+10 = conversion from cfs to ml/month.

The recreation dose equation then becomes:

$$D_r = \frac{1}{F} (29.8 A_1 + 1690 A_2 + 539 A_3 + 812 A_4) \quad (6.11)$$

where:

$A_1, A_2, A_3, A_4,$ = the activities of Co-58, Co-60, Cs-134, and Cs-137, respectively, μCi .

6.3.1.4 Monthly Summary

To obtain the total monthly dose to the total body, sum the total body dose from water ingestion, the total body dose from fish ingestion, and the recreation dose. This value will be compared to the limit for total body dose. To obtain the total monthly dose to the maximum organ, sum the maximum organ dose from water ingestion, the maximum organ dose from fish ingestion, and the recreation dose. This value will be compared to the limit for maximum organ dose. Calendar quarter and calendar year doses are first estimated by summing the doses calculated for each month in that year. However, if the annual doses determined in this manner exceed or approach the specification limits, doses calculated for previous quarters with the methodology of ODCM Section 6.6 will be used instead of those quarterly doses estimated by summing monthly results. An annual check will be made to ensure that the monthly dose estimates account for at least 95 percent of the dose calculated by the method described in ODCM Section 6.6. If less than 95 percent of the dose has been estimated, either a new list of principal isotopes will be prepared or a new correction factor will be used. The latter option will not be used if less than 90 percent of the total dose is predicted.

6.4 LIQUID RADWASTE TREATMENT SYSTEM

The liquid radwaste treatment system shall be maintained and operated to keep releases ALARA. A flow diagram for the LRTS is given in Figure 6.2.



6.5 DOSE PROJECTIONS

Dose projections will be done by averaging the calculated dose for the most recent month and the calculated dose for the previous month and assigning that average dose as the projection for the current month.



6.6 DOSE CALCULATIONS FOR REPORTING PURPOSES

A complete dose analysis utilizing the total estimated liquid releases for each calendar quarter will be performed and reported as required in ODCM Administrative Control 5.2. Methodology for this analysis is that which is described in this section using the quarterly release values reported by the plant personnel. The releases are assumed, for this calculation, to be continuous over the 90 day period.

The average dilution factor, D , used for these calculations is:

$$D = \frac{1}{RF * 0.30} \quad \begin{array}{l} \text{(for receptors upstream} \\ \text{of Wheeler Dam)} \end{array} \quad (6.13a)$$

and

$$D = \frac{1}{RF} \quad \begin{array}{l} \text{(for receptors downstream} \\ \text{of Wheeler Dam)} \end{array} \quad (6.13b)$$

where:

RF = the average actual riverflow for the location at which the dose is being determined, cfs.

0.30 = the fraction of the riverflow available for dilution in the near field, dimensionless.

6.6.1 Water Ingestion

Water ingestion doses are calculated for each Public Water Supply (PWS) identified within a 50 mile radius downstream of BFN (Table 6.1). Water ingestion doses are calculated for the total body and each internal organ as described below:

$$D_{org} = 10^6 \cdot 9.8E-09 \cdot A_{wit} \cdot Q_i \cdot D \cdot \exp(-8.64E+04 \lambda_i t_d) \quad (6.14)$$

where

10^6 = conversion factor, $\mu\text{Ci}/\text{Ci}$.

$9.8E-09$ = conversion factor, cfs per ml/hour.

A_{wit} = Dose factor for water ingestion for nuclide i , age group t , mrem/hour per $\mu\text{Ci}/\text{ml}$, as calculated in Section 6.7.1.

Q_i = Quantity of nuclide i released during the quarter, Curies.

D = dilution factor, as described above, cfs^{-1} .

λ_i = radiological decay constant of nuclide i , seconds^{-1} (Table 6.3).

t_d = decay time for water ingestion, equal to the travel time from the plant to the water supply plus one-half day (12 hours) to account for the time of processing at the water supply (per Regulatory Guide 1.109), days.

$8.64E+04$ = conversion factor, seconds per day.

6.6.2 Fish Ingestion

Fish ingestion doses are calculated for each identified reach within a 50 mile radius downstream of BFN (Table 6.1). Individual fish ingestion doses are calculated for the total body and each internal organ as described below:

$$D_{org} = 10^6 \cdot 9.8E-09 \cdot 0.25 \cdot A_{Fit} \cdot Q_i \cdot D \cdot \exp(-8.64E+04 \lambda_i t_d) \quad (6.15)$$

where

10^6 = conversion factor, $\mu\text{Ci}/\text{Ci}$.

$9.8E-09$ = conversion factor, cfs per ml/hour.

0.25 = fraction of the yearly fish consumption eaten in one quarter, dimensionless.

A_{Fit} = Dose factor for fish ingestion for nuclide i , age group t , mrem/hour per $\mu\text{Ci}/\text{ml}$, as calculated in ODCM Section 6.7.2.

Q_i = Quantity of nuclide i released during the quarter, Curies.

D = dilution factor, as described above, cfs^{-1} .

λ_i = radiological decay constant of nuclide i , seconds^{-1} (Table 6.3).

t_d = decay time for fish ingestion, equal to the travel time from the plant to the center of the reach plus one day to account for transit through the food chain and food preparation time (per Regulatory Guide 1.109), days.

$8.64E+04$ = conversion factor, seconds per day.

6.6.3 Shoreline Recreation

Recreation doses are calculated for each identified reach within a 50 mile radius downstream of BFN (Table 6.1). It is assumed that the maximum exposed individual spends 500 hours per year on the shoreline at a location immediately downstream from the diffusers. Individual recreation shoreline doses are calculated for the total body and skin as described below:

$$D_{org} = 10^6 \cdot 9.8E-09 \cdot rf \cdot A_{rit} \cdot Q_i \cdot D \cdot \exp(-8.64E+04 \lambda_i t_d) \quad (6.16)$$

where

10^6 = conversion factor, $\mu\text{Ci}/\text{Ci}$.

$9.8E-09$ = conversion factor, cfs per ml/hour.

rf = recreation factor, used to account for the fact that the same amount of time will not be spent at a recreation site during each quarter. Recreation factors used are:

- 1st quarter - 0.1
- 2nd quarter - 0.3
- 3rd quarter - 0.4
- 4th quarter - 0.2

- A_{rit} = Dose factor for shoreline recreation for nuclide i , age group t , mrem/hour per $\mu\text{Ci/ml}$, as calculated in ODCM Section 6.7.3.
 Q_i = Quantity of nuclide i released during the quarter, Curies.
 D = dilution factor, as described above, cfs^{-1} .
 λ_i = radiological decay constant of nuclide i , seconds^{-1} (Table 6.3).
 t_d = decay time for recreation, equal to the travel time from the plant to the center of the reach, days.
 $8.64\text{E}+04$ = conversion factor, seconds per day.

6.6.4 Total Maximum Individual Dose

The total maximum individual total body dose is obtained by summing the following for each age group: the highest total body water ingestion dose from among all the public water supplies; the highest total body fish ingestion dose from among all the reaches; and the total body maximum shoreline recreation dose. The total maximum individual organ dose is obtained by summing the following for each organ and each age group: that organ's highest water ingestion dose from among all the public water supplies; that organ's highest fish ingestion dose from among all the reaches; and the total body maximum shoreline recreation dose. The total maximum individual skin dose is that skin dose calculated for the maximum shoreline dose.

6.6.5 Population Doses

For determining population doses to the 50-mile population around the plant, an average dose is calculated for each age group and each pathway and then multiplied by the population.

For water ingestion, the general equation used for calculating the population doses, POPWTR, in man-rem for a given PWS is:

$$POPWTR_t = 10^{-3} \sum_{m=1}^3 POP_m \sum_{a=1}^4 POP_a ATMW_a TWDOS_{amt} \quad (6.17)$$

where:

POPWTR_t = water ingestion population dose to organ t, man-rem.

POP_a = fraction of population in each age group a (from NUREG CR-1004, Table 3.39).
= 0.665 for adult
= 0.168 for child
= 0.015 for infant
= 0.153 for teen

POP_m = population at PWS m. The 3 PWSs and their populations are listed in Table 6.1.

ATMW_a = ratio of average to maximum water ingestion rates for each age group a. Maximum water ingestion rates are given in Table 6.3. Average water ingestion rates are obtained from R.G. 1.109 Table E-4). The ratios are:
= 0.5069 for adult
= 0.5098 for child
= 0.7879 for infant
= 0.5098 for teen

TWDOS_{amt} = total individual water ingestion dose to organ t at PWS m, to the age group a, as described in Section 6.6.1, mrem.

10⁻³ = conversion factor for rem/mrem.

For population doses resulting from fish ingestion the calculation assumes that all fish caught within a 50-mile radius downstream of BFN are consumed by local population. An additional 7-days decay is added due to distribution time of sport fish. The general equation for calculating population doses, POPF, in man-rem from fish ingestion of all fish caught within a 50-mile radius downstream is:

$$POPF_t = 10^{-3} 10^{-3} \sum_{r=1}^3 \sum_{a=1}^3 \frac{453.6 HVST APR_r}{FISH_a POP_a} POP_a TFDOS_{art} \quad (6.18)$$

where:

POPF_t = total fish ingestion population dose to organ t, man-rem.
HVST = fish harvest for the Tennessee River, 8.32 lbs/acre/year.
APR_r = size of reach r, acres (Table 6.1).
TFDOS_{art} = total fish ingestion dose to organ t for reach r, for the age group a, as described in Section 6.6.2, mrem. Calculated with t_d in that equation equal to travel time plus 8 days.
POP_a = fraction of population in each age group a, as given above.
FISH_a = amount of fish ingested by each age group a, kg/year per person. The average fish ingestion rates (R.G. 1.109 Table E-4) are:

Adult = 6.9
Child = 2.2
Teen = 5.2

453.6 = conversion factor, g/lb.
10⁻³ = conversion factor, rem/mrem.
10⁻³ = conversion factor, kg/g.

For shoreline recreation, the general equation used for calculating the population doses, POPR, in man-rem is:

$$POPR_t = \frac{REQFRA}{10^3} \sum_{r=1}^3 SHVIS_r HRSVIS_r TSHDOS_{rt} \quad (6.19)$$

where:

POPR_t = total recreation population dose for all reaches to organ t, man-rem.
REQFRA = fraction of yearly recreation which occurs in that quarter, as given in Section 6.6.3, year per quarter.
SHVIS_r = shoreline visits per year at each reach r, (Table 6.1).
HRSVIS_r = length of shoreline recreation visit at reach r, 5 hours.
10³ = conversion factor, mrem/rem.
TSHDOS_{rt} = total shoreline dose rate for organ t, in reach r, mrem-quarter/h per quarter.
=
$$\frac{Q_i \exp(-\lambda_i t_r) K_c M DF_{Git} 10^{12} 24 10^3 D_r}{2.22E11 \lambda_i}$$

where:

Q_i = total activity released during the quarter, Ci.
λ_i = decay constant for nuclide i, day⁻¹.
t_r = travel time from the plant to reach r, days.
K_c = transfer coefficient from water to sediment, L/kg-hr, (Table 6.3).
M = mass density of sediment, kg/m², (Table 6.3).
DF_{Git} = dose conversion factor for standing on contaminated ground for nuclide i and organ t (total body and skin), mrem/hr per pCi/m².
10¹² = conversion factor, pCi/Ci.
24 = conversion factor, hr/day.
10³ = conversion factor, ml/L.
D_r = dilution factor for reach r, cfs⁻¹. Calculated as described in Equation 6.13.
2.22E11 = conversion factor, ml/quarter per cfs.



6.7 LIQUID DOSE FACTOR EQUATIONS

6.7.1 Water Ingestion Dose Factors

$$A_{Wit} = \frac{DF_{Liat} U_{wa} 10^6 10^3}{8760}$$

where:

DF_{Liat} = ingestion dose conversion factor for nuclide i, age group a, organ t, mrem/pCi, (Table 6.4).

U_{wa} = water consumption rate for age group a, L/year, (Table 6.3).

10^6 = conversion factor, pCi/ μ Ci.

10^3 = conversion factor, ml/L.

8760 = conversion factor, hours per year.

6.7.2 Fish Ingestion Dose Factors

$$A_{Fit} = \frac{DF_{Liat} U_{fa} B_i 10^6 10^3}{8760}$$

where:

DF_{Liat} = ingestion dose conversion factor for nuclide i, age group a, organ t, mrem/pCi, (Table 6.4).

U_{fa} = fish consumption rate for age group a, kg/year, (Table 6.3).

B_i = bioaccumulation factor for nuclide i, pCi/kg per pCi/L, (Table 6.5).

10^6 = conversion factor, pCi/ μ Ci.

10^3 = conversion factor, ml/L.

8760 = conversion factor, hours per year.

6.7.3 Shoreline Recreation Dose Factors

$$A_{Rit} = \frac{DF_{Git} K_c M W 10^3 10^6 U}{8760 * 3600 \lambda_i} [1 - \exp(-\lambda_i t_b)]$$

where:

DF_{Git} = dose conversion factor for standing on contaminated ground for nuclide i and organ t (total body and skin), mrem/hr per pCi/m², (Table 6.6).

K_c = transfer coefficient from water to shoreline sediment, L/kg-hr, (Table 6.3).

M = mass density of sediment, kg/m², (Table 6.3).

W = shoreline width factor, dimensionless, (Table 6.3).

10^3 = conversion factor, ml/L.

10^6 = conversion factor, pCi/ μ Ci.

3600 = conversion factor, seconds/hour.

λ_i = decay constant for nuclide i, seconds⁻¹, (Table 6.2).

t_b = time shoreline is exposed to the concentration in the water, seconds, (Table 6.3).

U = usage factor, 500 hours/year.

8760 = conversion factor, hours/year.



Table 6.1
RECEPTORS FOR LIQUID DOSE CALCULATIONS

Tennessee River Reaches Within
50 Mile Radius Downstream of BFN

<u>Name</u>	<u>Beginning TRM*</u>	<u>Ending TRM</u>	<u>Size (acres)</u>	<u>Recreation visits/year</u>
Wheeler Lake below BFN	294.0	275.0	26076	1,408,600
Wilson Lake	275.0	260.0	15930	3,816,800
Pickwick Lake	260.0	230.0	15048	705,500

Public Water Supplies Within
50 Mile Radius Downstream of BFN

<u>Name</u>	<u>TRM</u>	<u>Population</u>
Muscle Shoals, AL	259.6	10,740
Sheffield, AL	254.3	13,065
Cherokee, AL	239.2	3,400

* TRM = Tennessee River Mile

Table 6.2 (1 of 3)
RADIONUCLIDE DECAY AND STABLE ELEMENT TRANSFER DATA

	Half-Life (minutes)	λ (1/s)	Biv	F _{mi} (cow)	F _{mi} (goat)	F _{fi} (beef)
H-3	6.46E+06	1.79E-09	4.80E+00	1.00E-02	1.70E-01	1.20E-02
C-14	3.01E+09	3.84E-12	5.50E+00	1.20E-02	1.00E-01	3.10E-02
Na-24	9.00E+02	1.28E-05	5.20E-02	4.00E-02	4.00E-02	3.00E-02
P-32	2.06E+04	5.61E-07	1.10E+00	2.50E-02	2.50E-01	4.60E-02
Cr-51	3.99E+04	2.90E-07	2.50E-04	2.20E-03	2.20E-03	2.40E-03
Mn-54	4.50E+05	2.57E-08	2.90E-02	2.50E-04	2.50E-04	8.00E-04
Mn-56	1.55E+02	7.45E-05	2.90E-02	2.50E-04	2.50E-04	8.00E-04
Fe-55	1.42E+06	8.13E-09	6.60E-04	1.20E-03	1.30E-04	1.20E-02
Fe-59	6.43E+04	1.80E-07	6.60E-04	1.20E-03	1.30E-04	1.20E-02
Co-57	3.90E+05	2.96E-08	9.40E-03	1.00E-03	1.00E-03	1.30E-02
Co-58	1.02E+05	1.13E-07	9.40E-03	1.00E-03	1.00E-03	1.30E-02
Co-60	2.77E+06	4.17E-09	9.40E-03	1.00E-03	1.00E-03	1.30E-02
Ni-63	5.27E+07	2.19E-10	1.90E-02	6.70E-03	6.70E-03	5.30E-02
Ni-65	1.51E+02	7.65E-05	1.90E-02	6.70E-03	6.70E-03	5.30E-02
Cu-64	7.62E+02	1.52E-05	1.20E-01	1.40E-02	1.30E-02	9.70E-04
Zn-65	3.52E+05	3.28E-08	4.00E-01	3.90E-02	3.90E-02	3.00E-02
Zn-69m	8.26E+02	1.40E-05	4.00E-01	3.90E-02	3.90E-02	3.00E-02
Zn-69	5.56E+01	2.08E-04	4.00E-01	3.90E-02	3.90E-02	3.00E-02
Br-82	2.12E+03	5.45E-06	7.60E-01	5.00E-02	5.00E-02	2.60E-02
Br-83	1.43E+02	8.08E-05	7.60E-01	5.00E-02	5.00E-02	2.60E-02
Br-84	3.18E+01	3.63E-04	7.60E-01	5.00E-02	5.00E-02	2.60E-02
Br-85	2.87E+00	4.02E-03	7.60E-01	5.00E-02	5.00E-02	2.60E-02
Rb-86	2.69E+04	4.29E-07	1.30E-01	3.00E-02	3.00E-02	3.10E-02
Rb-88	1.78E+01	6.49E-04	1.30E-01	3.00E-02	3.00E-02	3.10E-02
Rb-89	1.54E+01	7.50E-04	1.30E-01	3.00E-02	3.00E-02	3.10E-02
Sr-89	7.28E+04	1.59E-07	1.70E-02	1.40E-03	1.40E-02	6.00E-04
Sr-90	1.50E+07	7.70E-10	1.70E-02	1.40E-03	1.40E-02	6.00E-04
Sr-91	5.70E+02	2.03E-05	1.70E-02	1.40E-03	1.40E-02	6.00E-04
Sr-92	1.63E+02	7.09E-05	1.70E-02	1.40E-03	1.40E-02	6.00E-04
Y-90	3.85E+03	3.00E-06	2.60E-03	1.00E-05	1.00E-05	4.60E-03
Y-91m	4.97E+01	2.32E-04	2.60E-03	1.00E-05	1.00E-05	4.60E-03
Y-91	8.43E+04	1.37E-07	2.60E-03	1.00E-05	1.00E-05	4.60E-03
Y-92	2.12E+02	5.45E-05	2.60E-03	1.00E-05	1.00E-05	4.60E-03
Y-93	6.06E+02	1.91E-05	2.60E-03	1.00E-05	1.00E-05	4.60E-03
Zr-95	9.22E+04	1.25E-07	1.70E-04	5.00E-06	5.00E-06	3.40E-02
Zr-97	1.01E+03	1.14E-05	1.70E-04	5.00E-06	5.00E-06	3.40E-02
Nb-95	5.05E+04	2.29E-07	9.40E-03	2.50E-03	2.50E-03	2.80E-01
Nb-97	7.21E+01	1.60E-04	9.40E-03	2.50E-03	2.50E-03	2.80E-01
Mo-99	3.96E+03	2.92E-06	1.20E-01	7.50E-03	7.50E-03	1.10E-03
Tc-99m	3.61E+02	3.20E-05	2.50E-01	2.50E-02	2.50E-02	4.00E-01
Tc-101	1.42E+01	8.13E-04	2.50E-01	2.50E-02	2.50E-02	4.00E-01
Ru-103	5.67E+04	2.04E-07	5.00E-02	1.00E-06	1.00E-06	4.00E-01
Ru-105	2.66E+02	4.34E-05	5.00E-02	1.00E-06	1.00E-06	4.00E-01
Ru-106	5.30E+05	2.18E-08	5.00E-02	1.00E-06	1.00E-06	4.00E-01
Ag-110m	3.60E+05	3.21E-08	1.50E-01	5.00E-02	5.00E-02	1.70E-02

Table 6.2 (2 of 3)
RADIONUCLIDE DECAY AND STABLE ELEMENT TRANSFER DATA

	Half-Life (minutes)	λ (1/s)	Biv	F _{mi} (cow)	F _{mi} (goat)	F _{fi} (beef)
Sb-124	8.67E+04	1.33E-07	N/A	1.50E-03	1.50E-03	N/A
Sb-125	1.46E+06	7.91E-09	N/A	1.50E-03	1.50E-03	N/A
Te-125m	8.35E+04	1.38E-07	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-127m	1.57E+05	7.36E-08	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-127	5.61E+02	2.06E-05	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-129m	4.84E+04	2.39E-07	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-129	6.96E+01	1.66E-04	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-131m	1.80E+03	6.42E-06	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-131	2.50E+01	4.62E-04	1.30E+00	1.00E-03	1.00E-03	7.70E-02
Te-132	4.69E+03	2.46E-06	1.30E+00	1.00E-03	1.00E-03	7.70E-02
I-130	7.42E+02	1.56E-05	2.00E-02	1.20E-02	4.30E-01	2.90E-03
I-131	1.16E+04	9.96E-07	2.00E-02	1.20E-02	4.30E-01	2.90E-03
I-132	1.38E+02	8.37E-05	2.00E-02	1.20E-02	4.30E-01	2.90E-03
I-133	1.25E+03	9.24E-06	2.00E-02	1.20E-02	4.30E-01	2.90E-03
I-134	5.26E+01	2.20E-04	2.00E-02	1.20E-02	4.30E-01	2.90E-03
I-135	3.97E+02	2.91E-05	2.00E-02	1.20E-02	4.30E-01	2.90E-03
Cs-134	1.08E+06	1.06E-08	1.00E-02	8.00E-03	3.00E-01	1.50E-02
Cs-136	1.90E+04	6.08E-07	1.00E-02	8.00E-03	3.00E-01	1.50E-02
Cs-137	1.59E+07	7.26E-10	1.00E-02	8.00E-03	3.00E-01	1.50E-02
Cs-138	3.22E+01	3.59E-04	1.00E-02	8.00E-03	3.00E-01	1.50E-02
Ba-139	8.31E+01	1.39E-04	5.00E-03	4.00E-04	4.00E-04	3.20E-03
Ba-140	1.84E+04	6.28E-07	5.00E-03	4.00E-04	4.00E-04	3.20E-03
Ba-141	1.83E+01	6.31E-04	5.00E-03	4.00E-04	4.00E-04	3.20E-03
Ba-142	1.07E+01	1.08E-03	5.00E-03	4.00E-04	4.00E-04	3.20E-03
La-140	2.41E+03	4.79E-06	2.50E-03	5.00E-06	5.00E-06	2.00E-04
La-142	9.54E+01	1.21E-04	2.50E-03	5.00E-06	5.00E-06	2.00E-04
Ce-141	4.68E+04	2.47E-07	2.50E-03	1.00E-04	1.00E-04	1.20E-03
Ce-143	1.98E+03	5.83E-06	2.50E-03	1.00E-04	1.00E-04	1.20E-03
Ce-144	4.09E+05	2.82E-08	2.50E-03	1.00E-04	1.00E-04	1.20E-03
Pr-143	1.95E+04	5.92E-07	2.50E-03	5.00E-06	5.00E-06	4.70E-03
Pr-144	1.73E+01	6.68E-04	2.50E-03	5.00E-06	5.00E-06	4.70E-03
Nd-147	1.58E+04	7.31E-07	2.40E-03	5.00E-06	5.00E-06	3.30E-03
W-187	1.43E+03	8.08E-06	1.80E-02	5.00E-04	5.00E-04	1.30E-03
Np-239	3.39E+03	3.41E-06	2.50E-03	5.00E-06	5.00E-06	2.00E-04
Ar-41	1.10E+02	1.05E-04	N/A	N/A	N/A	N/A
Kr-83m	1.10E+02	1.05E-04	N/A	N/A	N/A	N/A
Kr-85m	2.69E+02	4.29E-05	N/A	N/A	N/A	N/A
Kr-85	5.64E+06	2.05E-09	N/A	N/A	N/A	N/A
Kr-87	7.63E+01	1.51E-04	N/A	N/A	N/A	N/A
Kr-88	1.70E+02	6.79E-05	N/A	N/A	N/A	N/A
Kr-89	3.16E+00	3.66E-03	N/A	N/A	N/A	N/A
Kr-90	5.39E-01	2.14E-02	N/A	N/A	N/A	N/A
Xe-131m	1.70E+04	6.79E-07	N/A	N/A	N/A	N/A
Xe-133m	3.15E+03	3.67E-06	N/A	N/A	N/A	N/A



Table 6.2 (3 of 3)
RADIONUCLIDE DECAY AND STABLE ELEMENT TRANSFER DATA

	Half-Life (minutes)	λ (1/s)	Biv	F _{mi} (cow)	F _{mi} (goat)	F _{fi} (beef)
Xe-133	7.55E+03	1.53E-06	N/A	N/A	N/A	N/A
Xe-135m	1.54E+01	7.50E-04	N/A	N/A	N/A	N/A
Xe-135	5.47E+02	2.11E-05	N/A	N/A	N/A	N/A
Xe-137	3.83E+00	3.02E-03	N/A	N/A	N/A	N/A
Xe-138	1.41E+01	8.19E-04	N/A	N/A	N/A	N/A

References:

Half lives for all nuclides: DOE-TIC-11026, "Radioactive Decay Data Tables - A handbook of Decay Data for Application to Radiation Dosimetry and Radiological Assessment," D. C. Kocher, 1981.

Transfer factors for Sb- isotopes are from ORNL 4992, "Methodology for Calculating Radiation Doses from Radioactivity Released to the Environment," March 1976, Table 2-7.

Cow-milk transfer factors for Iodine, Strontium, and Cesium nuclides are from NUREG/CR-1004, Table 3.17.

Goat-milk transfer factors for Iodine nuclides are from NUREG/CR-1004, Table 3.17.

Beef transfer factors for Iron, Copper, Molybdenum, and Cesium nuclides are from NUREG/CR-1004, Table 3.18.

All other nuclides' transfer factors are from Regulatory Guide 1.109, Tables E-1 and E-2.

Table 6.3 (1 of 2)
DOSE CALCULATION FACTORS

Factor	Value	Units	Reference
BR _a (infant)	1400	m ³ /year	ICRP 23
BR _a (child)	5500	m ³ /year	ICRP 23
BR _a (teen)	8000	m ³ /year	ICRP 23
BR _a (adult)	8100	m ³ /year	ICRP 23
f _g	1		TVA Assumption
f _L	1		R. G. 1.109 (Table E-15)
f _p	1		TVA Assumption
f _s	0		TVA Assumption
H	9	g/m ³	TVA Value
K _c	0.072	L/kg-hr	R. G. 1.109 (Section 2.C.)
M	40	kg/m ²	R. G. 1.109 (Section 2.C.)
P	240	kg/m ²	R. G. 1.109 (Table E-15)
Q _f (cow)	64	kg/day	NUREG/CR-1004 (Sect. 3.4)
Q _f (goat)	08	kg/day	NUREG/CR-1004 (Sect. 3.4)
r	0.47		NUREG/CR-1004 (Sect. 3.2)
t _b	4.73E+08	seconds (15 years)	R. G. 1.109 (Table E-15)
t _{cb}	7.78E+06	seconds (90 days)	SQN FSAR Section 11.3.9.1
t _{csf}	1.56E+07	seconds (180 days)	SQN FSAR Section 11.3.9.1
t _e	5.18E+06	seconds (60 days)	R. G. 1.109 (Table E-15)
t _{ep}	2.59E+06	seconds (30 days)	R. G. 1.109 (Table E-15)
t _{esf}	7.78E+06	seconds (90 days)	R. G. 1.109 (Table E-15)
t _{fm}	8.64E+04	seconds (1 day)	SQN FSAR Section 11.3.9.1
t _{hc}	8.64E+04	seconds (1 day)	NUREG/CR-1004, Table 3.40
t _s	1.12E+06	seconds (13 days)	NUREG/CR-1004, Table 3.40
t _{sv}	2.38E+07	seconds (275 days)	SQN FSAR Section 11.3.9.1
U _m (infant)	0	kg/year	R. G. 1.109 (Table E-5)
U _m (child)	41	kg/year	R. G. 1.109 (Table E-5)
U _m (teen)	65	kg/year	R. G. 1.109 (Table E-5)
U _m (adult)	110	kg/year	R. G. 1.109 (Table E-5)
U _p (infant)	330	L/year	R. G. 1.109 (Table E-5)
U _p (child)	330	L/year	R. G. 1.109 (Table E-5)
U _p (teen)	400	L/year	R. G. 1.109 (Table E-5)
U _p (adult)	310	L/year	R. G. 1.109 (Table E-5)

Table 6.3 (2 of 2)
DOSE CALCULATION FACTORS

Factor	Value	Units	Reference
U _F (infant)	0	kg/year	R. G. 1.109 (Table E-5)
U _F (child)	6.9	kg/year	R. G. 1.109 (Table E-5)
U _F (teen)	16	kg/year	R. G. 1.109 (Table E-5)
U _F (adult)	21	kg/year	R. G. 1.109 (Table E-5)
U _{FL} (infant)	0	kg/year	R. G. 1.109 (Table E-5)
U _{FL} (child)	26	kg/year	R. G. 1.109 (Table E-5)
U _{FL} (teen)	42	kg/year	R. G. 1.109 (Table E-5)
U _{FL} (adult)	64	kg/year	R. G. 1.109 (Table E-5)
U _S (infant)	0	kg/year	R. G. 1.109 (Table E-5)
U _S (child)	520	kg/year	R. G. 1.109 (Table E-5)
U _S (teen)	630	kg/year	R. G. 1.109 (Table E-5)
U _S (adult)	520	kg/year	R. G. 1.109 (Table E-5)
U _w (infant)	330	L/year	R. G. 1.109 (Table E-5)
U _w (child)	510	L/year	R. G. 1.109 (Table E-5)
U _w (teen)	510	L/year	R. G. 1.109 (Table E-5)
U _w (adult)	730	L/year	R. G. 1.109 (Table E-5)
W	0.3	none	R. G. 1.109 (Table A-2)
Y _f	1.85	kg/m ²	NUREG/CR-1004 (Table 3.4)
Y _p	1.18	kg/m ²	NUREG/CR-1004 (Table 3.3)
Y _{sf}	0.64	kg/m ²	NUREG/CR-1004 (Table 3.3)
Y _{sv}	0.57	kg/m ²	NUREG/CR-1004 (Table 3.4) (value selected is for non-leafy vegetables)
λ _w (iodines)	7.71E-07	sec ⁻¹ (15.4 d half-life)	NUREG/CR-1004 (Table 3.10)
λ _w (particulates)	5.21E-07	sec ⁻¹ (10.4 d half-life)	NUREG/CR-1004 (Table 3.10)

Table 6.4 (1 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	ADULT						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
H-3	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07	1.05E-07
C-14	2.84E-06	5.68E-07	5.68E-07	5.68E-07	5.68E-07	5.68E-07	5.68E-07
Na-24	1.70E-06	1.70E-06	1.70E-06	1.70E-06	1.70E-06	1.70E-06	1.70E-06
P-32	1.93E-04	1.20E-05	7.46E-06	0.00E+00	0.00E+00	0.00E+00	2.17E-05
Cr-51	0.00E+00	0.00E+00	2.66E-09	1.59E-09	5.86E-10	3.53E-09	6.69E-07
Mn-54	0.00E+00	4.57E-06	8.72E-07	0.00E+00	1.36E-06	0.00E+00	1.40E-05
Mn-56	0.00E+00	1.15E-07	2.04E-08	0.00E+00	1.46E-07	0.00E+00	3.67E-06
Fe-55	2.75E-06	1.90E-06	4.43E-07	0.00E+00	0.00E+00	1.06E-06	1.09E-06
Fe-59	4.34E-06	1.02E-05	3.91E-06	0.00E+00	0.00E+00	2.85E-06	3.40E-05
Co-57	0.00E+00	1.75E-07	2.91E-07	0.00E+00	0.00E+00	0.00E+00	4.44E-06
Co-58	0.00E+00	7.45E-07	1.67E-06	0.00E+00	0.00E+00	0.00E+00	1.51E-05
Co-60	0.00E+00	2.14E-06	4.72E-06	0.00E+00	0.00E+00	0.00E+00	4.02E-05
Ni-63	1.30E-04	9.01E-06	4.36E-06	0.00E+00	0.00E+00	0.00E+00	1.88E-06
Ni-65	5.28E-07	6.86E-08	3.13E-08	0.00E+00	0.00E+00	0.00E+00	1.74E-06
Cu-64	0.00E+00	8.33E-08	3.91E-08	0.00E+00	2.10E-07	0.00E+00	7.10E-06
Zn-65	4.84E-06	1.54E-05	6.96E-06	0.00E+00	1.03E-05	0.00E+00	9.70E-06
Zn-69	1.03E-08	1.97E-08	1.37E-09	0.00E+00	1.28E-08	0.00E+00	2.96E-09
Zn-69m	1.70E-07	4.08E-07	3.73E-08	0.00E+00	2.47E-07	0.00E+00	2.49E-05
Br-82	0.00E+00	0.00E+00	2.26E-06	0.00E+00	0.00E+00	0.00E+00	2.59E-06
Br-83	0.00E+00	0.00E+00	4.02E-08	0.00E+00	0.00E+00	0.00E+00	5.79E-08
Br-84	0.00E+00	0.00E+00	5.21E-08	0.00E+00	0.00E+00	0.00E+00	4.09E-13
Br-85	0.00E+00	0.00E+00	2.14E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	2.11E-05	9.83E-06	0.00E+00	0.00E+00	0.00E+00	4.16E-06
Rb-88	0.00E+00	6.05E-08	3.21E-08	0.00E+00	0.00E+00	0.00E+00	8.36E-19
Rb-89	0.00E+00	4.01E-08	2.82E-08	0.00E+00	0.00E+00	0.00E+00	2.33E-21
Sr-89	3.08E-04	0.00E+00	8.84E-06	0.00E+00	0.00E+00	0.00E+00	4.94E-05
Sr-90	7.58E-03	0.00E+00	1.86E-03	0.00E+00	0.00E+00	0.00E+00	2.19E-04
Sr-91	5.67E-06	0.00E+00	2.29E-07	0.00E+00	0.00E+00	0.00E+00	2.70E-05
Sr-92	2.15E-06	0.00E+00	9.30E-08	0.00E+00	0.00E+00	0.00E+00	4.26E-05
Y-90	9.62E-09	0.00E+00	2.58E-10	0.00E+00	0.00E+00	0.00E+00	1.02E-04
Y-91m	9.09E-11	0.00E+00	3.52E-12	0.00E+00	0.00E+00	0.00E+00	2.67E-10
Y-91	1.41E-07	0.00E+00	3.77E-09	0.00E+00	0.00E+00	0.00E+00	7.76E-05
Y-92	8.45E-10	0.00E+00	2.47E-11	0.00E+00	0.00E+00	0.00E+00	1.48E-05
Y-93	2.68E-09	0.00E+00	7.40E-11	0.00E+00	0.00E+00	0.00E+00	8.50E-05
Zr-95	3.04E-08	9.75E-09	6.60E-09	0.00E+00	1.53E-08	0.00E+00	3.09E-05
Zr-97	1.68E-09	3.39E-10	1.55E-10	0.00E+00	5.12E-10	0.00E+00	1.05E-04
Nb-95	6.22E-09	3.46E-09	1.86E-09	0.00E+00	3.42E-09	0.00E+00	2.10E-05
Nb-97	5.22E-11	1.32E-11	4.82E-12	0.00E+00	1.54E-11	0.00E+00	4.87E-08
Mo-99	0.00E+00	4.31E-06	8.20E-07	0.00E+00	9.76E-06	0.00E+00	9.99E-06
Tc-99m	2.47E-10	6.98E-10	8.89E-09	0.00E+00	1.06E-08	3.42E-10	4.13E-07
Tc-101	2.54E-10	3.66E-10	3.59E-09	0.00E+00	6.59E-09	1.87E-10	1.10E-21
Ru-103	1.85E-07	0.00E+00	7.97E-08	0.00E+00	7.06E-07	0.00E+00	2.16E-05
Ru-105	1.54E-08	0.00E+00	6.08E-09	0.00E+00	1.99E-07	0.00E+00	9.42E-06
Ru-106	2.75E-06	0.00E+00	3.48E-07	0.00E+00	5.31E-06	0.00E+00	1.78E-04
Ag-110m	1.60E-07	1.48E-07	8.79E-08	0.00E+00	2.91E-07	0.00E+00	6.04E-05

Table 6.4 (2 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	ADULT						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
Sb-124	2.80E-06	5.29E-08	1.11E-06	6.79E-09	0.00E-00	2.18E-06	7.95E-05
Sb-125	1.79E-06	2.00E-08	4.26E-07	1.82E-09	0.00E-00	1.38E-06	1.97E-05
Te-125m	2.68E-06	9.71E-07	3.59E-07	8.06E-07	1.09E-05	0.00E+00	1.07E-05
Te-127m	6.77E-06	2.42E-06	8.25E-07	1.73E-06	2.75E-05	0.00E+00	2.27E-05
Te-127	1.10E-07	3.95E-08	2.38E-08	8.15E-08	4.48E-07	0.00E+00	8.68E-06
Te-129m	1.15E-05	4.29E-06	1.82E-06	3.95E-06	4.80E-05	0.00E+00	5.79E-05
Te-129	3.14E-08	1.18E-08	7.65E-09	2.41E-08	1.32E-07	0.00E+00	2.37E-08
Te-131m	1.73E-06	8.46E-07	7.05E-07	1.34E-06	8.57E-06	0.00E+00	8.40E-05
Te-131	1.97E-08	8.23E-09	6.22E-09	1.62E-08	8.63E-08	0.00E+00	2.79E-09
Te-132	2.52E-06	1.63E-06	1.53E-06	1.80E-06	1.57E-05	0.00E+00	7.71E-05
I-130	7.56E-07	2.23E-06	8.80E-07	1.89E-04	3.48E-06	0.00E+00	1.92E-06
I-131	4.16E-06	5.95E-06	3.41E-06	1.95E-03	1.02E-05	0.00E+00	1.57E-06
I-132	2.03E-07	5.43E-07	1.90E-07	1.90E-05	8.65E-07	0.00E+00	1.02E-07
I-133	1.42E-06	2.47E-06	7.53E-07	3.63E-04	4.31E-06	0.00E+00	2.22E-06
I-134	1.06E-07	2.88E-07	1.03E-07	4.99E-06	4.58E-07	0.00E+00	2.51E-10
I-135	4.43E-07	1.16E-06	4.28E-07	7.65E-05	1.86E-06	0.00E+00	1.31E-06
Cs-134	6.22E-05	1.48E-04	1.21E-04	0.00E+00	4.79E-05	1.59E-05	2.59E-06
Cs-136	6.51E-06	2.57E-05	1.85E-05	0.00E+00	1.43E-05	1.96E-06	2.92E-06
Cs-137	7.97E-05	1.09E-04	7.14E-05	0.00E+00	3.70E-05	1.23E-05	2.11E-06
Cs-138	5.52E-08	1.09E-07	5.40E-08	0.00E+00	8.01E-08	7.91E-09	4.65E-13
Ba-139	9.70E-08	6.91E-11	2.84E-09	0.00E+00	6.46E-11	3.92E-11	1.72E-07
Ba-140	2.03E-05	2.55E-08	1.33E-06	0.00E+00	8.67E-09	1.46E-08	4.18E-05
Ba-141	4.71E-08	3.56E-11	1.59E-09	0.00E+00	3.31E-11	2.02E-11	2.22E-17
Ba-142	2.13E-08	2.19E-11	1.34E-09	0.00E+00	1.85E-11	1.24E-11	3.00E-26
La-140	2.50E-09	1.26E-09	3.33E-10	0.00E+00	0.00E+00	0.00E+00	9.25E-05
La-142	1.28E-10	5.82E-11	1.45E-11	0.00E+00	0.00E+00	0.00E+00	4.25E-07
Ce-141	9.36E-09	6.33E-09	7.18E-10	0.00E+00	2.94E-09	0.00E+00	2.42E-05
Ce-143	1.65E-09	1.22E-06	1.35E-10	0.00E+00	5.37E-10	0.00E+00	4.56E-05
Ce-144	4.88E-07	2.04E-07	2.62E-08	0.00E+00	1.21E-07	0.00E+00	1.65E-04
Pr-143	9.20E-09	3.69E-09	4.56E-10	0.00E+00	2.13E-09	0.00E+00	4.03E-05
Pr-144	3.01E-11	1.25E-11	1.53E-12	0.00E+00	7.05E-12	0.00E+00	4.33E-18
Nd-147	6.29E-09	7.27E-09	4.35E-10	0.00E+00	4.25E-09	0.00E+00	3.49E-05
W-187	1.03E-07	8.61E-08	3.01E-08	0.00E+00	0.00E+00	0.00E+00	2.82E-05
Np-239	1.19E-09	1.17E-10	6.45E-11	0.00E+00	3.65E-10	0.00E+00	2.40E-05

References:

Regulatory Guide 1.109, Table E-11.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November, 1977, Table 4.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.

Table 6.4 (3 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	bone	liver	t body	TEEN thyroid	kidney	lung	gi-11i
H-3	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07	1.06E-07
C-14	4.06E-06	8.12E-07	8.12E-07	8.12E-07	8.12E-07	8.12E-07	8.12E-07
Na-24	2.30E-06	2.30E-06	2.30E-06	2.30E-06	2.30E-06	2.30E-06	2.30E-06
P-32	2.76E-04	1.71E-05	1.07E-05	0.00E+00	0.00E+00	0.00E+00	2.32E-05
Cr-51	0.00E+00	0.00E+00	3.60E-09	2.00E-09	7.89E-10	5.14E-09	6.05E-07
Mn-54	0.00E+00	5.90E-06	1.17E-06	0.00E+00	1.76E-06	0.00E+00	1.21E-05
Mn-56	0.00E+00	1.58E-07	2.81E-08	0.00E+00	2.00E-07	0.00E+00	1.04E-05
Fe-55	3.78E-06	2.68E-06	6.25E-07	0.00E+00	0.00E+00	1.70E-06	1.16E-06
Fe-59	5.87E-06	1.37E-05	5.29E-06	0.00E+00	0.00E+00	4.32E-06	3.24E-05
Co-57	0.00E+00	2.38E-07	3.99E-07	0.00E+00	0.00E+00	0.00E+00	4.44E-06
Co-58	0.00E+00	9.72E-07	2.24E-06	0.00E+00	0.00E+00	0.00E+00	1.34E-05
Co-60	0.00E+00	2.81E-06	6.33E-06	0.00E+00	0.00E+00	0.00E+00	3.66E-05
Ni-63	1.77E-04	1.25E-05	6.00E-06	0.00E+00	0.00E+00	0.00E+00	1.99E-06
Ni-65	7.49E-07	9.57E-08	4.36E-08	0.00E+00	0.00E+00	0.00E+00	5.19E-06
Cu-64	0.00E+00	1.15E-07	5.41E-08	0.00E+00	2.91E-07	0.00E+00	8.92E-06
Zn-65	5.76E-06	2.00E-05	9.33E-06	0.00E+00	1.28E-05	0.00E+00	8.47E-06
Zn-69	1.47E-08	2.80E-08	1.96E-09	0.00E+00	1.83E-08	0.00E+00	5.16E-08
Zn-69m	2.40E-07	5.66E-07	5.19E-08	0.00E+00	3.44E-07	0.00E+00	3.11E-05
Br-82	0.00E+00	0.00E+00	3.04E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	5.74E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	7.22E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	3.05E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	2.98E-05	1.40E-05	0.00E+00	0.00E+00	0.00E+00	4.41E-06
Rb-88	0.00E+00	8.52E-08	4.54E-08	0.00E+00	0.00E+00	0.00E+00	7.30E-15
Rb-89	0.00E+00	5.50E-08	3.89E-08	0.00E+00	0.00E+00	0.00E+00	8.43E-17
Sr-89	4.40E-04	0.00E+00	1.26E-05	0.00E+00	0.00E+00	0.00E+00	5.24E-05
Sr-90	8.30E-03	0.00E+00	2.05E-03	0.00E+00	0.00E+00	0.00E+00	2.33E-04
Sr-91	8.07E-06	0.00E+00	3.21E-07	0.00E+00	0.00E+00	0.00E+00	3.66E-05
Sr-92	3.05E-06	0.00E+00	1.30E-07	0.00E+00	0.00E+00	0.00E+00	7.77E-05
Y-90	1.37E-08	0.00E+00	3.69E-10	0.00E+00	0.00E+00	0.00E+00	1.13E-04
Y-91m	1.29E-10	0.00E+00	4.93E-12	0.00E+00	0.00E+00	0.00E+00	6.09E-09
Y-91	2.01E-07	0.00E+00	5.39E-09	0.00E+00	0.00E+00	0.00E+00	8.24E-05
Y-92	1.21E-09	0.00E+00	3.50E-11	0.00E+00	0.00E+00	0.00E+00	3.32E-05
Y-93	3.83E-09	0.00E+00	1.05E-10	0.00E+00	0.00E+00	0.00E+00	1.17E-04
Zr-95	4.12E-08	1.30E-08	8.94E-09	0.00E+00	1.91E-08	0.00E+00	3.00E-05
Zr-97	2.37E-09	4.69E-10	2.16E-10	0.00E+00	7.11E-10	0.00E+00	1.27E-04
Nb-95	8.22E-09	4.56E-09	2.51E-09	0.00E+00	4.42E-09	0.00E+00	1.95E-05
Nb-97	7.37E-11	1.83E-11	6.68E-12	0.00E+00	2.14E-11	0.00E+00	4.37E-07
Mo-99	0.00E+00	6.03E-06	1.15E-06	0.00E+00	1.38E-05	0.00E+00	1.08E-05
Tc-99m	3.32E-10	9.26E-10	1.20E-08	0.00E+00	1.38E-08	5.14E-10	6.08E-07
Tc-101	3.60E-10	5.12E-10	5.03E-09	0.00E+00	9.26E-09	3.12E-10	8.75E-17
Ru-103	2.55E-07	0.00E+00	1.09E-07	0.00E+00	8.99E-07	0.00E+00	2.13E-05
Ru-105	2.18E-08	0.00E+00	8.46E-09	0.00E+00	2.75E-07	0.00E+00	1.76E-05
Ru-106	3.92E-06	0.00E+00	4.94E-07	0.00E+00	7.56E-06	0.00E+00	1.88E-04
Ag-110m	2.05E-07	1.94E-07	1.18E-07	0.00E+00	3.70E-07	0.00E+00	5.45E-05

Table 6.4 (4 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	TEEN						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
Sb-124	3.87E-06	7.13E-08	1.51E-06	8.78E-09	0.00E-00	3.38E-06	7.80E-05
Sb-125	2.48E-06	2.71E-08	5.80E-07	2.37E-09	0.00E+00	2.18E-06	1.93E-05
Te-125m	3.83E-06	1.38E-06	5.12E-07	1.07E-06	0.00E+00	0.00E+00	1.13E-05
Te-127m	9.67E-06	3.43E-06	1.15E-06	2.30E-06	3.92E-05	0.00E+00	2.41E-05
Te-127	1.58E-07	5.60E-08	3.40E-08	1.09E-07	6.40E-07	0.00E+00	1.22E-05
Te-129m	1.63E-05	6.05E-06	2.58E-06	5.26E-06	6.82E-05	0.00E+00	6.12E-05
Te-129	4.48E-08	1.67E-08	1.09E-08	3.20E-08	1.88E-07	0.00E+00	2.45E-07
Te-131m	2.44E-06	1.17E-06	9.76E-07	1.76E-06	1.22E-05	0.00E+00	9.39E-05
Te-131	2.79E-08	1.15E-08	8.72E-09	2.15E-08	1.22E-07	0.00E+00	2.29E-09
Te-132	3.49E-06	2.21E-06	2.08E-06	2.33E-06	2.12E-05	0.00E+00	7.00E-05
I-130	1.03E-06	2.98E-06	1.19E-06	2.43E-04	4.59E-06	0.00E+00	2.29E-06
I-131	5.85E-06	8.19E-06	4.40E-06	2.39E-03	1.41E-05	0.00E+00	1.62E-06
I-132	2.79E-07	7.30E-07	2.62E-07	2.46E-05	1.15E-06	0.00E+00	3.18E-07
I-133	2.01E-06	3.41E-06	1.04E-06	4.76E-04	5.98E-06	0.00E+00	2.58E-06
I-134	1.46E-07	3.87E-07	1.39E-07	6.45E-06	6.10E-07	0.00E+00	5.10E-09
I-135	6.10E-07	1.57E-06	5.82E-07	1.01E-04	2.48E-06	0.00E+00	1.74E-06
Cs-134	8.37E-05	1.97E-04	9.14E-05	0.00E+00	6.26E-05	2.39E-05	2.45E-06
Cs-136	8.59E-06	3.38E-05	2.27E-05	0.00E+00	1.84E-05	2.90E-06	2.72E-06
Cs-137	1.12E-04	1.49E-04	5.19E-05	0.00E+00	5.07E-05	1.97E-05	2.12E-06
Cs-138	7.76E-08	1.49E-07	7.45E-08	0.00E+00	1.10E-07	1.28E-08	6.76E-11
Ba-139	1.39E-07	9.78E-11	4.05E-09	0.00E+00	9.22E-11	6.74E-11	1.24E-06
Ba-140	2.84E-05	3.48E-08	1.83E-06	0.00E+00	1.18E-08	2.34E-08	4.38E-05
Ba-141	6.71E-08	5.01E-11	2.24E-09	0.00E+00	4.65E-11	3.43E-11	1.43E-13
Ba-142	2.99E-08	2.99E-11	1.84E-09	0.00E+00	2.53E-11	1.99E-11	9.18E-20
La-140	3.48E-09	1.71E-09	4.55E-10	0.00E+00	0.00E+00	0.00E+00	9.82E-05
La-142	1.79E-10	7.95E-11	1.98E-11	0.00E+00	0.00E+00	0.00E+00	2.42E-06
Ce-141	1.33E-08	8.88E-09	1.02E-09	0.00E+00	4.18E-09	0.00E+00	2.54E-05
Ce-143	2.35E-09	1.71E-06	1.91E-10	0.00E+00	7.67E-10	0.00E+00	5.14E-05
Ce-144	6.96E-07	2.88E-07	3.74E-08	0.00E+00	1.72E-07	0.00E+00	1.75E-04
Pr-143	1.31E-08	5.23E-09	6.52E-10	0.00E+00	3.04E-09	0.00E+00	4.31E-05
Pr-144	4.30E-11	1.76E-11	2.18E-12	0.00E+00	1.01E-11	0.00E+00	4.74E-14
Nd-147	9.38E-09	1.02E-08	6.11E-10	0.00E+00	5.99E-09	0.00E+00	3.68E-05
W-187	1.46E-07	1.19E-07	4.17E-08	0.00E+00	0.00E+00	0.00E+00	3.22E-05
Np-239	1.76E-09	1.66E-10	9.22E-11	0.00E+00	5.21E-10	0.00E+00	2.67E-05

References:

Regulatory Guide 1.109, Table E-12.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November, 1977, Table 3.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.



Table 6.4 (5 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	CHILD						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
H-3	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07	2.03E-07
C-14	1.21E-05	2.42E-06	2.42E-06	2.42E-06	2.42E-06	2.42E-06	2.42E-06
Na-24	5.80E-06	5.80E-06	5.80E-06	5.80E-06	5.80E-06	5.80E-06	5.80E-06
P-32	8.25E-04	3.86E-05	3.18E-05	0.00E+00	0.00E+00	0.00E+00	2.28E-05
Cr-51	0.00E+00	0.00E+00	8.90E-09	4.94E-09	1.35E-09	9.02E-09	4.72E-07
Mn-54	0.00E+00	1.07E-05	2.85E-06	0.00E+00	3.00E-06	0.00E+00	8.98E-06
Mn-56	0.00E+00	3.34E-07	7.54E-08	0.00E+00	4.04E-07	0.00E+00	4.84E-05
Fe-55	1.15E-05	6.10E-06	1.89E-06	0.00E+00	0.00E+00	3.45E-06	1.13E-06
Fe-59	1.65E-05	2.67E-05	1.33E-05	0.00E+00	0.00E+00	7.74E-06	2.78E-05
Co-57	0.00E+00	4.93E-07	9.98E-07	0.00E+00	0.00E+00	0.00E+00	4.04E-06
Co-58	0.00E+00	1.80E-06	5.51E-06	0.00E+00	0.00E+00	0.00E+00	1.05E-05
Co-60	0.00E+00	5.29E-06	1.56E-05	0.00E+00	0.00E+00	0.00E+00	2.93E-05
Ni-63	5.38E-04	2.88E-05	1.83E-05	0.00E+00	0.00E+00	0.00E+00	1.94E-06
Ni-65	2.22E-06	2.09E-07	1.22E-07	0.00E+00	0.00E+00	0.00E+00	2.56E-05
Cu-64	0.00E+00	2.45E-07	1.48E-07	0.00E+00	5.92E-07	0.00E+00	1.15E-05
Zn-65	1.37E-05	3.65E-05	2.27E-05	0.00E+00	2.30E-05	0.00E+00	6.41E-06
Zn-69	4.38E-08	6.33E-08	5.85E-09	0.00E+00	3.84E-08	0.00E+00	3.99E-06
Zn-69m	7.10E-07	1.21E-06	1.43E-07	0.00E+00	7.03E-07	0.00E+00	3.94E-05
Br-82	0.00E+00	0.00E+00	7.55E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	1.71E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	1.98E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	9.12E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	6.70E-05	4.12E-05	0.00E+00	0.00E+00	0.00E+00	4.31E-06
Rb-88	0.00E+00	1.90E-07	1.32E-07	0.00E+00	0.00E+00	0.00E+00	9.32E-09
Rb-89	0.00E+00	1.17E-07	1.04E-07	0.00E+00	0.00E+00	0.00E+00	1.02E-09
Sr-89	1.32E-03	0.00E+00	3.77E-05	0.00E+00	0.00E+00	0.00E+00	5.11E-05
Sr-90	1.70E-02	0.00E+00	4.31E-03	0.00E+00	0.00E+00	0.00E+00	2.29E-04
Sr-91	2.40E-05	0.00E+00	9.06E-07	0.00E+00	0.00E+00	0.00E+00	5.30E-05
Sr-92	9.03E-06	0.00E+00	3.62E-07	0.00E+00	0.00E+00	0.00E+00	1.71E-04
Y-90	4.11E-08	0.00E+00	1.10E-09	0.00E+00	0.00E+00	0.00E+00	1.17E-04
Y-91m	3.82E-10	0.00E+00	1.39E-11	0.00E+00	0.00E+00	0.00E+00	7.48E-07
Y-91	6.02E-07	0.00E+00	1.61E-08	0.00E+00	0.00E+00	0.00E+00	8.02E-05
Y-92	3.60E-09	0.00E+00	1.03E-10	0.00E+00	0.00E+00	0.00E+00	1.04E-04
Y-93	1.14E-08	0.00E+00	3.13E-10	0.00E+00	0.00E+00	0.00E+00	1.70E-04
Zr-95	1.16E-07	2.55E-08	2.27E-08	0.00E+00	3.65E-08	0.00E+00	2.66E-05
Zr-97	6.99E-09	1.01E-09	5.96E-10	0.00E+00	1.45E-09	0.00E+00	1.53E-04
Nb-95	2.25E-08	8.76E-09	6.26E-09	0.00E+00	8.23E-09	0.00E+00	1.62E-05
Nb-97	2.17E-10	3.92E-11	1.83E-11	0.00E+00	4.35E-11	0.00E+00	1.21E-05
Mo-99	0.00E+00	1.33E-05	3.29E-06	0.00E+00	2.84E-05	0.00E+00	1.10E-05
Tc-99m	9.23E-10	1.81E-09	3.00E-08	0.00E+00	2.63E-08	9.19E-10	1.03E-06
Tc-101	1.07E-09	1.12E-09	1.42E-08	0.00E+00	1.91E-08	5.92E-10	3.56E-09
Ru-103	7.31E-07	0.00E+00	2.81E-07	0.00E+00	1.84E-06	0.00E+00	1.89E-05
Ru-105	6.45E-08	0.00E+00	2.34E-08	0.00E+00	5.67E-07	0.00E+00	4.21E-05
Ru-106	1.17E-05	0.00E+00	1.46E-06	0.00E+00	1.58E-05	0.00E+00	1.82E-04
Ag-110m	5.39E-07	3.64E-07	2.91E-07	0.00E+00	6.78E-07	0.00E+00	4.33E-05

Table 6.4 (6 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	CHILD						
	bone	liver	t body	thyroid	kidney	lung	gi-11i
Sb-124	1.11E-05	1.44E-07	3.89E-06	2.45E-08	0.00E+00	6.16E-06	6.94E-05
Sb-125	7.16E-06	5.52E-08	1.50E-06	6.63E-09	0.00E+00	3.99E-06	1.71E-05
Te-125m	1.14E-05	3.09E-06	1.52E-06	3.20E-06	0.00E+00	0.00E+00	1.10E-05
Te-127m	2.89E-05	7.78E-06	3.43E-06	6.91E-06	8.24E-05	0.00E+00	2.34E-05
Te-127	4.71E-07	1.27E-07	1.01E-07	3.26E-07	1.34E-06	0.00E+00	1.84E-05
Te-129m	4.87E-05	1.36E-05	7.56E-06	1.57E-05	1.43E-04	0.00E+00	5.94E-05
Te-129	1.34E-07	3.74E-08	3.18E-08	9.56E-08	3.92E-07	0.00E+00	8.34E-06
Te-131m	7.20E-06	2.49E-06	2.65E-06	5.12E-06	2.41E-05	0.00E+00	1.01E-04
Te-131	8.30E-08	2.53E-08	2.47E-08	6.35E-08	2.51E-07	0.00E+00	4.36E-07
Te-132	1.01E-05	4.47E-06	5.40E-06	6.51E-06	4.15E-05	0.00E+00	4.50E-05
I-130	2.92E-06	5.90E-06	3.04E-06	6.50E-04	8.82E-06	0.00E+00	2.76E-06
I-131	1.72E-05	1.73E-05	9.83E-06	5.72E-03	2.84E-05	0.00E+00	1.54E-06
I-132	8.00E-07	1.47E-06	6.76E-07	6.82E-05	2.25E-06	0.00E+00	1.73E-06
I-133	5.92E-06	7.32E-06	2.77E-06	1.36E-03	1.22E-05	0.00E+00	2.95E-06
I-134	4.19E-07	7.78E-07	3.58E-07	1.79E-05	1.19E-06	0.00E+00	5.16E-07
I-135	1.75E-06	3.15E-06	1.49E-06	2.79E-04	4.83E-06	0.00E+00	2.40E-06
Cs-134	2.34E-04	3.84E-04	8.10E-05	0.00E+00	1.19E-04	4.27E-05	2.07E-06
Cs-136	2.35E-05	6.46E-05	4.18E-05	0.00E+00	3.44E-05	5.13E-06	2.27E-06
Cs-137	3.27E-04	3.13E-04	4.62E-05	0.00E+00	1.02E-04	3.67E-05	1.96E-06
Cs-138	2.28E-07	3.17E-07	2.01E-07	0.00E+00	2.23E-07	2.40E-08	1.46E-07
Ba-139	4.14E-07	2.21E-10	1.20E-08	0.00E+00	1.93E-10	1.30E-10	2.39E-05
Ba-140	8.31E-05	7.28E-08	4.85E-06	0.00E+00	2.37E-08	4.34E-08	4.21E-05
Ba-141	2.00E-07	1.12E-10	6.51E-09	0.00E+00	9.69E-11	6.58E-10	1.14E-07
Ba-142	8.74E-08	6.29E-11	4.88E-09	0.00E+00	5.09E-11	3.70E-11	1.14E-09
La-140	1.01E-08	3.53E-09	1.19E-09	0.00E+00	0.00E+00	0.00E+00	9.84E-05
La-142	5.24E-10	1.67E-10	5.23E-11	0.00E+00	0.00E+00	0.00E+00	3.31E-05
Ce-141	3.97E-08	1.98E-08	2.94E-09	0.00E+00	8.68E-09	0.00E+00	2.47E-05
Ce-143	6.99E-09	3.79E-06	5.49E-10	0.00E+00	1.59E-09	0.00E+00	5.55E-05
Ce-144	2.08E-06	6.52E-07	1.11E-07	0.00E+00	3.61E-07	0.00E+00	1.70E-04
Pr-143	3.93E-08	1.18E-08	1.95E-09	0.00E+00	6.39E-09	0.00E+00	4.24E-05
Pr-144	1.29E-10	3.99E-11	6.49E-12	0.00E+00	2.11E-11	0.00E+00	8.59E-08
Nd-147	2.79E-08	2.26E-08	1.75E-09	0.00E+00	1.24E-08	0.00E+00	3.58E-05
W-187	4.29E-07	2.54E-07	1.14E-07	0.00E+00	0.00E+00	0.00E+00	3.57E-05
Np-239	5.25E-09	3.77E-10	2.65E-10	0.00E+00	1.09E-09	0.00E+00	2.79E-05

References:

Regulatory Guide 1.109, Table E-13.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November, 1977, Table 2.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.

Table 6.4 (7 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	INFANT						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
H-3	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07	3.08E-07
C-14	2.37E-05	5.06E-06	5.06E-06	5.06E-06	5.06E-06	5.06E-06	5.06E-06
Na-24	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05	1.01E-05
P-32	1.70E-03	1.00E-04	6.59E-05	0.00E+00	0.00E+00	0.00E+00	2.30E-05
Cr-51	0.00E+00	0.00E+00	1.41E-08	9.20E-09	2.01E-09	1.79E-08	4.11E-07
Mn-54	0.00E+00	1.99E-05	4.51E-06	0.00E+00	4.41E-06	0.00E+00	7.31E-06
Mn-56	0.00E+00	8.18E-07	1.41E-07	0.00E+00	7.03E-07	0.00E+00	7.43E-05
Fe-55	1.39E-05	8.98E-06	2.40E-06	0.00E+00	0.00E+00	4.39E-06	1.14E-06
Fe-59	3.08E-05	5.38E-05	2.12E-05	0.00E+00	0.00E+00	1.59E-05	2.57E-05
Co-57	0.00E+00	1.15E-06	1.87E-06	0.00E+00	0.00E+00	0.00E+00	3.92E-06
Co-58	0.00E+00	3.60E-06	8.98E-06	0.00E+00	0.00E+00	0.00E+00	8.97E-06
Co-60	0.00E+00	1.08E-05	2.55E-05	0.00E+00	0.00E+00	0.00E+00	2.57E-05
Ni-63	6.34E-04	3.92E-05	2.20E-05	0.00E+00	0.00E+00	0.00E+00	1.95E-06
Ni-65	4.70E-06	5.32E-07	2.42E-07	0.00E+00	0.00E+00	0.00E+00	4.05E-05
Cu-64	0.00E+00	6.09E-07	2.82E-07	0.00E+00	1.03E-06	0.00E+00	1.25E-05
Zn-65	1.84E-05	6.31E-05	2.91E-05	0.00E+00	3.06E-05	0.00E+00	5.33E-05
Zn-69	9.33E-08	1.68E-07	1.25E-08	0.00E+00	6.98E-08	0.00E+00	1.37E-05
Zn-69m	1.50E-06	3.06E-06	2.79E-07	0.00E+00	1.24E-06	0.00E+00	4.24E-05
Br-82	0.00E+00	0.00E+00	1.27E-05	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	3.63E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	3.82E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	1.94E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	1.70E-04	8.40E-05	0.00E+00	0.00E+00	0.00E+00	4.35E-06
Rb-88	0.00E+00	4.98E-07	2.73E-07	0.00E+00	0.00E+00	0.00E+00	4.85E-07
Rb-89	0.00E+00	2.86E-07	1.97E-07	0.00E+00	0.00E+00	0.00E+00	9.74E-08
Sr-89	2.51E-03	0.00E+00	7.20E-05	0.00E+00	0.00E+00	0.00E+00	5.16E-05
Sr-90	1.85E-02	0.00E+00	4.71E-03	0.00E+00	0.00E+00	0.00E+00	2.31E-04
Sr-91	5.00E-05	0.00E+00	1.81E-06	0.00E+00	0.00E+00	0.00E+00	5.92E-05
Sr-92	1.92E-05	0.00E+00	7.13E-07	0.00E+00	0.00E+00	0.00E+00	2.07E-04
Y-90	8.69E-08	0.00E+00	2.33E-09	0.00E+00	0.00E+00	0.00E+00	1.20E-04
Y-91m	8.10E-10	0.00E+00	2.76E-11	0.00E+00	0.00E+00	0.00E+00	2.70E-06
Y-91	1.13E-06	0.00E+00	3.01E-08	0.00E+00	0.00E+00	0.00E+00	8.10E-05
Y-92	7.65E-09	0.00E+00	2.15E-10	0.00E+00	0.00E+00	0.00E+00	1.46E-04
Y-93	2.43E-08	0.00E+00	6.62E-10	0.00E+00	0.00E+00	0.00E+00	1.92E-04
Zr-95	2.06E-07	5.02E-08	3.56E-08	0.00E+00	5.41E-08	0.00E+00	2.50E-05
Zr-97	1.48E-08	2.54E-09	1.16E-09	0.00E+00	2.56E-09	0.00E+00	1.62E-04
Nb-95	4.20E-08	1.73E-08	1.00E-08	0.00E+00	1.24E-08	0.00E+00	1.46E-05
Nb-97	4.59E-10	9.79E-11	3.53E-11	0.00E+00	7.65E-11	0.00E+00	3.09E-05
Mo-99	0.00E+00	3.40E-05	6.63E-06	0.00E+00	5.08E-05	0.00E+00	1.12E-05
Tc-99m	1.92E-09	3.96E-09	5.10E-08	0.00E+00	4.26E-08	2.07E-09	1.15E-06
Tc-101	2.27E-09	2.86E-09	2.83E-08	0.00E+00	3.40E-08	1.56E-09	4.86E-07
Ru-103	1.48E-06	0.00E+00	4.95E-07	0.00E+00	3.08E-06	0.00E+00	1.80E-05
Ru-105	1.36E-07	0.00E+00	4.58E-08	0.00E+00	1.00E-06	0.00E+00	5.41E-05
Ru-106	2.41E-05	0.00E+00	3.01E-06	0.00E+00	2.85E-05	0.00E+00	1.83E-04
Ag-110m	9.96E-07	7.27E-07	4.81E-07	0.00E+00	1.04E-06	0.00E+00	3.77E-05



Table 6.4 (8 of 8)
INGESTION DOSE FACTORS
(mrem/pCi ingested)

	INFANT						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
Sb-124	2.14E-05	3.15E-07	6.63E-06	5.68E-08	0.00E+00	1.34E-05	6.60E-05
Sb-125	1.23E-05	1.19E-07	2.53E-06	1.54E-08	0.00E+00	7.72E-06	1.64E-05
Te-125m	2.33E-05	7.79E-06	3.15E-06	7.84E-06	0.00E+00	0.00E+00	1.11E-05
Te-127m	5.85E-05	1.94E-05	7.08E-06	1.69E-05	1.44E-04	0.00E+00	2.36E-05
Te-127	1.00E-06	3.35E-07	2.15E-07	8.14E-07	2.44E-06	0.00E+00	2.10E-05
Te-129m	1.00E-04	3.43E-05	1.54E-05	3.84E-05	2.50E-04	0.00E+00	5.97E-05
Te-129	2.84E-07	9.79E-08	6.63E-08	2.38E-07	7.07E-07	0.00E+00	2.27E-05
Te-131m	1.52E-05	6.12E-06	5.05E-06	1.24E-05	4.21E-05	0.00E+00	1.03E-04
Te-131	1.76E-07	6.50E-08	4.94E-08	1.57E-07	4.50E-07	0.00E+00	7.11E-06
Te-132	2.08E-05	1.03E-05	9.61E-06	1.52E-05	6.44E-05	0.00E+00	3.81E-05
I-130	6.00E-06	1.32E-05	5.30E-06	1.48E-03	1.45E-05	0.00E+00	2.83E-06
I-131	3.59E-05	4.23E-05	1.86E-05	1.39E-02	4.94E-05	0.00E+00	1.51E-06
I-132	1.66E-06	3.37E-06	1.20E-06	1.58E-04	3.76E-06	0.00E+00	2.73E-06
I-133	1.25E-05	1.82E-05	5.33E-06	3.31E-03	2.14E-05	0.00E+00	3.08E-06
I-134	8.69E-07	1.78E-06	6.33E-07	4.15E-05	1.99E-06	0.00E+00	1.84E-06
I-135	3.64E-06	7.24E-06	2.64E-06	6.49E-04	8.07E-06	0.00E+00	2.62E-06
Cs-134	3.77E-04	7.03E-04	7.10E-05	0.00E+00	1.81E-04	7.42E-05	1.91E-06
Cs-136	4.59E-05	1.35E-04	5.04E-05	0.00E+00	5.38E-05	1.10E-05	2.05E-06
Cs-137	5.22E-04	6.11E-04	4.33E-05	0.00E+00	1.64E-04	6.64E-05	1.91E-06
Cs-138	4.81E-07	7.82E-07	3.79E-07	0.00E+00	3.90E-07	6.09E-08	1.25E-06
Ba-139	8.81E-07	5.84E-10	2.55E-08	0.00E+00	3.51E-10	3.54E-10	5.58E-05
Ba-140	1.71E-04	1.71E-07	8.81E-06	0.00E+00	4.06E-08	1.05E-07	4.20E-05
Ba-141	4.25E-07	2.91E-10	1.34E-08	0.00E+00	1.75E-10	1.77E-10	5.19E-06
Ba-142	1.84E-07	1.53E-10	9.06E-09	0.00E+00	8.81E-11	9.26E-11	7.59E-07
La-140	2.11E-08	8.32E-09	2.14E-09	0.00E+00	0.00E+00	0.00E+00	9.77E-05
La-142	1.10E-09	4.04E-10	9.67E-11	0.00E+00	0.00E+00	0.00E+00	6.86E-05
Ce-141	7.87E-08	4.80E-08	5.65E-09	0.00E+00	1.48E-08	0.00E+00	2.48E-05
Ce-143	1.48E-08	9.82E-06	1.12E-09	0.00E+00	2.86E-09	0.00E+00	5.73E-05
Ce-144	2.98E-06	1.22E-06	1.67E-07	0.00E+00	4.93E-07	0.00E+00	1.71E-04
Pr-143	8.13E-08	3.04E-08	4.03E-09	0.00E+00	1.13E-08	0.00E+00	4.29E-05
Pr-144	2.74E-10	1.06E-10	1.38E-11	0.00E+00	3.84E-11	0.00E+00	4.93E-06
Nd-147	5.53E-08	5.68E-08	3.48E-09	0.00E+00	2.19E-08	0.00E+00	3.60E-05
W-187	9.03E-07	6.28E-07	2.17E-07	0.00E+00	0.00E+00	0.00E+00	3.69E-05
Np-239	1.11E-08	9.93E-10	5.61E-10	0.00E+00	1.98E-09	0.00E+00	*2.87E-05

References:

Regulatory Guide 1.109, Table E-14.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November, 1977, Table 1.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.

Table 6.5
BIOACCUMULATION FACTORS FOR FRESHWATER FISH

H-3	9.0E-01	Tc-99m	1.5E+01
C-14	4.6E+03	Tc-101	1.5E+01
Na-24	1.0E+02	Ru-103	1.0E+01
P-32	1.0E+05	Ru-105	1.0E+01
Cr-51	2.0E+02	Ru-106	1.0E+01
Mn-54	4.0E+02	Ag-110m	0.0E+00
Mn-56	4.0E+02	Sb-124	1.0E+00
Fe-55	1.0E+02	Sb-125	1.0E+00
Fe-59	1.0E+02	Te-125m	4.0E+02
Co-57	5.0E+01	Te-127m	4.0E+02
Co-58	5.0E+01	Te-127	4.0E+02
Co-60	5.0E+01	Te-129m	4.0E+02
Ni-63	1.0E+02	Te-129	4.0E+02
Ni-65	1.0E+02	Te-131m	4.0E+02
Cu-64	5.0E+01	Te-131	4.0E+02
Zn-65	2.0E+03	Te-132	4.0E+02
Zn-69	2.0E+03	I-130	4.0E+01
Zn-69m	2.0E+03	I-131	4.0E+01
Br-82	4.2E+02	I-132	4.0E+01
Br-83	4.2E+02	I-133	4.0E+01
Br-84	4.2E+02	I-134	4.0E+01
Br-85	4.2E+02	I-135	4.0E+01
Rb-86	2.0E+03	Cs-134	1.9E+03
Rb-88	2.0E+03	Cs-136	1.9E+03
Rb-89	2.0E+03	Cs-137	1.9E+03
Sr-89	5.6E+01	Cs-138	1.9E+03
Sr-90	5.6E+01	Ba-139	4.0E+00
Sr-91	5.6E+01	Ba-140	4.0E+00
Sr-92	5.6E+01	Ba-141	4.0E+00
Y-90	2.5E+01	Ba-142	4.0E+00
Y-91m	2.5E+01	La-140	2.5E+01
Y-91	2.5E+01	La-142	2.5E+01
Y-92	2.5E+01	Ce-141	1.0E+00
Y-93	2.5E+01	Ce-143	1.0E+00
Zr-95	3.3E+00	Ce-144	1.0E+00
Zr-97	3.3E+00	Pr-143	2.5E+01
Nb-95	3.0E+04	Pr-144	2.5E+01
Nb-97	3.0E+04	Nd-147	2.5E+01
Mo-99	1.0E+01	W-187	1.2E+03
		Np-239	1.0E+01

References:

Bioaccumulation factors for Antimony nuclides are from ORNL-4992, "A Methodology for Calculating Radiation Doses from Radioactivity Released to the Environment, March 1976, Table 4.12A.

Bioaccumulation factors for Iodine, Cesium, and Strontium nuclides are from NUREG/CR-1004, Table 3.2.4.

All other nuclides' bioaccumulation factors are from Regulatory Guide 1.109, Table A-1.

Table 6.6 (1 of 2)
EXTERNAL DOSE FACTORS FOR STANDING ON CONTAMINATED GROUND
(mrem/h per pCi/m²)

Nuclide	Total Body	Skin
H-3	0.0	0.0
C-14	0.0	0.0
Na-24	2.50E-08	2.90E-08
P-32	0.0	0.0
Cr-51	2.20E-10	2.60E-10
Mn-54	5.80E-09	6.80E-09
Mn-56	1.10E-08	1.30E-08
Fe-55	0.0	0.0
Fe-59	8.00E-09	9.40E-09
Co-57	1.77E-09	2.21E-09
Co-58	7.00E-09	8.20E-09
Co-60	1.70E-08	2.00E-08
Ni-63	0.0	0.0
Ni-65	3.70E-09	4.30E-09
Cu-64	1.50E-09	1.70E-09
Zn-65	4.00E-09	4.60E-09
Zn-69	0.0	0.0
Zn-69m	5.50E-09	6.59E-09
Br-82	3.18E-08	3.90E-08
Br-83	6.40E-11	9.30E-11
Br-84	1.20E-08	1.40E-08
Br-85	0.0	0.0
Rb-86	6.30E-10	7.20E-10
Rb-88	3.50E-09	4.00E-09
Rb-89	1.50E-08	1.80E-08
Sr-89	5.60E-13	6.50E-13
Sr-91	7.10E-09	8.30E-09
Sr-92	9.00E-09	1.00E-08
Y-90	2.20E-12	2.60E-12
Y-91m	3.80E-09	4.40E-09
Y-91	2.40E-11	2.70E-11
Y-92	1.60E-09	1.90E-09
Y-93	5.70E-10	7.80E-10
Zr-95	5.00E-09	5.80E-09
Zr-97	5.50E-09	6.40E-09
Nb-95	5.10E-09	6.00E-09
Nb-97	8.11E-09	1.00E-08
Mo-99	1.90E-09	2.20E-09
Tc-99m	9.60E-10	1.10E-09
Tc-101	2.70E-09	3.00E-09
Ru-103	3.60E-09	4.20E-09
Ru-105	4.50E-09	5.10E-09
Ru-106	1.50E-09	1.80E-09
Ag-110m	1.80E-08	2.10E-08
Sb-124	2.17E-08	2.57E-08

Table 6.6 (2 of 2)
EXTERNAL DOSE FACTORS FOR STANDING ON CONTAMINATED GROUND
(mrem/h per pCi/m²)

Nuclide	Total Body	Skin
Sb-125	5.48E-09	6.80E-09
Te-125m	3.50E-11	4.80E-11
Te-127m	1.10E-12	1.30E-12
Te-127	1.00E-11	1.10E-11
Te-129m	7.70E-10	9.00E-10
Te-129	7.10E-10	8.40E-10
Te-131m	8.40E-09	9.90E-09
Te-131	2.20E-09	2.60E-06
Te-132	1.70E-09	2.00E-09
I-130	1.40E-08	1.70E-08
I-131	2.80E-09	3.40E-09
I-132	1.70E-08	2.00E-08
I-133	3.70E-09	4.50E-09
I-134	1.60E-08	1.90E-08
I-135	1.20E-08	1.40E-08
Cs-134	1.20E-08	1.40E-08
Cs-136	1.50E-08	1.70E-08
Cs-137	4.20E-09	4.90E-09
Cs-138	2.10E-08	2.40E-08
Ba-139	2.40E-09	2.70E-09
Ba-140	2.10E-09	2.40E-09
Ba-141	4.30E-09	4.90E-09
Ba-142	7.90E-09	9.00E-09
La-140	1.50E-08	1.70E-08
La-142	1.50E-08	1.80E-08
Ce-141	5.50E-10	6.20E-10
Ce-143	2.20E-09	2.50E-09
Ce-144	3.20E-10	3.70E-10
Pr-143	0.0	0.0
Pr-144	2.00E-10	2.30E-10
Nd-147	1.00E-09	1.20E-09
W-187	3.10E-09	3.60E-09
Np-239	9.50E-10	1.10E-09

References:

Regulatory Guide 1.109, Table E-6.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from Dose-Rate Conversion Factors for External Exposure to Photon and Electron Radiation from Radionuclides Occurring in Routine Releases from Nuclear Fuel Cycle Facilities, D. C. Kocher, Health Physics Volume 38, April 1980.



Figure 6.1
 LIQUID RELEASE POINTS

BFN Liquid Effluent Monitors
 (Typical Unit and Common Radwaste)







Figure 6.2
LIQUID RADWASTE SYSTEM



7.0 GASEOUS EFFLUENTS

RELEASE POINTS DESCRIPTION

There are eleven monitored discharge points at BFN: a Reactor Building exhaust for each unit, the Radwaste Building Exhaust, two sets of Turbine Deck Roof Fans for each unit, and the Stack. The Reactor and Radwaste Exhausts exit the plant on the roof of the reactor building.

The Reactor Building Exhausts include exhaust from the refuel floor of the reactor buildings, exhaust from the Primary Containment Purge System, and exhaust from the turbine buildings. These discharge points are monitored by radiation monitors 1-,2-,3-RM-90-250.

The Radwaste Building Exhaust includes exhaust from the common radwaste building. This discharge point is monitored by radiation monitor RM-90-252.

There are nine roof fans on the roof of each unit's turbine building to provide building ventilation. These are generally used in the warmer months to control building temperature. For each unit, there are two radiation monitors. One of these monitors the exhaust through four of the fans (1-,2-RM-90-249 and 3-RM-90-251). The other monitors the exhaust through the remaining five fans (1-,2-RM-90-251 and 3-RM-90-249).

The common 600 foot plant stack receives the Condenser Offgas exhaust, the Filter Cubicle exhaust, the Steam Packing and Mechanical Vacuum exhaust, and the Standby Gas Treatment System (SBGTS) exhaust. The stack effluents are monitored by radiation monitors RM-90-147 and 148.

Figures 7.1 and 7.2 show the Offgas System, the Standby Gas Treatment System and normal building ventilation with effluent monitor locations.



7.1 RELEASE RATE LIMIT METHODOLOGY

A dose rate (D_{TB} , D_S , or D_{TH}) is calculated based on the design objective source term mix used in the licensing of the plant. Dose rates are determined for (1) noble gases and (2) iodines and particulates as described below.

Total Body Dose Rate

The dose rate to the total body from nuclide i , D_{TBi} in mrem/year, is calculated using the following equation:

$$D_{TBi} = (X/Q) Q_i DF_{Bi}$$

where

- X/Q = relative concentration, s/m^3 . Relative air concentrations are calculated for the land-site boundary in each of the sixteen sectors as described in Section 7.9.2 using the historical meteorological data for the period 1977-1979 given in Table 7.3.
- Q_i = release rate of noble gas nuclide i , $\mu Ci/sec$.
- DF_{Bi} = total body dose factor due to gamma radiation for noble gas nuclide i , mrem/y per $\mu Ci/m^3$ (Table 7.4).

Skin Dose Rate

The dose rate to the skin for nuclide i , D_{Si} in mrem/year, is calculated using the following equation:

$$D_{Si} = (X/Q) Q_i (DF_{Si} + 1.11 DF_{Yi})$$

where

- X/Q = relative concentration, s/m^3 . Relative air concentrations are calculated for the land-site boundary in each of the sixteen sectors as described in Section 7.9.2 using the historical meteorological data for the period 1977-1979 given in Table 7.3.
- Q_i = release rate of noble gas nuclide i , $\mu Ci/sec$.
- DF_{Si} = skin dose factor due to beta radiation for noble gas nuclide i , mrem/y per $\mu Ci/m^3$ (Table 7.4).
- 1.11 = the average ratio of tissue to air energy absorption coefficients, mrem/mrad.
- DF_{Yi} = dose conversion factor for external gamma for noble gas nuclide i , mrad/year per $\mu Ci/m^3$ (Table 7.4).

Organ Dose Rate due to I-131, I-133, Tritium, and All Radionuclides in Particulate Form with Half-lives of Greater Than 8 Days

Organ dose rates are calculated for all age groups (adult, teen, child, and infant) and all organs (bone, liver, total body, thyroid, kidney, lung, and GI Tract) using the following equation:

For tritium,

$$D_{\text{org}} = Q_T(X/Q) [R_{\text{IT}} + R_{\text{CTP}}]$$

For all other particulates,

$$D_{\text{org}} = Q_i[(X/Q)R_{\text{Ii}} + (D/Q) [R_{\text{CPI}}+R_{\text{GI}}]]$$

where

- Q_T = release rate of tritium in, $\mu\text{Ci}/\text{sec}$.
 X/Q = relative concentration, s/m^3 . Relative air concentrations are calculated for the land-site boundary in each of the sixteen sectors as described in Section 7.9.2 using the historical meteorological data for the period 1977-1979 given in Table 7.3.
 R_{IT} = inhalation dose factor for tritium, mrem/year per $\mu\text{Ci}/\text{m}^3$. Dose factor is calculated as described in Section 7.8.13.
 R_{CTP} = Grass-cow-milk dose factor for tritium, mrem/year per $\mu\text{Ci}/\text{m}^3$. Dose factor is calculated as described in Section 7.8.7.
 Q_i = release rate of nuclide i , $\mu\text{Ci}/\text{sec}$.
 R_{Ii} = inhalation dose factor for each identified nuclide i , mrem/year per $\mu\text{Ci}/\text{m}^3$. Dose factors are calculated as described in Section 7.8.13.
 D/Q = relative deposition, $1/\text{m}^2$. Relative deposition is calculated for the land-site boundary in each of the sixteen sectors as described in Section 7.9.3 using the historical meteorological data for the period 1977-1979 given in Table 7.3.
 R_{CPI} = Grass-cow-milk dose factor for each identified nuclide i , $\text{m}^2\text{-mrem}/\text{year}$ per $\mu\text{Ci}/\text{s}$. Dose factors are calculated as described in Section 7.8.1.
 R_{GI} = ground plane dose factor for each identified nuclide i , $\text{m}^2\text{-mrem}/\text{year}$ per $\mu\text{Ci}/\text{s}$. Dose factors are calculated as described in Section 7.8.14.

The dose rate limits of interest are:

Total Body = 500 mrem/yr
Skin = 3000 mrem/yr
Maximum Organ = 1500 mrem/yr

These limits are divided by the corresponding calculated dose rates described above:

$$R_{TB}(\text{vent or stack}) = \frac{\text{Total Body Dose Rate Limit}}{D_{TB}(\text{vent or stack})}$$

$$R_S(\text{vent or stack}) = \frac{\text{Skin Dose Rate Limit}}{D_S(\text{vent or stack})}$$

$$R_{TH}(\text{vent or stack}) = \frac{\text{Maximum Organ Dose Rate Limit}}{D_{TH}(\text{vent or stack})}$$

These ratios represent how far above or below the guidelines the dose rate calculations were.

A total release rate, Q, for each nuclide type (noble gas or iodine/particulate) and release point (building vent or stack) is calculated, using the source term data in Table 7.2. Thus, four total release rates are calculated:

Q_{ngv} = Total noble gas release rate from building exhaust vents, Ci/s.

Q_{ngs} = Total noble gas release rate from main stack, Ci/s.

Q_{ipv} = Total iodine and particulate release rate from building exhaust vents, Ci/s.

Q_{ips} = Total iodine and particulate release rate from main stack, Ci/s.

To obtain a release rate limit, r, for each nuclide type and release point, the total release rate, Q, for that nuclide type and release point is multiplied by the corresponding ratio, R:

For noble gases released from building vents:

$$r_{ngv} = R_{TBv} Q_{ngv} \quad \text{or} \\ = R_{Sv} Q_{ngv}$$

whichever is more restrictive, i.e., smaller.



where

- r_{ngv} = Calculated release rate limit for noble gases released from building vents.
 R_{TBv} = Ratio of total body dose rate limit to total body dose rate for building vent releases, as calculated above.
 Q_{ngv} = Total Table 7.2 noble gas release rate from building vents.
 R_{Sv} = Ratio of skin dose rate limit to skin dose rate for building vent releases, as calculated above.

For noble gases released from the stack:

$$r_{ngs} = R_{TBs} Q_{ngs}, \quad \text{or} \\ = R_{Ss} Q_{ngs}$$

whichever is more restrictive, i.e., smaller.

where

- r_{ngs} = Calculated release rate limit for noble gases released from the stack.
 R_{TBs} = Ratio of total body dose rate limit to total body dose rate for stack releases, as calculated above.
 Q_{ngs} = Total Table 7.2 noble gas release rate from stack.
 R_{Ss} = Ratio of skin dose rate limit to skin dose rate for stack releases, as calculated above.

For iodines and particulates with half-lives greater than 8 days released from building vents:

$$r_{ipv} = R_{THv} Q_{ipv}$$

where

- r_{ipv} = Calculated release rate limit for iodines and particulates released from building vents.
 R_{THv} = Ratio of maximum organ dose rate limit to maximum organ dose rate for building vent releases, as calculated above.
 Q_{ipv} = Total Table 7.2 iodine and particulate release rate from building vents.

For iodines and particulates with half-lives greater than 8 days released from the stack:

$$r_{ips} = R_{THs} Q_{ips}$$

where

- r_{ips} = Calculated release rate limit for iodines and particulates released from the stack.
 R_{THs} = Ratio of maximum organ dose rate limit to maximum organ dose rate for stack releases, as calculated above.
 Q_{ips} = Total Table 7.2 iodine and particulate release rate from stack.

The release rate limits, r , calculated for BFN using this methodology are:

	<u>Noble Gas</u>	<u>Iodine and Particulate</u>
Stack	$r_{ngs} = 1.44E+01 \text{ Ci/s}$	$r_{ips} = 3.57E-05 \text{ Ci/s}$
Building Vents	$r_{ngv} = 1.50E-01 \text{ Ci/s}$	$r_{ipv} = 2.19E-06 \text{ Ci/s}$

The values listed are used as administrative guidelines for operation.

The instantaneous release rates, r in Ci/sec, for each nuclide type and release point are limited by the following equations:

For noble gases,

$$\begin{array}{r} r_{ngv} + r_{ngs} \leq 1 \\ 0.15 \quad 14.4 \end{array}$$

For iodines and particulates,

$$\begin{array}{r} r_{ipv} + r_{ips} \leq 1 \\ 2.19E-06 \quad 3.57E-05 \end{array}$$

7.2 GASEOUS EFFLUENT MONITOR INSTRUMENT SETPOINTS

7.2.1 Alarm/Trip Setpoints

Control 1.1.2 requires gaseous effluent monitors to have alarm/trip setpoints to ensure that the above dose rates are not exceeded. This section of the ODCM describes the methodology that will be used to determine these allowable values which are used to calculate setpoints. Figures 7.1 and 7.2 show the Offgas System, the Standby Gas Treatment System and normal building ventilation with effluent monitor locations.

The methodology for determining alarm/trip allowable values is divided into two major parts. The first consists of backcalculating from a dose rate to a release rate limit, in $\mu\text{Ci/s}$, for each nuclide and release point. The methodology for the calculation of these release rate limits is given in Section 7.1. The second consists of using the release rate limits to determine the allowable values which are used to calculate the physical settings on the monitors. The methodology for the calculation of the allowable values is given below. The monitor setpoints are calculated in the applicable Scaling and Setpoint Document.

7.2.2 Allowable Values

To determine allowable values for gaseous effluent monitors, shown in Figures 7.1 and 7.2, the noble gas release rate limits are used.

The allowable values are calculated using the following equation

$$\text{Allowable Value} \leq \frac{r f A}{F E} + B$$

where

- r = release rate limit for stack or ground level, $\mu\text{Ci/sec}$. The release rate limits used for the allowable value calculation are $1.44\text{E}+07$ $\mu\text{Ci/sec}$ for the stack and $1.50\text{E}+05$ $\mu\text{Ci/sec}$ for the building vents.
- f = fraction of the limits r which is allowed for the release mode (elevated or ground level).

NOTE: The sum of the f values for elevated and ground levels must be less than or equal to 1. This lowers the limits to ensure that the site dose rate limit will not be exceeded if both the stack and the ground level release rate limits were reached simultaneously.

- A = allocation factor. This is the portion of the release rate limit r which is assigned to the release point under consideration. This ensures that the ground level release rate limit will not be exceeded if all building vents were to reach their limit simultaneously. This is equal to 1 for the stack. The building vent release rate limit is divided among the ten vents based on the flow rates.

- F = flow rate for the vent, cc/sec. Maximum flow rates are used to ensure conservative setpoints.
- E = efficiency of the monitor, ($\mu\text{Ci/cc}$)/cpm (or ($\mu\text{Ci/cc}$)/cps for the stack monitor)
- B = background of the monitor, cpm (cps for the stack monitor)

The calculation of these setpoints are documented further in Technical Instruction (TI) 15 and the applicable Scaling and Setpoint Document, including the numerical values for each of the parameters described above.



7.3 GASEOUS EFFLUENTS - DOSE RATES

7.3.1 Noble Gas Dose Rates

Dose rates are calculated for total body and skin, due to submersion within a cloud of noble gases, using a semi-infinite cloud model. The use of a finite cloud model would result in calculated doses of 0 to 10 percent higher than those calculations using the semi-infinite cloud model for Browns Ferry Nuclear Plant (BFN). The dose rates are evaluated at the offsite locations with the highest expected concentrations, i.e., the nearest SITE BOUNDARY points in each sector (from Table 7.1) and at other locations expected to be the maximum exposure points.

The noble gas radionuclide mix used in this calculation is based on the design objective source term given in Table 7.2. Dispersion of the released radioactivity is handled as described in Section 7.9 using historical annual average meteorological data given in Table 7.3. No credit is taken for shielding by residence.

To calculate the noble gas dose rate from radiological effluents discharged from a given release point for any one of the potential maximum-exposure points, the equations given in Section 7.7.1 are used.

The total body and skin dose rate calculations are repeated for each release point. Dose rates for releases from all building vents are summed. The maximum stack and building vent total body and skin dose rates will be used to determine release rate limits.

7.3.2 I-131, I-133, Tritium and all Radionuclides in Particulate Form
with Half-lives of Greater than 8 days - Organ Dose Rate

Dose rates are calculated for the critical organ, thyroid, of the critical age group, infant. Pathways considered are inhalation, ground contamination and milk ingestion. The dose rates are evaluated at the offsite locations with the highest expected concentrations, i.e., the nearest SITE BOUNDARY points in each of the 16 sectors (from Table 7.1) and at other locations expected to be the maximum exposure points. This calculation assumes that a (hypothetical) cow is at each of these locations. These cows are assumed, conservatively, to obtain 100 percent of their food from pasture grass.

The inhalation, ground contamination, and milk ingestion dose rates (in mrem/year) for the selected organ (thyroid) and age group (infant) are calculated using Equation 7.9 as described in Section 7.6.2. For determining the total thyroid dose rate from iodines and particulates:

$$D_{TH} = D_{THI} + D_{TBG} + D_{THM} \quad (7.1)$$

where:

D_{TH} = total thyroid dose rate, mrem/yr.

D_{THI} = thyroid dose rate due to inhalation, mrem/yr.

D_{TBG} = total body dose rate due to ground contamination, mrem/yr. The thyroid dose rate is assumed to be equal to the total body dose rate for this pathway.

D_{THM} = thyroid dose rate due to pasture grass-cow-milk ingestion, mrem/yr.

The iodine and particulate dose rates are calculated for the design objective source term given in Table 7.2. The above dose rate calculation is repeated for each release point. Dose rates for releases from all building vents are summed. The maximum stack and building vent thyroid dose rates will be used to determine release rate limits.

7.4 DOSE - NOBLE GASES

7.4.1 Monthly Noble Gas Dose

Doses to be calculated are gamma and beta air doses due to exposure to a semi-infinite cloud of noble gases. The use of a finite cloud model would result in calculated doses of 0 to 10 percent higher than those calculations using the semi-infinite cloud model for BFN. Releases of Ar-41, Kr-85m, Kr-85, Kr-87, Kr-88, Xe-131m, Xe-133m, Xe-133, Xe-135m, Xe-135, and Xe-138 are considered. Because only these nuclides are considered, the dose is divided by 0.9, to account for a possible 10 percent contribution of dose from other nuclides.

The dispersion factor used will be the highest annual-average χ/Q based on 1977-1979 meteorological data (Table 7.3). Dispersion factors are calculated using the methodology described by Equation 7.11. Stack releases are considered elevated releases. All other vent releases will be treated as ground level.

No credit is taken for radioactive decay.

7.4.1.1 Monthly Conservative Model - Gamma Air Dose

$$D_{\gamma} = \frac{(\chi/Q)}{0.9} \frac{10^6}{3.15E+07} \sum_i Q_i DF_{\gamma i} \quad (7.2)$$

where:

- D_{γ} = gamma dose to air, mrad.
- χ/Q = highest annual-average relative concentration at or beyond the SITE BOUNDARY, s/m^3 (from Table 7.1).
 - = $1.84E-06$ for ground level releases,
 - = $2.08E-08$ for elevated releases (stack).
- 0.9 = fraction of total gamma dose expected to be contributed by the assumed nuclides.
- 10^6 = $\mu Ci/Ci$ conversion factor.
- $3.15E+07$ = s/yr conversion factor.
- Q_i = monthly release of radionuclide i , Ci.
- $DF_{\gamma i}$ = gamma-to-air dose factor for radionuclide i , mrad/yr per $\mu Ci/m^3$ (Table 7.4).

7.4.1.2 Monthly Conservative Model - Beta Air Dose

$$D_B = \frac{(X/Q)}{0.9} \frac{10^6}{3.15E+07} \sum_i Q_i DF_{Bi} \quad (7.3)$$

where:

- D_B = beta dose to air, mrad.
- X/Q = highest annual-average relative concentration at or beyond the SITE BOUNDARY, s/m^3 (from Table 7.1).
= $1.84E-06$ for ground level releases,
= $2.08E-08$ for elevated releases (stack).
- 0.9 = fraction of total beta dose expected to be contributed by the assumed nuclides.
- 10^6 = $\mu Ci/Ci$ conversion factor.
- $3.15E+07$ = s/yr conversion factor.
- Q_i = monthly release of radionuclide i, Ci.
- DF_{Bi} = beta-to-air dose factor for radionuclide i, mrad/yr per $\mu Ci/m^3$ (Table 7.4).

7.4.1.3 Cumulative Dose - Noble Gas

Cumulative calendar quarter doses are estimated by summing the doses calculated for each month in that quarter. Cumulative calendar year doses are estimated by summing the doses calculated for each month in that year.

7.4.1.4 Comparison to Limits

The cumulative calendar quarter and calendar year doses are compared to their respective limits to determine compliance.



7.5 CUMULATIVE DOSE - I-131, I-133, TRITIUM AND RADIONUCLIDES IN
PARTICULATE FORM WITH HALF-LIVES GREATER THAN 8 DAYS

Doses are to be calculated for the infant thyroid from milk ingestion and for the child bone and teen gastrointestinal tract (GIT) from vegetable ingestion. Releases of H-3, I-131, and I-133 are considered for the milk pathway. H-3, Sr-89, Sr-90, Cs-134, and Cs-137 releases are considered for the vegetable pathway to the child bone. H-3, Co-58, and Co-60 releases are considered for the vegetable pathway to the teen GIT. The most critical real cow location is considered for the milk pathway and the most critical location with a home-use garden is considered for the vegetable pathways (see Table 7.1). The cow is assumed to graze on pasture grass for the whole year.

The highest annual-average χ/Q and D/Q based on 1977-1979 meteorological data (Table 7.3) will be used for ingestion pathway locations. Dispersion values are calculated as described by Equations 7.12 and 7.13. Stack releases are considered elevated releases. All other vent releases will be treated as ground level.

No credit is taken for radioactive decay.

Doses are divided by 0.9 to account for a possible 10 percent contribution from other nuclides.

The maximum monthly organ dose is the highest of the three doses calculated.

7.5.1 Monthly Conservative Model - Infant Thyroid Dose-from Milk Ingestion

The monthly thyroid dose from milk ingestion is calculated using the following equation:

$$D_{TH} = \frac{\sum_i (Q_i R_{CPI}) D/Q + (Q_T R_{CPT}) X/Q \cdot 10^6}{0.9 (3.15E+07)} \quad (7.4)$$

where

- Q_i = monthly release of iodine nuclide i , Ci.
- Q_T = monthly release of H-3, Ci.
- R_{CPI} = I-131 or I-133 pasture grass-cow-milk ingestion dose factor for infant thyroid, mrem/yr per $\mu\text{Ci}/\text{m}^2\text{-s}$. Dose factors are calculated as described in Section 7.8.1.
- R_{CPT} = H-3 pasture grass-cow-milk ingestion dose factor for infant thyroid, mrem/yr per $\mu\text{Ci}/\text{m}^3$. The dose factor is calculated as described in Section 7.8.7.
- D/Q = highest relative deposition rate for a location with an identified milk cow, m^{-2} (from Table 7.1).
= $3.16E-10$ for ground level releases,
= $2.30E-10$ for elevated releases (stack).
- X/Q = highest relative air concentration for a location with an identified milk cow, s/m^3 (from Table 7.1).
= $1.47E-07$ for ground level releases,
= $1.69E-08$ for elevated releases (stack).
- 0.9 = fraction of dose expected to be contributed by I-131, I-133 and H-3.
- $3.15E+07$ = s/yr.
- 10^6 = $\mu\text{Ci}/\text{Ci}$.

7.5.2 Monthly Conservative Model - Child Bone Dose from Vegetable Ingestion

The monthly bone dose from vegetable ingestion is calculated using the following equation:

$$D_{BC} = \frac{\sum_i (Q_i DF_i) D/Q + Q_T DF_T X/Q \cdot 10^6}{0.9 (3.15E+07)} \quad (7.5)$$

where

- Q_i = monthly release of Sr or Cs nuclide i , Ci.
- Q_T = monthly release of H-3, Ci.
- DF_i = Total vegetable ingestion dose factor to child bone for Sr-89, Sr-90, Cs-134 or Cs-137, mrem/yr per $\mu\text{Ci}/\text{m}^2\text{-s}$.
= $R_{VFi} + R_{VSi}$, where R_{VFi} is the dose factor for fresh leafy vegetables (as calculated in Section 7.8.5) and R_{VSi} is the dose factor for stored vegetables (as calculated in Section 7.8.6).
- DF_T = Total vegetable ingestion dose factor for child bone for H-3, mrem/yr per $\mu\text{Ci}/\text{m}^3$.
= $R_{VFT} + R_{VST}$, where R_{VFT} is the tritium dose factor for fresh leafy vegetables (as calculated in Section 7.8.11) and R_{VSi} is the tritium dose factor for stored vegetables (as calculated in Section 7.8.12).
- D/Q = highest relative deposition rate for a location with an identified home use garden, m^{-2} (from Table 7.1).
= $4.46E-09$ for ground level releases,
= $1.13E-09$ for elevated releases (stack).
- X/Q = highest relative air concentration for a location with an identified home use garden, s/m^3 (from Table 7.1).
= $1.57E-06$ for ground level releases,
= $9.50E-09$ for elevated releases (stack).
- $3.15E+07$ = s/yr.
- 10^6 = $\mu\text{Ci}/\text{Ci}$.
- 0.9 = fraction of total child bone dose expected to be contributed by H-3, Sr-89, Sr-90, Cs-134, and Cs-137.



7.5.3 Monthly Conservative Model - Teen Gastrointestinal Tract (GIT)
Dose from Vegetable Ingestion

The monthly teen GIT dose from vegetable ingestion is calculated using the following equation:

$$D_{GIT} = \frac{\sum_i (Q_i DF_i) D/Q + Q_T DF_T \chi/Q \cdot 10^6}{0.9 (3.15E+07)} \quad (7.6)$$

where

- Q_i = monthly release of cobalt nuclide i , Ci.
- Q_T = monthly release of H-3, Ci.
- DF_i = Total vegetable ingestion dose factor to the teen GIT for Co-58 or Co-60, mrem/yr per $\mu\text{Ci}/\text{m}^2\text{-s}$.
= $R_{VFi} + R_{VSi}$, where R_{VFi} is the dose factor for fresh leafy vegetables (as calculated in Section 7.8.5) and R_{VSi} is the dose factor for stored vegetables (as calculated in Section 7.8.6).
- DF_T = Total vegetable ingestion dose factor to the teen GIT for H-3, mrem/yr per $\mu\text{Ci}/\text{m}^3$.
= $R_{VFT} + R_{VST}$, where R_{VFT} is the tritium dose factor for fresh leafy vegetables (as calculated in Section 7.8.11) and R_{VST} is the tritium dose factor for stored vegetables (as calculated in Section 7.8.12).
- D/Q = highest relative deposition rate for a location with an identified home use garden, m^{-2} (from Table 7.1).
= $4.46\text{E}-09$ for ground level releases,
= $1.13\text{E}-09$ for elevated releases (stack).
- χ/Q = highest relative air concentration for a location with an identified home use garden, s/m^3 (from Table 7.1).
= $1.57\text{E}-06$ for ground level releases,
= $9.50\text{E}-09$ for elevated releases (stack).
- $3.15\text{E}+07$ = s/yr.
- 10^6 = $\mu\text{Ci}/\text{Ci}$.
- 0.9 = fraction of total teen GIT dose expected to be contributed by H-3, Co-58, and Co-60.



7.5.4 Cumulative Doses

Cumulative calendar quarter doses are estimated by summing the doses calculated for each month in that quarter. Cumulative calendar year doses are estimated by summing the doses calculated for each month in that year.

7.5.5 Total Monthly Dose - Comparison to Limits

The cumulative calendar quarter and calendar year doses are compared to their respective limits to determine compliance.

7.6 GASEOUS RADWASTE TREATMENT

7.6.1 Dose Projections

Dose projections will be performed by averaging the calculated dose for the most recent month and the calculated dose for the previous month and assigning that average dose as the projection for the current month.

If the results of the dose projection indicate potential doses in excess of the monthly fraction of the annual dose limit, efforts will be made to minimize future releases.

7.6.2 System Description

A flow diagram for the GRTS is given in Figure 7.1. The system includes the subsystems that process and dispose of the gases from the main condenser air ejectors, the startup vacuum pumps, and the gland seal condensers. One gaseous radwaste treatment system is provided for each unit. The processed gases from each unit are routed to the plant stack for dilution and elevated release to the atmosphere. The air-ejector off-gas line of each unit and the stack are continuously monitored by radiation monitors.



7.7 DOSE CALCULATIONS FOR REPORTING PURPOSES

A complete dose analysis utilizing the total estimated gaseous releases for each calendar quarter will be performed and reported as required in ODCM Administrative Control 5.2. Methodology for this analysis is that which is described below, using the quarterly release values reported by the plant personnel. For iodine releases, it will be assumed that half the iodines released are organic iodines, which contribute only to the inhalation dose. All real pathways and receptor locations (as identified in the most recent land use survey) are considered. In addition, actual meteorological data representative of each corresponding calendar quarter will be used to calculate dispersion factors as described in Section 7.9. Stack releases will be considered elevated releases. Radwaste and reactor building releases will be considered split-level releases. Turbine building releases will be treated as ground level.

7.7.1 Noble Gas Dose

All measured radionuclides are used to calculate gamma and beta air doses. The dose is evaluated at the nearest SITE BOUNDARY point in each sector and at other locations expected to be maximum exposure points using a semi-infinite cloud model. The use of a finite cloud model would result in calculated doses of 0 to 10 percent higher than those calculations using the semi-infinite cloud model for BFN.

Radioactive decay is considered in this calculation. The quarterly release is averaged over one year to obtain an average release rate.

7.7.1.1 Gamma Dose to Air

$$D_{\gamma n} = \sum_i X_{ni} DF_{\gamma i} \quad (7.7)$$

where:

$D_{\gamma n}$ = gamma dose to air for sector n, mrad.

X_{ni} = air concentration of radionuclide i in sector n, $\mu\text{Ci-year}/\text{m}^3$. Air concentrations are calculated as described by Equation 7.11.

$DF_{\gamma i}$ = gamma-to-air dose factor for radionuclide i, mrad/yr per $\mu\text{Ci}/\text{m}^3$ (Table 7.4).

7.7.1.2 Beta Dose to Air

$$D_{\beta n} = \sum_i X_{ni} DF_{\beta i} \quad (7.8)$$

where:

$D_{\beta n}$ = beta dose to air for sector n, mrad.

X_{ni} = air concentration of radionuclide i in sector n, $\mu\text{Ci-year}/\text{m}^3$. Air concentrations are calculated as described by Equation 7.11.

$DF_{\beta i}$ = beta to air dose factor for radionuclide i, mrad/yr per $\mu\text{Ci}/\text{m}^3$ (Table 7.4).

7.7.2 Radioiodine, Particulate and Tritium - Maximum Organ Dose

Organ doses due to radioiodine, particulate and tritium releases are calculated using the following equation:

$$D_{org} = 3.17E-08 \left[\sum_i \left(\frac{D}{Q} \sum_P R_{Pi} + \frac{D}{Q} R_{Gi} + \frac{X}{Q} R_{Ii} \right) Q_i + \sum_P \left(\frac{X}{Q} R_{PT} \right) Q_T \right] \quad (7.9)$$

where:

- D_{org} = Organ dose, mrem.
 $3.17E-08$ = conversion factor, year/second.
 X/Q = Relative concentration for location under consideration, sec/m^3 . Relative concentrations are calculated as described by Equation 7.12.
 R_{Pi} = ingestion dose factor for pathway P for each identified nuclide i (except tritium), $\text{m}^2\text{-mrem}/\text{year}$ per $\mu\text{Ci}/\text{second}$.
Ingestion pathways available for consideration include:
pasture grass-cow-milk ingestion
stored feed-cow-milk ingestion
pasture grass-goat-milk ingestion
stored feed-goat-milk ingestion
pasture grass-beef ingestion
stored feed-beef ingestion
fresh leafy vegetable ingestion
stored vegetable ingestion
Equations for calculating these ingestion dose factors are given in Sections 7.8.1 through 7.8.6.
 D/Q = Relative deposition for location under consideration, m^{-2} . Relative deposition is calculated as described in Equation 7.13.
 R_{Gi} = Dose factor for standing on contaminated ground, $\text{m}^2\text{-mrem}/\text{year}$ per $\mu\text{Ci}/\text{second}$. The equation for calculating the ground plane dose factor is given in Section 7.8.14.
 R_{Ii} = Inhalation dose factor, mrem/year per $\mu\text{Ci}/\text{m}^3$. The equation for calculating the inhalation dose factor is given in Section 7.8.13.



Q_i = adjusted release for nuclide i for location under consideration, μCi . The initial release is adjusted to account for decay between the release point and the location, depending on the frequency of wind speeds applicable to that sector. Hence, the adjusted release is equal to the actual release decayed for an average travel time during the period.

$$= Q_{i0} \sum_{j=1}^9 f_j \exp(-\lambda_i x/u_j)$$

where

Q_{i0} = initial average release for nuclide i over the period, μCi .

f_j = joint relative frequency of occurrence of winds in windspeed class j blowing toward this exposure point, expressed as a fraction.

λ_i = radiological decay constant for nuclide i , sec^{-1} .

x = downwind distance, meters.

u_j = midpoint value of wind speed class interval j , m/s.

R_{PT} = ingestion dose factor for pathway P for tritium, $\text{mrem/year per } \mu\text{Ci/m}^3$. Ingestion pathways available for consideration are the same as those listed above for R_{Pi} . Equations for calculating ingestion dose factors for tritium are given in Sections 7.8.7 through 7.8.12..

Q_T = adjusted release for tritium for location under consideration, μCi . Calculated in the same manner as Q_i above.



7.7.3 Population Doses

For determining population doses to the 50-mile population around the plant, each compass sector is broken down into elements. These elements are defined in Table 7.5. For each of these sector elements, an average dose is calculated, and then multiplied by the population in that sector element. Dispersion factors are calculated for the midpoint of each sector element (see Table 7.5). For population doses resulting from ingestion, it is conservatively assumed that all food eaten by the average individual is grown locally.

The general equation used for calculating the population dose in a given sector element is:

$$\text{Dose}_{\text{pop}} = \sum_P \text{RATIO}_P * \text{POPN} * \text{AGE} * 0.001 * \text{DOSE}_P \quad (7.10)$$

where

- RATIO_P = ratio of average to maximum dose for pathway P. (Average ingestion rates are obtained from Regulatory Guide 1.109, Table E-4.)
- = 0.5 for submersion and ground exposure pathways, a shielding/occupancy factor.
 - = 1.0 for the inhalation pathway.
 - = 0.515, 0.515, 0.5, and 0.355 for milk, for infant, child, teen and adult, respectively. (It is assumed that the ratio of average to maximum infant milk ingestion rates is the same as that for child.)
 - = 1.0, 0.90, 0.91, 0.86 for beef ingestion, for infant, child, teen and adult, respectively.
 - = 1.0, 0.38, 0.38, 0.37 for vegetable ingestion, for infant, child, teen and adult, respectively. (It is assumed that the average individual eats no fresh vegetables, only stored vegetables.)
- POPN = the population of the sector element, persons (Table 7.6).
- AGE = fraction of the population belonging to each age group.
- = 0.015, 0.168, 0.153, 0.665 for infant, child, teen and adult, respectively (fractions taken from NUREG/CR-1004, Table 3.39).
- 0.001 = conversion from mrem to rem.
- DOSE_P = the dose for pathway P to the maximum individual at the location under consideration, mrem. For ingestion pathways, this dose is multiplied by an average decay correction to account for decay as the food is moved through the food distribution cycle. This average decay correction, ADC, is defined as:



$ADC = \exp(-\lambda_i t)$, for milk and vegetables,

where

λ_i = decay constant for nuclide i, seconds.
t = distribution time for food product under consideration
(from Regulatory Guide 1.109, Table D-1).
= 1.21E+06 seconds (14 days) for vegetables.
= 3.46E+05 seconds (4 days) for milk.

$$ADC = \frac{\exp(-\lambda_i t) \lambda_i t_{cb}}{1 - \exp(-\lambda_i t_{cb})}, \text{ for meat,}$$

where

λ_i = decay constant for nuclide i, seconds.
t = additional distribution time for meat, over and above the
time for slaughter to consumption described in
Section 7.8.3, 7 days (from Regulatory Guide 1.109,
Table D-2).

t_{cb} = time to consume a whole beef, as described in Section 7.8.3.

For beef ingestion, the additional factors in the calculation of ADC negate the integration of the dose term over the period during which a whole beef is consumed, for the calculation of population dose. This assumes that the maximum individual freezes and eats a whole beef, but the average individual buys smaller portions at a time.

Population doses are summed over all sector elements to obtain a total population dose for the 50-mile population.

7.7.4 Reporting of Doses

The calculated quarterly doses and calculated population doses described in this section are reported in the Semiannual Radioactive Effluent Release Report as described in ODCM Administrative Control 5.2

7.8 GASEOUS DOSE FACTOR EQUATIONS

7.8.1 Pasture Grass-Cow-Goat-Milk Ingestion Dose Factors (m²-mrem/year per μCi/sec)

$$R_{Cp_i} = 10^6 DFL_{iao} U_{ap} F_{mi} Q_f \exp(-\lambda_i t_{fm}) f_p \frac{r(1-\exp(-\lambda_E t_{ep}))}{Y_p \lambda_E} + \frac{B_{iv}(1-\exp(-\lambda_i t_b))}{P \lambda_i}$$

where:

- 10⁶ = conversion factor, pCi/μCi.
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- U_{ap} = milk ingestion rate for age group a, L/year.
- F_{mi} = transfer factor for nuclide i from animal's feed to milk, days/L (Table 6.2).
- Q_f = animal's consumption rate, kg/day.
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{fm} = transport time from milking to receptor, seconds.
- f_p = fraction of time animal spends on pasture, dimensionless.
- r = fraction of activity retained on pasture grass, dimensionless.
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹, equal to λ_i + λ_w.
- λ_w = weathering decay constant for leaf and plant surfaces, seconds⁻¹.
- t_{ep} = time pasture is exposed to deposition, seconds.
- Y_p = agricultural productivity by unit area of pasture grass, kg/m².
- B_{iv} = transfer factor for nuclide i from soil to vegetation, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time period over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.2 Stored Feed-Cow/Goat-Milk Ingestion Dose Factors
(m²-mrem/year per μ Ci/second)

$$R_{CSi} = 10^6 \text{ DFL}_{iao} U_{ap} F_{mi} Q_f f_s \exp(-\lambda_i t_{fm}) \frac{(1 - \exp(-\lambda_i t_{csf}))}{t_{csf} \lambda_i} \left[\frac{r(1 - \exp(-\lambda_E t_{esf}))}{Y_{sf} \lambda_E} + \frac{B_{iv}(1 - \exp(-\lambda_i t_b))}{P \lambda_i} \right]$$

where:

- 10⁶ = conversion factor, pCi/ μ Ci.
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- U_{ap} = milk ingestion rate for age group a, L/year.
- F_{mi} = transfer factor for nuclide i from animal's feed to milk, days/L (Table 6.2).
- Q_f = animal's consumption rate, kg/day.
- f_s = fraction of time animal spends on stored feed, dimensionless.
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{fm} = transport time from milking to receptor, seconds.
- t_{csf} = time between harvest of stored feed and consumption by animal, seconds.
- r = fraction of activity retained on pasture grass, dimensionless.
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹, equal to $\lambda_i + \lambda_w$.
- λ_w = weathering decay constant for leaf and plant surfaces, seconds⁻¹.
- t_{esf} = time stored feed is exposed to deposition, seconds.
- Y_{sf} = agricultural productivity by unit area of stored feed, kg/m².
- B_{iv} = transfer factor for nuclide i from soil to vegetation, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time period over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.3 Pasture Grass-Beef Ingestion Dose Factors
(m²-mrem/year per μCi/second)

$$R_{MPI} = 10^6 \text{ DFL}_{iao} U_{am} F_{fi} Q_f \frac{(1 - \exp(-\lambda_i t_{cb}))}{\lambda_i t_{cb}} \exp(-\lambda_i t_s) \\
f_p \frac{r(1 - \exp(-\lambda_E t_{ep}))}{Y_p \lambda_E} + \frac{B_{iv}(1 - \exp(-\lambda_i t_b))}{P \lambda_i}$$

where:

- 10⁶ = conversion factor, pCi/μCi.
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- U_{am} = meat ingestion rate for age group a, kg/year.
- F_{fi} = transfer factor for nuclide i from cow's feed to meat, days/kg (Table 6.2).
- Q_f = cow's consumption rate, kg/day.
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{cb} = time for receptor to consume a whole beef, seconds.
- t_s = transport time from slaughter to consumer, seconds.
- f_p = fraction of time cow spends on pasture, dimensionless.
- r = fraction of activity retained on pasture grass, dimensionless.
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹, equal to λ_i + λ_w.
- λ_w = weathering decay constant for leaf and plant surfaces, seconds⁻¹.
- t_{ep} = time pasture is exposed to deposition, seconds.
- Y_p = agricultural productivity by unit area of pasture grass, kg/m².
- B_{iv} = transfer factor for nuclide i from soil to vegetation, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.4 Stored Feed-Beef Ingestion Dose Factors
(m²-mrem/year per μCi/second)

$$RMS_i = 10^6 DFL_{iao} U_{am} F_{fi} Q_f \frac{(1 - \exp(-\lambda_i t_{cb})) \exp(-\lambda_i t_s)}{\lambda_i t_{cb}} + \frac{f_s (1 - \exp(-\lambda_i t_{csf}))}{\lambda_i t_{csf}} + \frac{r(1 - \exp(-\lambda_E t_{esf}))}{Y_{sf} \lambda_E} + \frac{B_{iv}(1 - \exp(-\lambda_i t_b))}{P \lambda_i}$$

where:

- 10⁶ = conversion factor, pCi/μCi.
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- U_{am} = meat ingestion rate for age group a, kg/year.
- F_{fi} = transfer factor for nuclide i from cow's feed to meat, days/kg (Table 6.2).
- Q_f = cow's consumption rate, kg/day.
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{cb} = time for receptor to consume a whole beef, seconds.
- t_s = transport time from slaughter to consumer, seconds.
- f_s = fraction of time cow spends on stored feed, dimensionless.
- t_{csf} = time between harvest of stored feed and consumption by cow, seconds.
- r = fraction of activity retained on pasture grass, dimensionless.
- t_{esf} = time stored feed is exposed to deposition, seconds.
- Y_{sf} = agricultural productivity by unit area of stored feed, kg/m².
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹, equal to λ_i + λ_w.
- λ_w = weathering decay constant for leaf and plant surfaces, seconds⁻¹.
- B_{iv} = transfer factor for nuclide i from soil to vegetation, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.5 Fresh Leafy Vegetable Ingestion Dose Factors
(m²-mrem/year per μCi/second)

$$RV_{Fi} = 10^6 DFL_{iao} e(-\lambda_i t_{hc}) U_{FLa} f_L \frac{r(1-e(-\lambda_E t_e))}{Y_f \lambda_E} + \frac{B_{iv}(1-e(-\lambda_i t_b))}{P \lambda_i}$$

where:

- 10⁶ = conversion factor, pCi/μCi.
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{hc} = average time between harvest of vegetables and their consumption and/or storage, seconds.
- U_{FLa} = consumption rate of fresh leafy vegetables by the receptor in age group a, kg/year.
- f_L = fraction of fresh leafy vegetables grown locally, dimensionless.
- r = fraction of deposited activity retained on vegetables, dimensionless.
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹.
= λ_i + λ_w
- λ_w = decay constant for removal of activity on leaf and plant surfaces by weathering, seconds⁻¹.
- t_e = exposure time in garden for fresh leafy and/or stored vegetables, seconds.
- Y_f = vegetation areal density for fresh leafy vegetables, kg/m².
- B_{iv} = transfer factor for nuclide i from soil to vegetables, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time period over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.6 Stored Vegetable Ingestion Dose Factors
 m^2 -mrem/year per $\mu\text{Ci}/\text{second}$)

$$R_{VSi} = 10^6 \text{ DFL}_{iao} \exp(-\lambda_i t_{hc}) U_{Sa} f_g \frac{(1-e(-\lambda_i t_{sv}))}{\lambda_i t_{sv}} \frac{r(1-e(-\lambda_E t_e))}{Y_{sv} \lambda_E} + \frac{B_{iv}(1-e(-\lambda_i t_b))}{P \lambda_i}$$

where:

- 10^6 = conversion factor, pCi/ μCi .
- DFL_{iao} = ingestion dose conversion factor for nuclide i, age group a, organ o, mrem/pCi (Table 6.4).
- λ_i = decay constant for nuclide i, seconds⁻¹ (Table 6.2).
- t_{hc} = average time between harvest of vegetables and their consumption and/or storage, seconds.
- U_{Sa} = consumption rate of stored vegetables by the receptor in age group a, kg/year.
- f_g = fraction of stored vegetables grown locally, dimensionless.
- t_{sv} = time between storage of vegetables and their consumption, seconds.
- r = fraction of deposited activity retained on vegetables, dimensionless.
- λ_E = the effective decay constant, due to radioactive decay and weathering, seconds⁻¹.
 $= \lambda_i + \lambda_w$
- λ_w = decay constant for removal of activity on leaf and plant surfaces by weathering, seconds⁻¹.
- t_e = exposure time in garden for fresh leafy and/or stored vegetables, seconds.
- Y_{sv} = vegetation areal density for stored vegetables, kg/m².
- B_{iv} = transfer factor for nuclide i from soil to vegetables, pCi/kg (wet weight of vegetation) per pCi/kg (dry soil).
- t_b = time period over which accumulation on the ground is evaluated, seconds.
- P = effective surface density of soil, kg/m².

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.



7.8.7 Tritium-Pasture Grass-Cow/Goat-Milk Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{CTP} = 10^3 10^6 \text{DFL}_{\text{Tao}} F_{\text{mT}} Q_f U_{\text{ap}} [0.75(0.5/H)] f_p \exp(-\lambda_T t_{\text{fm}})$$

where:

- 10^3 = conversion factor, g/kg.
 10^6 = conversion factor, pCi/ μCi .
 DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
 F_{mT} = transfer factor for tritium from animal's feed to milk, days/L (Table 6.2).
 Q_f = animal's consumption rate, kg/day.
 U_{ap} = milk ingestion rate for age group a, L/year.
0.75 = the fraction of total feed that is water.
0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water.
H = absolute humidity of the atmosphere, g/m^3 .
 f_p = fraction of time animal spends on pasture, dimensionless.
 λ_T = decay constant for tritium, seconds^{-1} (Table 6.2).
 t_{fm} = transport time from milking to receptor, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.



7.8.8 Tritium-Stored Feed-Cow/Goat-Milk Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{\text{CTS}} = 10^3 10^6 \text{DFL}_{\text{Tao}} F_{\text{mT}} Q_f U_{\text{ap}} [0.75(0.5/H)] f_s \frac{(1 - \exp(-\lambda_{\text{T}} t_{\text{csf}}))}{\lambda_{\text{T}} t_{\text{csf}}} \exp(-\lambda_{\text{T}} t_{\text{fm}})$$

where:

- 10^3 = conversion factor, g/kg.
- 10^6 = conversion factor, pCi/ μCi .
- DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
- F_{mT} = transfer factor for tritium from animal's feed to milk, days/L (Table 6.2).
- Q_f = animal's consumption rate, kg/day.
- U_{ap} = milk ingestion rate for age group a, L/year.
- 0.75 = the fraction of total feed that is water.
- 0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water.
- H = absolute humidity of the atmosphere, g/ m^3 .
- f_s = fraction of time animal spends on stored feed, dimensionless.
- λ_{T} = decay constant for tritium, seconds⁻¹ (Table 6.2).
- t_{csf} = time between harvest of stored feed and consumption by animal, seconds.
- t_{fm} = transport time from milking to receptor, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.9 Tritium-Pasture Grass-Beef Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{MT} = 10^3 10^6 \text{DFL}_{Tao} F_{fT} Q_f U_{am} [0.75(0.5/H)] f_p \exp(-\lambda_T t_s) \cdot \frac{(1-\exp(-\lambda_T t_{ep}))}{\lambda_T t_{ep}} \frac{(1-\exp(-\lambda_T t_{cb}))}{\lambda_T t_{cb}}$$

where:

- 10^3 = conversion factor, g/kg.
- 10^6 = conversion factor, pCi/ μCi .
- DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
- F_{fT} = transfer factor for tritium from cow's feed to meat, days/kg (Table 6.2).
- Q_f = cow's consumption rate, kg/day.
- U_{am} = meat ingestion rate for age group a, kg/year.
- 0.75 = the fraction of total feed that is water.
- 0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water.
- H = absolute humidity of the atmosphere, g/ m^3 .
- f_p = fraction of time cow spends on pasture, dimensionless.
- λ_T = decay constant for tritium, seconds⁻¹ (Table 6.2).
- t_s = transport time from slaughter to consumer, seconds.
- t_{ep} = time pasture is exposed to deposition, seconds.
- t_{cb} = time for receptor to consume a whole beef, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.10 Tritium-Stored Feed-Beef Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{\text{MTS}} = 10^3 10^6 \text{DFL}_{\text{Tao}} F_{\text{fT}} Q_{\text{f}} U_{\text{am}} [0.75(0.5/H)] f_{\text{s}} \exp(-\lambda_{\text{T}} t_{\text{s}}) \frac{(1-\exp(-\lambda_{\text{T}} t_{\text{csf}}))}{\lambda_{\text{T}} t_{\text{csf}}} \frac{(1-\exp(-\lambda_{\text{T}} t_{\text{cb}}))}{\lambda_{\text{T}} t_{\text{cb}}}$$

where:

- 10^3 = conversion factor, g/kg.
- 10^6 = conversion factor, pCi/ μCi .
- DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
- F_{fT} = transfer factor for tritium from cow's feed to meat, days/kg (Table 6.2).
- Q_{f} = cow's consumption rate, kg/day.
- U_{am} = meat ingestion rate for age group a, kg/year.
- 0.75 = the fraction of total feed that is water.
- 0.5 = the ratio of the specific activity of the feed grass water to the atmospheric water.
- H = absolute humidity of the atmosphere, g/m^3 .
- f_{s} = fraction of time cow spends on stored feed, dimensionless.
- λ_{T} = decay constant for tritium, seconds^{-1} (Table 6.2).
- t_{s} = transport time from slaughter to consumer, seconds.
- t_{csf} = time between harvest of stored feed and consumption by animal, seconds.
- t_{cb} = time for receptor to consume a whole beef, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.



7.8.11 Tritium-Fresh Leafy Vegetable Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{VTF} = 10^3 10^6 \text{DFL}_{\text{Tao}} [0.75(0.5/H)] U_{\text{FLa}} f_L \exp(-\lambda_T t_{\text{hc}})$$

where:

- 10^3 = conversion factor, g/kg.
 10^6 = conversion factor, pCi/ μCi .
 DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
0.75 = the fraction of total vegetation that is water.
0.5 = the ratio of the specific activity of the vegetables water to the atmospheric water.
H = absolute humidity of the atmosphere, g/m^3 .
 U_{FLa} = consumption rate of fresh leafy vegetables by the receptor in age group a, kg/year.
 f_L = fraction of fresh leafy vegetables grown locally, dimensionless.
 λ_T = decay constant for tritium, seconds^{-1} (Table 6.2).
 t_{hc} = time between harvest of vegetables and their consumption and/or storage, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.

7.8.12 Tritium-Stored Vegetables Dose Factor
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{VTS} = 10^3 10^6 \text{DFL}_{\text{Tao}} [0.75(0.5/H)] U_{\text{Sa}} f_g \frac{(1 - \exp(-\lambda_T t_{\text{sv}}))}{\lambda_T t_{\text{sv}}} \exp(-\lambda_T t_{\text{hc}})$$

where:

- 10^3 = conversion factor, g/kg.
 10^6 = conversion factor, pCi/ μCi .
 DFL_{Tao} = ingestion dose conversion factor for tritium for age group a, organ o, mrem/pCi (Table 6.4).
0.75 = the fraction of total vegetation that is water.
0.5 = the ratio of the specific activity of the vegetation water to the atmospheric water.
H = absolute humidity of the atmosphere, g/ m^3 .
 U_{Sa} = consumption rate of stored vegetables by the receptor in age group a, kg/year.
 f_g = fraction of stored vegetables grown locally, dimensionless.
 λ_T = decay constant for tritium, seconds $^{-1}$ (Table 6.2).
 t_{sv} = time between harvest of stored vegetables and their consumption and/or storage, seconds.
 t_{hc} = time between harvest of vegetables and their storage, seconds.

NOTE: Factors defined above which do not reference a table for their numerical values, are listed in Table 6.3.



7.8.13 Inhalation Dose Factors
(mrem/year per $\mu\text{Ci}/\text{m}^3$)

$$R_{i} = \text{DFA}_{iao} \text{BR}_a 10^6$$

where:

DFA_{iao} = inhalation dose conversion factor for nuclide i, age group a and organ o, mrem/pCi (Table 7.7).

BR_a = breathing rate for age group a, m^3/year (Table 6.3).

10^6 = conversion factor, pCi/ μCi .

7.8.14 Ground Plane Dose Factors
(m^2 -mrem/year per $\mu\text{Ci}/\text{second}$)

$$R_{Gi} = \text{DF}_{Gio} (1/\lambda_i) 10^6 8760 [1 - \exp(-\lambda_i t_b)]$$

where:

DF_{Gio} = dose conversion factor for standing on contaminated ground for nuclide i and organ o (total body and skin), mrem/hr per pCi/ m^2 (Table 6.6).

λ_i = decay constant of nuclide i, seconds⁻¹ (Table 6.2).

10^6 = conversion factor, pCi/ μCi .

8760 = conversion factor, hours/year.

t_b = time period over which the ground accumulation is evaluated, seconds (Table 6.3).

7.9 DISPERSION METHODOLOGY

Dispersion factors are calculated for radioactive effluent releases using hourly average meteorological data collected onsite.

Meteorological data for ground level releases consist of windspeed and direction measurements at 10m and temperature measurements of 10m and 45 m.

Hourly average meteorological data for the ground level portion of a split level release consist of wind speeds and directions measured at the 10m level and temperature measurements at 10m and 45m. The elevated portion of the split level release uses wind speeds and directions measured at the 46m level and temperature measurements at 45m and 90m.

Raw meteorological data for the elevated releases consist of windspeed and directions measured at 93m. Stability class D is assumed to persist during the entire period for elevated releases, except for the dose calculations described in Section 7.7 when all stability classes will be used to evaluate the elevated results.

Meteorological data are expressed as a joint-frequency distribution of wind speed, wind direction, and atmospheric stability for each release level (ground, split and elevated). The joint-frequency distributions which represent the historical meteorological data for the period January 1977 to December 1979 are given in Table 7.3.

The wind speed classes that are used are as follows:

<u>Number</u>	<u>Range (m/s)</u>	<u>Midpoint (m/s)</u>
1	<0.3	0.13
2	0.3-0.6	0.45
3	0.7-1.5	1.10
4	1.6-2.4	1.99
5	2.5-3.3	2.88
6	3.4-5.5	4.45
7	5.6-8.2	6.91
8	8.3-10.9	9.59
9	>10.9	10.95

The stability classes that will be used are the standard A through G classifications. The stability classes 1-7 will correspond to A=1, B=2, ..., G=7.

A sector-average dispersion equation consistent with Regulatory Guide 1.111 is used. The dispersion model considers plume depletion (using information from Figure 7.3), and building wake effects. Terrain effects on dispersion are not considered except for reducing the effective height of an elevated release by the terrain height.

7.9.1 Annual Average Air Concentration
 \bar{X} ($\mu\text{Ci-year}/\text{m}^3$)

Air concentrations of nuclides at downwind locations are calculated using the following equation:

$$\bar{X}_i = \sum_{j=1}^9 \sum_{k=1}^7 \frac{(2/\pi)^{1/2} f_{jk} Q_i P}{\Sigma_{zk} u_j (2\pi x/n)} \exp(-\lambda_i x/u_j) \exp(-h_e^2/2\sigma_{zk}^2) 10^6 3.17\text{E-}08 \quad (7.11)$$

where:

f_{jk} = joint relative frequency of occurrence of winds in windspeed class j , stability class k , blowing toward this exposure point, expressed as a fraction.

Q_i = amount released of radionuclide i , Ci.

P = fraction of radionuclide remaining in plume (Figure 7.3).

Σ_{zk} = vertical dispersion coefficient for stability class k which includes a building wake adjustment,
 $= (\sigma_{zk}^2 + cA/\pi)^{1/2}$,

or $= \sqrt{3} \sigma_{zk}$, whichever is smaller (for ground level releases).

where

σ_{zk} is the vertical dispersion coefficient for stability class k (m) (Figure 7.4),

c is a building shape factor ($c=0.5$),

A is the minimum building cross-sectional area (2400 m^2).

u_j = midpoint value of wind speed class interval j , m/s.

x = downwind distance, m.

n = number of sectors, 16.

λ_i = radioactive decay coefficient of radionuclide i , s^{-1}

$2\pi x/n$ = sector width at point of interest, m.

h_e = effective release height, m. The effective release height is calculated as described in Section 7.9.4.

10^6 = conversion factor, μCi per Ci.

$3.17\text{E-}08$ = conversion factor, years per second.

7.9.2 Relative Concentration
 x/Q (sec/m³)

Relative concentrations of nuclides at downwind locations are calculated using the following equation:

$$x/Q = \sum_{j=1}^9 \sum_{k=1}^7 (2/\pi)^{1/2} \frac{f_{jk}}{\Sigma_{zk} u_j (2\pi x/n)} \exp(-h_e^2/2\sigma_{zk}^2) \quad (7.12)$$

where:

f_{jk} = joint relative frequency of occurrence of winds in windspeed class j, stability class k, blowing toward this exposure point, expressed as a fraction.

Σ_{zk} = vertical dispersion coefficient for stability class k which includes a building wake adjustment,

$$= (\sigma_{zk}^2 + cA/\pi)^{1/2},$$

or = $\sqrt{3} \sigma_{zk}$, whichever is smaller (for ground level releases).

where

σ_{zk} is the vertical dispersion coefficient for stability class k (m) (Figure 7.4),

c is a building shape factor (c=0.5),

A is the minimum building cross-sectional area (2400 m²).

u_j = midpoint value of wind speed class interval j, m/s.

x = downwind distance, m.

n = number of sectors, 16.

$2\pi x/n$ = sector width at point of interest, m.

h_e = effective release height, m. The effective release height is calculated as described in Section 7.9.4.

7.9.3 Relative Dispersion
 D/Q (m⁻²)

Relative deposition of nuclides at downwind locations is calculated using the following equation:

$$D/Q = \sum_{j=1}^9 \sum_{k=1}^7 \frac{f_{jk} DR}{(2\pi x/n)} \quad (7.13)$$

where:

f_k = joint relative frequency of occurrence of winds in windspeed class j and stability class k, blowing toward this exposure point, expressed as a fraction.

DR = relative deposition rate, m⁻¹ (from Figure 7.5). The choice of figures is governed by the effective release height calculation described in Section 7.9.4. A linear interpolation is used for effluent release heights that fall in between the given curves.

x = downwind distance, m.

n = number of sectors, 16.

$2\pi x/n$ = sector width at point of interest, m.

7.9.4 Effective Release Height

For effluents exhausted from release points that are higher than twice the height of adjacent structures (elevated releases) the effective release height is determined by the following equation, consistent with Regulatory Guide 1.111

$$h_e = h_s + h_{pr} - h_t - c$$

where:

c = downwash correction factor for low relative exit velocity,
= $3(1.5 - W_0/u)d$,

where

W_0 = the vertical plume exit velocity, m/s.

u = mean wind speed at the height of the release, m/s.

d = inside diameter of the release point, m.

NOTE: If c is less than zero, it is set equal to zero.

h_{pr} = plume rise above the release point, m.

h_s = physical height of release point, m.

h_t = maximum terrain height between release point and receptor location, m.

For effluents released from points less than the height of adjacent structures, a ground level release is assumed ($h_e = 0$).

For effluents released from points at the level of or above adjacent structures, but lower than elevated release points, releases are treated as follows:

Case 1 - elevated if $W_0/u \geq 5$.

Case 2 - ground level ($h_e = 0$) if $W_0/u \leq 1$.

Case 3 - split level if $1 < W_0/u < 5$.

Under Case 3 a split level dispersion approach is implemented using a model that requires for each release point two JFDs, one for elevated releases and one for ground level releases. The summation of the elevated and ground level JFDs account for the total period of record. Releases are considered to be elevated $100(1 - E_t)$ percent of the time and ground level $100 E_t$ percent of the time where the entrainment coefficient, E_t , is defined by

$$E_t = 2.58 - 1.58(W_0/u) \text{ for } 1 < W_0/u \leq 1.5$$

$$E_t = 0.3 - 0.06(W_0/u) \text{ for } 1.5 < W_0/u \leq 5$$

Table 7.1
BFN - OFFSITE RECEPTOR LOCATION DATA

POINT	DISTANCE from plant (m)	Elev above plant grade (m)	GROUND LEVEL		ELEVATED		
			X/Q (s/m ³)	D/Q (1/m ²)	X/Q (s/m ³)	D/Q (1/m ²)	
Site Boundary	1525	N	7	1.60E-06	5.64E-09	N/A	N/A
Site Boundary	1300	NNE	4	7.88E-07	1.97E-09	N/A	N/A
Site Boundary	1250	NE	7	4.52E-07	1.56E-09	N/A	N/A
Site Boundary	1450	ENE	0	7.30E-07	2.92E-09	N/A	N/A
Site Boundary	1375	E	0	8.24E-07	4.04E-09	N/A	N/A
Site Boundary	1575	ESE	0	4.56E-07	3.28E-09	N/A	N/A
Site Boundary	5600	SE	-6	7.61E-08	3.63E-10	N/A	N/A
Site Boundary	2875	SSE	-6	4.86E-07	1.77E-09	N/A	N/A
Site Boundary	2550	S	-6	8.27E-07	2.24E-09	N/A	N/A
Site Boundary	2425	SSW	-6	1.08E-06	2.92E-09	N/A	N/A
Site Boundary	2300	SW	-6	6.87E-07	1.75E-09	N/A	N/A
Site Boundary	2500	WSW	-6	6.38E-07	1.14E-09	N/A	N/A
Site Boundary	2550	W	-6	6.70E-07	1.25E-09	N/A	N/A
Site Boundary	3325	WNW	-6	3.69E-07	9.07E-10	N/A	N/A
Site Boundary	2275	NW	-6	1.69E-06	4.92E-09	N/A	N/A
Site Boundary	1650	NNW	-6	1.84E-06	5.29E-09	N/A	N/A
Air Dose Point	6100	NW	-6	N/A	N/A	2.08E-08	4.75E-10
Garden	1830	NNW	34	1.57E-06	4.46E-09	N/A	1.13E-09
Garden	4437	E	19	N/A	N/A	9.50E-09	N/A
Milk Cow	8045	N	34	1.47E-07	3.16E-10	N/A	2.30E-10
Milk Cow	10975	NNW	34	N/A	N/A	1.69E-08	N/A

NOTE: For quarterly dose calculations, doses will also be calculated for all locations identified in the most recent land use census, and for any additional points deemed necessary.



Table 7.2
EXPECTED ANNUAL ROUTINE ATMOSPHERIC RELEASES FROM ONE UNIT AT BFN

Isotope	Building Vents (Ci/yr/Unit)			Stack (Ci/yr/Unit)	
	Reactor Complex Vent	Radwaste Building Vent	Turbine Building Vent	Gland Seal and Offgas	MVP
Kr-85m	6E+0	< 1	2E+0	1.66E+4	0.0E+0
Kr-85	-	-	-	6.3E+2	-
Kr-87	6E+0	< 1	9.5E+1	7.47E+2	0.0E+0
Kr-88	9E+0	< 1	1.02E+2	1.35E+4	0.0E+0
Kr-89	1E+0	3.4E+1	5.03E+2	4.10E+3	0.0E+0
Xe-131m	-	-	-	3.09E+2	0.0E+0
Xe-133m	0E+0	6.0E+1	0E+0	8.51E+2	0.0E+0
Xe-133	1.03E+2	2.94E+2	5.81E+2	9.47E+4	3.0E+2
Xe-135m	1.11E+2	6.67E+2	4.64E+2	9.17E+2	0.0E+0
Xe-135	1.73E+2	3.28E+2	6.72E+2	5.99E+2	2.0E+2
Xe-137	7.8E+1	1.13E+2	3.86E+2	5.04E+3	0.0E+0
Xe-138	1.2E+1	2E+0	1.18E+3	3.15E+3	0.0E+0
I-131 I	5.94E-2	5.0E-3	1.56E-2	4.1E-3	8.5E-3
I-132 I	5.94E-1	5.0E-2	1.79E-1	4.69E-2	9.73E-2
I-133 I	2.97E-1	2.5E-2	1.23E-1	3.23E-2	6.71E-2
I-134 I	1.49E+0	1.25E-1	2.67E-2	7.0E-3	1.45E-2
I-135 I	5.94E-1	5.0E-2	1.23E-1	3.23E-2	6.71E-2
I-131 O	3.16E-2	2.9E-2	6.5E-3	3.32E-2	2.74E-1
I-132 O	3.16E-1	2.9E-1	7.44E-2	3.80E-1	3.14E+0
I-133 O	1.58E-1	1.45E-1	5.13E-2	2.62E-1	2.16E+0
I-134 O	7.90E-1	7.25E-1	1.11E-2	5.68E-2	4.69E-1
I-135 O	3.16E-1	2.90E-1	5.13E-2	2.61E-1	2.16E+0
Cr-51	3E-3	9E-4	1E-3	1E-4	0.0E+0
Mn-54	3E-3	5E-3	2E-3	4E-5	0.0E+0
Co-58	2E-3	4E-4	9E-5	2E-5	0.0E+0
Fe-59	1E-4	8E-4	4E-4	2E-4	0.0E+0
Co-60	3E-2	6E-3	3E-3	1E-5	0.0E+0
Zn-65	3E-3	2E-4	4E-4	9E-5	0.0E+0
Sr-89	1E-2	3E-1	*	*	0.0E+0
Sr-90	2E-3	4E-3	*	*	0.0E+0
Nb-95	3E-4	2E-4	9E-6	8E-5	0.0E+0
Zr-95	1E-4	1E-4	8E-6	8E-5	0.0E+0
Ru-103	3E-5	1E-4	2E-4	1E-4	0.0E+0
Ag-110m	7E-6	*	*	*	0.0E+0
Sb-124	3E-5	3E-4	6E-5	8E-5	0.0E+0
Cs-134	5E-3	3E-4	5E-4	2E-5	0.0E+0
Cs-136	2E-3	5E-5	1E-4	9E-8	0.0E+0
Cs-137	7E-3	4E-4	2E-3	7E-4	0.0E+0
Ba-140	4E-3	5E-4	2E-2	8E-3	0.0E+0
Ce-141	4E-4	2E-4	2E-3	2E-5	0.0E+0
Ce-144	5E-6	*	*	4E-6	0.0E+0
Ar-41	2.5E+1	0E+0	0E+0	0E+0	0.0E+0
C-14	0E+0	0E+0	0E+0	9.5E+0	0.0E+0
H-3	0E+0	9.5E+0	0E+0	0E+0	0.0E+0

* Not available.

I denotes nonorganic iodine (elemental, particulate, HIO), O denotes organic iodine.

600(207)

Table 7.3 (1 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class A (Delta-T_c -1.9 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)							Total	
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		≥24.5
N	0.0	0.0	0.0	0.04	0.12	0.05	0.0	0.0	0.21
NNE	0.0	0.0	0.0	0.05	0.19	0.10	0.0	0.0	0.34
NE	0.0	0.0	0.0	0.04	0.06	0.0	0.0	0.0	0.10
ENE	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
E	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.01
ESE	0.0	0.01	0.11	0.17	0.02	0.0	0.0	0.0	0.31
SE	0.0	0.03	1.11	0.40	0.02	0.0	0.0	0.0	1.56
SSE	0.0	0.04	0.52	0.10	0.02	0.0	0.0	0.0	0.68
S	0.0	0.01	0.38	0.11	0.04	0.0	0.0	0.0	0.54
SSW	0.0	0.0	0.04	0.05	0.01	0.0	0.0	0.0	0.10
SW	0.0	0.0	0.05	0.04	0.0	0.0	0.0	0.0	0.09
WSW	0.0	0.0	0.04	0.07	0.04	0.0	0.0	0.0	0.15
W	0.0	0.0	0.01	0.05	0.05	0.01	0.0	0.0	0.12
WNW	0.0	0.0	0.02	0.03	0.09	0.06	0.0	0.0	0.20
NW	0.0	0.0	0.0	0.02	0.17	0.11	0.0	0.0	0.30
NNW	0.0	0.0	0.01	0.01	0.06	0.09	0.02	0.0	0.19
Sub- total	0.0	0.09	2.29	1.19	0.90	0.42	0.02	0.0	4.91

Total hours of valid stability observations - 25935

Total hours of Stability Class A - 1262

Total hours of valid wind direction-wind speed-Stability Class A - 1259

Total hours calm - 0

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN

Stability based on Delta-T measured between 10.03 and 45.30 meters

Wind speed and direction measured at the 10.42 meter level

Mean wind speed = 6.8 mph

Table 7.3 (2 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class B (-1.9 < Delta-T_c -1.7 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	>24.5	
NN	0.0	0.0	0.05	0.09	0.30	0.04	0.01	0.0	0.49
NNE	0.0	0.0	0.05	0.07	0.27	0.05	0.0	0.0	0.44
NE	0.0	0.0	0.04	0.02	0.09	0.01	0.0	0.0	0.16
ENE	0.0	0.01	0.01	0.01	0.01	0.0	0.0	0.0	0.04
E	0.0	0.0	0.02	0.01	0.0	0.0	0.0	0.0	0.03
ESE	0.0	0.02	0.10	0.04	0.0	0.0	0.0	0.0	0.16
SE	0.0	0.13	0.64	0.09	0.02	0.0	0.0	0.0	0.88
SSE	0.0	0.09	0.31	0.02	0.01	0.0	0.0	0.0	0.43
S	0.0	0.05	0.42	0.07	0.02	0.0	0.0	0.0	0.56
SSW	0.0	0.02	0.07	0.01	0.0	0.0	0.0	0.0	0.10
SW	0.0	0.0	0.17	0.02	0.0	0.0	0.0	0.0	0.19
WSW	0.0	0.0	0.11	0.13	0.05	0.01	0.0	0.0	0.30
W	0.0	0.02	0.04	0.17	0.17	0.03	0.0	0.0	0.43
WNW	0.0	0.0	0.07	0.11	0.23	0.08	0.04	0.0	0.53
NW	0.0	0.0	0.01	0.07	0.27	0.13	0.01	0.0	0.49
NNW	0.0	0.0	0.0	0.07	0.19	0.12	0.0	0.0	0.38
Sub- total	0.0	0.34	2.11	1.00	1.63	0.47	0.06	0.0	5.61

Total hours of valid stability observations - 25935
Total hours of Stability Class B - 1445
Total hours of valid wind direction-wind speed-Stability Class B - 1440
Total hours calm - 0

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T measured between 10.03 and 45.30 meters
Wind speed and direction measured at the 10.42 meter level
Mean wind speed = 7.2 mph



Table 7.3 (3 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class C (-1.7 < Delta-T_c -1.5 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)							≥24.5	Total
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		
N	0.0	0.01	0.08	0.11	0.21	0.02	0.0	0.0	0.43
NNE	0.0	0.01	0.07	0.09	0.17	0.20	0.0	0.0	0.36
NE	0.0	0.0	0.03	0.08	0.05	0.0	0.0	0.0	0.16
ENE	0.0	0.0	0.02	0.02	0.0	0.0	0.0	0.0	0.04
E	0.0	0.0	0.03	0.02	0.0	0.0	0.0	0.0	0.05
ESE	0.0	0.01	0.05	0.02	0.0	0.0	0.0	0.0	0.08
SE	0.0	0.17	0.29	0.09	0.01	0.0	0.0	0.0	0.56
SSE	0.0	0.12	0.17	0.04	0.01	0.0	0.0	0.0	0.34
S	0.0	0.11	0.25	0.04	0.02	0.0	0.0	0.0	0.42
SSW	0.0	0.03	0.06	0.01	0.0	0.0	0.0	0.0	0.10
SW	0.0	0.03	0.12	0.03	0.01	0.0	0.0	0.0	0.19
WSW	0.0	0.0	0.11	0.07	0.07	0.0	0.0	0.0	0.25
W	0.0	0.0	0.05	0.12	0.10	0.02	0.01	0.0	0.30
WNW	0.0	0.01	0.12	0.13	0.17	0.07	0.04	0.0	0.54
NW	0.0	0.0	0.05	0.09	0.22	0.10	0.01	0.0	0.47
NNW	0.0	0.0	0.02	0.08	0.18	0.10	0.0	0.0	0.38
Sub- total	0.0	0.50	1.52	1.04	1.22	0.33	0.06	0.0	4.67

Total hours of valid stability observations - 25935
Total hours of Stability Class C 1202
Total hours of valid wind direction-wind speed-Stability Class C - 1197
Total hours calm - 0

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T measured between 10.03 and 45.30 meters
Wind speed and direction measured at the 10.42 meter level
Mean wind speed = 7.0 mph

Table 7.3 (4 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class D ($-1.5 < \Delta T < -0.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.0	0.19	0.41	0.53	1.00	0.37	0.01	0.0	2.51
NNE	0.01	0.20	0.56	0.58	1.18	0.18	0.01	0.0	2.72
NE	0.01	0.12	0.38	0.43	0.52	0.01	0.0	0.0	1.47
ENE	0.0	0.26	0.23	0.15	0.05	0.01	0.0	0.0	0.70
E	0.0	0.20	0.31	0.17	0.05	0.0	0.0	0.0	0.73
ESE	0.0	0.24	0.51	0.30	0.08	0.0	0.0	0.0	1.13
SE	0.02	1.16	1.31	0.83	0.26	0.0	0.0	0.0	3.58
SSE	0.01	0.99	0.99	0.26	0.11	0.02	0.0	0.0	2.38
S	0.0	0.92	1.17	0.34	0.17	0.0	0.0	0.0	2.60
SSW	0.0	0.45	0.29	0.08	0.04	0.0	0.0	0.0	0.86
SW	0.0	0.24	0.29	0.09	0.02	0.01	0.0	0.0	0.65
WSW	0.0	0.32	0.70	0.29	0.33	0.11	0.0	0.0	1.75
W	0.0	0.18	0.55	0.62	0.63	0.22	0.03	0.0	2.23
WNW	0.0	0.13	0.39	0.42	1.10	0.82	0.22	0.01	3.09
NW	0.0	0.04	0.28	0.38	1.01	0.87	0.14	0.02	2.74
NNW	0.0	0.13	0.40	0.55	1.54	0.74	0.05	0.0	3.41
Sub- total	0.05	5.77	8.77	6.02	8.09	3.36	0.46	0.03	32.55

Total hours of valid stability observations - 25935

Total hours of Stability Class D - 8438

Total hours of valid wind direction-wind speed-Stability Class D - 8341

Total hours calm - 1

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN

Stability based on Delta-T measured between 10.03 and 45.30 meters

Wind speed and direction measured at the 10.42 meter level

Mean wind speed = 7.1 mph



Table 7.3 (5 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class E ($-0.5 < \Delta T < 1.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.04	0.47	0.54	0.43	0.41	0.05	0.01	0.0	1.95
NNE	0.05	0.61	0.74	0.55	0.47	0.04	0.0	0.0	2.46
NE	0.05	0.57	0.63	0.42	0.27	0.02	0.0	0.0	1.96
ENE	0.05	0.71	0.45	0.17	0.08	0.02	0.0	0.0	1.48
E	0.04	0.61	0.74	0.16	0.07	0.0	0.0	0.0	1.62
ESE	0.03	0.76	1.01	0.53	0.16	0.01	0.0	0.0	2.50
SE	0.11	2.04	1.75	0.92	0.55	0.02	0.0	0.0	5.39
SSE	0.07	1.16	0.78	0.48	0.33	0.04	0.0	0.0	2.86
S	0.05	1.03	0.74	0.44	0.63	0.14	0.01	0.0	3.04
SSW	0.02	0.52	0.14	0.08	0.06	0.01	0.0	0.0	0.83
SW	0.04	0.30	0.07	0.02	0.03	0.0	0.0	0.0	0.46
WSW	0.01	0.53	0.60	0.14	0.11	0.04	0.0	0.0	1.43
W	0.02	0.37	0.77	0.42	0.27	0.04	0.0	0.0	1.89
WNW	0.03	0.15	0.13	0.11	0.22	0.09	0.02	0.0	0.75
NW	0.02	0.17	0.20	0.14	0.25	0.09	0.02	0.0	0.89
NNW	0.05	0.41	0.48	0.54	0.59	0.09	0.01	0.0	2.17
Sub- total	0.68	10.41	9.77	5.55	4.50	0.70	0.07	0.0	31.68

Total hours of valid stability observations - 25935

Total hours of Stability Class E - 8264

Total hours of valid wind direction-wind speed-Stability Class E - 8098

Total hours calm - 3

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN

Stability based on Delta-T measured between 10.03 and 45.30 meters

Wind speed and direction measured at the-10.42 meter level

Mean wind speed = 5.0 mph



Table 7.3 (6 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class F (1.5 < Delta-T < 4.0 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)							Total	
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		≥24.5
N	0.05	0.36	0.52	0.28	0.06	0.0	0.0	0.0	1.27
NNE	0.05	0.51	0.66	0.34	0.11	0.0	0.0	0.0	1.67
NE	0.07	0.34	0.27	0.18	0.01	0.0	0.0	0.0	0.87
ENE	0.03	0.53	0.33	0.05	0.0	0.0	0.0	0.0	0.94
E	0.01	0.59	0.52	0.03	0.0	0.0	0.0	0.0	1.15
ESE	0.0	0.52	0.22	0.0	0.0	0.0	0.0	0.0	0.74
SE	0.09	0.97	0.48	0.17	0.13	0.01	0.0	0.0	1.85
SSE	0.05	0.54	0.34	0.17	0.25	0.02	0.01	0.0	1.38
S	0.03	0.29	0.18	0.20	0.27	0.01	0.0	0.0	0.98
SSW	0.03	0.13	0.03	0.0	0.01	0.0	0.0	0.0	0.20
SW	0.0	0.09	0.03	0.0	0.0	0.0	0.0	0.0	0.12
WSW	0.0	0.09	0.07	0.0	0.0	0.0	0.0	0.0	0.16
W	0.02	0.09	0.06	0.0	0.01	0.0	0.0	0.0	0.18
WNW	0.01	0.08	0.01	0.0	0.0	0.0	0.0	0.0	0.10
NW	0.01	0.08	0.04	0.01	0.0	0.0	0.0	0.0	0.14
NNW	0.05	0.27	0.27	0.16	0.05	0.0	0.0	0.0	0.80
Sub- total	0.50	5.48	4.03	1.59	0.90	0.04	0.01	0.0	12.55

Total hours of valid stability observations - 25935

Total hours of Stability Class F - 3268

Total hours of valid wind direction-wind speed-Stability Class F - 3223

Total hours calm - 2

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN

Stability based on Delta-T measured between 10.03 and 45.30 meters

Wind speed and direction measured at the 10.42 meter level

Mean wind speed = 4.0 mph



Table 7.3 (7 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class G (Delta-T > 4.0 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)							Total	
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		>24.5
N	0.07	0.76	0.32	0.02	0.0	0.0	0.0	0.0	1.17
NNE	0.05	0.83	0.51	0.18	0.02	0.0	0.0	0.0	1.59
NE	0.04	0.34	0.12	0.02	0.0	0.0	0.0	0.0	0.52
ENE	0.04	0.48	0.18	0.02	0.0	0.0	0.0	0.0	0.72
E	0.02	0.52	0.34	0.0	0.0	0.0	0.0	0.0	0.88
ESE	0.01	0.18	0.01	0.0	0.0	0.0	0.0	0.0	0.20
SE	0.08	0.43	0.09	0.04	0.03	0.0	0.0	0.0	0.67
SSE	0.03	0.44	0.31	0.16	0.08	0.0	0.0	0.0	1.02
S	0.05	0.09	0.12	0.10	0.04	0.0	0.0	0.0	0.40
SSW	0.05	0.05	0.01	0.0	0.0	0.0	0.0	0.0	0.11
SW	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.01
WSW	0.02	0.02	0.0	0.0	0.0	0.0	0.0	0.0	0.04
W	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.02
WNW	0.01	0.02	0.0	0.0	0.0	0.0	0.0	0.0	0.03
NW	0.04	0.04	0.0	0.0	0.0	0.0	0.0	0.0	0.08
NNW	0.05	0.23	0.12	0.03	0.0	0.0	0.0	0.0	0.43
Sub- total	0.57	4.45	2.13	0.57	0.17	0.0	0.0	0.0	7.89

Total hours of valid stability observations - 25935
Total hours of Stability Class G - 2056
Total hours of valid wind direction-wind speed-Stability Class G - 2019
Total hours calm - 4

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T measured between 10.03 and 45.30 meters
Wind speed and direction measured at the 10.42 meter level
Mean wind speed = 3.2 mph

Table 7.3 (8 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Disregarding Stability Class
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total
	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥24.5	
N	0.02	0.19	0.38	0.64	2.07	2.47	0.61	0.06	6.44
NNE	0.0	0.13	0.33	0.60	2.46	2.69	0.50	0.04	6.75
NE	0.0	0.12	0.35	0.64	2.16	1.85	0.58	0.02	5.72
ENE	0.02	0.14	0.32	0.36	1.15	0.95	0.34	0.04	3.32
E	0.0	0.22	0.47	0.45	0.99	0.43	0.08	0.01	2.65
ESE	0.01	0.23	0.53	0.66	1.79	1.63	0.42	0.09	5.36
SE	0.02	0.36	1.26	1.36	3.25	3.20	1.54	0.69	11.68
SSE	0.01	0.38	1.20	1.22	2.97	2.59	1.16	0.59	10.12
S	0.02	0.40	0.90	1.05	2.53	2.40	1.03	0.43	8.76
SSW	0.0	0.31	0.65	0.69	1.73	1.77	0.73	0.19	6.07
SW	0.02	0.38	0.66	0.69	1.55	1.62	0.50	0.14	5.56
WSW	0.01	0.26	0.69	0.68	1.15	1.05	0.36	0.17	4.37
W	0.02	0.20	0.66	0.81	1.76	1.04	0.42	0.35	5.26
WNW	0.01	0.17	0.46	0.69	2.03	1.54	0.76	0.30	5.96
NW	0.02	0.19	0.49	0.70	1.80	2.01	0.96	0.28	6.45
NNW	0.01	0.22	0.28	0.41	1.66	2.13	0.70	0.13	5.54
Sub- total	0.19	3.90	9.63	11.65	31.05	29.37	10.69	3.53	100.01

Total hours of valid wind observations - 25784
Total hours of observations - 26280
Recoverability percentage - 98.1
Total hours calm - 2

All columns and calm total 100 percent of joint valid observations

Meteorological facility: located 1.3 km ESE of BFN
Wind speed and direction measured at the 92.63 meter level
Mean wind speed = 12.0 mph

Table 7.3 (9 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class A (Delta-T < -1.9 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 1 of 2 ground level release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total	
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		>24.5
N	0.0	0.0	0.0	0.0	0.0	0.02	0.01	0.0	0.0	0.03
NNE	0.0	0.0	0.0	0.0	0.0	0.03	0.02	0.0	0.0	0.05
NE	0.0	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.01
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.02	0.0	0.0	0.0	0.0	0.02
SE	0.0	0.0	0.0	0.05	0.04	0.01	0.0	0.0	0.0	0.10
SSE	0.0	0.0	0.0	0.03	0.02	0.01	0.0	0.0	0.0	0.06
S	0.0	0.0	0.0	0.02	0.02	0.01	0.0	0.0	0.0	0.05
SSW	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.02
W	0.0	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.01
WNW	0.0	0.0	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.02
NW	0.0	0.0	0.0	0.0	0.0	0.02	0.02	0.0	0.0	0.04
NNW	0.0	0.0	0.0	0.0	0.0	0.01	0.02	0.02	0.0	0.05
Sub- total	0.0	0.0	0.0	0.10	0.12	0.15	0.08	0.02	0.0	0.47

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class A - 133.1
Total hours of ground level Stability Class A - 127.5

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 10.03 and 45.30 meters
Wind direction measured at 10.42 meter level
Wind speed measured at 10.42 meter level -
Effluent velocity = 12.60 m/s

Table 7.3 (10 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class B ($-1.9 < \Delta T \leq -1.7$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 1 of 2 ground level release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.0	0.0	0.0	0.0	0.01	0.05	0.01	0.01	0.0	0.08
NNE	0.0	0.0	0.0	0.0	0.01	0.05	0.01	0.0	0.0	0.07
NE	0.0	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.01
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
SE	0.0	0.0	0.0	0.02	0.02	0.01	0.0	0.0	0.0	0.05
SSE	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.02
S	0.0	0.0	0.0	0.02	0.01	0.01	0.0	0.0	0.0	0.04
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.02	0.01	0.0	0.0	0.0	0.03
W	0.0	0.0	0.0	0.0	0.01	0.02	0.02	0.01	0.0	0.06
WNW	0.0	0.0	0.0	0.0	0.01	0.03	0.02	0.03	0.0	0.09
NW	0.0	0.0	0.0	0.0	0.01	0.04	0.03	0.0	0.0	0.08
NNW	0.0	0.0	0.0	0.0	0.0	0.03	0.04	0.0	0.0	0.07
Sub- total	0.0	0.0	0.0	0.05	0.12	0.26	0.13	0.05	0.0	0.61

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class B - 185.1
Total hours of ground level Stability Class B - 163.4

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 10.03 and 45.30 meters
Wind direction measured at 10.42 meter level
Wind speed measured at 10.42 meter level-
Effluent velocity = 12.60 m/s

Table 7.3 (11 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class C ($-1.7 < \Delta T_c < -1.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 1 of 2 ground level release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.0	0.0	0.0	0.0	0.01	0.03	0.0	0.0	0.0	0.04
NNE	0.0	0.0	0.0	0.0	0.01	0.02	0.0	0.0	0.0	0.03
NE	0.0	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.02
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.02
SSE	0.0	0.0	0.0	0.01	0.01	0.01	0.0	0.0	0.0	0.03
S	0.0	0.0	0.0	0.01	0.01	0.01	0.0	0.0	0.0	0.03
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.02
W	0.0	0.0	0.0	0.0	0.01	0.01	0.01	0.01	0.0	0.04
WNW	0.0	0.0	0.0	0.0	0.01	0.02	0.02	0.03	0.0	0.08
NW	0.0	0.0	0.0	0.0	0.01	0.03	0.02	0.01	0.0	0.07
NNW	0.0	0.0	0.0	0.0	0.01	0.02	0.03	0.0	0.0	0.06
Sub- total	0.0	0.0	0.0	0.03	0.11	0.17	0.08	0.05	0.0	0.44

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class C - 259.0
Total hours of ground level Stability Class C - 106.3

Meteorological facility: located 1.3 km ESE of BFN
Stability based on ΔT between 10.03 and 45.30 meters
Wind direction measured at 10.42 meter level
Effluent velocity = 12.60 m/s



Table 7.3 (12 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class D ($-1.5 < \Delta T_c < -0.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 1 of 2 ground level release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	>24.5	
N	0.0	0.0	0.0	0.01	0.04	0.15	0.10	0.01	0.0	0.31
NNE	0.0	0.0	0.0	0.01	0.05	0.18	0.05	0.01	0.0	0.30
NE	0.0	0.0	0.0	0.01	0.04	0.08	0.0	0.0	0.0	0.13
ENE	0.0	0.0	0.0	0.01	0.01	0.01	0.0	0.0	0.0	0.03
E	0.0	0.0	0.0	0.01	0.02	0.01	0.0	0.0	0.0	0.04
ESE	0.0	0.0	0.0	0.03	0.04	0.01	0.0	0.0	0.0	0.08
SE	0.0	0.0	0.01	0.11	0.13	0.06	0.0	0.0	0.0	0.31
SSE	0.0	0.0	0.02	0.09	0.06	0.05	0.02	0.0	0.0	0.24
S	0.0	0.0	0.02	0.09	0.06	0.06	0.0	0.0	0.0	0.23
SSW	0.0	0.0	0.01	0.02	0.01	0.01	0.0	0.0	0.0	0.05
SW	0.0	0.0	0.0	0.01	0.01	0.0	0.01	0.0	0.0	0.03
WSW	0.0	0.0	0.0	0.03	0.03	0.06	0.04	0.0	0.0	0.16
W	0.0	0.0	0.0	0.02	0.06	0.10	0.09	0.02	0.0	0.29
WNW	0.0	0.0	0.0	0.0	0.03	0.16	0.19	0.14	0.01	0.53
NW	0.0	0.0	0.0	0.0	0.03	0.15	0.23	0.10	0.02	0.53
NNW	0.0	0.0	0.0	0.01	0.05	0.25	0.19	0.04	0.0	0.54
Sub- total	0.0	0.0	0.6	0.46	0.67	1.34	0.92	0.32	0.03	3.80

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class D - 13904.1
Total hours of ground level Stability Class D - 968.6

Meteorological facility: located 1.3 km ESE of BFN
Stability based on ΔT between 10.03 and 45.30 meters
Wind direction measured at 10.42 meter level
Effluent velocity = 12.60 m/s

Table 7.3 (13 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class E ($-0.5 < \Delta T < 1.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 1 of 2 ground level release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	>24.5	
N	0.0	0.0	0.0	0.04	0.06	0.07	0.02	0.01	0.0	0.20
NNE	0.0	0.0	0.01	0.06	0.07	0.08	0.02	0.0	0.0	0.24
NE	0.0	0.0	0.01	0.06	0.06	0.05	0.01	0.0	0.0	0.19
ENE	0.0	0.0	0.02	0.04	0.03	0.01	0.01	0.0	0.0	0.11
E	0.0	0.0	0.02	0.07	0.02	0.01	0.0	0.0	0.0	0.12
ESE	0.0	0.0	0.02	0.08	0.07	0.03	0.0	0.0	0.0	0.20
SE	0.0	0.0	0.08	0.22	0.16	0.18	0.02	0.0	0.0	0.66
SSE	0.0	0.0	0.05	0.12	0.12	0.19	0.04	0.0	0.0	0.52
S	0.0	0.0	0.06	0.10	0.09	0.27	0.13	0.01	0.0	0.66
SSW	0.0	0.0	0.02	0.02	0.02	0.02	0.01	0.0	0.0	0.09
SW	0.0	0.0	0.01	0.0	0.0	0.01	0.0	0.0	0.0	0.02
WSW	0.0	0.0	0.01	0.05	0.02	0.03	0.02	0.0	0.0	0.13
W	0.0	0.0	0.01	0.06	0.05	0.05	0.01	0.0	0.0	0.18
WNW	0.0	0.0	0.0	0.01	0.01	0.04	0.02	0.01	0.0	0.09
NW	0.0	0.0	0.0	0.01	0.02	0.04	0.03	0.01	0.0	0.11
NNW	0.0	0.0	0.0	0.03	0.07	0.10	0.02	0.01	0.0	0.23
Sub- total	0.0	0.0	0.32	0.97	0.87	1.18	0.36	0.05	0.0	3.75

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class E - 7920.6
Total hours of ground level Stability Class E - 957.9

Meteorological facility: located 1.3 km ESE of BFN
Stability based on ΔT between 10.03 and 45.30 meters
Wind direction measured at 10.42 meter level
Wind speed measured at 10.42 meter level -
Effluent velocity = 12.60 m/s



Table 7.3 (14 of 22).
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class F ($1.5 < \Delta T \leq 4.0$ degrees C per 100 m)
Part 1 of 2 ground level release mode
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	Total
N	0.0	0.0	0.01	0.06	0.04	0.01	0.0	0.0	0.0	0.12
NNE	0.0	0.0	0.01	0.08	0.05	0.02	0.0	0.0	0.0	0.16
NE	0.0	0.0	0.01	0.03	0.03	0.0	0.0	0.0	0.0	0.07
ENE	0.0	0.0	0.02	0.03	0.01	0.0	0.0	0.0	0.0	0.06
E	0.0	0.0	0.01	0.04	0.0	0.0	0.0	0.0	0.0	0.05
ESE	0.0	0.0	0.02	0.02	0.0	0.0	0.0	0.0	0.0	0.04
SE	0.0	0.0	0.05	0.06	0.03	0.06	0.01	0.0	0.0	0.21
SSE	0.0	0.0	0.04	0.06	0.05	0.18	0.02	0.01	0.0	0.36
S	0.0	0.0	0.02	0.03	0.04	0.11	0.01	0.0	0.0	0.21
SSW	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.01
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.01
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.01	0.03	0.02	0.01	0.0	0.0	0.0	0.07
Sub- total	0.0	0.0	0.21	0.45	0.27	0.39	0.04	0.01	0.0	1.37

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class F - 2385.0
Total hours of ground level Stability Class F - 357.0

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 10.03 and 45.30 meters
Wind speed measured at 10.42 meter level
Effluent velocity = 12.60 m/s

Table 7.3 (15 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class G (Delta-T > 4.0 degrees C per 100 m)
Part 1 of 2 ground level release mode
BROWNS FERRY NUCLEAR PLANT
January 1, 1977 - December 31, 1979

	Calm	Wind Speed (mph)								Total
		0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥24.5	
N	0.0	0.0	0.02	0.04	0.0	0.0	0.0	0.0	0.0	0.06
NNE	0.0	0.0	0.02	0.06	0.03	0.0	0.0	0.0	0.0	0.11
NE	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.02
ENE	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.02
E	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.02
ESE	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.01
SE	0.0	0.0	0.03	0.01	0.01	0.02	0.0	0.0	0.0	0.07
SSE	0.0	0.0	0.04	0.05	0.03	0.06	0.0	0.0	0.0	0.18
S	0.0	0.0	0.01	0.02	0.02	0.01	0.0	0.0	0.0	0.06
SSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.01	0.01	0.08	0.0	0.0	0.0	0.0	0.02
Sub- total	0.0	0.0	0.17	0.22	0.09	0.09	0.0	0.0	0.0	0.57

Total hours of valid observations - 25482.0
Total hours of ground level release - 2832.4
Total hours of Stability Class G - 694.7
Total hours of ground level Stability Class G - 151.7

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 10.03 and 45.30 meters
Wind speed and direction measured at the 10.42 meter level
Effluent velocity = 12.60 m/s



Table 7.3 (16 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class A (Delta-T_c -1.9 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
SW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WSW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub- total	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01

Total hours of valid observations - 25482.0

Total hours of elevated releases - 22649.6

Total hours of Stability Class A - 133.1

Total hours of elevated Stability Class A - 5.6

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind direction measured at 45.67 meter level
Wind speed measured at 45.67 meter level -
Effluent velocity = 12.60 m/s

Table 7.3 (17 of 22)
SPLIT JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class B (-1.9 < Delta-T < -1.7 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)								Total	
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4		>24.5
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SE	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.02
SSE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
S	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
SSW	0.0	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.01
SW	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
WSW	0.0	0.0	0.0	0.0	0.0	0.02	0.0	0.0	0.0	0.02
W	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
WNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub- total	0.0	0.0	0.01	0.01	0.01	0.03	0.0	0.0	0.0	0.06

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class B - 185.1
Total hours of elevated stability class B - 21.8

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind direction measured at 45.67 meter level
Wind speed measured at 45.67 meter level -
Effluent velocity = 12.60 m/s



Table 7.3 (18 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class C ($-1.7 < \Delta T < -1.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Calm	Wind Speed (mph)								Total
		0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNE	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.01
NE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ENE	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
E	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
ESE	0.0	0.0	0.0	0.01	0.01	0.01	0.0	0.0	0.0	0.03
SE	0.0	0.0	0.02	0.05	0.01	0.0	0.0	0.0	0.0	0.08
SSE	0.0	0.0	0.0	0.04	0.0	0.0	0.0	0.0	0.0	0.04
S	0.0	0.0	0.01	0.01	0.0	0.0	0.0	0.0	0.0	0.02
SSW	0.0	0.0	0.0	0.02	0.02	0.01	0.0	0.0	0.0	0.05
SW	0.0	0.0	0.0	0.05	0.05	0.02	0.01	0.0	0.0	0.13
WSW	0.0	0.0	0.0	0.0	0.03	0.05	0.01	0.0	0.0	0.09
W	0.0	0.0	0.0	0.0	0.01	0.03	0.02	0.02	0.0	0.08
WNW	0.0	0.0	0.0	0.0	0.0	0.02	0.02	0.0	0.0	0.04
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.01	0.0	0.0	0.01
NNW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
Sub- total	0.0	0.0	0.03	0.18	0.14	0.14	0.07	0.02	0.0	0.58

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class C - 259.0
Total hours of elevated Stability Class C - 152.7

Meteorological facility: located 1.3 km ESE of BFN
Stability based on ΔT between 45.30 and 89.60 meters
Wind speed and direction measured at the 45.67 meter level
Effluent velocity = 12.60 m/s



Table 7.3 (19 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class D (-1.5 < Delta-T < -0.5 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥24.5	Total
N	0.0	0.0	0.12	0.40	0.62	1.49	0.87	0.12	0.0	3.62
NNE	0.0	0.01	0.13	0.46	0.72	1.88	0.91	0.05	0.0	4.16
NE	0.0	0.0	0.09	0.36	0.48	1.04	0.14	0.02	0.0	2.13
ENE	0.0	0.01	0.11	0.24	0.23	0.23	0.04	0.01	0.0	0.87
E	0.0	0.01	0.10	0.20	0.28	0.25	0.05	0.01	0.0	0.90
ESE	0.0	0.01	0.22	0.52	0.68	1.07	0.16	0.0	0.0	2.66
SE	0.0	0.01	0.67	1.66	0.89	1.75	0.84	0.16	0.01	5.99
SSE	0.0	0.01	0.48	0.90	0.63	1.49	1.08	0.26	0.02	4.87
S	0.0	0.0	0.34	0.99	0.67	0.99	0.93	0.33	0.02	4.27
SSW	0.0	0.01	0.20	0.52	0.37	0.69	0.34	0.11	0.0	2.24
SW	0.0	0.01	0.24	0.79	0.43	0.49	0.32	0.05	0.0	2.33
WSW	0.0	0.02	0.16	0.51	0.57	0.57	0.27	0.08	0.0	2.18
W	0.0	0.0	0.07	0.36	0.80	1.34	0.55	0.16	0.01	3.29
WNW	0.0	0.0	0.09	0.33	0.48	1.25	0.94	0.32	0.01	3.42
NW	0.0	0.0	0.07	0.36	0.55	1.40	1.44	0.37	0.01	4.20
NNW	0.0	0.0	0.09	0.29	0.53	1.36	1.15	0.19	0.0	3.61
Sub- total	0.0	0.10	3.18	8.89	8.93	17.29	10.03	2.24	0.08	50.74

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class D - 13904.1
Total hours of elevated Stability Class D - 12935.5

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind speed and direction measured at the 45.67 meter level
Effluent velocity = 12.60 m/s

Table 7.3 (20 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class E ($-0.5 < \Delta T < 1.5$ degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Calm	Wind Speed (mph)								Total
		0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥ 24.5	
N	0.0	0.0	0.13	0.22	0.31	0.80	0.15	0.0	0.0	1.61
NNE	0.0	0.0	0.15	0.24	0.39	1.04	0.28	0.0	0.0	2.10
NE	0.0	0.01	0.11	0.25	0.39	0.88	0.18	0.0	0.0	1.82
ENE	0.0	0.0	0.20	0.21	0.33	0.39	0.10	0.0	0.0	1.23
E	0.0	0.0	0.09	0.24	0.30	0.55	0.06	0.0	0.0	1.24
ESE	0.0	0.01	0.29	0.58	0.86	1.10	0.09	0.01	0.0	2.94
SE	0.0	0.02	0.41	1.04	1.02	1.37	0.55	0.08	0.01	4.50
SSE	0.0	0.01	0.23	0.60	0.54	0.87	0.59	0.14	0.01	2.99
S	0.0	0.01	0.14	0.49	0.32	0.70	0.34	0.05	0.0	2.05
SSW	0.0	0.0	0.11	0.28	0.30	0.48	0.19	0.01	0.0	1.37
SW	0.0	0.01	0.17	0.27	0.28	0.29	0.09	0.0	0.0	1.11
WSW	0.0	0.01	0.12	0.25	0.24	0.28	0.06	0.0	0.0	0.96
W	0.0	0.0	0.09	0.19	0.26	0.34	0.05	0.0	0.0	0.93
WNW	0.0	0.0	0.06	0.13	0.11	0.20	0.04	0.01	0.0	0.55
NW	0.0	0.0	0.09	0.14	0.13	0.31	0.08	0.0	0.0	0.75
NNW	0.0	0.0	0.12	0.21	0.16	0.52	0.16	0.0	0.0	1.17
Sub- total	0.0	0.08	2.51	5.34	5.94	10.12	3.01	0.30	0.02	27.32

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class E - 7920.9
Total hours of elevated Stability Class E - 6962.9

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind speed and direction measured at the 45.67 meter level
Effluent velocity = 12.60 m/s

Table 7.3 (21 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class F (1.5 < Delta-T < 4.0 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Calm	Wind Speed (mph)								Total
		0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	≥24.5	
N	0.0	0.0	0.03	0.08	0.06	0.34	0.05	0.0	0.0	0.56
NNE	0.0	0.0	0.04	0.06	0.11	0.42	0.21	0.0	0.0	0.84
NE	0.0	0.0	0.04	0.10	0.15	0.40	0.12	0.0	0.0	0.81
ENE	0.0	0.0	0.04	0.11	0.11	0.29	0.07	0.0	0.0	0.62
E	0.0	0.0	0.03	0.07	0.11	0.32	0.02	0.0	0.0	0.55
ESE	0.0	0.0	0.13	0.26	0.24	0.24	0.0	0.0	0.0	0.87
SE	0.0	0.0	0.13	0.38	0.30	0.19	0.0	0.0	0.0	1.00
SSE	0.0	0.0	0.09	0.11	0.12	0.14	0.03	0.0	0.0	0.49
S	0.0	0.0	0.08	0.11	0.13	0.21	0.03	0.0	0.0	0.56
SSW	0.0	0.0	0.04	0.12	0.14	0.24	0.01	0.0	0.0	0.55
SW	0.0	0.0	0.04	0.09	0.10	0.06	0.0	0.0	0.0	0.29
WSW	0.0	0.0	0.03	0.07	0.06	0.05	0.0	0.0	0.0	0.21
W	0.0	0.01	0.04	0.04	0.05	0.04	0.0	0.0	0.0	0.18
WNW	0.0	0.0	0.02	0.04	0.01	0.01	0.0	0.0	0.0	0.08
NW	0.0	0.0	0.03	0.04	0.03	0.02	0.0	0.0	0.0	0.12
NNW	0.0	0.0	0.02	0.02	0.04	0.10	0.0	0.0	0.0	0.18
Sub- total	0.0	0.01	0.83	1.70	1.76	3.07	0.54	0.0	0.0	7.91

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class F - 2385.0
Total hours of elevated Stability Class F - 2028.0

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind speed and direction measured at the 45.67 meter level
Effluent velocity = 12.60 m/s



Table 7.3 (22 of 22)
JOINT PERCENTAGE FREQUENCIES OF WIND SPEED BY WIND DIRECTION
Stability Class G (Delta-T > 4.0 degrees C per 100 m)
BROWNS FERRY NUCLEAR PLANT
Part 2 of 2 elevated release mode
January 1, 1977 - December 31, 1979

	Wind Speed (mph)									Total
	Calm	0.6- 1.4	1.5- 3.4	3.5- 5.4	5.5- 7.4	7.5- 12.4	12.5- 18.4	18.5- 24.4	>24.5	
N	0.0	0.0	0.0	0.0	0.02	0.06	0.01	0.0	0.0	0.09
NNE	0.0	0.0	0.01	0.02	0.04	0.11	0.04	0.0	0.0	0.22
NE	0.0	0.0	0.02	0.02	0.03	0.12	0.02	0.0	0.0	0.21
ENE	0.0	0.0	0.0	0.02	0.02	0.07	0.02	0.0	0.0	0.13
E	0.0	0.0	0.0	0.02	0.01	0.04	0.0	0.0	0.0	0.07
ESE	0.0	0.01	0.05	0.15	0.07	0.01	0.0	0.0	0.0	0.29
SE	0.0	0.0	0.12	0.20	0.13	0.04	0.0	0.0	0.0	0.49
SSE	0.0	0.0	0.03	0.06	0.06	0.02	0.0	0.0	0.0	0.17
S	0.0	0.0	0.02	0.07	0.06	0.01	0.0	0.0	0.0	0.16
SSW	0.0	0.0	0.0	0.02	0.02	0.06	0.0	0.0	0.0	0.10
SW	0.0	0.0	0.01	0.01	0.03	0.02	0.0	0.0	0.0	0.07
WSW	0.0	0.0	0.01	0.0	0.0	0.0	0.0	0.0	0.0	0.01
W	0.0	0.0	0.01	0.0	0.01	0.0	0.0	0.0	0.0	0.02
WNW	0.0	0.0	0.02	0.0	0.0	0.0	0.0	0.0	0.0	0.02
NW	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
NNW	0.0	0.0	0.01	0.01	0.0	0.01	0.0	0.0	0.0	0.03
Sub- total	0.0	0.01	0.31	0.60	0.50	0.57	0.09	0.0	0.0	2.08

Total hours of valid observations - 25482.0
Total hours of elevated releases - 22649.6
Total hours of Stability Class G - 694.7
Total hours of elevated Stability Class G - 543.1

Meteorological facility: located 1.3 km ESE of BFN
Stability based on Delta-T between 45.30 and 89.60 meters
Wind speed and direction measured at the 45.67 meter level
Effluent velocity = 12.60 m/s

Table 7.4
DOSE FACTORS FOR SUBMERSION IN NOBLE GASES

	Submersion dose mrem/yr per $\mu\text{Ci}/\text{m}^3$		Air dose mrad/yr per $\mu\text{Ci}/\text{m}^3$	
	DF _{B_i}	DF _{S_i}	DF _{γ_i}	DF _{B_i}
Kr-83m	7.56E-02	---	1.93E+01	2.88E+02
Kr-85m	1.17E+03	1.46E+03	1.23E+03	1.97E+03
Kr-85	1.61E+01	1.34E+03	1.72E+01	1.95E+03
Kr-87	5.92E+03	9.73E+03	6.17E+03	1.03E+04
Kr-88	1.47E+04	2.37E+03	1.52E+04	2.93E+03
Kr-89	1.66E+04	1.01E+04	1.73E+04	1.06E+04
Kr-90	1.56E+04	7.29E+03	1.63E+04	7.83E+03
Xe-131m	9.15E+01	4.76E+02	1.56E+02	1.11E+03
Xe-133m	2.51E+02	9.94E+02	3.27E+02	1.48E+03
Xe-133	2.94E+02	3.06E+02	3.53E+02	1.05E+03
Xe-135m	3.12E+03	7.11E+02	3.36E+03	7.39E+02
Xe-135	1.81E+03	1.86E+03	1.92E+03	2.46E+03
Xe-137	1.42E+03	1.22E+04	1.51E+03	1.27E+04
Xe-138	8.83E+03	4.13E+03	9.21E+03	4.75E+03
Ar-41	8.84E+03	2.69E+03	9.30E+03	3.28E+03

Reference:
Regulatory Guide 1.109, Table B-1.



Table 7.5
SECTOR ELEMENTS CONSIDERED FOR POPULATION DOSES

Range of Sector Element	Midpoint of Sector Element
Site boundary - 1 mile	0.8 mile
1 - 2 miles	1.5 miles
2 - 3 miles	2.5 miles
3 - 4 miles	3.5 miles
4 - 5 miles	4.5 miles
5 - 10 miles	7.5 miles
10 - 20 miles	15 miles
20 - 30 miles	25 miles
30 - 40 miles	35 miles
40 - 50 miles	45 miles



Table 7.6
BFN 50-MILE POPULATION WITHIN EACH SECTOR ELEMENT

	Distance to Midpoint of Sector Element									
	0.8	1.5	2.5	3.5	4.5	7.5	15	25	35	45
N	0	10	55	35	85	670	1515	2615	10660	3690
NNE	0	5	15	65	55	915	2990	2230	3125	3420
NE	0	5	25	45	88	4180	14180	6625	5385	12625
ENE	0	15	50	40	70	1310	4990	9615	13860	5425
E	0	0	30	10	40	945	1910	73405	75125	4610
ESE	0	0	5	0	0	165	1880	2535	7465	9575
SE	0	0	0	0	20	10390	30945	4660	6230	13850
SSE	0	0	0	0	50	1630	6250	11630	15175	18945
S	0	0	20	35	90	1250	3805	1800	4475	3730
SSW	0	0	60	75	175	845	5895	1270	1490	2535
SW	0	0	20	35	90	685	2970	2280	2725	10675
WSW	0	0	35	15	135	295	3060	3005	11545	3755
W	0	0	25	5	30	625	2960	6830	35070	4785
WNW	0	0	0	25	55	50	885	9300	39875	5545
NW	0	0	0	0	5	345	4345	5215	5485	3260
NNW	0	5	35	25	20	625	2090	2440	12350	7360



Table 7.7 (1 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	ADULT							
	bone	liver	t body	thyroid	kidney	lung	gi-11i	
H-3	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07	1.58E-07
C-14	2.27E-06	4.26E-07	4.26E-07	4.26E-07	4.26E-07	4.26E-07	4.26E-07	4.26E-07
Na-24	1.28E-06	1.28E-06	1.28E-06	1.28E-06	1.28E-06	1.28E-06	1.28E-06	1.28E-06
P-32	1.65E-04	9.64E-06	6.26E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00	1.08E-05
Cr-51	0.00E+00	0.00E+00	1.25E-08	7.44E-09	2.85E-09	1.80E-06	4.15E-07	4.15E-07
Mn-54	0.00E+00	4.95E-06	7.87E-07	0.00E+00	1.23E-06	1.75E-04	9.67E-06	9.67E-06
Mn-56	0.00E+00	1.55E-10	2.29E-11	0.00E+00	1.63E-10	1.18E-06	2.53E-06	2.53E-06
Fe-55	3.07E-06	2.12E-06	4.93E-07	0.00E+00	0.00E+00	9.01E-06	7.54E-07	7.54E-07
Fe-59	1.47E-06	3.47E-06	1.32E-06	0.00E+00	0.00E+00	1.27E-04	2.35E-05	2.35E-05
Co-57	0.00E+00	8.65E-08	8.39E-08	0.00E+00	0.00E+00	4.62E-05	3.93E-06	3.93E-06
Co-58	0.00E+00	1.98E-07	2.59E-07	0.00E+00	0.00E+00	1.16E-04	1.33E-05	1.33E-05
Co-60	0.00E+00	1.44E-06	1.85E-06	0.00E+00	0.00E+00	7.46E-04	3.56E-05	3.56E-05
Ni-63	5.40E-05	3.93E-06	1.81E-06	0.00E+00	0.00E+00	2.23E-05	1.67E-06	1.67E-06
Ni-65	1.92E-10	2.62E-11	1.14E-11	0.00E+00	0.00E+00	7.00E-07	1.54E-06	1.54E-06
Cu-64	0.00E+00	1.83E-10	7.69E-11	0.00E+00	5.78E-10	8.48E-07	6.12E-06	6.12E-06
Zn-65	4.05E-06	1.29E-05	5.82E-06	0.00E+00	8.62E-06	1.08E-04	6.68E-06	6.68E-06
Zn-69	4.23E-12	8.14E-12	5.65E-13	0.00E+00	5.27E-12	1.15E-07	2.04E-09	2.04E-09
Zn-69m	1.02E-09	2.45E-09	2.24E-10	0.00E+00	1.48E-09	2.38E-06	1.71E-05	1.71E-05
Br-82	0.00E+00	0.00E+00	1.69E-06	0.00E+00	0.00E+00	0.00E+00	1.30E-06	1.30E-06
Br-83	0.00E+00	0.00E+00	3.01E-08	0.00E+00	0.00E+00	0.00E+00	2.90E-08	2.90E-08
Br-84	0.00E+00	0.00E+00	3.91E-08	0.00E+00	0.00E+00	0.00E+00	2.05E-13	2.05E-13
Br-85	0.00E+00	0.00E+00	1.60E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	1.69E-05	7.37E-06	0.00E+00	0.00E+00	0.00E+00	2.08E-06	2.08E-06
Rb-88	0.00E+00	4.84E-08	2.41E-08	0.00E+00	0.00E+00	0.00E+00	4.18E-19	4.18E-19
Rb-89	0.00E+00	3.20E-08	2.12E-08	0.00E+00	0.00E+00	0.00E+00	1.16E-21	1.16E-21
Sr-89	3.80E-05	0.00E+00	1.09E-06	0.00E+00	0.00E+00	1.75E-04	4.37E-05	4.37E-05
Sr-90	1.24E-02	0.00E+00	7.62E-04	0.00E+00	0.00E+00	1.20E-03	9.02E-05	9.02E-05
Sr-91	7.74E-09	0.00E+00	3.13E-10	0.00E+00	0.00E+00	4.56E-06	2.39E-05	2.39E-05
Sr-92	8.43E-10	0.00E+00	3.64E-11	0.00E+00	0.00E+00	2.06E-06	5.38E-06	5.38E-06
Y-90	2.61E-07	0.00E+00	7.01E-09	0.00E+00	0.00E+00	2.12E-05	6.32E-05	6.32E-05
Y-91m	3.26E-11	0.00E+00	1.27E-12	0.00E+00	0.00E+00	2.40E-07	1.66E-10	1.66E-10
Y-91	5.78E-05	0.00E+00	1.55E-06	0.00E+00	0.00E+00	2.13E-04	4.81E-05	4.81E-05
Y-92	1.29E-09	0.00E+00	3.77E-11	0.00E+00	0.00E+00	1.96E-06	9.19E-06	9.19E-06
Y-93	1.18E-08	0.00E+00	3.26E-10	0.00E+00	0.00E+00	6.06E-06	5.27E-05	5.27E-05
Zr-95	1.34E-05	4.30E-06	2.91E-06	0.00E+00	6.77E-06	2.21E-04	1.88E-05	1.88E-05
Zr-97	1.21E-08	2.45E-09	1.13E-09	0.00E+00	3.71E-09	9.84E-06	6.54E-05	6.54E-05
Nb-95	1.76E-06	9.77E-07	5.26E-07	0.00E+00	9.67E-07	6.31E-05	1.30E-05	1.30E-05
Nb-97	2.78E-11	7.03E-12	2.56E-12	0.00E+00	8.18E-12	3.00E-07	3.02E-08	3.02E-08
Mo-99	0.00E+00	1.51E-08	2.87E-09	0.00E+00	3.64E-08	1.14E-05	3.10E-05	3.10E-05
Tc-99m	1.29E-13	3.64E-13	4.63E-12	0.00E+00	5.52E-12	9.55E-08	5.20E-07	5.20E-07
Tc-101	5.22E-15	7.52E-15	7.38E-14	0.00E+00	1.35E-13	4.99E-08	1.36E-21	1.36E-21
Ru-103	1.91E-07	0.00E+00	8.23E-08	0.00E+00	7.29E-07	6.31E-05	1.38E-05	1.38E-05
Ru-105	9.88E-11	0.00E+00	3.89E-11	0.00E+00	1.27E-10	1.37E-06	6.02E-06	6.02E-06
Ru-106	8.64E-06	0.00E+00	1.09E-06	0.00E+00	1.67E-05	1.17E-03	1.14E-04	1.14E-04
Ag-110m	1.35E-06	1.25E-06	7.43E-07	0.00E+00	2.46E-06	5.79E-04	3.78E-05	3.78E-05



Table 7.7 (2 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	ADULT						
	bone	liver	t body	thyroid	kidney	lung	gi-11i
Sb-124	3.90E-06	7.36E-08	1.55E-06	9.44E-09	0.00E+00	3.10E-04	5.08E-05
Sb-125	6.67E-06	7.44E-08	1.58E-06	6.75E-09	0.00E+00	2.18E-04	1.26E-05
Te-125m	4.27E-07	1.98E-07	5.84E-08	1.31E-07	1.55E-06	3.92E-05	8.83E-06
Te-127m	1.58E-06	7.21E-07	1.96E-07	4.11E-07	5.72E-06	1.20E-04	1.87E-05
Te-127	1.75E-10	8.03E-11	3.87E-11	1.32E-10	6.37E-10	8.14E-07	7.17E-06
Te-129m	1.22E-06	5.84E-07	1.98E-07	4.30E-07	4.57E-06	1.45E-04	4.79E-05
Te-129	6.22E-12	2.99E-12	1.55E-12	4.87E-12	2.34E-11	2.42E-07	1.96E-08
Te-131m	8.74E-09	5.45E-09	3.63E-09	6.88E-09	3.86E-08	1.82E-05	6.95E-05
Te-131	1.39E-12	7.44E-13	4.49E-13	1.17E-12	5.46E-12	1.74E-07	2.30E-09
Te-132	3.25E-08	2.69E-08	2.02E-08	2.37E-08	1.82E-07	3.60E-05	6.37E-05
I-130	5.72E-07	1.68E-06	6.60E-07	1.42E-04	2.61E-06	0.00E+00	9.61E-07
I-131	3.15E-06	4.47E-06	2.56E-06	1.49E-03	7.66E-06	0.00E+00	7.85E-07
I-132	1.45E-07	4.07E-07	1.45E-07	1.43E-05	6.48E-07	0.00E+00	5.08E-08
I-133	1.08E-06	1.85E-06	5.65E-07	2.69E-04	3.23E-06	0.00E+00	1.11E-06
I-134	8.05E-08	2.16E-07	7.69E-08	3.73E-06	3.44E-07	0.00E+00	1.26E-10
I-135	3.35E-07	8.73E-07	3.21E-07	5.60E-05	1.39E-06	0.00E+00	6.56E-07
Cs-134	4.66E-05	1.06E-04	9.10E-05	0.00E+00	3.59E-05	1.22E-05	1.30E-06
Cs-136	4.88E-06	1.83E-05	1.38E-05	0.00E+00	1.07E-05	1.50E-06	1.46E-06
Cs-137	5.98E-05	7.76E-05	5.35E-05	0.00E+00	2.78E-05	9.40E-06	1.05E-06
Cs-138	4.14E-08	7.76E-08	4.05E-08	0.00E+00	6.00E-08	6.07E-09	2.33E-13
Ba-139	1.17E-10	8.32E-14	3.42E-12	0.00E+00	7.78E-14	4.70E-07	1.12E-07
Ba-140	4.88E-06	6.13E-09	3.21E-07	0.00E+00	2.09E-09	1.59E-04	2.73E-05
Ba-141	1.25E-11	9.41E-15	4.20E-13	0.00E+00	8.75E-15	2.42E-07	1.45E-17
Ba-142	3.29E-12	3.38E-15	2.07E-13	0.00E+00	2.86E-15	1.49E-07	1.96E-26
La-140	4.30E-08	2.17E-08	5.73E-09	0.00E+00	0.00E+00	1.70E-05	5.73E-05
La-142	8.54E-11	3.88E-11	9.65E-12	0.00E+00	0.00E+00	7.91E-07	2.64E-07
Ce-141	2.49E-06	1.69E-06	1.91E-07	0.00E+00	7.83E-07	4.52E-05	1.50E-05
Ce-143	2.33E-08	1.72E-08	1.91E-09	0.00E+00	7.60E-09	9.97E-06	2.83E-05
Ce-144	4.29E-04	1.79E-04	2.30E-05	0.00E+00	1.06E-04	9.72E-04	1.02E-04
Pr-143	1.17E-06	4.69E-07	5.80E-08	0.00E+00	2.70E-07	3.51E-05	2.50E-05
Pr-144	3.76E-12	1.56E-12	1.91E-13	0.00E+00	8.81E-13	1.27E-07	2.69E-18
Nd-147	6.59E-07	7.62E-07	4.56E-08	0.00E+00	4.45E-07	2.76E-05	2.16E-05
W-187	1.06E-09	8.85E-10	3.10E-10	0.00E+00	0.00E+00	3.63E-06	1.94E-05
Np-239	2.87E-08	2.82E-09	1.55E-09	0.00E+00	8.75E-09	4.70E-06	1.49E-05

Reference:

Regulatory Guide 1.109, Table E-7.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November 1977, Table 8.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.

Table 7.7 (3 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	bone	liver	t body	TEEN thyroid	kidney	lung	gi-11i
H-3	1.59E-07	1.59E-07	1.59E-07	1.59E-07	1.59E-07	1.59E-07	1.59E-07
C-14	3.25E-06	6.09E-07	6.09E-07	6.09E-07	6.09E-07	6.09E-07	6.09E-07
Na-24	1.72E-06	1.72E-06	1.72E-06	1.72E-06	1.72E-06	1.72E-06	1.72E-06
P-32	2.36E-04	1.37E-05	8.95E-06	0.00E+00	0.00E+00	0.00E+00	1.16E-05
Cr-51	0.00E+00	0.00E+00	1.69E-08	9.37E-09	3.84E-09	2.62E-06	3.75E-07
Mn-54	0.00E+00	6.39E-06	1.05E-06	0.00E+00	1.59E-06	2.48E-04	8.35E-06
Mn-56	0.00E+00	2.12E-10	3.15E-11	0.00E+00	2.24E-10	1.90E-06	7.18E-06
Fe-55	4.18E-06	2.98E-06	6.93E-07	0.00E+00	0.00E+00	1.55E-05	7.99E-07
Fe-59	1.99E-06	4.62E-06	1.79E-06	0.00E+00	0.00E+00	1.91E-04	2.23E-05
Co-57	0.00E+00	1.18E-07	1.15E-07	0.00E+00	0.00E+00	7.33E-05	3.93E-06
Co-58	0.00E+00	2.59E-07	3.47E-07	0.00E+00	0.00E+00	1.68E-04	1.19E-05
Co-60	0.00E+00	1.89E-06	2.48E-06	0.00E+00	0.00E+00	1.09E-03	3.24E-05
Ni-63	7.25E-05	5.43E-06	2.47E-06	0.00E+00	0.00E+00	3.84E-05	1.77E-06
Ni-65	2.73E-10	3.66E-11	1.59E-11	0.00E+00	0.00E+00	1.17E-06	4.59E-06
Cu-64	0.00E+00	2.54E-10	1.06E-10	0.00E+00	8.01E-10	1.39E-06	7.68E-06
Zn-65	4.82E-06	1.67E-05	7.80E-06	0.00E+00	1.08E-05	1.55E-04	5.83E-06
Zn-69	6.04E-12	1.15E-11	8.07E-13	0.00E+00	7.53E-12	1.98E-07	3.56E-08
Zn-69m	1.44E-09	3.39E-09	3.11E-10	0.00E+00	2.06E-09	3.92E-06	2.14E-05
Br-82	0.00E+00	0.00E+00	2.28E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	4.30E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	5.41E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	2.29E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	2.38E-05	1.05E-05	0.00E+00	0.00E+00	0.00E+00	2.21E-06
Rb-88	0.00E+00	6.82E-08	3.40E-08	0.00E+00	0.00E+00	0.00E+00	3.65E-15
Rb-89	0.00E+00	4.40E-08	2.91E-08	0.00E+00	0.00E+00	0.00E+00	4.22E-17
Sr-89	5.43E-05	0.00E+00	1.56E-06	0.00E+00	0.00E+00	3.02E-04	4.64E-05
Sr-90	1.35E-02	0.00E+00	8.35E-04	0.00E+00	0.00E+00	2.06E-03	9.56E-05
Sr-91	1.10E-08	0.00E+00	4.39E-10	0.00E+00	0.00E+00	7.59E-06	3.24E-05
Sr-92	1.19E-09	0.00E+00	5.08E-11	0.00E+00	0.00E+00	3.43E-06	1.49E-05
Y-90	3.73E-07	0.00E+00	1.00E-08	0.00E+00	0.00E+00	3.66E-05	6.99E-05
Y-91m	4.63E-11	0.00E+00	1.77E-12	0.00E+00	0.00E+00	4.00E-07	3.77E-09
Y-91	8.26E-05	0.00E+00	2.21E-06	0.00E+00	0.00E+00	3.67E-04	5.11E-05
Y-92	1.84E-09	0.00E+00	5.36E-11	0.00E+00	0.00E+00	3.35E-06	2.06E-05
Y-93	1.69E-08	0.00E+00	4.65E-10	0.00E+00	0.00E+00	1.04E-05	7.24E-05
Zr-95	1.82E-05	5.73E-06	3.94E-06	0.00E+00	8.42E-06	3.36E-04	1.86E-05
Zr-97	1.72E-08	3.40E-09	1.57E-09	0.00E+00	5.15E-09	1.62E-05	7.88E-05
Nb-95	2.32E-06	1.29E-06	7.08E-07	0.00E+00	1.25E-06	9.39E-05	1.21E-05
Nb-97	3.92E-11	9.72E-12	3.55E-12	0.00E+00	1.14E-11	4.91E-07	2.71E-07
Mo-99	0.00E+00	2.11E-08	4.03E-09	0.00E+00	5.14E-08	1.92E-05	3.36E-05
Tc-99m	1.73E-13	4.83E-13	6.24E-12	0.00E+00	7.20E-12	1.44E-07	7.66E-07
Tc-101	7.40E-15	1.05E-14	1.03E-13	0.00E+00	1.90E-13	8.34E-08	1.09E-16
Ru-103	2.63E-07	0.00E+00	1.12E-07	0.00E+00	9.29E-07	9.79E-05	1.36E-05
Ru-105	1.40E-10	0.00E+00	5.42E-11	0.00E+00	1.76E-10	2.27E-06	1.13E-05
Ru-106	1.23E-05	0.00E+00	1.55E-06	0.00E+00	2.38E-05	2.01E-03	1.20E-04
Ag-110m	1.73E-06	1.64E-06	9.99E-07	0.00E+00	3.13E-06	8.44E-04	3.41E-05



Table 7.7 (4 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	TEEN						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
Sb-124	5.38E-06	9.92E-08	2.10E-06	1.22E-08	0.00E+00	4.81E-04	4.98E-05
Sb-125	9.23E-06	1.01E-07	2.15E-06	8.80E-09	0.00E+00	3.42E-04	1.24E-05
Te-125m	6.10E-07	2.80E-07	8.34E-08	1.75E-07	0.00E+00	6.70E-05	9.38E-06
Te-127m	2.25E-06	1.02E-06	2.73E-07	5.48E-07	8.17E-06	2.07E-04	1.99E-05
Te-127	2.51E-10	1.14E-10	5.52E-11	1.77E-10	9.10E-10	1.40E-06	1.01E-05
Te-129m	1.74E-06	8.23E-07	2.81E-07	5.72E-07	6.49E-06	2.47E-04	5.06E-05
Te-129	8.87E-12	4.22E-12	2.20E-12	6.48E-12	3.32E-11	4.12E-07	2.02E-07
Te-131m	1.23E-08	7.51E-09	5.03E-09	9.06E-09	5.49E-08	2.97E-05	7.76E-05
Te-131	1.97E-12	1.04E-12	6.30E-13	1.55E-12	7.72E-12	2.92E-07	1.89E-09
Te-132	4.50E-08	3.63E-08	2.74E-08	3.07E-08	2.44E-07	5.61E-05	5.79E-05
I-130	7.80E-07	2.24E-06	8.96E-07	1.86E-04	3.44E-06	0.00E+00	1.14E-06
I-131	4.43E-06	6.14E-06	3.30E-06	1.83E-03	1.05E-05	0.00E+00	8.11E-07
I-132	1.99E-07	5.47E-07	1.97E-07	1.89E-05	8.65E-07	0.00E+00	1.59E-07
I-133	1.52E-06	2.56E-06	7.78E-07	3.65E-04	4.49E-06	0.00E+00	1.29E-06
I-134	1.11E-07	2.90E-07	1.05E-07	4.94E-06	4.58E-07	0.00E+00	2.55E-09
I-135	4.62E-07	1.18E-06	4.36E-07	7.76E-05	1.86E-06	0.00E+00	8.69E-07
Cs-134	6.28E-05	1.41E-04	6.86E-05	0.00E+00	4.69E-05	1.83E-05	1.22E-06
Cs-136	6.44E-06	2.42E-05	1.71E-05	0.00E+00	1.38E-05	2.22E-06	1.36E-06
Cs-137	8.38E-05	1.06E-04	3.89E-05	0.00E+00	3.80E-05	1.51E-05	1.06E-06
Cs-138	5.82E-08	1.07E-07	5.58E-08	0.00E+00	8.28E-08	9.84E-09	3.38E-11
Ba-139	1.67E-10	1.18E-13	4.87E-12	0.00E+00	1.11E-13	8.08E-07	8.06E-07
Ba-140	6.84E-06	8.38E-09	4.40E-07	0.00E+00	2.85E-09	2.54E-04	2.86E-05
Ba-141	1.78E-11	1.32E-14	5.93E-13	0.00E+00	1.23E-14	4.11E-07	9.33E-14
Ba-142	4.62E-12	4.63E-15	2.84E-13	0.00E+00	3.92E-15	2.39E-07	5.99E-20
La-140	5.99E-08	2.95E-08	7.82E-09	0.00E+00	0.00E+00	2.68E-05	6.09E-05
La-142	1.20E-10	5.31E-11	1.32E-11	0.00E+00	0.00E+00	1.27E-06	1.50E-06
Ce-141	3.55E-06	2.37E-06	2.71E-07	0.00E+00	1.11E-06	7.67E-05	1.58E-05
Ce-143	3.32E-08	2.42E-08	2.70E-09	0.00E+00	1.08E-08	1.63E-05	3.19E-05
Ce-144	6.11E-04	2.53E-04	3.28E-05	0.00E+00	1.51E-04	1.67E-03	1.08E-04
Pr-143	1.67E-06	6.64E-07	8.28E-08	0.00E+00	3.86E-07	6.04E-05	2.67E-05
Pr-144	5.37E-12	2.20E-12	2.72E-13	0.00E+00	1.26E-12	2.19E-07	2.94E-14
Nd-147	9.83E-07	1.07E-06	6.41E-08	0.00E+00	6.28E-07	4.65E-05	2.28E-05
W-187	1.50E-09	1.22E-09	4.29E-10	0.00E+00	0.00E+00	5.92E-06	2.21E-05
Np-239	4.23E-08	3.99E-09	2.21E-09	0.00E+00	1.25E-08	8.11E-06	1.65E-05

Reference:

Regulatory Guide 1.109, Table E-8.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November 1977, Table 7.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.



Table 7.7 (5 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	CHILD						
	bone	liver	t body	thyroid	kidney	lung	gi-11i
H-3	3.04E-07	3.04E-07	3.04E-07	3.04E-07	3.04E-07	3.04E-07	3.04E-07
C-14	9.70E-06	1.82E-06	1.82E-06	1.82E-06	1.82E-06	1.82E-06	1.82E-06
Na-24	4.35E-06	4.35E-06	4.35E-06	4.35E-06	4.35E-06	4.35E-06	4.35E-06
P-32	7.04E-04	3.09E-05	2.67E-05	0.00E+00	0.00E+00	0.00E+00	1.14E-05
Cr-51	0.00E+00	0.00E+00	4.17E-08	2.31E-08	6.57E-09	4.59E-06	2.93E-07
Mn-54	0.00E+00	1.16E-05	2.57E-06	0.00E+00	2.71E-06	4.26E-04	6.19E-06
Mn-56	0.00E+00	4.48E-10	8.43E-11	0.00E+00	4.52E-10	3.55E-06	3.33E-05
Fe-55	1.28E-05	6.80E-06	2.10E-06	0.00E+00	0.00E+00	3.00E-05	7.75E-07
Fe-59	5.59E-06	9.04E-06	4.51E-06	0.00E+00	0.00E+00	3.43E-04	1.91E-05
Co-57	0.00E+00	2.44E-07	2.88E-07	0.00E+00	0.00E+00	1.37E-04	3.58E-06
Co-58	0.00E+00	4.79E-07	8.55E-07	0.00E+00	0.00E+00	2.99E-04	9.29E-06
Co-60	0.00E+00	3.55E-06	6.12E-06	0.00E+00	0.00E+00	1.91E-03	2.60E-05
Ni-63	2.22E-04	1.25E-05	7.56E-06	0.00E+00	0.00E+00	7.43E-05	1.71E-06
Ni-65	8.08E-10	7.99E-11	4.44E-11	0.00E+00	0.00E+00	2.21E-06	2.27E-05
Cu-64	0.00E+00	5.39E-10	2.90E-10	0.00E+00	1.63E-09	2.59E-06	9.92E-06
Zn-65	1.15E-05	3.06E-05	1.90E-05	0.00E+00	1.93E-05	2.69E-04	4.41E-06
Zn-69	1.81E-11	2.61E-11	2.41E-12	0.00E+00	1.58E-11	3.84E-07	2.75E-06
Zn-69m	4.26E-09	7.28E-09	8.59E-10	0.00E+00	4.22E-09	7.36E-06	2.71E-05
Br-82	0.00E+00	0.00E+00	5.66E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	1.28E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	1.48E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	6.84E-09	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	5.36E-05	3.09E-05	0.00E+00	0.00E+00	0.00E+00	2.16E-06
Rb-88	0.00E+00	1.52E-07	9.90E-08	0.00E+00	0.00E+00	0.00E+00	4.66E-09
Rb-89	0.00E+00	9.33E-08	7.83E-08	0.00E+00	0.00E+00	0.00E+00	5.11E-10
Sr-89	1.62E-04	0.00E+00	4.66E-06	0.00E+00	0.00E+00	5.83E-04	4.52E-05
Sr-90	2.73E-02	0.00E+00	1.74E-03	0.00E+00	0.00E+00	3.99E-03	9.28E-05
Sr-91	3.28E-08	0.00E+00	1.24E-09	0.00E+00	0.00E+00	1.44E-05	4.70E-05
Sr-92	3.54E-09	0.00E+00	1.42E-10	0.00E+00	0.00E+00	6.49E-06	6.55E-05
Y-90	1.11E-06	0.00E+00	2.99E-08	0.00E+00	0.00E+00	7.07E-05	7.24E-05
Y-91m	1.37E-10	0.00E+00	4.98E-12	0.00E+00	0.00E+00	7.60E-07	4.64E-07
Y-91	2.47E-04	0.00E+00	6.59E-06	0.00E+00	0.00E+00	7.10E-04	4.97E-05
Y-92	5.50E-09	0.00E+00	1.57E-10	0.00E+00	0.00E+00	6.46E-06	6.46E-05
Y-93	5.04E-08	0.00E+00	1.38E-09	0.00E+00	0.00E+00	2.01E-05	1.05E-04
Zr-95	5.13E-05	1.13E-05	1.00E-05	0.00E+00	1.61E-05	6.03E-04	1.65E-05
Zr-97	5.07E-08	7.34E-09	4.32E-09	0.00E+00	1.05E-08	3.06E-05	9.49E-05
Nb-95	6.35E-06	2.48E-06	1.77E-06	0.00E+00	2.33E-06	1.66E-04	1.00E-05
Nb-97	1.16E-10	2.08E-11	9.74E-12	0.00E+00	2.31E-11	9.23E-07	7.52E-06
Mo-99	0.00E+00	4.66E-08	1.15E-08	0.00E+00	1.06E-07	3.66E-05	3.42E-05
Tc-99m	4.81E-13	9.41E-13	1.56E-11	0.00E+00	1.37E-11	2.57E-07	1.30E-06
Tc-101	2.19E-14	2.30E-14	2.91E-13	0.00E+00	3.92E-13	1.58E-07	4.41E-09
Ru-103	7.55E-07	0.00E+00	2.90E-07	0.00E+00	1.90E-06	1.79E-04	1.21E-05
Ru-105	4.13E-10	0.00E+00	1.50E-10	0.00E+00	3.63E-10	4.30E-06	2.69E-05
Ru-106	3.68E-05	0.00E+00	4.57E-06	0.00E+00	4.97E-05	3.87E-03	1.16E-04
Ag-110m	4.56E-06	3.08E-06	2.47E-06	0.00E+00	5.74E-06	1.48E-03	2.71E-05



Table 7.7 (6 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	CHILD						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
Sb-124	1.55E-05	2.00E-07	5.41E-06	3.41E-08	0.00E+00	8.76E-04	4.43E-05
Sb-125	2.66E-05	2.05E-07	5.59E-06	2.46E-08	0.00E+00	6.27E-04	1.09E-05
Te-125m	1.82E-06	6.29E-07	2.47E-07	5.20E-07	0.00E+00	1.29E-04	9.13E-06
Te-127m	6.72E-06	2.31E-06	8.16E-07	1.64E-06	1.72E-05	4.00E-04	1.93E-05
Te-127	7.49E-10	2.57E-10	1.65E-10	5.30E-10	1.91E-09	2.71E-06	1.52E-05
Te-129m	5.19E-06	1.85E-06	8.22E-07	1.71E-06	1.36E-05	4.76E-04	4.91E-05
Te-129	2.64E-11	9.45E-12	6.44E-12	1.93E-11	6.94E-11	7.93E-07	6.89E-06
Te-131m	3.63E-08	1.60E-08	1.37E-08	2.64E-08	1.08E-07	5.56E-05	8.32E-05
Te-131	5.87E-12	2.28E-12	1.78E-12	4.59E-12	1.59E-11	5.55E-07	3.60E-07
Te-132	1.30E-07	7.36E-08	7.12E-08	8.58E-08	4.79E-07	1.02E-04	3.72E-05
I-130	2.21E-06	4.43E-06	2.28E-06	4.99E-04	6.61E-06	0.00E+00	1.38E-06
I-131	1.30E-05	1.30E-05	7.37E-06	4.39E-03	2.13E-05	0.00E+00	7.68E-07
I-132	5.72E-07	1.10E-06	5.07E-07	5.23E-05	1.69E-06	0.00E+00	8.65E-07
I-133	4.48E-06	5.49E-06	2.08E-06	1.04E-03	9.13E-06	0.00E+00	1.48E-06
I-134	3.17E-07	5.84E-07	2.69E-07	1.37E-05	8.92E-07	0.00E+00	2.58E-07
I-135	1.33E-06	2.36E-06	1.12E-06	2.14E-04	3.62E-06	0.00E+00	1.20E-06
Cs-134	1.76E-04	2.74E-04	6.07E-05	0.00E+00	8.93E-05	3.27E-05	1.04E-06
Cs-136	1.76E-05	4.62E-05	3.14E-05	0.00E+00	2.58E-05	3.93E-06	1.13E-06
Cs-137	2.45E-04	2.23E-04	3.47E-05	0.00E+00	7.63E-05	2.81E-05	9.78E-07
Cs-138	1.71E-07	2.27E-07	1.50E-07	0.00E+00	1.68E-07	1.84E-08	7.29E-08
Ba-139	4.98E-10	2.66E-13	1.45E-11	0.00E+00	2.33E-13	1.56E-06	1.56E-05
Ba-140	2.00E-05	1.75E-08	1.17E-06	0.00E+00	5.71E-09	4.71E-04	2.75E-05
Ba-141	5.29E-11	2.95E-14	1.72E-12	0.00E+00	2.56E-14	7.89E-07	7.44E-08
Ba-142	1.35E-11	9.73E-15	7.54E-13	0.00E+00	7.87E-15	4.44E-07	7.41E-10
La-140	1.74E-07	6.08E-08	2.04E-08	0.00E+00	0.00E+00	4.94E-05	6.10E-05
La-142	3.50E-10	1.11E-10	3.49E-11	0.00E+00	0.00E+00	2.35E-06	2.05E-05
Ce-141	1.06E-05	5.28E-06	7.83E-07	0.00E+00	2.31E-06	1.47E-04	1.53E-05
Ce-143	9.89E-08	5.37E-08	7.77E-09	0.00E+00	2.26E-08	3.12E-05	3.44E-05
Ce-144	1.83E-03	5.72E-04	9.77E-05	0.00E+00	3.17E-04	3.23E-03	1.05E-04
Pr-143	4.99E-06	1.50E-06	2.47E-07	0.00E+00	8.11E-07	1.17E-04	2.63E-05
Pr-144	1.61E-11	4.99E-12	8.10E-13	0.00E+00	2.64E-12	4.23E-07	5.32E-08
Nd-147	2.92E-06	2.36E-06	1.84E-07	0.00E+00	1.30E-06	8.87E-05	2.22E-05
W-187	4.41E-09	2.61E-09	1.17E-09	0.00E+00	0.00E+00	1.11E-05	2.46E-05
Np-239	1.26E-07	9.04E-09	6.35E-09	0.00E+00	2.63E-08	1.57E-05	1.73E-05

Reference:

Regulatory Guide 1.109, Table E-9.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November 1977, Table 6.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.




Table 7.7 (7 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	INFANT						
	bone	liver	t body	thyroid	kidney	lung	gi-lli
H-3	4.62E-07	4.62E-07	4.62E-07	4.62E-07	4.62E-07	4.62E-07	4.62E-07
C-14	1.89E-05	3.79E-06	3.79E-06	3.79E-06	3.79E-06	3.79E-06	3.79E-06
Na-24	7.54E-06	7.54E-06	7.54E-06	7.54E-06	7.54E-06	7.54E-06	7.54E-06
P-32	1.45E-03	8.03E+05	5.53E-05	0.00E+00	0.00E+00	0.00E+00	1.15E-05
Cr-51	0.00E+00	0.00E+00	6.39E-08	4.11E-08	9.45E-09	9.17E-06	2.55E-07
Mn-54	0.00E+00	1.81E-05	3.56E-06	0.00E+00	3.56E-06	7.14E-04	5.04E-06
Mn-56	0.00E+00	1.10E-09	1.58E-10	0.00E+00	7.86E-10	8.95E-06	5.12E-05
Fe-55	1.41E-05	8.39E-06	2.38E-06	0.00E+00	0.00E+00	6.21E-05	7.82E-07
Fe-59	9.69E-06	1.68E-05	6.77E-06	0.00E+00	0.00E+00	7.25E-04	1.77E-05
Co-57	0.00E+00	4.65E-07	4.58E-07	0.00E+00	0.00E+00	2.71E-04	3.47E-06
Co-58	0.00E+00	8.71E-07	1.30E-06	0.00E+00	0.00E+00	5.55E-04	7.95E-06
Co-60	0.00E+00	5.73E-06	8.41E-06	0.00E+00	0.00E+00	3.22E-03	2.28E-05
Ni-63	2.42E-04	1.46E-05	8.29E-06	0.00E+00	0.00E+00	1.49E-04	1.73E-06
Ni-65	1.71E-09	2.03E-10	8.79E-11	0.00E+00	0.00E+00	5.80E-06	3.58E-05
Cu-64	0.00E+00	1.34E-09	5.53E-10	0.00E+00	2.84E-09	6.64E-06	1.07E-05
Zn-65	1.38E-05	4.47E-05	2.22E-05	0.00E+00	2.32E-05	4.62E-04	3.67E-05
Zn-69	3.85E-11	6.91E-11	5.13E-12	0.00E+00	2.87E-11	1.05E-06	9.44E-06
Zn-69m	8.98E-09	1.84E-08	1.67E-09	0.00E+00	7.45E-09	1.91E-05	2.92E-05
Br-82	0.00E+00	0.00E+00	9.49E-06	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-83	0.00E+00	0.00E+00	2.72E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-84	0.00E+00	0.00E+00	2.86E-07	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Br-85	0.00E+00	0.00E+00	1.46E-08	0.00E+00	0.00E+00	0.00E+00	0.00E+00
Rb-86	0.00E+00	1.36E-04	6.30E-05	0.00E+00	0.00E+00	0.00E+00	2.17E-06
Rb-88	0.00E+00	3.98E-07	2.05E-07	0.00E+00	0.00E+00	0.00E+00	2.42E-07
Rb-89	0.00E+00	2.29E-07	1.47E-07	0.00E+00	0.00E+00	0.00E+00	4.87E-08
Sr-89	2.84E-04	0.00E+00	8.15E-06	0.00E+00	0.00E+00	1.45E-03	4.57E-05
Sr-90	2.92E-02	0.00E+00	1.85E-03	0.00E+00	0.00E+00	8.03E-03	9.36E-05
Sr-91	6.83E-08	0.00E+00	2.47E-09	0.00E+00	0.00E+00	3.76E-05	5.24E-05
Sr-92	7.50E-09	0.00E+00	2.79E-10	0.00E+00	0.00E+00	1.70E-05	1.00E-04
Y-90	2.35E-06	0.00E+00	6.30E-08	0.00E+00	0.00E+00	1.92E-04	7.43E-05
Y-91m	2.91E-10	0.00E+00	9.90E-12	0.00E+00	0.00E+00	1.99E-06	1.68E-06
Y-91	4.20E-04	0.00E+00	1.12E-05	0.00E+00	0.00E+00	1.75E-03	5.02E-05
Y-92	1.17E-08	0.00E+00	3.29E-10	0.00E+00	0.00E+00	1.75E-05	9.04E-05
Y-93	1.07E-07	0.00E+00	2.91E-09	0.00E+00	0.00E+00	5.46E-05	1.19E-04
Zr-95	8.24E-05	1.99E-05	1.45E-05	0.00E+00	2.22E-05	1.25E-03	1.55E-05
Zr-97	1.07E-07	1.83E-08	8.36E-09	0.00E+00	1.85E-08	7.88E-05	1.00E-04
Nb-95	1.12E-05	4.59E-06	2.70E-06	0.00E+00	3.37E-06	3.42E-04	9.05E-06
Nb-97	2.44E-10	5.21E-11	1.88E-11	0.00E+00	4.07E-11	2.37E-06	1.92E-05
Mo-99	0.00E+00	1.18E-07	2.31E-08	0.00E+00	1.89E-07	9.63E-05	3.48E-05
Tc-99m	9.98E-13	2.06E-12	2.66E-11	0.00E+00	2.22E-11	5.79E-07	1.45E-06
Tc-101	4.65E-14	5.88E-14	5.80E-13	0.00E+00	6.99E-13	4.17E-07	6.03E-07
Ru-103	1.44E-06	0.00E+00	4.85E-07	0.00E+00	3.03E-06	3.94E-04	1.15E-05
Ru-105	8.74E-10	0.00E+00	2.93E-10	0.00E+00	6.42E-10	1.12E-05	3.46E-05
Ru-106	6.20E-05	0.00E+00	7.77E-06	0.00E+00	7.61E-05	8.26E-03	1.17E-04
Ag-110m	7.13E-06	5.16E-06	3.57E-06	0.00E+00	7.80E-06	2.62E-03	2.36E-05

Table 7.7 (8 of 8)
INHALATION DOSE FACTORS
(mrem/pCi inhaled)

	INFANT							
	bone	liver	t body	thyroid	kidney	lung	gi-lli	
Sb-124	2.71E-05	3.97E-07	8.56E-06	7.18E-08	0.00E+00	1.89E-03	4.22E-05	
Sb-125	3.69E-05	3.41E-07	7.78E-06	4.45E-08	0.00E+00	1.17E-03	1.05E-05	
Te-125m	3.40E-06	1.42E-06	4.70E-07	1.16E-06	0.00E+00	3.19E-04	9.22E-06	
Te-127m	1.19E-05	4.93E-06	1.48E-06	3.48E-06	2.68E-05	9.37E-04	1.95E-05	
Te-127	1.59E-09	6.81E-10	3.49E-10	1.32E-09	3.47E-09	7.39E-06	1.74E-05	
Te-129m	1.01E-05	4.35E-06	1.59E-06	3.91E-06	2.27E-05	1.20E-03	4.93E-05	
Te-129	5.63E-11	2.48E-11	1.34E-11	4.82E-11	1.25E-10	2.14E-06	1.88E-05	
Te-131m	7.62E-08	3.93E-08	2.59E-08	6.38E-08	1.89E-07	1.42E-04	8.51E-05	
Te-131	1.24E-11	5.87E-12	3.57E-12	1.13E-11	2.85E-11	1.47E-06	5.87E-06	
Te-132	2.66E-07	1.69E-07	1.26E-07	1.99E-07	7.39E-07	2.43E-04	3.15E-05	
I-130	4.54E-06	9.91E-06	3.98E-06	1.14E-03	1.09E-05	0.00E+00	1.42E-06	
I-131	2.71E-05	3.17E-05	1.40E-05	1.06E-02	3.70E-05	0.00E+00	7.56E-07	
I-132	1.21E-06	2.53E-06	8.99E-07	1.21E-04	2.82E-06	0.00E+00	1.36E-06	
I-133	9.46E-06	1.37E-05	4.00E-06	2.54E-03	1.60E-05	0.00E+00	1.54E-06	
I-134	6.58E-07	1.34E-06	4.75E-07	3.18E-05	1.49E-06	0.00E+00	9.21E-07	
I-135	2.76E-06	5.43E-06	1.98E-06	4.97E-04	6.05E-06	0.00E+00	1.31E-06	
Cs-134	2.83E-04	5.02E-04	5.32E-05	0.00E+00	1.36E-04	5.69E-05	9.53E-07	
Cs-136	3.45E-05	9.61E-05	3.78E-05	0.00E+00	4.03E-05	8.40E-06	1.02E-06	
Cs-137	3.92E-04	4.37E-04	3.25E-05	0.00E+00	1.23E-04	5.09E-05	9.53E-07	
Cs-138	3.61E-07	5.58E-07	2.84E-07	0.00E+00	2.93E-07	4.67E-08	6.26E-07	
Ba-139	1.06E-09	7.03E-13	3.07E-11	0.00E+00	4.23E-13	4.25E-06	3.64E-05	
Ba-140	4.00E-05	4.00E-08	2.07E-06	0.00E+00	9.59E-09	1.14E-03	2.74E-05	
Ba-141	1.12E-10	7.70E-14	3.55E-12	0.00E+00	4.64E-14	2.12E-06	3.39E-06	
Ba-142	2.84E-11	2.36E-14	1.40E-12	0.00E+00	1.36E-14	1.11E-06	4.95E-07	
La-140	3.61E-07	1.43E-07	3.68E-08	0.00E+00	0.00E+00	1.20E-04	6.06E-05	
La-142	7.36E-10	2.69E-10	6.46E-11	0.00E+00	0.00E+00	5.87E-06	4.25E-05	
Ce-141	1.98E-05	1.19E-05	1.42E-06	0.00E+00	3.75E-06	3.69E-04	1.54E-05	
Ce-143	2.09E-07	1.38E-07	1.58E-08	0.00E+00	4.03E-08	8.30E-05	3.55E-05	
Ce-144	2.28E-03	8.65E-04	1.26E-04	0.00E+00	3.84E-04	7.03E-03	1.06E-04	
Pr-143	1.00E-05	3.74E-06	4.99E-07	0.00E+00	1.41E-06	3.09E-04	2.66E-05	
Pr-144	3.42E-11	1.32E-11	1.72E-12	0.00E+00	4.80E-12	1.15E-06	3.06E-06	
Nd-147	5.67E-06	5.81E-06	3.57E-07	0.00E+00	2.25E-06	2.30E-04	2.23E-05	
W-187	9.26E-09	6.44E-09	2.23E-09	0.00E+00	0.00E+00	2.83E-05	2.54E-05	
Np-239	2.65E-07	2.37E-08	1.34E-08	0.00E+00	4.73E-08	4.25E-05	1.78E-05	

Reference:

Regulatory Guide 1.109, Table E-10.

Dose Factors for Co-57, Zn-69m, Br-82, Nb-97, Sb-124 and Sb-125 are from NUREG-0172 Age Specific Radiation Dose Commitment Factors for a One Year Chronic Intake, November 1977, Table 5.

NOTE: The tritium dose factor for bone is assumed to be equal to the total body dose factor.



Figure 7.1
OFFGAS SYSTEM AND SGTS' EFFLUENT MONITORING








Figure 7.2
NORMAL BUILDING VENTILATION



* Used seasonally to control temperature




Figure 7.3
PLUME DEPLETION EFFECT
(Page 1 of 4)



Plume Depletion Effect for Ground-Level Releases (All Atmospheric Stability Classes)




Figure 7.3
PLUME DEPLETION EFFECT
(Page 2 of 4)



Plume Depletion Effect for 30-m Releases, (Letters denote Pasquill Stability Class);




Figure 7.3
PLUME DEPLETION EFFECT
(Page 3 of 4)



Plume Depletion Effect for 60-m Releases (Letters denote Pasquill Stability Class)




Figure 7.3
PLUME DEPLETION EFFECT
(Page 4 of 4)



Plume Depletion Effect for 100-m Releases (Letters denote Pasquill Stability Class)




Figure 7.4
VERTICAL STANDARD DEVIATION OF MATERIAL IN A PLUME



Vertical Standard Deviation of Material in a Plume (Letters denote Pasquill Stability Class)




Figure 7.5
RELATIVE DEPOSITION
(Page 1 of 4)



Relative Deposition for Ground-Level Releases (All Atmospheric Stability Classes)




Figure 7.5
RELATIVE DEPOSITION
(Page 2 of 4)



Relative Deposition for 30-m Releases (Letters denote Pasquill Stability Class)




Figure 7.5
RELATIVE DEPOSITION
(Page 3 of 4)



Relative Deposition for 60-m Releases (Letters denote Pasquill Stability Class)

Figure 7.5
RELATIVE DEPOSITION
(Page 4 of 4)



Relative Deposition for 100-m Releases (Letters denote Pasquill Stability Class)



SECTION 8.0

TOTAL DOSE



8.0 TOTAL DOSE

To determine compliance with 40 CFR 190, the annual dose contributions to the maximum individual from BFN radioactive effluents and all other nearby uranium fuel cycle sources will be considered. The annual dose to the maximum individual will be conservatively estimated by: first, summing the total body air submersion dose, and the critical organ dose (except thyroid) from gaseous effluents; the total body dose, and critical organ dose (except thyroid) from liquid effluents for each quarter calculated in accordance with Sections 6.6 and 7.7. Then to this sum for each quarter is added any identifiable increase in direct radiation dose levels attributable to the plant as determined by the environmental monitoring program outlined in Section 9.0. These quarterly sums are then conservatively summed for the four calendar quarters to estimate the maximum individual dose for the year. This dose is compared to the limit in Control 3.2.3, i.e., 25 mrem per year to the total body or any organ (except thyroid), to determine compliance.

The total annual thyroid dose to the maximum individual will be conservatively estimated in the following manner. For each calendar quarter, a total dose will be obtained by summing the total body gaseous submersion dose, the gaseous thyroid dose, the liquid total body dose, and the liquid thyroid dose. To this sum for each quarter is added any identifiable increase in direct radiation dose levels attributable to the plant as determined by the environmental monitoring program outlined in Section 9.0. These quarterly sums are then added together to estimate the maximum individual thyroid dose for the year. This dose is compared to the limit in Control 3.2.3, i.e., 75 mrem per year to determine compliance.



SECTION 9.0

ENVIRONMENTAL MONITORING PROGRAM



9.1 MONITORING PROGRAM DESCRIPTION

An environmental radiological monitoring program as described in Tables 9.1, 9.2 and 9.3 and in Figures 9.1, 9.2, and 9.3 shall be conducted. Results of this program shall be reported in accordance with ODCM Administrative Control 5.1.

The atmospheric environmental radiological monitoring program shall consist of 10 monitoring stations from which samples of air particulates and radioiodine shall be collected.

The terrestrial monitoring program shall consist of the collection of milk, soil, drinking water, and food crops. In addition, direct gamma radiation levels will be measured at 40 or more locations in the vicinity of the plant.

The reservoir sampling program shall consist of the collection of samples of surface water, sediment, and fish.

9.2 DETECTION CAPABILITIES

Analytical techniques shall be such that the detection capabilities listed in Table 2.3-2 are achieved.

9.3 LAND USE CENSUS

A land use survey shall be conducted in accordance with the requirements in Control 1.3.2. The results of the survey shall be reported in the Annual Radiological Environmental Operating Report.

9.4 INTERLABORATORY COMPARISON PROGRAM

Analyses shall be performed on radioactive materials supplied as part of an Interlaboratory Comparison Program which has been approved by the NRC. A summary of the results obtained in the intercomparison shall be included in the Annual Radiological Environmental Operating Report (or the EPA program code designation may be provided).

If analyses are not performed as required corrective actions taken to prevent a recurrence shall be reported in the Annual Radiological Environmental Operating Report.



Table 9.1 (1 of 5)
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
AIRBORNE Particulates	6 samples from locations (in different sectors) at or near the site boundary (LM-1, LM-2, LM-3, LM-4, LM-6, and LM-7) 2 samples from control locations greater than 10 miles from the plant (RM-1 and RM-6) 3 samples from locations in communities approximately 10 miles from the plant (PM-1, PM-2 and PM-3)	Continuous sampler operation with sample collection as required by dust loading but at least once per 7 days.	Particulate sampler. Analyze for gross beta radioactivity >24 hrs following filter change. Perform gamma isotopic analysis on each sample when gross beta activity is >10 times the average of control samples. Perform gamma isotopic analysis on composite (by location) sample at least once per 31 days.
Radioiodine	Same locations as air particulates	Continuous sampler operation with charcoal canister collection at least once per 7 days	I-131 every 7 days
SOIL	Samples from same locations as air particulates	Once every year	Gamma scan, Sr-89, Sr-90 once per year
DIRECT	2 or more dosimeters placed at locations (in different sectors) at or near the site boundary in each of the 16 sectors	At least once per 92 days	Gamma dose once per 92 days



Table 9.1 (2 of 5)
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
DIRECT (continued)	2 or more dosimeters placed at stations located approximately 5 miles from the plant in each of the 16 sectors 2 or more dosimeters in at least 8 additional locations of special interest	At least once per 92 days.	Gamma dose once per 92 days.
WATERBORNE Surface	1 sample upstream (TRM 305.0) 1 sample immediately downstream of discharge (TRM 293.5) 1 sample downstream from plant (TRM 285.2)	Collected by automatic sequential-type sampler with composite sample taken at least once per 31 days ^a .	Gamma scan at least once per 31 days. Composite for tritium at least once per 92 days
Drinking	1 sample at the first potable surface water supply downstream from the plant (TRM 282.6)	Collected by automatic sequential-type sampler with composite sample taken at least once per 31 days ^{a,b}	Gross beta and gamma scan at least once per 31 days. Composite for Sr-89, Sr-90 and tritium at least once per 92 days.

^a Composite samples shall be collected by collecting an aliquot at intervals not exceeding 2 hours.

^b This assumes that the nearest drinking water intake is >3.0 mile downstream of the plant discharge. If a drinking water intake is constructed within 3.0 miles downstream of the plant discharge, sampling and analysis shall be every 2 weeks.



Table 9.1 (3 of 5)
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
Drinking (continued)	3 additional samples of potable surface water downstream from the plant (TRM 274.9, TRM 259.8, and TRM 259.5) 1 sample at a control location (TRM 306)	Grab sample taken at least once per 31 days.	Gross beta and gamma scan at least once per 31 days. Composite for Sr-89 and Sr-90 and tritium at least once per 92 days
	1 additional sample at a control location ^c (TRM 305)	Collected by automatic sequential-type sampler with composite sample taken at least once per 31 days ^a	
GROUND	1 sample adjacent to the plant (well #6)	Collected by automatic sequential-type sampler with composite sample taken at least once per 31 days.	Composite for gamma scan, Sr-89, Sr-90, and tritium at least once per 92 days.
	1 sample at a control location upgradient from the plant (Farm Bn)	Grab sample taken at least once per 31 days.	Composite for gamma scan, Sr-89, Sr-90, and tritium at least once per 92 days.
AQUATIC Sediment	2 samples upstream from discharge point (TRM 297.0 and TRM 307.52)	At least once per 184 days	Gamma scan, Sr-89, and Sr-90 analyses

^a Composite samples shall be collected by collecting an aliquot at intervals not exceeding 2 hours.

^c The surface water control sample shall be considered a control for the drinking water sample.



Table 9.1 (4 of 5)
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
Sediment (continued)	1 sample in immediate downstream area of discharge point (TRM 293.7) 2 additional samples downstream from the plant (TRM 288.78 and 277.98)	At least once per 184 days	Gamma scan, Sr-89 and Sr-90 analyses
INGESTION Milk	At least 2 samples from dairy farms in the immediate vicinity of the plant (Farms B and Bn) At least 1 sample from control locations (Farm G1 or Be)	At least once per 15 days when animals are on pasture; at least once per 31 days at other times.	Gamma scan and I-131 on each sample. Sr-89 and Sr-90 at least once per 31 days
Fish	3 samples representing commercial and game species in Guntersville Reservoir above the plant 3 samples representing commercial and game species in Wheeler Reservoir near the plant	At least once per 184 days	Gamma scan at least once per 184 days on edible portions.



Table 9.1 (5 of 5)
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM

<u>Exposure Pathway and/or Sample</u>	<u>Number of Samples and Sample Locations</u>	<u>Sampling and Collection Frequency</u>	<u>Type and Frequency of Analysis</u>
Clams	1 sample down-stream from the discharge	At least once per 184 days.	Gamma scan on flesh only
	1 sample upstream from the plant. (No permanent stations established; depends on availability of clams).		
Fruits & Vegetables	Samples of food crops such as corn, green beans, tomatoes, and potatoes grown at private gardens and/or farms in the immediate vicinity of the plant	At least once per year at time of harvest	Gamma scan on edible portion
	1 sample of each of the same foods grown at greater than 10 miles distance from the plant		
Vegetation (pasturage)	Samples from farms producing milk but not providing a milk sample (Farm T).	Once per 31 days	I-131, gamma scan once per 31 days. Sr-89 and Sr-90 analysis on the last monthly sample of each quarter.
	Control sample from 1 control dairy farm (Farm G1)		



Table 9.2
ENVIRONMENTAL RADIOLOGICAL MONITORING PROGRAM SAMPLING LOCATIONS

Map Location Number ^a	Station	Sector	Approximate Distance (Miles)	Indicator (I) or Control (C)	Samples Collected ^b
1	PM-1	NW	13.8	I	AP, CF, S
2	PM-2	NE	10.9	I	AP, CF, S
3	PM-3	SSE	7.5	I	AP, CF, S
4	LM-7	W	2.1	I	AP, CF, S
5	RM-1	W	31.3	C	AP, CF, S
6	RM-6	E	24.2	C	AP, CF, S
7	LM-1	N	1.0	I	AP, CF, S
8	LM-2	NNE	0.9	I	AP, CF, S
9	LM-3	ENE	0.9	I	AP, CF, S
10	LM-4	NNW	1.7	I	AP, CF, S
11	LM-6	SSW	3.0	I	AP, CF, S
12	Farm B	NNW	6.8	I	M
13	Farm Bn	N	5.0	I	M, W
18	Farm G1	WSW	35	C	M, V
22	Well #6	NW	0.02	I	W
23	TRM ^c 282.6	-	11.4 ^d	I	PW
24	TRM 303.0	-	12.0	C	PW
25	TRM 259.6	-	34.4 ^d	I	PW
26	TRM 274.9	-	19.1 ^d	I	PW
27	TRM 285.2	-	8.8 ^d	I	SW
28	TRM 293.5	-	0.5 ^d	I	SW
29	TRM 305.0	-	11.0 ^d	C ^e	SW
30	TRM 307.52	-	13.52	C	SD
31	TRM 293.7	-	0.3 ^d	I	SD
32	TRM 288.78	-	5.22 ^d	I	SD
33	TRM 277.98	-	16.02 ^d	I	SD
34	Farm Be	NW	28.8	C	M
36	Farm T	WNW	3.2	I	V
37	TRM 297.0	-	3.0 ^d	C	SD
	Wheeler Reservoir (TRM 275-349)			I/C	F, CL
	Guntersville Reservoir (TRM 349-424)			I	F
70	TRM 259.8	-	34.2 ^d	I	PW

^a See Figures 9.1, 9.2, and 9.3

^b Sample codes:

AP = Air particulate filter	S = Soil	SD = Sediment
CF = Charcoal Filter	SW = Surface Water	CL = Clams
F = Fish	V = Vegetation	PW = Public Water
W = Well Water	M = Milk	

^c TRM = Tennessee River Mile

^d Miles from plant discharge (TRM 294)

^e Also used as a control for public water



Table 9.3
THERMOLUMINESCENT DOSIMETRY LOCATIONS

<u>Map Location Number</u>	<u>Station</u>	<u>Sector</u>	<u>Approximate Distance (Miles)</u>	<u>Onsite (On)^a or Offsite (Off)</u>
1	NW-3	NW	13.8	Off
2	NE-3	NE	10.9	Off
3	SSE-2	SSE	7.5	Off
5	W-3	W	31.3	Off
6	E-3	E	24.2	Off
7	N-1	N	1.0	On
8	NNE-1	NNE	0.9	On
9	ENE-1	ENE	0.9	On
10	NNW-2	NNW	1.7	On
38	N-2	N	5.0	Off
39	NNE-2	NNE	0.7	On
40	NNE-3	NNE	5.2	Off
41	NE-1	NE	0.8	On
42	NE-2	NE	5.0	Off
43	ENE-2	ENE	6.2	Off
44	E-1	E	0.8	On
45	E-2	E	5.2	Off
46	ESE-1	ESE	0.9	On
47	ESE-2	ESE	3.0	Off
48	SE-1	SE	0.5	On
49	SE-2	SE	5.4	Off
50	SSE-1	SSE	5.1	Off
51	S-1	S	3.1	Off
52	S-2	S	4.8	Off
53	SSW-2	SSW	3.0	Off
54	SSW-2	SSW	4.4	Off
55	SW-1	SW	1.9	On
56	SW-2	SW	4.7	Off
57	SW-3	SW	6.0	Off
58	WSW-1	WSW	2.7	Off
59	WSW-2	WSW	5.1	Off
60	WSW-3	WSW	10.5	Off
61	W-1	W	1.9	On
62	W-2	W	4.7	Off
63	W-4	W	32.1	Off
64	WNW-1	WNW	3.3	Off
65	WNW-2	WNW	4.4	Off
66	NW-1	NW	2.2	Off
67	NW-2	NW	5.3	Off
68	NNW-1	NNW	1.0	On
69	NNW-3	NNW	5.2	Off

^aTLDs designated onsite are those located two miles or less from the plant.
TLDs designated offsite are those located more than two miles from the plant.



Figure 9.1
ENVIRONMENTAL RADIOLOGICAL SAMPLING LOCATIONS
WITHIN 1 MILE OF THE PLANT









Figure 9.3
ENVIRONMENTAL RADIOLOGICAL SAMPLING LOCATIONS
GREATER THAN 5 MILES FROM THE PLANT





RETS MANUAL

Section IV

PROCESS CONTROL PROGRAM
(PCP)

IV-1



1.0 INTRODUCTION

1.1 Scope

This Process Control Program (PCP) is applicable to radioactive waste solidification and dewatering of wet solid radioactive wastes generated as a result of the operation and maintenance of Browns Ferry Nuclear Plant. This PCP is not applicable to the treatment of mixed wastes.

1.2 Purpose

The PCP provides those controls necessary to ensure that disposal criteria are met by BFN processing techniques, or by vendor supplied systems, if used for dewatering or solidification.

2.0 DEFINITIONS

- 2.1 Absorb - To take liquid in through pores, or as if through pores or interstices of a material.
- 2.2 Absorbent - Media or material used to absorb liquid.
- 2.3 Batch - An isolated quantity of waste to be processed having constant physical and chemical characteristics.
- 2.4 Container - The primary receptacle in which processed wastes (dewatered, solidified or absorbed) are packaged for disposal.
- 2.5 Dewatered - Wet solid wastes which have had excess water removed.
- 2.6 Free Liquid - Uncombined liquid not bound by the solid matrix of the solid waste mass; capable of flowing.
- 2.7 Homogeneous - Of uniform composition; the waste is uniformly distributed throughout the container.
- 2.8 Liquid waste - For the purposes of this PCP, any aqueous or non-aqueous radioactive liquid which requires solidification or absorption before disposal. This may include oils, chemicals, water or other liquids unsuitable for in-plant clean-up or treatment.



- 2.9 Mixed waste - Low level radioactive wastes containing chemical constituents which are hazardous under Environmental Protection Agency regulations in 40 CFR Part 261.
- 2.10 Solidification agent - Material, which when mixed in prescribed proportions with liquid or wet solid wastes, can form a free standing product with no free liquid.
- 2.11 Solidify - To immobilize by use of a solidification agent or method which converts the liquid or wet solid waste to a free standing monolithic solid.
- 2.12 Stability - A property of the waste form such that it is able to maintain its structural integrity under the expected disposal conditions; stabilized waste should maintain its gross physical properties and identity over a 300 year period.
- 2.13 Wet solid wastes - Spent powdered ion exchange resins, filter aid sludge, bead ion exchange resins, and other sludges or slurries consisting of liquids with a high insoluble solid content.

3.0 REFERENCES

- 3.1 Code of Federal Regulations (CFR) Title 10, Parts 20, 61, and 71 [10 CFR 20, 10 CFR 61, and 10 CFR 71] - Energy
- 3.2 Code of Federal Regulations (CFR) Title 49 [49 CFR] - Transportation
- 3.3 Browns Ferry Nuclear Plant Final Safety Analysis Report, Volume 4, Chapter 9.3, Solid Radwaste system
- 3.4 Browns Ferry Nuclear Plant Technical Specifications (BFN Tech Spec) 4.8.F.1, 3.8.F.1 & 3.8.F.2, 6.10.1.f, and 6.11.1, 2 & 3
- 3.5 TVA Office of Nuclear Power Radioactive Material Shipment Manual (RMSM)
- 3.6 Nuclear Regulatory Commission (NRC) Low-Level Waste Licensing Branch Technical Position on Radioactive Waste Classification, May 1983, Rev. 0
- 3.7 Nuclear Regulatory Commission (NRC) Technical Position on Waste Form, May 1983, Rev. 0
- 3.8 Topical Report No. TP-02-NP-A Rev. 0



4.0 WASTE CHARACTERISTICS

4.1 Waste Streams

Three general waste streams applicable to this PCP have been identified for Browns Ferry. These are the Condensate Waste Phase Separator (CWPS), Reactor Water Cleanup Phase Separator (RWCU), and Dry Active waste (DAW). Other waste streams may be established based upon plant operational needs.

CWPS is fed by several waste sub-streams, including the Equipment Drain, Chemical Waste, Floor Drain, Fuel Pool Cooling, and Condensate systems.

RWCU is fed by Reactor Water Cleanup only.

DAW is used for wastes generated within the regulated areas of the reactor buildings and turbine buildings which cannot be appropriately attributed to either RWCU or CWPS. DAW normally includes paper, plastic, wood, metal and other such material generated as a result of the operation and maintenance of the plant.

4.2 Waste Form

Wet solid radioactive wastes consist of bead resins, filter aids (such as activated charcoals or carbons), powdered resins, and slurries or sludges.

Wastes which may require solidification may include, but are not limited to, liquids which cannot be processed using installed plant systems, oils, chemicals, aqueous filter media, and decontamination wastes.

Wastes are processed as appropriate to ensure that the minimum physical characteristics required by 10 CFR and disposal site criteria are met. All Class B and Class C waste is stabilized. On occasion, Class A waste (such as aqueous filter media with a concentration > 1 uCi/cc of isotopes with half-lives > 5 years) may be solidified or stabilized by BFN. Class A liquid wastes may be either solidified or packaged in sufficient absorbent material to absorb twice the volume of the liquid, as appropriate to the specific disposal site criteria or license requirements.

Tests are performed on those wastes which are solidified to ensure the adequacy of the solidification agent and procedural technique. These tests are made on a minimum of three samples from each waste batch to be solidified.



4.3 Waste Classification

Scaling factors which relate hard-to-measure isotopes to key isotopes commonly measured at BFN have been developed for each waste stream. These scaling factors are used in the classification of the waste for disposal. Scaling factors may be developed on an as needed basis depending on changing plant operational conditions. Updates are performed at least every two years for waste normally considered to be Class A, on an annual basis for other wastes, or when the scaling factors are considered to be high or low by a factor of ten.

Batch samples, separator samples, or sludge samples are taken for radiochemical analysis prior to processing the waste for shipment. DAW samples or area smears are taken to establish the relative percent abundance of isotopes for the DAW waste stream.

Materials which do not fit within the scope of existing scaling factors and waste streams are sampled. The samples are sent offsite for analysis and development of scaling factors prior to disposal of the materials.

5.0 SHIPMENT MANIFESTS

5.1 Manifest Preparation

Manifests are prepared for each shipment of radioactive waste for disposal. Programmatic guidance for manifest preparation is provided through the TVA Office of Nuclear Power, Radwaste Branch to ensure that all 10 CFR and 49 CFR criteria are met. Procedures for manifest preparation implement the specific requirements of 10 CFR 20.311, Transfer for Disposal and Manifests.

5.2 Manifest Tracking

Acknowledgment of receipt for each shipment to a disposal site is sent to BFN Radwaste Group by the disposal site. Shipments for which acknowledgment is not received within the time limits allowed in 10 CFR 20.311 are traced by the TVA Office of Nuclear Power, Radwaste Branch.



6.0 ADMINISTRATIVE CONTROLS

6.1 Procedures and Surveillance

Detailed procedures are written and maintained by BFN which cover plant process systems, waste packaging, and shipment requirements. Surveillance Instructions are used to verify that plant Technical Specifications for waste processing are met.

Programmatic guidance is provided through the TVA Office of Nuclear Power, Radwaste Branch. The Radwaste Branch maintains the Radioactive Material Shipment Manual and the Package Quality Assurance Program (for packages licensed under 10 CFR 71).

6.2 Quality Assurance/Quality Control

Quality assurance audits are conducted by the BFN site Quality Assurance organization, and by the TVA Division of Nuclear Quality Assurance (DNQA). Audit findings are reviewed by BFN management, ensuring prompt corrective actions when needed.

Quality control measures include quarterly tests of the resin dewatering system performed by BFN personnel upon actual dewatered High Integrity Containers (HICs) or liners, site review of all radwaste vendor procedures before use, and second party verification by BFN personnel of end points or acceptance criteria in vendor procedures. Quality control of solidification methods is performed through controlled testing of a minimum of three samples from each batch to be solidified. Proportions of solidification agents are established which meet the standards for waste form and free liquid criteria.

6.3 Training

Personnel involved in processing radioactive waste for shipment are trained in site procedures, regulatory requirements, and disposal site criteria. Training and retraining sessions are held when needed to support operations. Retraining is required on an annual basis to maintain qualification. Personnel found not complying with procedures may have their qualifications revoked by the Radwaste Group Supervisor, if deemed necessary. Qualifications may be reestablished through completion of retraining, and approval of the Radwaste Group Supervisor.



6.4 Retention of Records

Records are maintained to furnish documentation of items or activities affecting quality. Quality assurance records are stored in accordance with plant instructions and the TVA Nuclear Quality Assurance Manual. Retention times for radwaste records are established in the Radioactive Material Shipment Manual.

7.0 APPENDICES

7.1 Solidification Description

Topical Report Reference: None

System or method in use: None

Plant/Equipment Interfaces: None

7.2 Dewatering Description

Topical Report Reference: DW-11118-01-P-A, Chem Nuclear Systems, Inc., CNSI Dewatering Control Process Containers, and RDS-25506-01-P, Chem Nuclear Systems, Inc., RDS-1000 Radioactive Waste Dewatering System, Rev. 0

NOTE: See appended letter of interim approval from NRC to TVA of May 6, 1988.

Topical Report Reference: TP-02-NP-A, Nuclear Packing, Inc. Covering Nuclear Packaging, Inc. Dewatering System, Rev. 0.

System or method in use: Vacuum dewatering using portable air driven diaphragm pumps and 10 HP electric high vacuum pump; and/or, Vacuum dewatering/high speed drying using the CNSI RDS-1000 Radioactive Waste Dewatering System; and/or pressure vessel dewatering using portable air driven pumps, and/or Nuclear Packaging, Inc. Dewatering System.

Plant/Equipment Interfaces: See appended letters of February 11, 1987 and October 16, 1987 from TVA to NRC. (RIMS #L44 870211 808 and #L44 871016 807), and Attachment 1 and 2.



07 02 17 07 30

L44 870211 808

5H 157B Lookout Place

FEB 11 1987

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Office of Nuclear Reactor Regulation
Washington, D.C. 20555

Attention: Mr. D. R. Muller

In the Matter of the)
Tennessee Valley Authority)

Docket Nos. 50-259
50-260
50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - PROCESS CONTROL PROGRAM FOR DEMINERALIZER RESIN DEWATERING

Demineralizer resin dewatering is performed at BFN using equipment fabricated by TVA to meet Chem-Nuclear Systems, Inc., (CNSI) equipment specifications. BFN has adopted the operating methodology outlined by CNSI in a topical report (CNSI-DW-11118-01-P) titled, "CNSI Dewatering Control Process Containers: Topical Report." NRC accepted this topical report for reference by license applicants in a letter from C. O. Thomas (NRC) to L. K. Poppe (CNSI) dated June 11, 1985.

The enclosure provides information required by NRC to review applicability of the report to specific licensees as outlined in the associated safety evaluation. We request that NRC review the enclosed information and provide approval for use of this report as a process control program as defined in the Radiological Effluent Technical Specification (RETS) amendment (TVA BFN TS-221, dated September 30, 1986). It is further requested that NRC approval of the process control program coincide with the RETS implementation date or that the submittal be accepted on an interim basis until approval of the program is finalized.

If you have any questions concerning this request, please call L. V. Tonty at (205) 729-2677.

Very truly yours,

TENNESSEE VALLEY AUTHORITY
Original Signed By
R. L. Gridley

R. Gridley, Director
Nuclear Safety and Licensing

Enclosure
cc: See page 2

IV-8

600(207)



-2-

U.S. Nuclear Regulatory Commission

FEB 11 1987

cc (Enclosure):

U.S. Nuclear Regulatory Commission
Region II
Attn: Dr. J. Nelson Grace, Regional Administrator
101 Marietta Street, NW, Suite 2900
Atlanta, Georgia 30323

Mr. C. E. Gears
Browns Ferry Project Manager
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Bethesda, Maryland 20814

Mr. C. G. Zach, Director
TVA Projects
U.S. Nuclear Regulatory Commission
101 Marietta St., NW, Suite 2900
Atlanta, Georgia 30323

Browns Ferry Resident Inspector
Browns Ferry Nuclear Plant
P.O. Box 311
Athens, Alabama 35611

HJH:JWH:LVT:BJL

cc (Enclosure):

RHS, BR 4N 72A-C
R. W. Cantrell, W12 A12 C-K
E. S. Christenbury, E11 B33 C-K
W. H. Hannum, BR 1N 76B-C
R. L. Lewis, Browns Ferry
H. J. Hay, BFN - Licensing
D. R. Nichols, LP 5N 302B-C
R. C. Parker, LP 4N 45A-C
H. P. Pomrehn, Browns Ferry
L. J. Riales, BR 5S 144X-C
C. G. Robertson, LP 5S 83E-C
R. K. Selberling, 716C-C
D. L. Williams, W10 B85 C-K

0579c

IV-9

600(207)



ENCLOSURE

Dewatering is conducted at BFN using plant equipment and plant personnel. Chem-Nuclear Systems, Inc., (CNSI) high-integrity containers and the CNSI dewatering procedures are used.

1. EXCEPTIONS OR DEVIATIONS TAKEN TO CNSI TOPICAL REPORT DATED DECEMBER 1983.

BFN dewaterers powdered resin, filter media, and mixtures of powdered resin with small quantities of bead resin (normally less than 10 percent bead resin) using Chem-Nuclear Procedure FO-OP-022, "Ecodex Precoat/Powdex/Solka-Floc/Diatomaceous Earth Dewatering Procedure for CNSI 14-195 or Small Liners." The dewatering system was fabricated by TVA to meet the equipment specifications in FO-OP-022. The TVA dewatering system differs from the Chem-Nuclear system in that:

- (a) TVA's system has no off-gas collector. The high integrity containers are open to the waste packaging room air during filling and dewatering. Air from this room is normally discharged through the Radwaste Building ventilation system. This air then flows through a HEPA filter and is released through a monitored release point on the Reactor Building roof.
- (b) The valves on the pump suction manifold are manually operated. The system is not operated remotely. However, the high integrity containers are enclosed behind a shielded wall or inside a shielded cask during filling and dewatering to keep radiation levels in the vicinity of the system near background.
- (c) There are no vacuum gauges at each inlet connection. A single vacuum gauge is provided at the flush inlet connection to the manifold. This vacuum gauge will indicate a break in vacuum in any active (not isolated) filter set. Loss of vacuum normally occurs in sequence from the top to the bottom set of filters. When vacuum breaks at a given filter level, that level is isolated. Therefore, vacuum is monitored continually for all active filter sets.
- (d) There is no automatic level control or level indicating instrument in the TVA dewatering system. Level is determined by visual observations.

TVA has conducted tests which conclude that mixtures of bead and powdered resin, in proportions of up to 50-percent bead, can be adequately dewatered using a modified procedure for dewatering powdered resin. These tests were conducted using TVA-fabricated steel liners with dewatering internals similar to those found in the Chem-Nuclear high-integrity containers and a dewatering pump which is inferior to that



-2-

specified in FO-OP-022, in that it is limited to a vacuum of 13" Hg and has a flow rate of six SCFM. In addition, the dewatering procedure used for the tests called for only four hours of bulk dewatering, as opposed to three eight-hour pumping cycles specified in FO-OP-022. The conditions of the test were clearly less conducive to proper dewatering than those specified in FO-OP-022 (this equipment and procedure is not used for normal operation). However, results show that adequate dewatering is guaranteed either by extending the dewatering time in the procedure or by applying an additional dewatering cycle at the end of the bulk dewatering process using a high flow rate (approximately 200 SCFM at 28" Hg) vacuum pump. TVA has modified FO-OP-022 to include two hours of additional dewatering with the 200 SCFM vacuum pump for all resin.

2. INTERFACES BETWEEN PLANT AND CNSI EQUIPMENT

- (a) The high-integrity container is filled with spent resin slurry through a one-inch flexible hose. Flow through the hose is controlled by way of a diaphragm-operated valve. The hose is connected to the high-integrity container with an Evertight quick disconnect fitting that has been modified for remote operation.
- (b) The dewatering pump discharges through a one-inch flexible hose to the plant waste packaging drain header which leads to the waste package drain tank. The connection to the header is made by an OPW 633 D Kamlock quick disconnect fitting.
- (c) Radwaste compressed air is supplied through a flexible hose with Chicago connections to the air operated positive displacement pump.
- (d) Demineralized water is provided by a flexible hose with Chicago connections to the flush-inlet valve on the dewatering pump suction manifold.
- (e) The dewatering system is located inside the radwaste packaging room (see figure 1). Any leaks or spills will be contained inside this room by exterior doors which are closed during filling, and collected in radwaste floor drains. Failure of any of these resin processing components will not provide a pathway for radioactive materials into the environment or potable water supply.

3. LOCATION AND ARRANGEMENT OF DEWATERING SYSTEM IN PLANT

See Figure 1.

IV-11



-3-

4. WASTE CLASSIFICATION TO MEET 10 CFR 61.55

Radionuclide concentrations are determined by direct measurement. Samples or smears, as appropriate, of standard waste streams are sent offsite for analysis. An inferential measurement program is then established whereby concentrations of radioisotopes which cannot be readily measured are projected through ratioing to concentrations of similar behaving isotopes which can be readily measured. Scaling factors are developed on a waste stream specific basis. Scaling factors are periodically reconfirmed through sampling and analysis. A QC program is in place to ensure compliance with 10 CFR 61.55 and 61.56.

5. DESCRIPTION OF WASTE CONTAINER

High-integrity containers manufactured by CNSI are used for packaging resin. The following containers are used: 8-120, 14-195, 14-170 and are discussed in a topical report dated December 1983 entitled, "Chem-Nuclear Systems, Inc., Topical Report Polyethylene High Integrity Containers CNSI-HIC-14571-01-NP."

6. CAPABILITY TO MEET 10 CFR 50 APPENDIX I


This dewatering process does not cause any direct releases to the environment (note 1.a above).

IV-12



Reference: Browns Ferry
FSAR 9.2 - 1b

FIGURE 1



Waste Packaging Room Layout for Chem Nuclear system
Plan Elevation 565'



L44 871016 807

511 1578 Lookout Place

OCT 16 1987

U.S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555

Gentlemen:

In the Matter of
Tennessee Valley Authority

)
)
Docket Nos. 50-259
50-260
50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - PROCESS CONTROL PROGRAM FOR DEMINERALIZER RESIN DEWATERING

By letter from me to D. R. Muller, dated February 11, 1987, TVA described its process control program for demineralizer resin dewatering and requested NRC to review and approve it as described in that letter. This resin dewatering process was time-consuming. Chem-Nuclear Systems Inc. (CNSI) has since improved this process by developing the RDS-1000, Rapid Dewatering System, for accelerating the dewatering process. The time savings in this dewatering process will allow BFN to accommodate its spent resin generated during power production. TVA intends to implement the RDS-1000 process before Unit 2 restart. Therefore, this submittal supersedes the February 11, 1987 letter. Consequently, TVA has elected not to answer NRC's request for additional information from J. A. Zwolinski to S. A. White dated July 21, 1987 concerning BFN's current dewatering process in a separate submittal. However, these items are addressed in the enclosures to this letter for the RDS-1000 system.

Demineralizer resin dewatering will be performed at BFN using CNSI equipment. The operating methodology outlined by CNSI in topical reports DW-11118-01-P-A, "CNSI Dewatering Control Process Containers Topical Report" and RDS-25506-01-P, "RDS-1000 Radioactive Waste Dewatering System" will be used. NRC accepted CNSI Topical Report DW-11118-01-P-A for reference by license applicants in a letter from G. O. Thomas (NRC) to L. K. Poppe (CNSI) dated June 11, 1985. CNSI Topical Report RDS-25506-01-P was submitted to NRC by CNSI for approval by letter from W. B. House (CNSI) to R. L. Emch (NRC) dated March 26, 1987 and a nonproprietary copy is enclosed to this letter (enclosure 2). These CNSI topical reports will form the basis of the BFN demineralizer resin dewatering process and system.

Enclosure 1 provides information required by NRC to review applicability of the report to specific licensees as outlined in the safety evaluation for CNSI Topical Report DW-11118-01-P-A. Procedures for this new process and system are scheduled to be internally approved by October 1987. TVA requests that NRC review the enclosed information and provide approval, within this same timeframe, for use of this report as a process control program as defined in the BFN technical specification 6.9.

IV-14

600(207)



U.S. Nuclear Regulatory Commission

OCT 16 1987

If you have any questions concerning this request, please telephone
J. L. Turner at (205) 729-2853.

Enclosed is a check for the \$150 review fee required by 10 CFR 170.12.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

R. G. Tidley
R. G. Tidley, Director
Nuclear Licensing and
Regulatory Affairs

Subscribed and sworn to before me
on this 16th day of Oct. 1987.

Charllette H. White
Notary Public

My Commission Expires 8-24-88

Enclosures

cc (Enclosures):

Mr. G. C. Zech, Assistant Director
Regional Inspections
Division of TVA Projects
Office of Special Projects
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., NW, Suite 2900
Atlanta, Georgia 30323

Mr. J. A. Zwolinski, Assistant Director
for Projects
Division of TVA Projects
Office of Special Projects
U.S. Nuclear Regulatory Commission
4350 East-West Highway
E-W 322
Bethesda, Maryland 20814

Browns Ferry Resident Inspector
Browns Ferry Nuclear Plant
Route 2, P.O. Box 311
Athens, Alabama 35611

IV-15



U.S. Nuclear Regulatory Commission

OCT 19 1987

cc (Enclosures):

Mr. C. C. Zeeh, Assistant Director
Regional Inspections
Division of TVA Projects
Office of Special Projects
U.S. Nuclear Regulatory Commission
Region II
101 Marietta St., NW, Suite 2900
Atlanta, Georgia 30323

Mr. J. A. Zwolinski, Assistant Director
for Projects
Division of TVA Projects
Office of Special Projects
U.S. Nuclear Regulatory Commission
4350 East-West Highway
EW 322
Bethesda, Maryland 20814

Browns Ferry Resident Inspector
Browns Ferry Nuclear Plant
Route 2, P.O. Box 311
Athens, Alabama 35611

JDW:JLT:XBL:CEL

cc (Enclosures):

HMHS, MR 4N 72A-C
C. E. Ayers, LP 6N 25D-C
E. S. Christenbury, E11 B33 C-K
W. H. Hannum, BR 1N 77H-C
T. A. Ippolito, Bethesda Licensing Office
H. C. Kazanas, LP 4N 45A-C
J. A. Kirkebo, W12 A12 C-K
H. J. May, Browns Ferry
C. R. Inullee, BR 5S 168A-C
D. R. Nichols, BR 5S 100A-C
H. P. Pomrehn, Browns Ferry
S. J. Smith, LP 6N 38A-C
D. L. Williams, W10 B85 C-K

Licensing and Safety Browns Ferry Nuclear Plant		
OCT 20 '87		
	INFO	ACTION
FILM	<input checked="" type="checkbox"/>	<input type="checkbox"/>
Compliance Regulatory	<input type="checkbox"/>	<input type="checkbox"/>
Costs AM	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>
FILE 87-156		
NRC OUTG BR		



ENCLOSURE 1

Dewatering will be conducted at BFN using the Chem-Nuclear Systems, Inc. (CNSI) Rapid Dewatering System (RDS-1000). CNSI high-integrity containers and/or steel liners and plant specific versions of CNSI Procedure FO-OP-032, "Setup and Operating Procedure for the RDS-1000 Unit" and CNSI Procedure FO-OP-035, "Setup and Operating Procedure for Dewatering Pre-Coat Media in a 21-300 Liner Using the RDS-1000" will be used.

1. EXCEPTIONS OR DEVIATIONS TAKEN TO CNSI TOPICAL REPORTS DW-11118-01-P-A AND RDS-25506-01-P

TVA's system has no off-gas system connection available for interface with the RDS-1000. The rapid dewatering skid of the RDS-1000 system has a HEPA filter installed downstream of the safety relief valve and manual bypass valve. Liners will be vented through this HEPA filter to the waste packaging room. Air from this room is normally discharged through the radwaste building ventilation system. This air then flows through an installed HEPA filter before release through a monitored release point on the reactor building roof. Exterior doors from the waste packaging room are closed during liner filling and dewatering operations.

2. INTERFACES BETWEEN PLANT AND CNSI EQUIPMENT

A. A plant connection stand (PCS) is provided as part of the RDS-1000 system. Its components are:

1. A remotely operated valve to control influent to the liner;
2. A diaphragm pump with connections to the liner fillhead for initial gross dewatering;
3. Manifolds for air and service water supplies to control elements and flushing systems.

B. Radwaste building compressed service air will be provided to the PCS at approximately 40 SCFM at 80 psig (+20, -10 psig) through a flexible hose. The connection to plant air and water is made via quick-disconnect fittings. The PCS connection to CNSI equipment is also a quick-disconnect fitting.



-2-

- C. Radwaste building service water (demineralized) will be provided to the PCS at approximately 25 gpm at 80 psig (+20 psig) through a flexible hose. Both connection points (plant and PCS) are equipped with quick-disconnect fittings.
- D. The dewatering pump discharge is provided by a 1.5 inch flexible hose to the plant waste packaging drain header which leads to the waste package drain tank. The connection to the drain header is made by a 1-inch Kamlock quick-disconnect fitting. The dewatering pump connection is a 1.5 inch Kamlock quick-disconnect fitting. A 1 to 1.5-inch Kamlock adaptor will be used at the drain header.
- E. The connection to the plant waste media line will be made either by a 1.5-inch 150 ANSI flat faced flange connection or by a flange connection to Kamlock quick-disconnect adaptor utilizing existing flexible hose. A waste isolation valve will be installed downstream of this connection, providing local control by the CNSI operator over the flow of waste to the liners being filled. The waste isolation is controlled remotely, and is interlocked to close on high waste level, high-high level, decreasing air pressure, or loss of electrical power.

3. LOCATION AND ARRANGEMENT OF DEWATERING SYSTEM IN PLANT

See Figure 1

The RDS-1000 system will be located inside the radwaste packaging room, elevation 565'. Any leaks or spills will be contained inside this room by exterior doors, which are closed during liner filling and dewatering operations. Any spillage will be collected in the radwaste floor drains. Failure of any of these resin processing components will not provide a pathway for radioactive materials into the environment or potable water supply.

IV-18



-3-

4. WASTE CLASSIFICATION TO MEET 10 CFR 61.55

Radionuclide concentrations are determined by direct measurement. Samples or smears, as appropriate, of standard waste streams are sent offsite for analysis. An inferential measurement program is then established whereby concentrations of radioisotopes which cannot be readily measured are projected through ratioing to concentrations of similarly behaving isotopes which can be readily measured. Scaling factors are developed on a waste stream specific basis. Scaling factors are periodically reconfirmed through sampling and analysis. Computerized calculation of individual container isotopic contents is performed. Maintenance, testing, and independent verification of this program ascertain correct data manipulation. TVA QA audits of the vendor laboratory conducting the periodic sample analysis confirm quality practices at that location. Procedural controls, corporate assessments of the radwaste program, periodic QA audits of the program, and management evaluation of audit findings ensure quality in the plant program.

5. DESCRIPTION OF WASTE CONTAINER

High-integrity containers manufactured by CNSI are used for packaging resin. The following containers are used: 8-120, 14-195, and 14-170. They are discussed in a topical report dated December 1983 entitled, "Chem-Nuclear Systems, Inc., Topical Report Polyethylene High Integrity Containers CNSI-HIC-14571-01-NP." CNSI 21-300 steel liners are compatible with the dewatering system and may also be used.

6. CAPABILITY TO MEET 10 CFR 50 APPENDIX I

This dewatering process does not cause any direct releases to the environment.


IV-19



FIGURE 2

Reference: Browns Ferry
 FSAR 9.2 - 1b

- ① or ② Location for remote control panel
- ③ Plant connection stand and MIS-1000 skid location
- ④ MIC location
- ⑤ MIC location (alternate)



Waste Packaging Room Layout for Chem Nuclear System
 Plant Elevation 565'






Mr. S. A. White ..

-2-

May 6, 1989

If you have any questions concerning this issue, please contact your Project Manager, G. Gears at 301-492-0767.

Sincerely,



Robert A. Hermann, Acting Assistant Director
TVA Projects Division
Office of Special Projects

cc: See next page

IV-22



ATTACHMENT 1

Dewatering is conducted at BFN using Chem-Nuclear System, Inc (CNSI) supplied portable air driven pumps. Dewatering will be performed on CNSI 24 inch diameter pressure vessels.

1. EXCEPTIONS OR DEVIATIONS TAKEN TO CNSI TOPICAL REPORT

None. Plant specific versions of CNSI Procedure FO-OP-025 and vendor supplied equipment will be used to dewater vessels.

2. INTERFACES BETWEEN PLANT AND CNSI EQUIPMENT

- (a) The dewatering pump discharges through a flexible to a plant floor drain. This water will be processed through Radwaste.
- (b) Compressed air is supplied from the plant air system through a flexible hose with Chicago connections to the air driven pump.
- (c) The dewatering system will be located in a permanent plant building. Any leaks or spills will be contained inside this building and collected in floor drains. Failure of any of the components will not provide a pathway for radioactive releases to the environment or to a portable water supply.

3. LOCATION AND ARRANGEMENT OF DEWATERING SYSTEM IN PLANT

The dewatering will be performed in a permanent plant building. The dewatering pump will be located in the immediate vicinity of the pressure vessels and as close as possible to a floor drain.

4. WASTE CLASSIFICATION TO MEET 10 CFR 61.55

Radionuclide concentrations are determined by direct measurement. Samples or smears, as appropriate, of standard waste streams are sent off site for analysis. An inferential measurement program is then established whereby concentrations of radioisotopes which cannot be readily measured are projected through ratioing to concentrations of similar behaving isotopes which can be readily measured. Scaling factors are developed on a waste stream specific basis. Scaling factors are periodically reconfirmed through sampling and analysis. A QC program is in place to ensure compliance with 10 CFR 61.55 and 61.56.

5. DESCRIPTION OF WASTE CONTAINER

The waste containers are the CNSI 24 inch diameter carbon steel and fiberglass re-inforced plastic pressure vessels.

6. CAPABILITY TO MEET 10CFR50 Appendix I

This dewatering process does not cause any direct releases to the environment (see note 2C above).



ATTACHMENT 2

Dewatering will be conducted at BFN using the Pacific Nuclear Systems, Inc./Nu Pac Services Division, Inc. Resin Drying (Dewatering) System. Pacific Nuclear Systems, Inc./Nu Pac Services Division, Inc. high-integrity containers and plant specific versions of Pacific Nuclear Systems, Inc./Nu Pac Services Division, Inc. procedures OM-43-NS, "Operating Procedure for the Resin Drying (Dewatering) System," and OM-16-NS, "Users Guide for the Nu Pac Crosslinked Polyethylene High Integrity Containers" will be used.

1. EXCEPTIONS OR DEVIATIONS TAKEN TO PACIFIC NUCLEAR TOPICAL REPORT TP-02-NP-A


TVA's system has no off-gas connection available for connection to the Resin Drying System. The Resin Drying System blower skid contains a HEPA filter which removes airborne particulate matter from the container vent pathway during the container filling cycle and vents this air to the general area around the skid. This air is then discharged through the plant ventilation system. This air flows through an installed HEPA filter through a monitored release point prior to its release to the environment.

2. INTERFACES BETWEEN PLANT AND PACIFIC NUCLEAR SYSTEMS, INC EQUIPMENT

- A. Plant compressed service air will be supplied to the Resin Drying System at approximately 40 SCFM at 100 psi through a flexible hose.
- B. Plant service water (demineralized) will be supplied to the Resin Drying System at approximately 25 gpm at 80 psi through a flexible hose.
- C. The Resin Drying System will discharge the water removed from the high-integrity container to the plant radwaste system through a flexible hose.
- D. The connection to the waste transfer line is made via a high pressure flexible hose to the fillhead which is connected to the high-integrity container. A waste isolation valve provides the Pacific Nuclear System operator local control over the flow of waste to the liners. The waste transfer isolation is controlled remotely and the fillhead is interlock to close automatically on high waste level, or high fillhead pressure alarms.

3. LOCATION AND ARRANGEMENT OF DEWATERING SYSTEM IN PLANT

The Resin Drying System will be located inside a permanent plant building. Any leaks or spills would be contained inside this building. Any spillage would be collected in the plant floor drains. Failure of any of these resin processing components will not provide a pathway for radioactive materials into the environment or a portable water supply.



4. WASTE CLASSIFICATION TO MEET 10 CFR 61.55

Radionuclide concentrations are determined by direct measurement. Samples or smears, as appropriate, of standard waste streams are sent offsite for analysis. An inferential measurement program is then established whereby concentrations of radioisotopes which cannot be readily measured are projected through ratioing to concentrations of similarly behaving isotopes which can be readily measured. Scaling factors are developed on a waste stream specific basis. Scaling factors are periodically reconfirmed through sampling and analysis. Computerized calculation of individual container isotopic contents is performed. Maintenance, testing, and independent verification of this program ascertain correct data manipulation. TVA QA audits of the vendor laboratory conducting the periodic sample analysis confirm quality practices at that location. Procedural controls, corporate assessments of the Radwaste program, periodic QC audits of the program, and management evaluation of audit finding ensure qualify in the plant program.

5. DESCRIPTION OF WASTE CONTAINERS

High-integrity containers manufactured by Pacific Nuclear Systems, inc. are used for packaging resin.

6. CAPABILITY TO MEET 10 CFR 50 APPENDIX I

This dewatering process does not cause any direct releases to the environment.