

REGULATOR INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 7812120103 DOC. DATE: 78/11/30 NOTARIZED: NO  
 FACIL: 50-220 NINE MILE POINT #1, NIAGARA MOHAWK POWER CORP.  
 AUTH. NAME AUTHOR AFFILIATION  
 PERKINS, T.J. NIAGARA MOHAWK PWR  
 RECIP. NAME RECIPIENT AFFILIATION

DOCKET #  
 05000220

SUBJECT: Monthly Oper Rept for Nov 1978.

DISTRIBUTION CODE: A008S COPIES RECEIVED: LTR \_\_\_ ENCL \_\_\_ SIZE: \_\_\_\_\_  
 TITLE: ANNUAL, SEMI-ANNUAL & MONTHLY OPERATING REPORTS (OL STAG

NOTES: \_\_\_\_\_

ACTION:	RECIPIENT	COPIES		RECIPIENT	COPIES	
	ID CODE/NAME	LTR	ENCL	ID CODE/NAME	LTR	ENCL
	05 BC	6	6			
INTERNAL:	01 REG FILE	1	1	02 NRC PDR	01	01
	11 I & E	02	02	13 HANAUER	01	01
	14 MIPC	02	02	16 DIR DOR	01	01
	17AD SYS & PROJ	01	01	18 ENGR BR	01	01
	19 REAC SAFT BR	01	01	20 PLANT SYS BR	01	01
	21 EEB	01	01	22 CORE PERF BR	01	01
	23 EFFL TR SYS	01	01			
EXTERNAL:	03 LPDR	02	02	04 NSIC	01	01
	24 NATL LAB	01	01	25 BROOKHAVEN	01	01
	26 ACRS	15	15			

TOTAL NUMBER OF COPIES REQUIRED: LTR 41 ENCL 41

THE  
STATE OF  
NEW YORK  
IN SENATE  
January 10, 1912.

REPORT  
OF THE  
COMMISSIONERS OF THE LAND OFFICE  
IN RESPONSE TO A RESOLUTION PASSED BY THE SENATE  
MAY 11, 1911.

ALBANY:  
J. B. LIPPINCOTT COMPANY,  
PRINTERS,  
1912.

OPERATING DATA REPORT

DOCKET NO. 50-220  
 DATE December 5, 1978  
 COMPLETED BY T.J. Perkins  
 TELEPHONE 315-343-2110  
 ext. 1312

OPERATING STATUS

1. Unit Name: Nine Mile Point Unit #1
2. Reporting Period: 11/01/78 - 11/30/78
3. Licensed Thermal Power (MWt): 1850
4. Nameplate Rating (Gross MWe): 640
5. Design Electrical Rating (Net MWe): 620
6. Maximum Dependable Capacity (Gross MWe): 630
7. Maximum Dependable Capacity (Net MWe): 610
8. If Changes Occur in Capacity Ratings (Items Number 3 Through 7) Since Last Report, Give Reasons:

Notes

9. Power Level To Which Restricted, If Any (Net MWe): 550 Mwe (net) 1702 Mwt
10. Reasons For Restrictions, If Any: 92% scram reactivity coast down

	This Month	Yr.-to-Date	Cumulative
11. Hours In Reporting Period	<u>720</u>	<u>8,016</u>	<u>79,608</u>
12. Number Of Hours Reactor Was Critical	<u>720</u>	<u>7,659.8</u>	<u>58,729</u>
13. Reactor Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>1,204</u>
14. Hours Generator On-Line	<u>720</u>	<u>7,588.6</u>	<u>56,278.8</u>
15. Unit Reserve Shutdown Hours	<u>0</u>	<u>0</u>	<u>20.2</u>
16. Gross Thermal Energy Generated (MWH)	<u>1,181,836</u>	<u>12,679,612</u>	<u>91,133,621</u>
17. Gross Electrical Energy Generated (MWH)	<u>387,357</u>	<u>4,210,845</u>	<u>29,922,557</u>
18. Net Electrical Energy Generated (MWH)	<u>374,330</u>	<u>4,070,477</u>	<u>29,047,400</u>
19. Unit Service Factor	<u>100</u>	<u>94.7</u>	<u>70.7</u>
20. Unit Availability Factor	<u>100</u>	<u>94.7</u>	<u>70.7</u>
21. Unit Capacity Factor (Using MDC Net)	<u>85.2</u>	<u>83.2</u>	<u>59.8</u>
22. Unit Capacity Factor (Using DER Net)	<u>83.9</u>	<u>81.9</u>	<u>58.9</u>
23. Unit Forced Outage Rate	<u>0</u>	<u>1.6</u>	<u>10.2</u>

24. Shutdowns Scheduled Over Next 6 Months (Type, Date, and Duration of Each):

March 4, 1979 Annual Shutdown, Overhaul and Refuel

25. If Shut Down At End Of Report Period, Estimated Date of Startup: \_\_\_\_\_
26. Units In Test Status (Prior to Commercial Operation):

	Forecast	Achieved
INITIAL CRITICALITY	_____	_____
INITIAL ELECTRICITY	_____	_____
COMMERCIAL OPERATION	_____	_____

SECRET

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-220

UNIT Nine Mile Pt. Unit#1

DATE December 5, 1978

COMPLETED BY T.J. Perkins

TELEPHONE 315-343-2110  
ext. 1312

MONTH NOVEMBER

DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1	<u>552</u>	17	<u>554</u>
2	<u>551</u>	18	<u>554</u>
3	<u>554</u>	19	<u>553</u>
4	<u>551</u>	20	<u>553</u>
5	<u>543</u>	21	<u>552</u>
6	<u>555</u>	22	<u>548</u>
7	<u>542</u>	23	<u>548</u>
8	<u>556</u>	24	<u>383</u>
9	<u>555</u>	25	<u>391</u>
10	<u>540</u>	26	<u>422</u>
11	<u>551</u>	27	<u>497</u>
12	<u>537</u>	28	<u>551</u>
13	<u>553</u>	29	<u>555</u>
14	<u>551</u>	30	<u>554</u>
15	<u>553</u>	31	<u>          </u>
16	<u>553</u>		

INSTRUCTIONS

On this format, list the average daily unit power level in MWe-Net for each day in the reporting month. Compute to the nearest whole megawatt.



**UNIT SHUTDOWNS AND POWER REDUCTIONS**

REPORT MONTH NOVEMBER

DOCKET NO. 50-220  
 UNIT NAME Nine Mile Pt. Unit 1  
 DATE December 5, 1978  
 COMPLETED BY T.J. Perkins  
 TELEPHONE 315-343-2110  
 ext. 1312

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report #	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause & Corrective Action to Prevent Recurrence
	11/05/78	S	3.6	H	1				Condensate Demin Change
	11/10/78	S	4.5	H	1				#12 Condensate Demin Change
	11/12/78	S	6.7	H	1				#13 Condensate Demin Change
	11/24/78	S	96	H	1				All Control Rods Full Out - Preconditioning

<sup>1</sup>  
 F: Forced  
 S: Scheduled

<sup>2</sup>  
 Reason:  
 A-Equipment Failure (Explain)  
 B-Maintenance of Test  
 C-Refueling  
 D-Regulatory Restriction  
 E-Operator Training & License Examination  
 F-Administrative  
 G-Operational Error (Explain)  
 H-Other (Explain)

<sup>3</sup>  
 Method:  
 1-Manual  
 2-Manual Scram.  
 3-Automatic Scram.  
 4-Other (Explain)

<sup>4</sup>  
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

<sup>5</sup>  
 Exhibit I - Same Source

(9/77)



3  
4



NIAGARA MOHAWK POWER CORPORATION  
NINE MILE POINT NUCLEAR STATION UNIT #1

NARRATIVE OF OPERATING EXPERIENCE

November 1978

The station operated at 85.2% electrical capacity factor with an availability of 100%. The unit is derated to 92.0% thermal power as a result of scram reactivity restrictions.

- November 1-4            The unit operated at 92% power maintained with recirculation flow.
- November 5            Reduced load to 500 MWe for condensate demineralizer change at 0005. At 0335 load was increased back to 558 MWe after demineralizer change.
- November 6-9          The unit maintained 92% power with recirculation flow.
- November 10           Reduced load to 500 MWe at 0130 for condensate demineralizer change. At 0558 load was returned to 560 MWe after demineralizer change.
- November 11           Unit was operated at 92% power.
- November 12           Reduced load to 500 MWe for condensate demineralizer change at 0132. At 0648 load was returned after demineralizer change.
- November 13-21        Maintained load at 92% thermal power with recirculation flow. On the 21st, 100% recirc flow was reached.
- November 21-24        Load slowly coasted down until 0600 on the 24th when power was reduced to 350 MWe for control rod pattern change to an all rods out configuration. At 0840 all control rods were at position 48. At 1345 pre-conditioning started at a rate of approximately 3 MWe/hr.
- November 24-27        Increasing load as PCIOMR limits allow.
- November 28           Reached 92% power (all rods out).
- November 29-30        The unit maintained 92% power with recirculation flow.

