

# LICENSEE EVENT REPORT

CONTROL BLOCK:            ①

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

⑦ ⑧ ⑨ N Y N M P 1 ② 0 0 - 0 0 0 0 0 0 - 0 0 ③ 4 1 1 1 1 ④            ⑤  
7 8 9 14 15 25 26 57 CAT 58

CON'T  
⑦ ⑧ ⑨ 0 1 REPORT SOURCE L ⑥ 0 5 0 0 0 2 2 0 ⑦ 0 2 1 1 8 7 9 ⑧ 0 3 1 1 3 7 9 ⑨  
7 8 60 61 68 69 74 75 80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES ⑩

⑦ ⑧ ⑨ 0 2 During steady state operation, performance of surveillance test N1-ISP-  
0 3 IC26, found flow comparator #11 did not produce rod block within required  
0 4 tolerance, required setpoint is 14% +/- 2, the unit was found 20%. This  
0 5 condition resulted in minimal safety implications.  
0 6 \_\_\_\_\_  
0 7 \_\_\_\_\_  
0 8 \_\_\_\_\_

⑦ ⑧ ⑨ 0 9 SYSTEM CODE I A ⑪ CAUSE CODE E ⑫ CAUSE SUBCODE G ⑬ COMPONENT CODE I N S T R U ⑭ COMP. SUBCODE Y ⑮ VALVE SUBCODE Z ⑯  
7 8 9 10 11 12 13 18 19 20  
⑦ ⑧ ⑨ 0 9 LER/RO. REPORT NUMBER 7 9 ⑰ EVENT YEAR 7 9 ⑱ SEQUENTIAL REPORT NO. 0 0 1 ⑲ OCCURRENCE CODE 0 3 ⑳ REPORT TYPE L ㉑ REVISION NO. 0 ㉒  
7 8 9 21 22 23 24 26 27 28 29 30 31 32  
⑦ ⑧ ⑨ 0 9 ACTION TAKEN C ⑳ FUTURE ACTION D ㉑ EFFECT ON PLANT Z ㉒ SHUTDOWN METHOD Z ㉓ HOURS 0 0 0 0 ㉔ ATTACHMENT SUBMITTED N ㉕ NPFD-4 FORM SUB. N ㉖ PRIME COMP. SUPPLIER N ㉗ COMPONENT MANUFACTURER G 0 8 0 ㉘  
7 8 9 33 34 35 36 37 40 41 42 43 44 47

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS ㉚

⑦ ⑧ ⑨ 1 0 Replaced defective flow comparator and the setpoint was left at 14%.  
1 1 \_\_\_\_\_  
1 2 \_\_\_\_\_  
1 3 \_\_\_\_\_  
1 4 \_\_\_\_\_

⑦ ⑧ ⑨ 1 5 FACILITY STATUS E ㉙ % POWER 0 7 1 1 ㉚ OTHER STATUS NA ㉛ METHOD OF DISCOVERY B ㉜ DISCOVERY DESCRIPTION Surveillance Testing ㉝  
7 8 9 10 12 13 44 45 46 80

⑦ ⑧ ⑨ 1 6 ACTIVITY CONTENT RELEASED OF RELEASE Z ㉞ AMOUNT OF ACTIVITY NA ㉟ LOCATION OF RELEASE NA ㊱  
7 8 9 10 11 44 45 80

⑦ ⑧ ⑨ 1 7 PERSONNEL EXPOSURES NUMBER 0 0 0 ㊲ TYPE Z ㊳ DESCRIPTION NA ㊴  
7 8 9 11 12 13 80

⑦ ⑧ ⑨ 1 8 PERSONNEL INJURIES NUMBER 0 0 0 ㊵ DESCRIPTION NA ㊶  
7 8 9 11 12 13 80

⑦ ⑧ ⑨ 1 9 LOSS OF OR DAMAGE TO FACILITY TYPE Z ㊷ DESCRIPTION NA ㊸  
7 8 9 11 12 80

⑦ ⑧ ⑨ 2 0 ISSUED PUBLICITY DESCRIPTION NA ㊹  
7 8 9 10 80

NAME OF PREPARER R. Jutras

7908190280  
NRC USE ONLY  
PHONE: (315)343-2110 ext. 1327

