(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYNMP1 (2) | 00-00000-00 (3) | 41111 (4) | (5)
7 8 | 9 LICENSEE CODE 14 | 15 LICENSE NUMBER 25 | 26 LICENSE TYPE 30 | 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000222 (7) | 102779 (8) | 111979 (9)
7 8 | 60 | 61 DOCKET NUMBER 68 | 69 EVENT DATE 74 | 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady state operations, personnel performing instrument sur-
03 veillance tests were unable to zero #11 Side APRM Flow Converter. The
04 error in flow indication was in the conservative direction and all trip
05 points were operable. The faulty converter unit was replaced by a new
06 unit and the problem was eliminated. This event had no safety implica-
07 tions.
08
7 8 9 80

09
7 8

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
IA (11)	E (12)	G (13)	INSTRU (14)	(15)	Z (16)
9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 (21 22) — (23) SEQUENTIAL REPORT NO. 025 (24 26) / (27) OCCURRENCE CODE 03 (28 29) REPORT TYPE L (30) — (31) REVISION NO. 0 (32)

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0000	N (23)	N (24)	N (25)	G080 (26)
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Technicians were unable to zero APRM flow converter unit due to compo-
11 nent failure. The entire unit was replaced and the problem was elim-
12 inated.
13
14
7 8 9 80

15
7 8

FACILITY STATUS E (28) | % POWER 096 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Instrument Surveillance Test
9 10 12 | 13 44 | 45 46 | 80

16
7 8

ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
9 | 10 | 11 44 | 45 80

17
7 8

PERSONNEL EXPOSURES
NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
9 11 | 12 | 13 80

18
7 8

PERSONNEL INJURIES
NUMBER 000 (40) | DESCRIPTION (41) NA
9 11 | 12 80

19
7 8

LOSS OF OR DAMAGE TO FACILITY (43)
TYPE Z (42) | DESCRIPTION NA
9 | 10 80

20
7 8

PUBLICITY
ISSUED N (44) | DESCRIPTION (45) NA
9 | 10

7911300 484 S

NRC USE ONLY
68 69 80

NAME OF PREPARER E. Duda PHONE: (315) 343-2110 Ext 1558

GPO 917-926