NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01	NYNMP1 (2)	00-00000-00 (3)	41111 (4)	(5)	
	LICENSEE CODE	LICENSE NUMBER	LICENSE TYPE	CAT	

CON'T

01	REPORT SOURCE L (6)	05000220 (7)	010980 (8)	011680 (9)	
		DOCKET NUMBER	EVENT DATE	REPORT DATE	

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady state operation, routine review of the differential
03 recorder revealed that the condenser inlet/screenwell discharge
04 differential temperature was over established limits for more than
05 8 hours in a 24 hour period. Since subsequent review of the event
06 indicated that it was caused by calibration of equipment rather
07 than actual temperatures, there were no significant effects on
08 the environment.

09

SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
HF (11)	X (12)	Z (13)	INSTRU (14)	T (15)	Z (16)

(17) LER/RO REPORT NUMBER

EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
80	—	002	/	04	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
E (18)	G (19)	Z (20)	Z (21)	0000	N (23)	N (24)	L (25)	R335 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Investigation of the problem indicated that the problem was with the
11 instrumentation rather than the temperature itself. Recalibration
12 of the transmitter feeding the diff. recorder brought the indicated
13 output within limits. Procedures are being revised to provide for
14 more frequent monitoring of the equipment.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
15	E (28)	098 (29)	NA	B (31)	Operational Event

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
16	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
17	000 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
18	000 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
19	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)
20	N (44)	NA

NRC USE ONLY

NAME OF PREPARER Michael Falise 8001220520 PHONE: 315-343-2110, Ext. 1208

GPO 917-926