NRC FORM 366
(7-77)

U.S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: [ ] (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | NYNMP1 (2) | 00-00000-00 (3) | 4111 (4) | (5)
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T
01 | REPORT SOURCE L (6) | 05000220 (7) | 01 02 80 (8) | 01 10 80 (9)
7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During steady state operation calculations determined the average
03 planar linear heat generation rate to be greater than that allowed
04 by T.S. 3.1.7A. This T.S. requires that APLHGR not exceed 8.25 KW/ft.
05 It was found to be 8.29 KW/ft. This event resulted in minimal safety
06 implications because of its duration and magnitude.
07
08
7 8 9 80

09 | SYSTEM CODE ZZ (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)
7 8 9 10 11 12 13 18 19 20

(17) LER/RO REPORT NUMBER: EVENT YEAR 80 | — | SEQUENTIAL REPORT NO. 001 | / | OCCURRENCE CODE 03 | REPORT TYPE L | — | REVISION NO. 0
21 22 23 24 26 27 28 29 30 31 32

ACTION TAKEN X (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT B (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0000 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER 2999 (26)
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Upon discovery of the event Rx power was decreased by 20 MW Thermal.
11 Subsequent calculations revealed APLHGR within limits; that is,
12 8.22 KW/ft. vs. the 8.25 KW/ft. limit.
13
14
7 8 9 80

15 | FACILITY STATUS E (28) | % POWER 098 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Computer Printout
7 8 9 10 12 13 44 45 46 80

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA
7 8 9 10 11 44 45 80

17 | PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA
7 8 9 11 12 13 80

18 | PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA
7 8 9 11 12 80

19 | LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION NA
7 8 9 10 80

20 | PUBLICITY ISSUED Z (44) | DESCRIPTION (45) NA | NRC USE ONLY
7 8 9 10 68 69 80

8001280199

NAME OF PREPARER Michael J. Falise PHONE: 315-343-2110, Ext. 1208

GPO 917-926