

TELECOPY MESSAGE

TO: 215-337-5324 Telephone Number FROM: 315-343-2110 X1126 Telephone Number DATE/TIME 02/05/80
84-1350 315-343-2110 X1126

TO: BOYCE H. GRIER Director of Regulatory Operation NRC Region I 631 Park Avenue King of Prussia, PA. 19406 FROM: Niagara Mohawk Power Corporation Nine Mile Point Nuclear Station Unit #1 P.O. Box #32 Lycoming, New York 13093

SUBJECT: PROMPT REPORTABLE OCCURRENCE DOCKET NO. 50-220 LICENSE NO. DPR-63 ASSIGNED LER NO. 00-05

EVENT DATE: 2/3/80 REPORT DATE: 2/4/80

EVENT DESCRIPTION: NRC Engineering evaluation of G.R. 311.299 requires that the triple low level setpoint be raised 20" to account for differences in indicated versus actual water level caused by a large increase in drywell temperature during a loss of coolant accident.

COMPONENTS INVOLVED: Rosemount Analog Trip Unit

CAUSE AND REMEDIAL ACTION: Due to the piping configuration of the instrument reference tap, and the possibility of indicated versus true vessel level difference being as much as 19", it is possible that actuation of triple low setpoint may not have occurred. Therefore, the setpoint was adjusted upward by 20" on 2/3/80.

FACILITY STATUS: THERMAL MW 96

- c) Routine Startup _____
- d) Routine Shutdown _____
- e) Steady State Oper X
- f) Load Change _____
- g) Shutdown _____
- h) Refueling _____
- i) Other _____
- j) Not Applicable _____

A written follow-up report will be sent within two weeks.

TELECOPY TO R. R. Schneider FROM T.I. Perkins DATE 2/5/80
NAME NAME
Boyce Grier T.I. Perkins

5
80 02140 618
M007
3/10



11