NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0	1	N Y N M P 1 (2)	0 0 - 0 0 0 0 0 - 0 0 (3)	4 1 1 1 1 (4)	(5)
7	8	9 LICENSEE CODE 14	15 LICENSE NUMBER 25	26 LICENSE TYPE 30	57 CAT 58

CON'T

0 1	REPORT SOURCE L (6)	0 5 0 0 0 2 2 0 (7)	0 5 2 8 8 0 (8)	0 6 0 3 8 0 (9)
7 8	60	61 DOCKET NUMBER 68	69 EVENT DATE 74	75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 While performing valve checks an operator discovered the cardox tank
0 3 pressure below tech spec limits. Investigation revealed that a recent
0 4 delivery of CO^2 had been pumped into the cardox tank at too low a temp.
0 5 In addition it was discovered that the low pressure alarm had never
0 6 been connected in the control room. The impact on health and safety can
0 7 be considered limited as the CO^2 system was still considered operational.
0 8 Tests indicated that CO^2 delivery to hazards was still adequate.

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	A B (11)	D (12)	Z (13)	A N N U N C (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 0	—	0 1 0	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
F (18)	G (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	L (25)	C 1 2 5 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 The cardox tank pressure dropped as a result of a delivery of too low
1 1 a temp CO^2 by the supplier. The low pressure was not discovered in the
1 2 control room as the annunciator had never been connected. Since the
1 3 occurrance the low pressure alarm has been connected and procedures are
1 4 being revised to instruct personnel receiving cardox.

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	0 9 9 (29)	NA	B (31)	OPERATOR MAKING ROUNDS

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA

PERSONNEL EXPOSURES

	NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

	NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

	TYPE	DESCRIPTION
1 9	Z (42)	NA

PUBLICITY

	ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	

NAME OF PREPARER Michael J. Falise PHONE: 315-343-2110 X1208

8006090 362

GPO 917-926