FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | N Y N M P 1 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT 58

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 2 2 0 (7) | 0 4 1 9 8 0 (8) | 0 8 0 1 8 0 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During normal operation while performing surveillance
03 testing of the turbine anticipatory trip bypass, rx scram
04 switch 02-13A was found to be operating outside its setpoint
05 of 355 psi and tolerance of ± 5 psi as found at 362 psi.
06 Three other switches performing the same function
07 were found at proper setpoints and functioning as
08 designed.

SYSTEM CODE H B (11) | CAUSE CODE X (12) | CAUSE SUBCODE Z (13) | COMPONENT CODE I N S T R U (14) | COMP. SUBCODE S (15) | VALVE SUBCODE Z (16)

(17) LER RO REPORT NUMBER: EVENT YEAR 8 0 | — | SEQUENTIAL REPORT NO. 0 1 2 | / | OCCURRENCE CODE 0 3 | REPORT TYPE L | — | REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION X (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS (22) 0 0 0 0 | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. Y (24) | PRIME COMP. SUPPLIER N (25) | COMPONENT MANUFACTURER 8 0 6 9

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 This event is attributed to instrument drift. The
11 switch was immediately adjusted within setpoint limits
12 and is regularly tested on a monthly basis.
13
14

15 FACILITY STATUS E (28) | % POWER 0 9 9 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Surveillance Test

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES: NUMBER 0 0 0 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES: NUMBER 0 0 0 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION NA

20 PUBLICITY: ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

8008110344

NAME OF PREPARER Paul Harrison PHONE: (315)343-2110 Ext. 1212