

# LICENSEE EVENT REPORT

CONTROL BLOCK:          <sup>①</sup> (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 <sup>7 8</sup> | N | Y | N | M | P | 1 | 00 - 00000000 - 000 | 411111 | 0 <sup>9 14 15 25 26 30 57 58</sup>  
 LICENSEE CODE      LICENSE NUMBER      LICENSE TYPE      CAT 58

CON'T  
01 <sup>7 8</sup> | L | 05000220 | 121680 | 011681 | 9 <sup>60 61 68 69 74 75 80</sup>  
 REPORT SOURCE      DOCKET NUMBER      EVENT DATE      REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES <sup>⑩</sup>

02 | During normal operation, while performing the Emergency Ventilation System (Standby Gas  
03 | Treatment) HEPA filter cold D.O.P. surveillance test, one filter bank in #11 branch  
04 | produced an unacceptable efficiency of 8% leakage. The efficiency required by station  
05 | tech specs is less than 1% bypass leakage. This had no significant safety or environ-  
06 | mental effect since the overall branch efficiency was acceptable and the alternate re-  
07 | dundant system was proven operable. All other testing involved provided acceptable  
08 | results. <sup>7 8 9 80</sup>

09 <sup>7 8 9</sup> | S | C | X | Z | F | I | L | T | E | R | Z | Z | <sup>9 10 11 12 13 14 15 16 17 18 19 20</sup>  
 SYSTEM CODE      CAUSE CODE      CAUSE SUBCODE      COMPONENT CODE      COMP. SUBCODE      VALVE SUBCODE

17 | 80 | 032 | 03 | L | 0 | <sup>21 22 23 24 25 26 27 28 29 30 31 32</sup>  
 LER/RO REPORT NUMBER      EVENT YEAR      SEQUENTIAL REPORT NO.      OCCURRENCE CODE      REPORT TYPE      REVISION NO.

A | Z | Z | Z | 0000 | N | N | L | C045 | <sup>33 34 35 36 37 40 41 42 43 44 47</sup>  
 ACTION TAKEN      FUTURE ACTION      EFFECT ON PLANT      SHUTDOWN METHOD      HOURS      ATTACHMENT SUBMITTED      NPD-4 FORM SUB.      PRIME COMP. SUPPLIER      COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS <sup>⑳</sup>

10 | Inspection revealed that the filter sealing gasket was defective. Efforts to reseal  
11 | the gasket surface were unsuccessful so a new filter unit was installed. Test results  
12 | of the new filter were acceptable. Surveillance testing on this system continues on  
13 | a regular basis or as certain conditions necessitate as described in Technical  
14 | Specifications. <sup>7 8 9 80</sup>

15 | E | 081 | N/A | B | SURVEILLANCE TESTING | <sup>7 8 9 10 11 12 13 44 45 46 80</sup>  
 FACILITY STATUS      % POWER      OTHER STATUS      METHOD OF DISCOVERY      DISCOVERY DESCRIPTION

16 | Z | Z | N/A | N/A | N/A | <sup>7 8 9 10 11 44 45 80</sup>  
 ACTIVITY RELEASED OF RELEASE      AMOUNT OF ACTIVITY      LOCATION OF RELEASE

17 | 000 | Z | N/A | <sup>7 8 9 10 11 12 13 80</sup>  
 PERSONNEL EXPOSURES NUMBER      TYPE      DESCRIPTION

18 | 000 | N/A | <sup>7 8 9 10 11 12 13 80</sup>  
 PERSONNEL INJURIES NUMBER      DESCRIPTION

19 | Z | N/A | <sup>7 8 9 10 11 12 80</sup>  
 LOSS OF OR DAMAGE TO FACILITY TYPE      DESCRIPTION

20 | N | N/A | N/A | <sup>7 8 9 10 11 12 80</sup>  
 PUBLICITY ISSUED      DESCRIPTION      NRC USE ONLY

8102100641      NAME OF PREPARER Paul Harrison      PHONE: (315)343-2110, Ext.1549

