

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8401060171 DOC. DATE: 85/12/20 NOTARIZED: NO DOCKET #
 FACIL: 50-410 Nine Mile Point Nuclear Station, Unit 2, Niagara Moha 05000410
 AUTH. NAME AUTHOR AFFILIATION
 LEMPGES, T. E. Niagara Mohawk Power Corp.
 RECIP. NAME RECIPIENT AFFILIATION
 ADENSAM, E. G. BWR Project Directorate 3

SUBJECT: Forwards suppl to 840410 response to Generic Ltr 83-28.
 Topics addressed include post-trip review program
 description, post-trip data & info capability, equipment
 classification & vendor interface re reactor trip sys parts.

DISTRIBUTION CODE: A055D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 11
 TITLE: OR/Licensing Submittal: Salem ATWS Events GL-83-28

NOTES:

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	BWR PD3 PD 01	3 3	HAUGHEY, M	1 1
INTERNAL:	ACRS	6 6	ADM/LFMB	1 0
	ELD/HDS3	1 0	IE/DI	1 1
	IE/DGAVT	1 1	NRR BWR ADTS	1 1
	NRR PWR-A ADTS	1 1	NRR PWR-B ADTS	1 1
	NRR/DSRO DIR	1 1	NRR/DRAS	1 1
	NRR/TAMB	1 1	<u>REG FILE</u> 04	1 1
	RGN1	1 1		
EXTERNAL:	24X	1 1	LPDR 03	1 1
	NRC PDR 02	1 1	NSIC 05	1 1

Add

EB-LIAW
 PSB - L. Hulman
 EICSB - Srinivasan
 RSB - Acting
 FOB - VASSALLO
 AD - G. LAMAS (ltr only)

TOTAL NUMBER OF COPIES REQUIRED: LTTR

32 29
 26 ENCL 24

RECEIVED
 DEPT. OF THE ARMY
 WASHINGTON, D. C.
 MAY 10 1944
 FROM: [illegible]
 TO: [illegible]
 SUBJECT: [illegible]

The following information was received from the [illegible]
 [illegible] [illegible] [illegible] [illegible] [illegible]
 [illegible] [illegible] [illegible] [illegible] [illegible]
 [illegible] [illegible] [illegible] [illegible] [illegible]

[illegible] [illegible] [illegible] [illegible] [illegible]
 [illegible] [illegible] [illegible] [illegible] [illegible]

[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]
[illegible]	[illegible]	[illegible]	[illegible]	[illegible]

December 20, 1985
(NMP2L 0566)

Ms. Elinor G. Adensam, Director
BWR Project Directorate No. 3
U.S. Nuclear Regulatory Commission
7920 Norfolk Avenue
Washington, DC 20555

Dear Ms. Adensam:

Re: Nine Mile Point Unit 2
Docket No. 50-410

Attached are six additional responses (Sections 1.1, 2.1, 2.2, 2.2.2, 3.1, 3.2 and 4.5) concerning Generic Letter 83-28. These responses are in addition to the previous responses sent to the Nuclear Regulatory Commission on April 10, 1984 (G.K. Rhode (NMPC) to A. Schwencer (NRC)).

Very truly yours,



T. E. Lempges
Vice President
Nuclear Generation

TEL/TL:rla
1156G
Attachments

xc: R. A. Gramm, NRC Resident Inspector
Project File (2)

8601060171 851220
PDR ADDCK 05000410
A PDR

ADD:

EB (LIAN)
PSB (L. HULMAN)
EICSB (SRINIVASAN)
RSB (ACTING)
FOB (VASSALLO)
AD - G. LAINAS (Ltr only)

A055
11



1. The first part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

2. The second part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

3. The third part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

4. The fourth part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

5. The fifth part of the document is a list of names and addresses. The names are: John Doe, Jane Doe, and John Doe. The addresses are: 123 Main St, 456 Main St, and 789 Main St.

ADDITIONAL INFORMATION CONCERNING GENERIC LETTER 83-28I. POST-TRIP REVIEW (PROGRAM DESCRIPTION AND PROCEDURE SECTION 1.1)Position

Licensees and applicants shall describe their program for ensuring that unscheduled reactor shutdowns are analyzed and that a determination is made that the plant can be restarted safely. A report describing the program for review and analysis of such unscheduled reactor shutdowns should include, as a minimum:

1.1.1. The criteria for determining the acceptability of restart.

Response:

Nine Mile Point Unit 2's criteria for determining the acceptability of restart are contained in the Interim Operating Procedure N2-IOP-101A (Plant Startup) which will be upgraded to a permanent operating procedure by startup. This procedure requires the use of pre-startup checkoff sheets which are used to ensure all instrumentation is operating in accordance with plant specifications. The order to start up the plant is issued by the Station Superintendent or his designated alternate. Additionally, in the event that the cause of the scram or plant transient is not fully understood, the Site Operations Review Committee (SORC) will review the scram reports prepared per Niagara Mohawk Procedures. In addition, Nine Mile Point Unit 2 endorses the BWR Owners' Group position with regard to Section 1.1.1.

1.1.2. The responsibilities and authorities of personnel who will perform the review and analysis of these events.

Response:

The Superintendent Operations, Station Shift Supervisor and technical department personnel will perform the post-trip review analysis. Their duties are specifically stated in Administrative Procedures AP-1.2 and AP-1.3, Composition and Responsibility of Unit Organization and Personnel Responsibilities and Authority. They are assisted by the Reactor Analyst Department which is directly responsible for the collection of data, and to assist in the evaluation as to the cause of the reactor scram. The responsibilities and authorities of the Reactor Analyst Supervisor and Unit Reactor Analyst Supervisor are stated in the Administrative Procedure AP-1.1, Composition and Responsibility of Site Organization.

Our review of the administrative controls which regulate the responsibilities and authorities of personnel evaluating the Post-Trip Review, meet the intent of Section 1.1.2 and therefore no further action will be taken.



.....

.....

.....

.....

.....

.....

.....

.....

- 1.1.3 The necessary qualifications and training for the responsible personnel.

Response:

The analysis of unscheduled shutdowns at Nine Mile Point Unit 2 will be performed by a select group of trained and qualified individuals. The education, training, and job related experience of these people provide the basis for the evaluation needed to make the post-trip review and restart recommendation.

The qualifications and training for the positions of Station Superintendent, Superintendent Operations, and Unit Reactor Analyst Supervisor comply with the requirements of ANSI/ANS 3.1-1978 and 10CFR55. The Station Shift Supervisor and Shift Technical Advisor also meet the requirements of NTP-10 (Training of Licensed Operator Candidates) and NTP-11 (Licensed Operator Retraining).

In addition to all the initial training requirements for these positions per Nine Mile Training Procedure NTP-11, retraining and periodic requalification are performed. Retraining examines plant operations and off-normal events while requalification ensures that the recommended degree of knowledge is being maintained.

- 1.1.4. The sources of plant information necessary to conduct the review and analysis. The sources of information should include the measures and equipment that provide the necessary detail and type of information to reconstruct the event accurately and in sufficient detail for proper understanding. (See Action 1.2)

Response:

The sources of information necessary to conduct the review and analysis will be provided in Reactor Analyst Procedure N2-RAP-6 (Post Reactor Scram Analysis and Evaluation) and Interim Operating Procedure N2-IOP-101A (Plant Startup). The Reactor Analyst Procedure N2-RAP-6 is in the process of being written and will contain data collection sheets which will provide the necessary information to make an evaluation of the cause of a scram. This procedure will be completed prior to startup. Interim Operating Procedure N2-IOP-101A is currently available for review. This evaluation will include the information provided by a GETARS system.

- 1.1.5 The methods and criteria for comparing the event information with known or expected plant behavior (e.g., that safety-related equipment operates as required by the Technical Specifications or other performance specifications related to the safety function).

The first part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

The second part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

The third part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

The fourth part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

The fifth part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

The sixth part of the document is a list of the names of the persons who were present at the meeting. The names are listed in alphabetical order. The names are: [illegible]

Response:

The individuals responsible for the event analysis are qualified per ANSI/ANS 3.1-1978. At their disposal will be records of previous reactor trips and the Final Safety Analysis Report Data which are used at their discretion for comparing the transient to expected responses.

Since Nine Mile Point Unit 2 will have sufficient data capability for comparing these events, and the operating personnel are trained and qualified to perform this evaluation, no further action will be taken at this time.

1.1.6 Criteria for Determining the Need for Independent Assessment

Response:

In the event that the scram report, Post-Reactor Scram Analysis and Evaluation procedure, and/or the startup checkoff sheets reveal a condition that is not understood, the station superintendent will not authorize restart. Instead, the appropriate staff members (representing the Site Operations Review Committee) will be requested to assist in the evaluation of the event.

Additionally, Administrative Procedure AP-3.4.1 (Administration of Technical and Safety Reviews) provides further guidance for determining the need for independent assessment.

11

THE UNITED STATES OF AMERICA
DO hereby certify that the within and foregoing is a true and correct copy of the original as the same appears in the records of the Department of the Interior.

WITNESSED my hand and the seal of the Department of the Interior at Washington, D.C., this 1st day of January, 1900.

JOHN W. FOSTER, Secretary of the Interior.

Approved: _____
Special Agent in Charge, Bureau of Land Management.

Approved: _____
Assistant Secretary of the Interior.

II. POST-TRIP REVIEW - DATA AND INFORMATION CAPABILITY (1:2)

Niagara Mohawk will provide a response to this section by fuel load.

III. EQUIPMENT CLASSIFICATION AND VENDOR INTERFACE

(Reactor Trip System Components) (Section 2.1)

Niagara Mohawk does not currently plan to develop a specific list of components that would comprise a reactor trip system. The reactor trip function is accomplished at Nine Mile Point Unit 2 by utilizing redundant plant process instrumentation that input to a one-out-of-two twice logic system. These signals initiate a reactor trip (rapid control rod insertion i.e. scram) by deenergizing solenoid operated scram pilot valves that vent air from the reactor scram valves. Additional information is available in our current FSAR Section 7.2, "Reactor Protection (Trip) System (RPS) Instrumentation and Control."

The components that contribute to the reactor trip function are contained in several systems rather than one reactor trip system. Those systems whose components contribute to the reactor trip function include reactor protection system, reactor vessel instrumentation system, neutron monitoring system and control rod drive system. Therefore, a new system identified as the reactor trip system would cause unnecessary inconsistencies with existing Nine Mile Point Unit 2 system nomenclature. This would require extensive revision to existing documentation and a training program with no resultant enhancement of safety.

However, Niagara Mohawk will review maintenance procedures to ensure that safety classification information is included with the appropriate maintenance documentation.

Niagara Mohawk will review General Electric Service Information letters pertaining to the reactor trip components. Appropriate changes to equipment or procedures deemed necessary will be incorporated.

As a part of the startup of Nine Mile Point Unit 2, vendor manuals are being compiled for the appropriate NMP2 equipment. The task will be complete prior to startup. The permanent update program will be completed prior to commercial operation and will be onsite for your review.

IV. EQUIPMENT CLASSIFICATION AND VENDOR INTERFACE

(Programs For All Safety-Related Components) (2:2)

- 2.2.1.3 A description of the process by which station personnel use this information handling system to determine that an activity is safety-related and what procedures for maintenance, surveillance, parts replacement and other activities defined in the introduction to 10CFR50, Appendix B, apply to safety-related components.

Response:

The following is a description of the process of determining if an activity is safety related. The supervisor of the department responsible for the activity has the responsibility to utilize the Equipment Classification List (Q-List) to determine the equipment classification. Documents such as work requests and purchase requisitions are reviewed and approved by the Quality Assurance Department. Activities such as surveillance or preventative maintenance are covered by procedures which are reviewed per technical specification requirements. The final administrative control before work occurs is the requirement that the Shift Supervisor grant permission. Based on the training, experience and knowledge of Technical Specifications required to fill the position, the Shift Supervisor can determine if the correct practices are to be used. This control includes signoffs in the procedures, work requests and markups (tags) to be used. It is the intent of the process at Nine Mile Point Unit 2 to have checks and balances in the system to assure that an error on the part of an individual will not result in "non-safety related practices" being applied to safety-related equipment.

V. VENDOR INTERFACE PROGRAM "RESPONSE" (Section 2:2:2)

The Vendor Interface Program currently being implemented at Nine Mile Point Unit 2 consists of procedures and data collection requirements necessary to perform a complete evaluation on vendor/engineering recommendations. The Administrative and Technical procedures which support this program are AP-3.4.2 (Operations Experience Assessment) and TDP-5 (Administration of Operational Engineering Assessment Items). These procedures provide an engineering evaluation for tracking an item until it is incorporated into plant operations.

In addition to our administrative controls, Niagara Mohawk was an active participant in the Nuclear Utility Task Action Committee formed to address Section 2.2.2. Niagara Mohawk is currently in compliance with their response. Therefore, no further action will be taken at this time.



1. The first part of the document discusses the importance of maintaining accurate records of all transactions. It emphasizes that this is crucial for ensuring the integrity of the financial system and for providing a clear audit trail.

2. The second part of the document outlines the specific procedures for recording transactions. It details the steps involved in entering data into the system, from initial data collection to final verification and posting.

3. The third part of the document addresses the challenges associated with data entry and record keeping. It identifies common errors and provides strategies to minimize them, such as double-checking entries and using standardized formats.

4. The fourth part of the document discusses the role of technology in improving the efficiency of the record-keeping process. It highlights the benefits of using automated systems and provides examples of how these systems can be implemented.

5. The fifth part of the document concludes by summarizing the key points discussed and reiterates the importance of maintaining accurate records. It also provides a brief overview of the next steps in the process.

VI. POST-MAINTENANCE TESTING (REACTOR TRIP SYSTEM COMPONENTS) (SECTION 3.1)

Niagara Mohawk is revising Administrative Procedure AP-5 (Procedure for Repairs) which will require that post-maintenance testing be performed on applicable safety-related equipment. This procedure will be revised by startup. Technical specifications will also be reviewed to ensure that post-maintenance testing be performed on applicable safety-related equipment.

Niagara Mohawk will review General Electric Service Information letters for test guidance on reactor trip system components and incorporate the appropriate changes into procedures.

The technical specifications will be reviewed to ensure that post-maintenance test procedures will not degrade safety. These actions will be completed prior to startup.

1. The first part of the document is a list of names and addresses of the members of the committee.

2. The second part of the document is a list of names and addresses of the members of the committee.

3. The third part of the document is a list of names and addresses of the members of the committee.

4. The fourth part of the document is a list of names and addresses of the members of the committee.

5. The fifth part of the document is a list of names and addresses of the members of the committee.

6. The sixth part of the document is a list of names and addresses of the members of the committee.

7. The seventh part of the document is a list of names and addresses of the members of the committee.

8. The eighth part of the document is a list of names and addresses of the members of the committee.

VII. POST-MAINTENANCE TESTING (ALL OTHER SAFETY-RELATED COMPONENTS) (3:2)

Niagara Mohawk is revising Administrative Procedure AP-5 (Procedure for Repair) which will require that post-maintenance testing be performed on applicable safety-related equipment. This procedure will be revised by startup. Technical specifications will also be reviewed to ensure that post-maintenance testing be performed on applicable safety-related equipment.

Niagara Mohawk will review General Electric Service Information letters for test guidance on safety-related systems and incorporate the appropriate changes into procedures.

Technical specifications will be reviewed to ensure that post-maintenance test procedures will not degrade safety. These actions will be completed prior to startup.

... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..

... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..
... ..

... ..

... ..

... ..

VIII. REACTOR TRIP SYSTEM RELIABILITY (SYSTEM FUNCTIONAL TESTING) (SECTION 4.5)

Niagara Mohawk will perform testing of backup scram valves (including initiating circuitry) during refueling outages in lieu of on-line testing. This guidance was provided in a letter dated March 19, 1985, from Mr. A. Schwencer to B. G. Hooten. This response satisfies the concerns of Section 4.5.



1. 1940

11

3

$\frac{1}{n} \sum_{i=1}^n x_i = \bar{x}$

Figure 1. The effect of the concentration of the *Agrobacterium* suspension on the transformation efficiency of *Agrobacterium* strains. The *Agrobacterium* strains were grown in the YEA medium for 24 h at 28 °C. The cell concentration of the strains was adjusted to 1.0 × 10⁸ cells/ml. The cell suspension was mixed with the plant tissue and incubated for 24 h at 28 °C. The plant tissue was then cultured on the selective medium. The transformation efficiency was calculated as the number of transformants per 100 mg of plant tissue. The data were the mean ± SD of three independent experiments.

TABLE 1
STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.1	Post-Trip Review (program description and procedure)		
1.1.1	Criteria for Determining Acceptability of Restart	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.2	Responsibilities and Authorities of personnel who will perform the Review and Analysis of these events	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.3	Qualifications and Training for the responsible Personnel	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.4	Source of plant information necessary to conduct the review	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.5	Methods and Criteria for comparing event information with known or expected plant behavior	Complete	Response in 12/20/85 letter to NRC.
1.1.6	Criteria for Determining the need for Independent Assessment	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-01

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2	Post-Trip Review - Data and Information Capability	A report will be submitted to the NRC prior to startup which describes the post-trip review and data and information capability for Nine Mile Point Unit 2 by fuel load.	
1.2.1	Capability of Assessing Sequence of Events (on-off indications)	(See Section 1.2)	
1.2.1.1	Description of Equipment (e.g. plant computer, dedicated computer, strip chart)	(See Section 1.2)	
1.2.1.2	Parameters Monitored	(See Section 1.2)	
1.2.1.3	Time Discrimination Between Events	(See Section 1.2)	
1.2.1.4	Format for Displaying Data and Information	(See Section 1.2)	

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-02

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

0 7 7 4 9 0 7 5 8

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2.1.5	Capability for Retention of Data and Information	(See Section 1.2)	
1.2.1.6	Power Source(s) (e.g., Class IE, Non-Class IE, Non-Interruptable)	(See Section 1.2)	
1.2.2	Capability for assessing the time history of analog variables needed to determine the cause of unscheduled reactor shutdowns, and the functioning of safety related equipment	(See Section 1.2)	
1.2.2.1	Brief Description of Equipment (e.g., Plant Computer, Dedicated Computer, Strip Charts)	(See Section 1.2)	
1.2.2.2	Parameters Monitored, Sampling Rate and Basis for Selecting Parameters and Sampling Rate	(See Section 1.2)	SI APERTURE CARD Also Available On Aperture Card
1.2.2.3	Duration of Time History (Minutes Before Trip and Minutes After Trip)	(See Section 1.2)	
1.2.2.4	Format for Displaying Data Including Scale (Readability of Time Histories)	(See Section 1.2)	

8601060171-03

077490759

TABLE 1
STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2.2.5	Capability for Retention of Data, Information and Physical Evidence (Both Hardware & Software)	(See Section 1.2)	
1.2.2.6	Power Source(s) (e.g., Class IE, Non-Class noninterruptable)	(See Section 1.2)	
1.2.3	Other Data and Information Provided to Assess the cause of Unscheduled Reactor Shutdowns	(See Section 1.2)	
1.2.4	Schedule for any Planned Changes to Existing Data and Information Capability	(See Section 1.2)	
2.1	Equipment Classification and Vendor Interface (Reactor Trip System Components)		
	Review Maintenance Procedures (mechanical, electrical and I&C) to ensure classification information is included with the appropriate maintenance documentation.	Prior to startup	Response in 12/20/85 letter to NRC
	Complete investigation of SIL's pertaining to Reactor Trip Function Components and change procedures and equipment, as necessary	Prior to startup	Response in 12/20/85 letter to NRC

SI
APERTURE
CARD
Also Available On
Aperture Card

8601060171-04

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
	Compile vendor manuals for appropriate NMP2 equipment	Prior to startup	Response in 12/20/85 letter to NRC
	Permanent update program will be completed prior to commercial operation	Prior to startup	Response in 12/20/85 letter to NRC
2.2	Equipment classification and vendor interface (programs for all safety-related components)		
2.2.1	Describe the program for ensuring safety-related components are identified as safety-related in appropriate documentation	Complete	Response in 4/10/83 letter to NRC
2.2.1.1	Criteria for identifying components as safety-related (review engineering procedures to ensure a method exists for identifying safety-related components and services)	Procedure review to be completed prior to startup	Response in 4/10/83 letter to NRC
2.2.1.2	Description of the information handling system used to identify safety related components	Complete	Response in 4/10/83 letter to NRC

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-05

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

<u>SECTION</u>	<u>TITLE</u>	<u>DECEMBER 1985 SCHEDULE/STATUS</u>	<u>COMMENTS</u>
2.2.1.3	Description of the process by which station personnel use this information handling system to determine that an activity is safety-related and what procedures for maintenance, surveillance parts replacement and other activities defined in 10CFR50, Appendix B, apply to safety-related components	Complete	Response in 12/20/85 letter to NRC
2.2.1.4	Description of the management controls utilized to verify that the procedures for preparation, validation and routine utilization of the information handling system have been followed	Complete	Response in 4/10/83 letter to NRC
2.2.1.5	Demonstrate that the appropriate design verification and qualification testing is specified for procurement of safety-related components	Ensure engineering procedures ensure that applicable regulatory requirements design bases and quality requirements are met when obtaining material and services	Response in 4/10/83 letter to NRC
2.2.1.6	Licensees and applicants need only to submit for staff review the equipment classification program for safety-related components	Complete	Response in 4/10/84 letter to NRC
2.2.2	Vendor Interface Program	Procedures to be implemented prior to startup.	Response in 12/20/85 letter.

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-06

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

<u>SECTION</u>	<u>TITLE</u>	<u>DECEMBER 1985 SCHEDULE/STATUS</u>	<u>COMMENTS</u>
3.1	Post Maintenance Testing (Reactor Trip System Components)		
3.1.1	Revise administrative procedures to ensure post-maintenance testing for Reactor Trip Components prior to startup	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
	Review Tech Specs to ensure post-maintenance testing for Reactor Trip components prior to startup	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.1.2	Review of SIL's recommendations to ensure appropriate test guidance is included in procedures	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.1.3	Identify any post-maintenance test requirements in technical specifications which can be demonstrated to degrade rather than enhance safety	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.2	Post-Maintenance Testing (all other safety-related components)		

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-07

017 7490762

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
3.2.1	Revise administrative procedures to ensure post-maintenance testing for safety-related equipment	Review to be complete prior to startup	Response in 12/20/85 letter to NRC
	Review Technical Specifications to ensure post-maintenance testing for safety-related equipment	Review to be complete prior to startup	"
3.2.2	Review of SIL's to ensure appropriate test guidance is included in procedures.	Review to be complete prior to startup	"
3.2.3	Identify any post-maintenance test requirements in technical specifications which can be demonstrated to degrade rather than enhance safety	"	"
4.5	Reactor Trip System Reliability (System Functional Testing)	Complete	Response in 12/20/85 letter to NRC
	Functional Testing of scram pilot valves and backup scram valves.	"	"
	Evaluate existing intervals for on-line functional testing required by technical specifications	"	"

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-08


0 7 7 4 9 0 7 6 4
FILE COPY *Generic* *2B 8328*
NIAGARA MOHAWK

INTERNAL CORRESPONDENCE
FORM 112-2-R 02-80 55-01-013

FROM T. Loomis
S. Nicolas
R. Randall
D. LoSurdo

DISTRICT Syracuse
DATE January 2, 1986 **FILE CODE**
SUBJECT Commitments in Regard to Generic
Letter 83-28

Attached is a draft listing of the commitments required to complete the actions identified in Generic Letter 83-28. Please review this listing and provide any comments or corrections by January 6, 1986. It is my intention to forward this list to the NMP2 site management for a formal assignment of responsibilities.



T. Loomis
Licensing Engineer

TL:ja
Attachment
xc: A. F. Zallnick, Jr
Project File (2)

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.1	Post-Trip Review (program description and procedure)		
1.1.1	Criteria for Determining Acceptability of Restart	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.2	Responsibilities and Authorities of personnel who will perform the Review and Analysis of these events	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.3	Qualifications and Training for the responsible Personnel	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.4	Source of plant information necessary to conduct the review	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.
1.1.5	Methods and Criteria for comparing event information with known or expected plant behavior	Complete	Response in 12/20/85 letter to NRC.
1.1.6	Criteria for Determining the need for Independent Assessment	Procedures to be implemented for startup.	Response in 12/20/85 letter to NRC.

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-09

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2	Post-Trip Review - Data and Information Capability	A report will be submitted to the NRC prior to startup which describes the post-trip review and data and information-capability for Nine Mile Point Unit 2 by fuel load.	
1.2.1	Capability of Assessing Sequence of Events (on-off indications)	(See Section 1.2)	
1.2.1.1	Description of Equipment (e.g. plant computer, dedicated computer, strip chart)	(See Section 1.2)	
1.2.1.2	Parameters Monitored	(See Section 1.2)	
1.2.1.3	Time Discrimination Between Events	(See Section 1.2)	
1.2.1.4	Format for Displaying Data and Information	(See Section 1.2)	

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-10

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2.1.5	Capability for Retention of Data and Information	(See Section 1.2)	
1.2.1.6	Power Source(s) (e.g., Class IE, Non-Class IE, Non-Interruptable)	(See Section 1.2)	
1.2.2	Capability for assessing the time history of analog variables needed to determine the cause of unscheduled reactor shutdowns, and the functioning of safety related equipment	(See Section 1.2)	
1.2.2.1	Brief Description of Equipment (e.g., Plant Computer, Dedicated Computer, Strip Charts)	(See Section 1.2)	
1.2.2.2	Parameters Monitored, Sampling Rate and Basis for Selecting Parameters and Sampling Rate	(See Section 1.2)	
1.2.2.3	Duration of Time History (Minutes Before Trip and Minutes After Trip)	(See Section 1.2)	
1.2.2.4	Format for Displaying Data Including Scale (Readability of Time Histories)	(See Section 1.2)	

SI
APERTURE
CARDAlso Available On
Aperture Card

8601060171-11

07749076B

TABLE 1
STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
1.2.2.5	Capability for Retention of Data, Information and Physical Evidence (Both Hardware & Software)	(See Section 1.2)	
1.2.2.6	Power Source(s) (e.g., Class IE, Non-Class noninterruptable)	(See Section 1.2)	
1.2.3	Other Data and Information Provided to Assess the cause of Unscheduled Reactor Shutdowns	(See Section 1.2)	
1.2.4	Schedule for any Planned Changes to Existing Data and Information Capability	(See Section 1.2)	
2.1	Equipment Classification and Vendor Interface (Reactor Trip System Components)		
	Review Maintenance Procedures (mechanical, electrical and I&C) to ensure classification information is included with the appropriate maintenance documentation.	Prior to startup	Response in 12/20/85 letter to NRC
	Complete investigation of SIL's pertaining to Reactor Trip Function Components and change procedures and equipment, as necessary	Prior to startup	Response in 12/20/85 letter to NRC

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-12

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

<u>SECTION</u>	<u>TITLE</u>	<u>DECEMBER 1985 SCHEDULE/STATUS</u>	<u>COMMENTS</u>
	Compile vendor manuals for appropriate NMP2 equipment	Prior to startup	Response in 12/20/85 letter to NRC
	Permanent update program will be completed prior to commercial operation	Prior to startup	Response in 12/20/85 letter to NRC
2.2	Equipment classification and vendor interface (programs for all safety-related components)		
2.2.1	Describe the program for ensuring all safety-related components are identified as safety-related in appropriate documentation	Complete	Response in 4/10/83 letter to NRC
2.2.1.1	Criteria for identifying components as safety-related (review engineering procedures to ensure a method exists for identifying safety-related components and services)	Procedure review to be completed prior to startup	Response in 4/10/83 letter to NRC
2.2.1.2	Description of the information handling system used to identify safety related components	Complete	Response in 4/10/83 letter to NRC

ST
APERTURE
CARD

Also Available On
Aperture Card

8601060171-13

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

<u>SECTION</u>	<u>TITLE</u>	<u>DECEMBER 1985 SCHEDULE/STATUS</u>	<u>COMMENTS</u>
2.2.1.3	Description of the process by which station personnel use this information handling system to determine that an activity is safety-related and what procedures for maintenance, surveillance parts replacement and other activities defined in 10CFR50, Appendix B, apply to safety-related components	Complete	Response in 12/20/85 letter to NRC
2.2.1.4	Description of the management controls utilized to verify that the procedures for preparation, validation and routine utilization of the information handling system have been followed	Complete	Response in 4/10/83 letter to NRC
2.2.1.5	Demonstrate that the appropriate design verification and qualification testing is specified for procurement of safety-related components	Ensure engineering procedures ensure that applicable regulatory requirements design bases and quality requirements are met when obtaining material and services	Response in 4/10/83 letter to NRC
2.2.1.6	Licensees and applicants need only to submit for staff review the equipment classification program for safety-related components	Complete	Response in 4/10/84 letter to NRC
2.2.2	Vendor Interface Program	Procedures to be implemented prior to startup.	Response in 12/20/85 letter.

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-14

TABLE 1

STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
3.1	Post Maintenance Testing (Reactor Trip System Components)		
3.1.1	Revise administrative procedures to ensure post-maintenance testing for Reactor Trip Components prior to startup	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
	Review Tech Specs to ensure post-maintenance testing for Reactor Trip components prior to startup	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.1.2	Review of SIL's recommendations to ensure appropriate test guidance is included in procedures	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.1.3	Identify any post-maintenance test requirements in technical specifications which can be demonstrated to degrade rather than enhance safety	Review to be completed prior to startup	Response in 12/20/85 letter to NRC
3.2	Post-Maintenance Testing (all other safety-related components)		

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-15

0177490772

TABLE 1
STATUS OF GENERIC LETTER 83-28
REGULATORY ACTION ITEMS
NINE MILE POINT UNIT 2

SECTION	TITLE	DECEMBER 1985 SCHEDULE/STATUS	COMMENTS
3.2.1	Revise administrative procedures to ensure post-maintenance testing for safety-related equipment	Review to be complete prior to startup	Response in 12/20/85 letter to NRC
	Review Technical Specifications to ensure post-maintenance testing for safety-related equipment	Review to be complete prior to startup	"
3.2.2	Review of SIL's to ensure appropriate test guidance is included in procedures.	Review to be complete prior to startup	"
3.2.3	Identify any post-maintenance test requirements in technical specifications which can be demonstrated to degrade rather than enhance safety	"	"
4.5	Reactor Trip System Reliability (System Functional Testing)	Complete	Response in 12/20/85 letter to NRC
	Functional Testing of scram pilot valves and backup scram valves.	"	"
	Evaluate existing intervals for on-line functional testing required by technical specifications	"	"

SI
APERTURE
CARD

Also Available On
Aperture Card

8601060171-16

