

# NIAGARA MOHAWK

07-604-91

NINE MILE POINT NUCLEAR STATION / P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

Joseph F. Firlit  
Vice President  
Nuclear Generation

NMP81983  
September 11, 1991

Mr. Steven A. Varga  
Director, Division of Reactor Projects-I,II  
U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555


Dear Mr. Varga:

Niagara Mohawk responded to your request for additional information on Uninterruptible Power Supply (UPS) issues in letter NMP2L 1315 dated September 10, 1991. A number of follow-up discussions have taken place with the NRC staff on Item 4 (Procedures and Training) of that response. The purpose of this letter is to provide additional information on Item 4 regarding means available to the operators to determine if a reactor scram has occurred when control rod indication is lost due to loss of UPS1A. Furthermore, we are providing additional detail regarding our efforts to develop an alternate method to verify control rod position when indication is lost.

The steps an operator could take to verify a reactor scram without control rod position indication are detailed below. The expected response to a reactor scram included in each of these steps is discussed thoroughly during licensed operator training. The steps are listed in order of the availability and accessibility of the information to the operator.

1. Check nuclear instrumentation response including
  - a. APRM's indicate less than 4% power and lowering (EOP entry condition)
  - b. IRM's (after driven into the core) indicate on-scale less than or equal to range 6 or 7 and lowering
  - c. SRM's (after driven into the core) indicate on-scale
2. Check scram pilot valve solenoid lights are extinguished on panel 2CEC\*PNL603
3. Check indications that steam production is at post shutdown decay heat levels (less than or equal to one turbine bypass valve or safety relief valve open, or by any available feed or steam flow indications)

~~4-109180153~~ 3 pp.




Mr. Steven A. Varga  
September 11, 1991  
Page -2-

4. Check main steam line radiation monitors indicate downscale (ie. normal shutdown levels) on panels 2CEC\*PNL606 and 2CEC\*PNL633
5. Check scram discharge volume level indication on panels 2CEC\*PNL609 and 2CEC\*PNL611 (Rosemount indicating trip units) for upscale or rising level
6. Check both air operated scram inlet and outlet valves at each Hydraulic Control Unit (locally) for open indication
7. Check 2RPS-PI133 locally at instrument rack 2CGS-RAK102 to verify that the scram air header has been depressurized as shown by a downscale or zero psig indication on the gauge

Niagara Mohawk is actively pursuing development of an alternate method to verify control rod position by means of measurements to be taken in control room back panels for each of the one hundred eighty five control rods. It is our intent to address this issue with caution and deliberation to ensure that the activities to be included in procedures are well founded and do not create unanticipated complications for the operators. Niagara Mohawk believes this process is necessary to minimize risks associated with any activity in the control room panels. Consequently, the procedure will be completed after plant restart.


If there are any questions on this material, please contact me at (315) 349-2447.

Sincerely,




Joseph F. Firlit  
Vice President - Nuclear Generation

/lac



pc: Regional Administrator, Region I  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. R. A. Capra, Project Directorate No. I-1, NRR  
Mr. D. S. Brinkman, Project Manager, NRR  
Mr. C. W. Hehl, Director, Reactor Projects  
Mr. D. R. Haverkamp, Chief Reactor Projects, Section 1B  
Records Management



WORK REQUEST

*file*

DATE: 9/13/91

DATE REQUIRED: \_\_\_\_\_

NAME OF REQUESTOR: R Conte (from Don Brinkman, son)

SPECIAL INSTRUCTIONS: (1) Record & File in Biblio

\* URGENT: (2) cc: Technical IIT Members

COMPLETED BY: \_\_\_\_\_

DATE COMPLETED: \_\_\_\_\_

COMMENTS:

\* cc: IIT Technical members





# NIAGARA MOHAWK

07-604-91

NINE MILE POINT NUCLEAR STATION / P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

Joseph F. Firlit  
Vice President  
Nuclear Generation

NMP81983  
September 11, 1991

Mr. Steven A. Varga  
Director, Division of Reactor Projects-I,II  
U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555


Dear Mr. Varga:

Niagara Mohawk responded to your request for additional information on Uninterruptible Power Supply (UPS) issues in letter NMP2L 1315 dated September 10, 1991. A number of follow-up discussions have taken place with the NRC staff on Item 4 (Procedures and Training) of that response. The purpose of this letter is to provide additional information on Item 4 regarding means available to the operators to determine if a reactor scram has occurred when control rod indication is lost due to loss of UPS1A. Furthermore, we are providing additional detail regarding our efforts to develop an alternate method to verify control rod position when indication is lost.

The steps an operator could take to verify a reactor scram without control rod position indication are detailed below. The expected response to a reactor scram included in each of these steps is discussed thoroughly during licensed operator training. The steps are listed in order of the availability and accessibility of the information to the operator.

1. Check nuclear instrumentation response including
  - a. APRM's indicate less than 4% power and lowering (EOP entry condition)
  - b. IRM's (after driven into the core) indicate on-scale less than or equal to range 6 or 7 and lowering
  - c. SRM's (after driven into the core) indicate on-scale
2. Check scram pilot valve solenoid lights are extinguished on panel 2CEC\*PNL603
3. Check indications that steam production is at post shutdown decay heat levels (less than or equal to one turbine bypass valve or safety relief valve open, or by any available feed or steam flow indications)

~~910918/0153~~



Mr. Steven A. Varga

September 11, 1991


Page -2-

4. Check main steam line radiation monitors indicate downscale (ie. normal shutdown levels) on panels 2CEC\*PNL606 and 2CEC\*PNL633
5. Check scram discharge volume level indication on panels 2CEC\*PNL609 and 2CEC\*PNL611 (Rosemount indicating trip units) for upscale or rising level
6. Check both air operated scram inlet and outlet valves at each Hydraulic Control Unit (locally) for open indication
7. Check 2RPS-PI133 locally at instrument rack 2CGS-RAK102 to verify that the scram air header has been depressurized as shown by a downscale or zero psig indication on the gauge

Niagara Mohawk is actively pursuing development of an alternate method to verify control rod position by means of measurements to be taken in control room back panels for each of the one hundred eighty five control rods. It is our intent to address this issue with caution and deliberation to ensure that the activities to be included in procedures are well founded and do not create unanticipated complications for the operators. Niagara Mohawk believes this process is necessary to minimize risks associated with any activity in the control room panels. Consequently, the procedure will be completed after plant restart.


If there are any questions on this material, please contact me at (315) 349-2447.

Sincerely,




Joseph F. Firlit  
Vice President - Nuclear Generation

/lac



pc: Regional Administrator, Region I  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. R. A. Capra, Project Directorate No. I-1, NRR  
Mr. D. S. Brinkman, Project Manager, NRR  
Mr. C. W. Hehl, Director, Reactor Projects  
Mr. D. R. Haverkamp, Chief Reactor Projects, Section 1B  
Records Management



WORK REQUEST

DATE: 9/13/91

DATE REQUIRED: \_\_\_\_\_

NAME OF REQUESTOR: R Conte (from Don Brinkman, son)

SPECIAL INSTRUCTIONS: (1) Record & File in Biblio


\* URGENT: (2) cc: Technical IIT Members

COMPLETED BY: \_\_\_\_\_

DATE COMPLETED: \_\_\_\_\_

COMMENTS:

\* cc: IIT Technical members





**NIAGARA  
MOHAWK**

07-604-91

NINE MILE POINT NUCLEAR STATION / P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

Joseph F. Firlit  
Vice President  
Nuclear GenerationNMP81983  
September 11, 1991Mr. Steven A. Varga  
Director, Division of Reactor Projects-I,II  
U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555


Dear Mr. Varga:

Niagara Mohawk responded to your request for additional information on Uninterruptible Power Supply (UPS) issues in letter NMP2L 1315 dated September 10, 1991. A number of follow-up discussions have taken place with the NRC staff on Item 4 (Procedures and Training) of that response. The purpose of this letter is to provide additional information on Item 4 regarding means available to the operators to determine if a reactor scram has occurred when control rod indication is lost due to loss of UPS1A. Furthermore, we are providing additional detail regarding our efforts to develop an alternate method to verify control rod position when indication is lost.

The steps an operator could take to verify a reactor scram without control rod position indication are detailed below. The expected response to a reactor scram included in each of these steps is discussed thoroughly during licensed operator training. The steps are listed in order of the availability and accessibility of the information to the operator.

1. Check nuclear instrumentation response including
  - a. APRM's indicate less than 4% power and lowering (EOP entry condition)
  - b. IRM's (after driven into the core) indicate on-scale less than or equal to range 6 or 7 and lowering
  - c. SRM's (after driven into the core) indicate on-scale
2. Check scram pilot valve solenoid lights are extinguished on panel 2CEC\*PNL603
3. Check indications that steam production is at post shutdown decay heat levels (less than or equal to one turbine bypass valve or safety relief valve open, or by any available feed or steam flow indications)

~~41-691-80153~~




Mr. Steven A. Varga  
September 11, 1991  
Page -2-

4. Check main steam line radiation monitors indicate downscale (ie. normal shutdown levels) on panels 2CEC\*PNL606 and 2CEC\*PNL633
5. Check scram discharge volume level indication on panels 2CEC\*PNL609 and 2CEC\*PNL611 (Rosemount indicating trip units) for upscale or rising level
6. Check both air operated scram inlet and outlet valves at each Hydraulic Control Unit (locally) for open indication
7. Check 2RPS-PI133 locally at instrument rack 2CGS-RAK102 to verify that the scram air header has been depressurized as shown by a downscale or zero psig indication on the gauge

Niagara Mohawk is actively pursuing development of an alternate method to verify control rod position by means of measurements to be taken in control room back panels for each of the one hundred eighty five control rods. It is our intent to address this issue with caution and deliberation to ensure that the activities to be included in procedures are well founded and do not create unanticipated complications for the operators. Niagara Mohawk believes this process is necessary to minimize risks associated with any activity in the control room panels. Consequently, the procedure will be completed after plant restart.


If there are any questions on this material, please contact me at (315) 349-2447.

Sincerely,




Joseph F. Firlit  
Vice President - Nuclear Generation

/lac



pc: Regional Administrator, Region I  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. R. A. Capra, Project Directorate No. I-1, NRR  
Mr. D. S. Brinkman, Project Manager, NRR  
Mr. C. W. Hehl, Director, Reactor Projects  
Mr. D. R. Haverkamp, Chief Reactor Projects, Section 1B  
Records Management



WORK REQUEST

DATE: 9/13/91

DATE REQUIRED: \_\_\_\_\_

NAME OF REQUESTOR: R Conte (from Don Brinkman, son)

SPECIAL INSTRUCTIONS: (1) Record & File in Biblio

\* URGENT: (2) cc: Technical IIT Members

COMPLETED BY: \_\_\_\_\_

DATE COMPLETED: \_\_\_\_\_

COMMENTS:

\* cc: IIT Technical Members

10

1. The first part of the document is a list of names and addresses.

2. The second part of the document is a list of names and addresses.

3. The third part of the document is a list of names and addresses.

4. The fourth part of the document is a list of names and addresses.

5. The fifth part of the document is a list of names and addresses.





07-604-91

NINE MILE POINT NUCLEAR STATION / P.O. BOX 32 LYCOMING, NEW YORK 13093 / TELEPHONE (315) 343-2110

Joseph F. Firlit  
Vice President  
Nuclear Generation

NMP81983  
September 11, 1991

Mr. Steven A. Varga  
Director, Division of Reactor Projects-I,II  
U. S. Nuclear Regulatory Commission  
Attention: Document Control Desk  
Washington, D. C. 20555

Dear Mr. Varga:

Niagara Mohawk responded to your request for additional information on Uninterruptible Power Supply (UPS) issues in letter NMP2L 1315 dated September 10, 1991. A number of follow-up discussions have taken place with the NRC staff on Item 4 (Procedures and Training) of that response. The purpose of this letter is to provide additional information on Item 4 regarding means available to the operators to determine if a reactor scram has occurred when control rod indication is lost due to loss of UPS1A. Furthermore, we are providing additional detail regarding our efforts to develop an alternate method to verify control rod position when indication is lost.

The steps an operator could take to verify a reactor scram without control rod position indication are detailed below. The expected response to a reactor scram included in each of these steps is discussed thoroughly during licensed operator training. The steps are listed in order of the availability and accessibility of the information to the operator.

1. Check nuclear instrumentation response including
  - a. APRM's indicate less than 4% power and lowering (EOP entry condition)
  - b. IRM's (after driven into the core) indicate on-scale less than or equal to range 6 or 7 and lowering
  - c. SRM's (after driven into the core) indicate on-scale
2. Check scram pilot valve solenoid lights are extinguished on panel 2CEC\*PNL603
3. Check indications that steam production is at post shutdown decay heat levels (less than or equal to one turbine bypass valve or safety relief valve open, or by any available feed or steam flow indications)

~~9109180153~~

11-1-1

11-1-1


SEP 12 21 47:01 TIME ENDING  
Mr. Steven A. Varga  
September 11, 1991  
Page -2-

4. Check main steam line radiation monitors indicate downscale (ie. normal shutdown levels) on panels 2CEC\*PNL606 and 2CEC\*PNL633
5. Check scram discharge volume level indication on panels 2CEC\*PNL609 and 2CEC\*PNL611 (Rosemount indicating trip units) for upscale or rising level
6. Check both air operated scram inlet and outlet valves at each Hydraulic Control Unit (locally) for open indication
7. Check 2RPS-PI133 locally at instrument rack 2CGS-RAK102 to verify that the scram air header has been depressurized as shown by a downscale or zero psig indication on the gauge

Niagara Mohawk is actively pursuing development of an alternate method to verify control rod position by means of measurements to be taken in control room back panels for each of the one hundred eighty five control rods. It is our intent to address this issue with caution and deliberation to ensure that the activities to be included in procedures are well founded and do not create unanticipated complications for the operators. Niagara Mohawk believes this process is necessary to minimize risks associated with any activity in the control room panels. Consequently, the procedure will be completed after plant restart.


If there are any questions on this material, please contact me at (315) 349-2447.

Sincerely,



Joseph F. Firlit  
Vice President - Nuclear Generation

/lac



pc: Regional Administrator, Region I  
Mr. W. L. Schmidt, Senior Resident Inspector  
Mr. R. A. Capra, Project Directorate No. I-1, NRR  
Mr. D. S. Brinkman, Project Manager, NRR  
Mr. C. W. Hehl, Director, Reactor Projects  
Mr. D. R. Haverkamp, Chief Reactor Projects, Section 1B  
Records Management

100

## NRC RESPONSE

07-605-91  
File

**INSPECTOR:** Jose Ibarra/NRC

### *Question/Request*

What rad monitors were available to monitor radiation release out of the stack? Other effluents? (gaseous and liquid, concentrations, concentrate on SR and T.S. monitors)

### *NMPC Response*

The following release pathways with a description of effluent monitoring operability is discussed below. In addition, other steps were taken to help conclude that no releases of radioactive material on site or to the environment occurred.

### *Stack*

#### Systems Operable:

The Stack Gaseous Effluent Monitoring System, GEMS was operable prior to and during the event. At the time of the event the stack GEMS lost communication with the chart recorder in the main control room after the computer experienced an apparent power interruption. However, local indication was available on Turbine Building 306 and was monitored by a chem tech by approximately 0700. A computer reboot was initiated at 0805 to resolve the communication problem with the control room chart recorder. Communication between stack GEMS and the control room recorder was restored at 0825.

#### Systems Inoperable:

None

#### Alternate Sampling Capabilities:

- GTS-105, Standby Gas Treatment System Gas Monitor, however at the time of the power loss, this monitor was not being polled by the mini computer.
- Inplant AMS-3s with continuous readout, chart recorders and local alarm located in the Turbine Building.
- Low volume air samples were available and running during the event providing the capability of obtaining grab samples of Turbine Building atmosphere.

11 - 12 - 13

12



## *Vent*

### Systems Inoperable:

The vent GEMS was inoperable for scheduled calibration. The vent GEMS was inop on 8/12/91 under equipment status log entry 91-458A and returned to operable on 8/14/91.

### Additional Information Sources:

- Chemistry grab samples
- Above and Below Refuel Floor gas and particulate monitors.
- Drywell atmosphere gas and particulate continuous air monitors.
- Inplant AMS-3s with continuous readout, chart recorders and local alarm located at various locations in the Reactor Building and Rad Waste Buildings.
- Low volume air samples were available and running during the event providing the capability of obtaining grab samples of Reactor Building and Rad Waste Building atmosphere.

## *Service Water Effluent Monitoring*

### System Operable:

Service Water monitor SWP\*146B was administratively inoperable due to repeated pump trips caused by flow switch failures. LCO grab samples were being taken. The monitor was running normally and providing information during the event.

RHR service water monitor SWP\*23B was operable and available for service should operations require RHR heat exchangers to be used.

### System Inoperable:

Service Water monitor SWP\*146A was inoperable during the event. ESL 91-456 was entered on 9/11/91 due to flow switch problems and returned to service on 8/16/91.

SWP\*CAB23A was inoperable due to flow switch problems. It was declared inoperable on 8/9/91 under ESL entry 91-455 and returned to service on 8/23/91. However, this monitor was not needed since operations elected to run the B RHR loop.

## *Liquid Radioactive Waste Monitoring*

### Systems Operable:

The liquid rad waste monitor LWS-206 was operable but no waste releases were in progress. However, at the time of the power loss the mini computer stopped polling for information.

4

## *Cooling Tower Blowdown Monitor*

### Systems Operable:

The cooling tower blowdown monitor CWS-157 was operable however, at the time of the power loss the mini computer stopped polling this non 1E monitor.

The initial response by radiation protection was in accordance with S-RPIP-10.1, "Radiation Protection Startup and Shutdown Activities". Actions included notifying supervisions, reporting to the control room, verifying operability of control room monitors, and assigning technicians to perform plant walkdowns to report results back to the SSS an RP supervision. Radiation Monitors on Panel 880 in the control room were noted to be operating as expected with no abnormal radiation readings.

The following were utilized to gather information to assure the Emergency Director of no release of radioactive material.

- Above and below refuel floor monitors
- Containment atmosphere monitors
- Drywell high range monitors
- Scram walkdown surveys of reactor building
- AMS-3 portable continuous air monitors
- Control Room air intake monitors
- Post Accident Samples of reactor coolant
- Down wind survey sample teams continuously obtaining air, soil and water samples.

/mak

