

87-455-91 2

MASTER COPY FOR INFORMATION ONLY

NINE MILE POINT NUCLEAR STATION UNIT 2
ELECTRICAL PREVENTIVE MAINTENANCE PROCEDURE
PROCEDURE NO. N2-EPM-GEN-R520

"AC" LIMITORQUE OPERATORS (TYPE SMB, SB, AND SMC)
AND ASSOCIATED MOTOR CONTROL CENTER (MCC) UNIT

FOR INFORMATION ONLY

DATE AND INITIALS

APPROVALS

SIGNATURES

REVISION 2 REVISION 3 REVISION 4

Site Superintendent
Maintenance-Nuclear
W. C. Drews

W.C. Drews
2/1/89

Station Superintendent
NMPNS Unit 2
R. B. Abbott

R.B. Abbott

R.B.A.
2/1/89

General Superintendent
Nuclear Generation
J. L. Willis

J.L. Willis

WL
2/3/89

Summary of Pages

Revision 2 (Effective 2/3/89)

Pages
1,2,4,7-12.
5,6
3,15,16,18-27
13,14,17

Date
February 1991 (TCN-17 and
Publication Change *2)
March 1991 (Publication Change *3)
June 1991 (TCN-18)
June 1991 (PCE 15899)

*Periodic Review, 2/27/91, No changes.

THIS PROCEDURE IS A GENERAL REWRITE.
NIAGARA MOHAWK POWER CORPORATION

THIS PROCEDURE NOT TO BE
USED AFTER February 1993
SUBJECT TO PERIODIC REVIEW.

(9305040264 911031
PDR ADDCK 05000410
PDR)
S

9305040264

12

6. 1. 1968
V. G. K. MURTHY

MR. R. S. RAO, M. S. RAO, DR. V. G. K. MURTHY
TOMS HALL, MURTHY, RAO, RAO AND MURTHY

"AC" LIMITORQUE OPERATORS (TYPE SMB, SB, AND SMC)
AND ASSOCIATED MOTOR CONTROL CENTER (MCC) UNIT

1.0 PURPOSE

1.1 This procedure describes the steps necessary to perform a wiring, lubrication and cleaning inspection of the "AC" type Limitorque Operators, GE and ITE-Gould Motor Control Center (MCC) Units.

1.2 Applicability

This procedure is applicable to all Limitorque operators type SMB, SB, SMC and MCC units (refer to N2-EMP-GEN-517, Safety Related Limitorque Valve Listing, for safety related motor operated valves).

1.3 Frequency

Safety-Related EQ operators will be maintained at least once every two years. Remaining safety-related operators will be maintained at least once every four years. All other operators will be maintained as dictated by operating experience.

1.4 The Service Water Strainer Backwash valves (2SWP*MOV1A through 1F) will be maintained at or before the 1st refuel.

1.5 Quality Requirements

Safety Related, Non-Safety Related and quality program applies.

1.6 EQ and Safety Related Maintenance Requirements

1.6.1 The designated Limitorque operators listed in N2-EMP-GEN-517 are equipment qualified for a harsh and mild environment.

1.6.2 The EQ requirements of Equipment Qualification Required Maintenance 2MOV-1 are incorporated in this procedure, as applicable (refer to N2-EMP-GEN-517, Safety Related Limitorque Valve Listing, for safety related motor operated valves). | *2

| *2

12

4

12

4

- *2
- 2.0 REFERENCES
- 2.1 AP-3.3.2, "Radiation Work Permit Procedure" *2
- 2.2 NMPC Accident Prevention Rules
- 2.3 AP-4.2 "Control of Equipment, Markups"
- 2.4 AP-6.1, "Control of Equipment, Temporary Modifications" *2
- 2.5 Limitorque Type HBC Instruction and Maintenance Manual, NMPC File Seq. #, N20697
- 2.6 Limitorque Type SMB Instruction and Maintenance Manual, NMPC File Seq. # N20407
- 2.7 ITE-Gould Instruction Manual (MCC Breaker/Starter Units), NMPC File Seq. # N20121
- 2.8 GE Instruction Manual (MCC Brkr Units), NMPC File Seq. # N20585
- 2.9 EQRM 2MOV-1 Revision 00 *2
- 2.10 12177-EP-410, Motor Operated Valve Setpoints & Operation Data
- 2.11 Drawing EE-9AE, "Selection of Thermal Overload Relay Heaters"
- 2.12 AE-003, Overload Heater List
- 2.13 N2-EMP-GEN-517, "Safety Related Limitorque Operator Valve List"
- 2.14 FDDR No. KG1-5502, HPCS Valve Actuators
- 2.15 Problem Report 8406, Torquing of Limitorque Electrical Component Mounting Hardware
- 2.16 SER 18-88, T-Drain Problems *2
- 3.0 TECHNICAL SPECIFICATION
- 3.1 Section 3/4.6.3, Primary Containment Isolation Valves.
- 3.2 Table 3.6.3-1, Automatic Isolation Valves, and Remote Manual Isolation Valves.
- 3.3 As determined by SSS on an individual basis.

12

12

4.0 SPECIAL TOOLS, MATERIALS AND M&TE

4.1 M&TE

4.1.1 Megger (500/1000VDC)

4.1.2 Multimeter (DVOM)

4.1.3 Clamp-on Ammeter

4.1.4 Stopwatch

4.1.5 Grease Gun

4.1.6 Torque Wrench (45 - 155 in.-lb.)

TCN-18

4.2 Materials

4.2.1 Lubricants:

4.2.1.1 Nebula Grease EP-1 or EP-0 (calcium base)

4.2.1.2 Sun Oil Co. 50 EP or EP-740 Grease (lithium lead base)

4.2.1.3 Exxon Beacon-325 Grease (less than 150°F)

4.2.1.4 Mobil 28 (greater than 150°F)

4.2.1.5 "Never Seez" Nickel Special

4.2.2 CRC - Lectra Cleaner

4.2.3 Geared Limit Switch Gear Box Cover Gasket (PC. #51)(93-10-893)

TCN-18

4.3 Special Tools

4.3.1 Socket head Allen wrenches

5.0 PRECAUTIONS AND LIMITATIONS


5.1 Always wear rubber gloves when working with equipment that may be possibly energized.

5.2 Do not file contacts.

5.3 Always use extreme care when engaging or disengaging a MCC unit from an energized bus.

5.4 Ensure that the work area is clean to prevent entry of dirt or other foreign matter into exposed valve internals.

5.5 When performing work on a valve inside/outside containment penetration, ensure that the associated penetration containment isolation valve is closed or as directed by SSS.



- 5.6 Do not oil or grease magnetic mating surfaces.
- 5.7 When adding grease to a limitorque operator or limit switch compartment, ensure the correct grease is added.
- 5.8 Keep breaker compartment door closed at all times (except when actually inserting or withdrawing circuit breaker/starter unit).
- 5.9 Personnel shall comply with the requirements of NMPC Accident Prevention Rules. Install Safety grounds to steel surface when testing.
- 5.10 Repeated operation can cause overload device actuation or motor damage. Motors are not rated for continuous duty.
- 5.11 AP-6.1 shall apply when lifting or relanding wires during plant #2 normal operation or as required by SSS.
- 5.12 If any reportable problems are determined while performing maintenance on the equipment, notify both the Assistant Maintenance Supervisor and SSS to determine if an Occurrence Report should be initiated.
- 5.13 If the molded case breaker load or line terminations are lifted, reference N2-EPM-GEN-V582 for testing and retermination of the connections.
- 5.14 Limit switch and torque switch adjustments shall not be made.
- 5.15 Do not allow CRC-Lectra Clean to enter into station water systems, drains, etc.

6.0 PREREQUISITES


Initials/Date

- 6.1 The Electrical Maintenance and Operations Department shall determine the plant conditions, system conditions and plant impact (See Step 6.4) on an individual basis prior to obtaining SSS permission. This should normally be completed as part of a staging process.

Plant Conditions _____

System Conditions _____


Ops
Maint. / /



- | | <u>Initials/Date</u> | | | | | | | | | |
|-----------------------------|---|----------------------|-------|-----|-------------|-------|--|---------|-------|----------------------|
| 6.2 | Plant Conditions as stated in 6.1 acceptable. Maint. _____ / _____ | | | | | | | | | |
| 6.3 | System conditions as stated in 6.1 acceptable.
Maint. _____ / _____ | | | | | | | | | |
| 6.4 | Obtain permission from SSS to start work. SSS _____ / _____ | | | | | | | | | |
| <u>PLANT IMPACT:</u> | | | | | | | | | | |
| | 1. MARKED-UP BREAKER/VALVE WILL NOT BE AVAILABLE FOR SERVICE. | | | | | | | | | |
| | 2. LEADS ARE LIFTED AS TEMPORARY MODIFICATIONS. | | | | | | | | | |
| | 3. WHERE MAINTENANCE IS TO BE PERFORMED ON DOUBLE ISOLATION VALVES, THE ONE ISOLATION VALVE TO BE WORKED ON WILL BE INOPERATIVE. THE OTHER ISOLATION VALVE SHALL BE MARKED-UP CLOSED UNLESS OTHERWISE DIRECTED BY THE SSS. | | | | | | | | | |
| | 4. OTHER IMPACTS: _____

_____ | | | | | | | | | |
| 6.5 | Notify CSO of intent to perform maintenance. CSO _____ / _____ | | | | | | | | | |
| 6.6 | Markups - Obtain markups per AP-4.2.
No. _____ Maint. _____ / _____ | | | | | | | | | |
| 6.7 | Radiation Work Permit (RWP) - Obtain an RWP in accordance with AP-3.3.2, Radiation Work Permit Procedure, stating location and elevation of required permit.
No. _____
<input type="checkbox"/> N/A - No RWP Required Maint. _____ / _____ | | | | | | | | | |
| 6.8 | Notify QA for safety related or "Q" equipment.
Maint. _____ / _____ | | | | | | | | | |
| 6.9 | Obtain ISI Open/Close stroke times.
Open _____ sec. Close _____ sec.
<input type="checkbox"/> N/A - No ISI Requirements. Maint. _____ / _____ | | | | | | | | | |
| 6.10 | Obtain torque switch settings from approved design documents (Ref. 2.10, EP-410 drawings) and record:

<table border="0"> <thead> <tr> <th style="text-align: center;">Open</th> <th style="text-align: center;">Close</th> <th style="text-align: right; vertical-align: top;">* 3</th> </tr> </thead> <tbody> <tr> <td>Recommended</td> <td>_____</td> <td></td> </tr> <tr> <td>Maximum</td> <td>_____</td> <td>Maint. _____ / _____</td> </tr> </tbody> </table> | Open | Close | * 3 | Recommended | _____ | | Maximum | _____ | Maint. _____ / _____ |
| Open | Close | * 3 | | | | | | | | |
| Recommended | _____ | | | | | | | | | |
| Maximum | _____ | Maint. _____ / _____ | | | | | | | | |
| 6.11 | Personnel performing this procedure have read it in its entirety and are thoroughly familiar with its contents.
Maint. _____ / _____ | | | | | | | | | |



Equipment Piece No. _____

Initials/Date

- 6.12 Verify test equipment is currently calibrated and record the test equipment as used.

<u>Test Equipment</u>	<u>I.D. No.</u>	<u>Cal. Due Date</u>
Megger	_____	_____
Multimeter	_____	_____
Clamp-on Ammeter	_____	_____
Stopwatch	_____	_____
_____	_____	_____

Maint. _____ / _____

- 6.13 Those steps in this procedure not performed or applicable due to a particular situation should be marked "NA" on the Data Sheets with explanations noted in the Remarks Section. Maint. _____ / _____

7.0 PROCEDURE

- NOTE:
1. AP-6.1 shall apply when lifting or relanding wires.
 2. The sequence of steps is not critical and may be performed separately or in parallel.

7.1 Starter/Breaker Unit Removal

WARNING:


INTERLOCKING CONTROL CIRCUITS FROM OTHER SOURCES MAY STILL BE ENERGIZED.

- 7.1.1 Check all termination points to ground to ensure the MCC unit has no energized wires. Maint. _____ / _____
- 7.1.2 Lift all external unit wiring and record on Attachment 10.1, Lifted Lead and Jumper Log.


WARNING:

WEAR RUBBER GLOVES WHEN INSERTING OR WITHDRAWING MCC BREAKER/STARTER UNIT.

- 7.1.3 Withdraw the starter/breaker unit from the MCC, taking care that unit does not drop as it is withdrawn. Maint. _____ / _____




Equipment Piece No. _____		Initials/Date
7.2	<u>Starter/Breaker Cubicle</u>	
7.2.1	Clean the starter/breaker cubicle.	Maint. _____ / _____
7.2.2	Check all cubicle hardware for tightness.	Maint. _____ / _____ *2
7.2.3	Check all terminations and connections for tightness and wiring for insulation deterioration.	Maint. _____ / _____ *2
7.2.4	Check the unit's stabs and stab openings (bus) for deformation and discoloration.	Maint. _____ / _____
7.2.5	At the breaker compartment check the door interlock for proper operation.	Maint. _____ / _____
7.3	<u>Starter/Breaker Bucket</u>	
7.3.1	Check the molded case circuit breaker as follows:	
7.3.1.1	Check the breaker connections for discoloration or signs of arcing, ensuring a proper electrical joint. Clean connections as required.	Maint. _____ / _____
7.3.1.2	Check the breaker casing for cracks/breaks.	Maint. _____ / _____
7.3.1.3	Check trip adjustment to verify that it agrees with appropriate setting sheet. (refer to Reference 2.12) <input type="checkbox"/> N/A - No Breaker Trip Adjustment	Maint. _____ / _____ TCN. 1
7.3.2	<u>Check the starter as follows:</u>	
CAUTION:		
DO NOT LUBRICATE STARTER.		
7.3.2.1	Check starter contacts for erosion, pitting or beads due to arcing.	Maint. _____ / _____ *2
7.3.2.2	Check the starter and overload relay casing for cracks.	Maint. _____ / _____
7.3.2.3	Check the starter coil for insulation cracks/deterioration.	Maint. _____ / _____
7.3.2.4	With coil removed, check interior of contactor for damage.	Maint. _____ / _____



Equipment Piece No. _____ Initials/Date

- 7.3.2.5 Reassemble and manually cycle the starter checking for binding or seizing. Maint. _____ / *2
- 7.3.2.6 Manually cycle all control/auxiliary contacts to determine proper operation. Maint. _____ / *2
- 7.3.2.7 Check the overload relay heaters for evidence of corrosion or contamination and connections for tightness. Clean and tighten as required being sure to check the screw that connects the overload relay to the contactor (electrical connection). Maint. _____ / *2
- 7.3.3 Visually inspect the control transformer for physical defects or degradation. Maint. _____ /
- *7.3.4 Check all fuse holders for tightness and fuse(s) for correct size and type.
 F1 Type _____, Size _____
 F2 Type _____, Size _____ Maint. _____ /
- 7.3.5 Check all terminations and connections for tightness and wiring for insulation deterioration. Maint. _____ / *2
- 7.3.6 Visually inspect, wire wraps, terminal blocks and miscellaneous devices for cracks and degradation. Maint. _____ / *2
- 7.3.7 Perform a starter/breaker megger test as follows (closed starter/breaker test - refer to Attachment 10.4).
- 7.3.7.1 Remove control transformer primary and secondary connections. Record lifted wires on Attachment 10.1, Lifted Lead and Jumper Log.
- 7.3.7.2 Establish test grounds on the line side of breaker (G1, G2 and G3 on Attachment 10.4). Maint. _____ /
- 7.3.7.3 Close breaker. Maint. _____ /
- *7.3.7.4 Remove one test ground at a time and megger the line at 1000VDC with the open starter manually closed, and repeat with the close starter manually closed. Megger reading shall be \geq 1.6 megohms. Repeat step for each phase, maintain grounds on the remaining phases.

*Denotes Trendable Data.



Equipment Piece No. _____

Initials/Date

*7.3.7.4 (Cont'd)

Line to ground, close contactor closed.
 A _____, B _____, C _____ Megohms

Line to ground, open contactor closed.
 A _____, B _____, C _____ Megohms

7.3.7.5 Remove all test grounds.

Maint. _____ /

*7.3.7.6 Megger secondary of transformer to ground at 500VDC.
 Megger reading shall be \geq 1.5 megohms.

_____ Megohms Maint. _____ /

*7.3.7.7 Megger primary of transformer to ground at 1000VDC.
 Megger reading shall be \geq 1.6 megohms.

_____ Megohms Maint. _____ /

7.3.7.8 Open breaker.

Maint. _____ /

7.3.7.9 Reconnect control transformer primary and
 secondary connections and record on Attachment
 10.1, Lifted Lead and Jumper Log. Maint. _____ /7.3.8 Cycle (open and close) the circuit breaker 6
 times ensuring smooth mechanical operation.

Maint. _____ / *2

7.3.9 Hand operate all electrical devices checking
 for binding or seizing. Use an ohmmeter to test
 for proper operation of all main and auxiliary
 contacts on the breaker, starter and overload
 relays.

Maint. _____ / *2

7.3.10 Check all bolted connections for tightness. Maint. _____ /


7.3.11 Check gaskets for sign of deterioration. Maint. _____ / *2

7.3.12 Ensure the breaker is in the "off" position
 and reinstall the breaker/starter unit back
 into the MCC cubicle.

Maint. _____ /

7.4 Limiterorque Operator Electrical Components7.4.1 Swing open or remove limit switch compartment cover.
 Maint. _____ /

*Denotes Trendable Data.



Equipment Piece No. _____

Initials/Date _____

WARNING:

INTERLOCKING CONTROL CIRCUITS FROM OTHER SOURCES
MAY STILL BE ENERGIZED.

7.4.2 Check all termination points to ground to ensure that the compartment has no energized wires. _____ /

7.4.3 Lift wiring as required and record on Attachment 10.1, Lifted Lead and Jumper Log.

7.4.4 Check the torque switches as follows:

*7.4.4.1 Record the "As Found" torque switch settings and verify in accordance with approved design documents (Reference 2.10, EP-410 drawings).

Switch Setting	<u>Open</u>	<u>Close</u>
Limiting Plate,	____	____
Label Rec.	____	____
Label Max.	____	____

Maint. _____ /

*7.4.4.2 Record the spring pack ID No. Spring pack No. is located on torque switch nameplate attached to limit switch gear box cover. (See Attachment 10.2).

Spring Pack No. _____ Maint. _____ /

7.4.4.3 Ensure that the contacts are free of pitting, corrosion or signs of arcing. Clean the contacts, as required, using CRC-Lectra Cleaner. (EQ)

Maint. _____ /

|*2

*Denotes Trendable Data.



Equipment Piece No. _____

Initials/Date

- 7.4.4.4 Record the color of the torque switch insulation material and verify it is correct for the application per table below.

Color _____

NOTE 1: Some older size 00 operators may have size 000 style torque switches installed (see Sheet 1 of Attach. 10.3). If this is the case, use the size 000 guidelines.

NOTE: For the following actuators, red color torque switches are acceptable.

2CSH*MOV101 2CSH*MOV111 2RHS*MOV2A
2CSH*MOV105 2CSH*MOV112 2RHS*MOV2B
2CSH*MOV110 2CSH*MOV118

Application	Torque Switch Color			
	Brown	White	Red	Black
EQ Size 000	X			
Safety-Related				
Size 000 (Non-EQ)	X		X	
Non-safety Related				
Size 000	X	X	X	
EQ Size 00 through 5 (See Note 1)	X	X		
Non EQ				
Size 00 through 5	X	X	X	X

X = Acceptable

Maint. _____ / _____

- 7.4.4.5 For SMB-000 valve operators, check that the color/material of the cam lug is brass. (See Attachment 10.3)

N/A - Not an SMB-000 Valve Operator Maint. _____ / _____

- 7.4.4.6 For SMB-000 operators, check the torque switch ensuring that metal shims are installed under contact screws. See Attachment 10.3 (SER 67-84).

N/A - Not an SMB-000 Valve Operator Maint. _____ / _____


- 7.4.4.7 Check that the torque switch mounting bolts are tight.

Maint. _____ / _____

- 7.4.5 Check the limit switches for the following:

- 7.4.5.1 Ensure that the rotors and finger bases are free from cracks.

Maint. _____ / _____



Equipment Piece No. _____

Initials/Date

- 7.4.5.2 Ensure that the rotors contacts are free of pitting, corrosion or signs of arcing. Clean the contacts, as required, using CRC-Lectra Cleaner. (EQ) Maint. _____ / |*2

- 7.4.5.3 Record the color of the rotors and fingerbase insulation material and verify it is correct for the application per table below.

Rotor Color _____
Fingerbase Color _____

NOTE 1: Red and Black are acceptable for the following operators.

2CSH*MOV101 2CSH*MOV111 2RHS*MOV2A
2CSH*MOV105 2CSH*MOV112 2RHS*MOV2B
2CSH*MOV110 2CSH*MOV118

Application	Rotor/Fingerbase Color			
	Brown	White	Red	Black
EQ	X	X		
Non-EQ	X	X	X	X

X = Acceptable

Maint. _____ /

- 7.4.5.4 Check all wiring, terminations, connections and plastic crimps for tightness, damage and deterioration. (EQ) Maint. _____ / |*2

- 7.4.6 Check flex conduit for physical damage. Maint. _____ /

- 7.4.7 Ensure that the equipment ground is tight and free of corrosion. Maint. _____ /


- 7.4.8 Check the limit switch compartment for cleanliness. Clean as required. Maint. _____ /

- 7.4.8.1 Should moisture be evident, dry the compartment and components. (EQ) Maint. _____ / |*2

- 7.4.9 Check terminal strips and blocks for cracks and ensure all lock nuts are tight (mounting hardware). (EQ) Maint. _____ / |*2

- 7.4.10 Check that all internal jumper wiring is Rockbestos Firewall III (gray), Raychem Flamtrol (black), or XLPE 600V (black). Maint. _____ /

- 7.4.11 Reconnect wiring and record on Attachment 10.1, Lifted Lead and Jumper Log.



Equipment Piece No. _____

Initials/Date

7.5 Limitorque Valve Lubrications and Checks

NOTE: Steps 7.5.1.1 through 7.5.1.3 can be N/A if removal of limit switch is not required for limit switch gear box cover removal.

WARNING:

SHOCK HAZARD
CONTROL VOLTAGE MAY BE PRESENT ON SOME POINTS OF GEARED LIMIT SWITCH.

- 7.5.1.1 Clutch in set rods (for rotors) on geared limit switches to disengage rotors then record valve position.

N/A, Geared limit switch removal not required.....(____)

15899

Valve position.....(____) Maint. _____ / _____

- 7.5.1.2 Lift leads as necessary to allow removal of limit switch assembly. Record on Attachment 10.1, Lifted Lead and Jumper Log.

N/A, Lifted leads not required.....(____) Maint. _____ / _____

- 7.5.1.3 Remove limit switch mounting bolts and withdraw limit switch assembly.

N/A, Limit Switch removal not required.....(____) Maint. _____ / _____

15899

- 7.5.1.4 Remove the limit switch gear box cover(s). Maint. _____ / _____

- 7.5.2 Check limit switch intermittent gears for broken or missing teeth. (EQ) Maint. _____ / _____

NOTES: 1. Limitorques located in high temperature areas > 150°F may be lubricated using Mobil 28 (color - dark red). (EQ)


2. Do not mix Exxon Beacon-325 (peanut butter color) with Mobil-28. (EQ)

- 7.5.3 Check lubricant for cleanliness and consistency. Lubricant should be soft to the touch. Lubricate with Exxon Beacon-325 (color/consistency - peanut butter), as required. (EQ)

Maint. _____ / _____



Equipment Piece No.	Initials/Date
7.5.4 Check the limit switch gear box housing gasket for cracking and deterioration. Replace gasket as necessary.	Maint. /
7.5.4.1 Clean gasketed surfaces on cover.	Maint. /
7.5.5.1 Install limit switch gear box cover(s).	Maint. /
NOTE: Steps 7.5.5.2 through 7.5.5.4 can be N/A if limit switch removal was not required for limit switch gear box cover removal.	
7.5.5.2 Install limit switch assembly in operator and torque mounting bolts per Attachment 10.5, Torque Table.	
N/A, Limit switch assembly not removed in Step 7.5.1.3.....()	Maint. /
7.5.5.3 Land leads lifted in Step 7.5.1.2 and record on Attachment 10.1, Lifted Lead and Jumper Log.	
N/A, No leads lifted in Step 7.5.1.2..()	Maint. /
7.5.5.4 Verify valve position is the same as Step 7.5.1.1 and declutch set rods (for rotors) on geared limit switches to engage rotors.	
N/A, Set rods not clutched in per Step 7.5.1.1.....()	Maint. /
7.5.6 Check that the limit switch mounting bolts are tight.	Maint. /
NOTE: Excessive oil leaking from seals and joints may be an indication of mixed grease.	
7.5.7 Visually check shaft penetrations for indications of leakage at the gear frame cover, cartridge assembly seal, torque switch seal and valve stem housing. (EQ)	Maint. /
7.5.8 Check exposed valve stem for cracks, gouges and wear.	Maint. /
7.5.8.1 Clean and lubricate rising valve stem with "Never Seez" Nickel Special. (EQ) <input type="checkbox"/> N/A, no rising stem	Maint. /




Equipment Piece No. _____

Initials/Date _____

- NOTES:
1. Do not mix Sun Oil Co. 50-EP or EP-740 (lithium lead base) with Nebula EP-0 or EP-1 (calcium base).
 2. Nebula EP-0 and EP-1 should be dark tan in color; Sun Oil Co. 50EP should be black in color.
 3. Mixed grease separates into oil and solids.

- 7.5.9 Check the lubricant (Nebula EP-0, EP-1 or Sun Oil Co. 50-EP, EP-740) in main gear case to be free of contaminants and for proper consistency (lubricant should be of a butter like consistency). (EQ) Maint. _____ / _____
- 7.5.10 Check the grease level by removing the fill and or drain plug (the gear case should be approximately 90% full of grease and the worm should be totally immersed), add grease as required. (EQ) Maint. _____ / _____
- 7.5.11 Using the same lubricant as in the main gear case, lubricate the drive sleeve upper bearing through the zerk fitting in the housing cover. (EQ) Maint. _____ / _____
- 7.5.12 If applicable, lubricate handwheel grease fitting. Maint. _____ / _____
- 7.5.13 If applicable, check the lubricant (Nebula EP-0 or EP-1) in the HBC unit, ensuring that it is free of contaminants.
 N/A, No HBC Unit or no Inspection Plugs Maint. _____ / _____
- 7.5.14 Check the following for tightness:
- 7.5.14.1 Stem protector and stem protector cap (EQ) Maint. _____ / _____
- 7.5.14.2 Handwheel (EQ) Maint. _____ / _____
- 7.5.14.3 Declutch lever (EQ) Maint. _____ / _____
- 7.5.14.4 Operator mounting bolts and operator to valve yoke bolts (where accessible)
 N/A, Not Accessible Maint. _____ / _____
- 7.5.15 Verify that the torque switch setting is the same as "As Found". Maint. _____ / _____



Equipment Piece No. _____

Initials/Date

7.5.16 Replace the limit switch compartment cover while performing the following:

7.5.16.1 Check the limit switch compartment cover gasket for cracking or deterioration. Clean gasketed surfaces and replace gasket as necessary. (EQ)

Maint. _____ / _____

7.5.16.2 Ensure that cover gasket is properly seated and mounting bolts are tight.

Maint. _____ / _____

7.5.17 Clean exterior of motor.

Maint. _____ / _____

7.5.18 If present, remove and discard any plastic caps located on the grease reliefs.

Maint. _____ / _____

7.5.19 Check T-drains (as-applicable) to ensure drain hole is not plugged. (EQ)

N/A, No T-drains installed.

Maint. _____ / _____

7.6 Maintenance Test

7.6.1 Reconnect motor external wiring at MCC and record on Attachment 10.1, Lifted Lead and Jumper Log.

*7.6.2 Megger the associated operator motor and power cable at 1000VDC to ground and record insulation resistance on Data Sheet. Insulation resistance shall be \geq 1.6 megohms (EQ).

A_____, B_____, C_____ Megohms

Maint. _____ / _____

*7.6.3 Using a multimeter on the low ohm scale, check the motor and power cable phase resistance.


1-2_____ ohms, 1-3_____ ohms, 2-3_____ ohms

Maint. _____ / _____

7.6.4 Reconnect external control wiring at MCC and record on Attachment 10.1, Lifted Lead and Jumper Log.

7.6.5 Lift wiring as needed (interlocks, etc.) and record on Attachment 10.1, Lifted Lead and Jumper Log.

*Denotes Trendable Data.



Equipment Piece No. _____

Initials/Date

7.6.6 Notify Operations to stroke the valve open to close and close to open and perform the following:

*7.6.6.1 Record stroke times by using indicating lights in Control Room.

Closed _____ sec.
Open _____ sec.

Maint. _____ / _____

NOTE: Inrush current is an EQ item for actuators with magnesium rotors only.

*7.6.6.2 While stroking the valve, record the unseating current, running current, seating current, inrush current and cutoff current. (EQ)

Inrush Current	_____	amps	Unseating Current	_____	amps
Running Current	_____	amps	Running Current	_____	amps
Seating Current	_____	amps	Cutoff Current	_____	amps

Maint. _____ / _____

7.6.6.3 Verify smooth operation with no binding.

Maint. _____ / _____

7.6.6.4 Verify position indicators indicate proper valve position.

Maint. _____ / _____

7.6.6.5 Using the operator handwheel, verify the valve is not backseating.

Maint. _____ / _____

15899


7.6.6.6 Compare recorded stroke times to Technical Specification allowable as listed in N2-EMP-GEN-517.

/ Not Applicable, no Tech. Spec. Maint. _____ / _____

7.6.6.7 Notify ISI to perform evaluation if stroke time(s) is greater than 75% of Technical Specification allowable. ISI to initial if evaluation is required. Use Remarks Section to record results of evaluation as necessary.

/ Not Applicable, no evaluation required. ISI Maint. _____ / _____

*Denotes Trendable Data.



Equipment Piece No. _____

Initials/Date

CAUTION:

MOTORS ARE NOT RATED FOR CONTINUOUS DUTY.

7.6.7 Repeat Step 7.6.6.2 and note readings for comparison.
Maint. _____ /

7.6.8 Reconnect wiring lifted in 7.6.5 and record on
Attachment 10.1, Lifted Lead and Jumper Log.

8.0 RETURN TO NORMAL

8.1 Return the RWP.
 N/A - No RWP Required Maint. _____ /

8.2 Leads lifted as temporary modifications have
been restored to normal. Maint. _____ /
SSS _____ /
CSO _____ /

8.3 Surrender/clear the markups to Operations. Maint. _____ /

8.4 Operations notified equipment is available
for post maintenance test. The following
test is recommended, as applicable. Maint. _____ /

8.4.1 Cycle the valve (open and close) per
applicable Operations Surveillance Test
(see N2-EMP-GEN-517).

9.0 ACCEPTANCE CRITERIA

9.1 Megger readings shall be as follows:

9.1.1 \geq 1.6 megohms for equipment rating \geq 600
volts. Maint. _____ /


9.1.2 \geq 1.5 megohms for equipment rating \leq 600
volts. Maint. _____ /

9.2 No unsatisfactory inspection items. Part
replacement not required. Maint. _____ /

9.3 Lubricants are in satisfactory condition
and show no evidence of mixing. Maint. _____ /

9.4 MCC electrical contacts operate properly. Maint. _____ /

9.5 Torque switch set in accordance with design
documents (Ref 2.10, EP-410 dwgs). Maint. _____ /



Equipment Piece No. _____

Initials/Date

9.6 Valve stroke time(s) shall be in accordance with applicable Technical Specification (Reference N2-EMP-GEN-517).

N/A - No Tech. Spec. Requirement

Maint. _____ / _____

9.7 Valve stroke time(s) shall be in accordance with applicable ISI requirements.

N/A - No ISI Requirement

Maint. _____ / _____

Signature Table

<u>INITIALS</u>	<u>SIGNATURE</u>	<u>PRINTED NAME</u>
-----------------	------------------	---------------------

Performed by: _____

Results:

1. () Acceptable

2. () Acceptable with comments. Work Request No. _____

3. () Unsatisfactory, (Use Remarks Section as necessary and initiate a Work Request). Work Request No. _____

Remarks:

Review


Maintenance Man _____

Date _____

Assistant/Maintenance Supervisor _____ Date _____


ISI _____

Date _____



10.0 ATTACHMENTS

- 10.1 Lifted Lead and Jumper Log**
- 10.2 Torque Switch Calibration Nameplate**
- 10.3 Torque Switch Layout**
- 10.4 Test Configuration, Closed Contactor/Breaker**



NM NIAGARA
MOHAWK

LIFTED LEAD AND JUMPER LOG


1 UNIT:	2 TEMP. MOD. #	<input type="checkbox"/> NA
3 WORK DOC:	4 PROC. #	<input type="checkbox"/> NA

WIRING DATA

#	CABLE NUMBER (if applicable)	WIRE NUMBER OR "JUMPER"	COLOR	"FROM" TERMINATION DEVICE		PT	LIFTED YES NO	"TO" TERMINATION DEVICE		PT	LIFTED YES NO	APPLICATION		RETURN TO NORMAL		
				PERF'D INIT.	VERF'D INIT.			PERF'D INIT.	VERF'D INIT.			PERF'D INIT.	VERF'D INIT.	PERF'D INIT.	VERF'D INIT.	
1																
2																
3																
4																
5																
6																
7																
8																
9																
10																
11																
12																
13																
14																
15																
16																
17																

5. APPLICATION

SIGNATURE	INITIAL	DATE	TIME	SIGNATURE	INITIAL	DATE	TIME
313-253 R11-86 SYMBOL NO.55-32-211	PERFORMED BY: VERIFIED BY:						





LIFTED LEAD AND JUMPER LOG


1 UNIT:	2 TEMP. MOD. #	<input type="checkbox"/> NA
3 WORK DOC:	4 PROC. #	<input type="checkbox"/> NA

WIRING DATA

#	CABLE NUMBER (if applicable)	WIRE NUMBER OR "JUMPER"	COLOR	"FROM" TERMINATION		LIFTED PT	"TO" TERMINATION		LIFTED PT	APPLICATION		RETURN TO NORMAL		
				DEVICE	PT		DEVICE	PT		YES NO	YES NO	PERF'D INIT.	VERF'D INIT.	PERF'D INIT.
1														
2														
3														
4														
5														
6														
7														
8														
9														
10														
11														
12														
13														
14														
15														
16														
17														

5. APPLICATION

	SIGNATURE	INITIAL	DATE	TIME	SIGNATURE	INITIAL	DATE	TIME
313-253 R11-86 SYMBOL NO.55-32-211	PERFORMED BY:							
	VERIFIED BY:							



TORQUE SWITCH CALIBRATION NAMEPLATE

TORQUE SWITCH CALIBRATION						
SWS-3	Spring Pack ID # 60-600-0073-1 (950-11 4.7 MN)					
FT-L3	200	300	400	500	600	700
SETTING	1-1/2	2	2-1/2	3	3-1/2	4
UNIT RATING	DO NOT EXCEED ↓ LOW NUMBER NORMAL SETTING HIGH NUMBER MAXIMUM SETTING					
LIMITORQUE CORP.						

SPRING PACK
ID NUMBER


Torque Switch Calibration Nameplate

This nameplate is mounted inside the limit switch compartment on the gear box of the limit switch. The information on this plate relates to the torque switch and torque output of the unit.


Torque Switch Settings/Output Torque

The nameplate has two scales of numbers, which represent settings of the torque switch and their respective output torques. The various output torques are listed directly above the respective torque switch settings.

The torque switch scale usually ranges (in quarter-or half-increments) from 1 to 5. Two numbers on the torque switch scale will be indicated by punch holes. The one punched on the lower end of the scale will be the normal setting of the torque switch. This is the value to which the switch will initially be set by Limitorque. The output torque directly above this punched number represents the amount of torque needed to trip the torque switch. This value of torque was calculated by the valve manufacturer as required to seat the particular valve (under normal system operating conditions) the unit operates. This torque value will not be met or exceeded during normal cycling of the valve.




SMB-000 TORQUE SWITCH




PC. NO.	NO. REQD.	DESCRIPTION
1	1	TERMINAL BLOCK
2	2	CONTACT BRIDGE
3	4	CONTACT SCREW
4	4	FINGER HOLDER
5	4	FINGER
6	4	SHUNT
7	4	SHUNT WASHER $\frac{1}{16}$ O.D. $\frac{3}{32}$ I.O. $\frac{1}{32}$ THK.
8	4	RIVET
9	4	FINGER SPRING STUD
10	4	COMPRESSION SPRING
11	8	SPRING CUP WASHER
12	4	COTTER PIN ($\frac{1}{16}$ x $\frac{1}{8}$)
13	4	HEX. HD. MACH. SCR. #10-32 x $\frac{3}{8}$
14	4	RING TORQUE CONNECTOR 18" #16 AWG TYPE TU PIGTAIL
15	4	LOCKWASHER SHAKEPROOF
16	1	TORQUE SW. MTG. BRACKET
17	1	"O" RING
18	1	"O" RING
19	2	SOC. HD. CAP SCR. $\frac{1}{16}$ -20 x $\frac{1}{8}$ LG.
20	1	CAM
21	1	TORSION SPRING
22	1	SPRING MANDREL
23	1	DIAL
24	1	SHAFT
25	2	STRIKER
26	1	TORQUE LIMITING PLATE
27	1	STRIKER HUB
28	1	ROLL PIN $\frac{1}{16}$ Ø x $\frac{1}{8}$
29	1	#4 SWAGE NUT
30	2	PAN HD. SCREW #8-32 x $\frac{1}{8}$ LG. SLOTTED
31	2	LOCKWASHER SHAKEPROOF
32	2	FLATWASHER $\frac{1}{16}$ I.D. x $\frac{1}{16}$ O.D. x .032 THK.
33	1	ARM
34	1	ROLLER
35	1	ROLLER PIN
36	1	GROOVE PIN $\frac{3}{32}$ DIA. x $\frac{1}{8}$
37	1	ARC BARRIER
38	1	PAN HD. SCR. #4-40 x $\frac{1}{8}$
39	1	LOCKWASHER, EXTERNAL TOOTH
40	4	WASHER $\frac{1}{16}$ O.D. x $\frac{13}{64}$ I.D. x $\frac{1}{32}$ THK.
42	2	RD. HD. MACH. SCR. $\frac{1}{16}$ -18 x $\frac{1}{8}$

SMB-00 THROUGH SMB-5 TORQUE SWITCH



PC. NO.	NO. REQ.	DESCRIPTION
1 1	1	TERMINAL BLOCK
2 2	2	CONTACT BLOCK
4 2	2	ARM
5 1	1	DIAL
6 1	1	ACTUATING LINK
7 2	2	POINTER
8 1	1	SHAFT
9 1	1	SPACER
10 2	2	CONTACT SUPPORT
11 1	1	TORQUE LIMITER
12 1	1	BUSHING
13 1	1	T.SW. PINION
14 1	1	BEARING
15 2	2	CONTACT FINGER
16 4	4	TERMINAL STUD
17 2	2	COMPR. SPRING
18 2	2	TORSION SPRING
19 1	1	INSULATOR
20 1	1	FLAT WASHER
21 1	1	"O"-RING
22 2	2	SCREW-ROUND HD. SLOTTED $\frac{1}{8}$ -18 x $\frac{1}{8}$ LG.
23 1	1	ROLL-PIN $\frac{3}{32}$ DIA. x $\frac{5}{16}$ LG.
24 1	1	LOCKWASHER - $\frac{1}{4}$
25 3	3	THRUST WASHER
26 2	2	$\frac{5}{16}$ LOCKWASHER
27 12	12	LOCKWASHER #10
28 1	1	ROLL PIN $\frac{3}{32}$ DIA. x $\frac{3}{4}$ LG.
29 8	8	HEX. NUT #10-32
30 2	2	HEX. NUT #6-32
31 1	1	COTTER PIN $\frac{3}{32}$ DIA. x $\frac{1}{8}$ LG.
32 1	1	SCREW-SOC. HD. CAP $\frac{1}{4}$ -20 x $\frac{1}{8}$ LG.
33 2	2	SCREW-PAN HD. SELF-TAPPING #4-40 x $\frac{1}{8}$ LG.
34 2	2	SCREW-HEX. SOC. SET #6-32 x $\frac{5}{16}$ LG.
35 8	8	SCREW-MACH. RD. HD. #10-32 x $\frac{3}{16}$ LG.
36 1	1	SCREW-MACH. RD. HD. #5-40 x $\frac{3}{16}$ LG.
37		WAX AS REQUIRED
39 2	2	LOCKWASHER
45 1	1	"O"-RING
46 1	1	MOUNTING BRACKET

TEST CONFIGURATION CLOSED CONTACTOR/BREAKER



20

Attachment 10.5
Sheet 1 of 1

TORQUE TABLE

<u>TORQUE TABLE</u>		
Screw Size	Application	Torque (in.-lb.)
1/4	Non Metallic Mountings	50 ±5
1/4	Metallic Mountings	110 ±5
5/16	Metallic Mountings	150 ±5

1973

Give to reporter

NRC MEETING
ATTENDANCE SHEET

DATE 8-16-91
 LOCATION U-1 Sx. Conf Rm
 SUBJECT IIT

UNIT 2
 INSPECTION RPT # _____
 INSPECTOR _____

	NAME
1.	<u>Tack Rosenthal</u>
2.	<u>Michael Jordan</u>
3.	<u>Richard Conic</u>
4.	<u>Dennis Allison</u>
5.	<u>GENE TRAGER</u>
6.	<u>Julio LARA</u>
7.	<u>John KAUFFMAN</u>
8.	<u>CARL Sisco</u>
9.	<u>STAN WILCZEK, JR.</u>
10.	<u>B R ALPHI SYLVIA</u>
11.	<u>JOSEPH F. FIRLIT</u>
12.	<u>Martin J. McCannick Jr</u>
13.	<u>James A Perry</u>
14.	<u>RICHARD B. ABBOTT</u>
15.	<u>William J. Vatter</u>
16.	<u>OPAL G Z. GORDON</u>
17.	<u>Kim Dahlberg</u>
18.	_____
19.	_____
20.	_____

	TITLE	PHONE #
1.	<u>Branch Chief/AEOD/ROAB</u>	<u>4924440</u>
2.	<u>Chief, Operatn Licensing</u> ^{Section}	<u>790-5552</u>
3.	<u>Chief, BWR Section, RI</u>	<u>215-346-5210</u>
4.	<u>Sr Program Mgr AEOD</u>	<u>301 492 4148</u>
5.	<u>REACTOR SYSTEMS ENGINEER</u>	<u>(301) 492-4496</u>
6.	<u>NRC Reactor Engineer RI</u>	<u>215-337-5144</u>
7.	<u>NRC SR RE Sys. Eng., AEOD</u>	<u>(301)-492-4436</u>
8.	<u>OPERATIONS ENGINEER</u>	<u>(210) 337-5076</u>
9.	<u>VP Nuclear Support</u>	<u>315 428 7151</u>
10.	<u>EXEC V.P.-NUCLEAR</u>	<u>315-4287494</u>
11.	<u>VP - Nuclear Generation</u>	<u>315 349-2447</u>
12.	<u>Plant Manager - Unit 2</u>	<u>315 349-2465</u>
13.	<u>VP-Quality Assurance</u>	<u>315 349-2660</u>
14.	<u>MGR. ENGINEERING I&P 2</u>	<u>315-428-7147</u>
15.	<u>Asst. Mgr. Human Perf., INPO</u>	<u>404-859-1859</u>
16.	<u>SR. EP SPLST., RI</u>	<u>FTS 346-5044</u>
17.	<u>Plant Manager Unit 1</u>	<u>6134413</u>
18.	_____	_____
19.	_____	_____
20.	_____	_____

200

S. M.

200

200

200

200

200

200

200

200

200

200

200

200

200

200

200

NRC MEETING
ATTENDANCE SHEET

DATE	<u>8-16-91</u>	UNIT	<u>2</u>
LOCATION	<u>U-1 Sde. Conf Rm.</u>	INSPECTION RPT #	<u></u>
SUBJECT	<u>IIT</u>	INSPECTOR	<u></u>

	NAME	TITLE	PHONE #
1.	<u>Steve Doty</u>	<u>Gen Supr. Elect Maint</u>	<u>4594</u>
2.	<u>John Conway</u>	<u>Manager Tech Supr.</u>	<u>2698</u>
3.	<u>JERRY HELKEN</u>	<u>Gen Supr. Ops</u>	<u>7523</u>
4.	<u>Tom Tomlinson</u>	<u>Supr Reactor Eng</u>	<u>7348</u>
5.	<u>AL SALAMI</u>	<u>Director Ellipse PRPA</u>	<u>4476</u>
6.	<u>RAY Main</u>	<u>Maint. Support Eng.</u>	<u>7297</u>
7.	<u>Jim Spadaford</u>	<u>ISEG</u>	<u>4220</u>
8.	<u>JOHN T. PAVEL</u>	<u>LICENSING</u>	<u>7441</u>
9.	<u>Nick Spagnola</u>	<u>Licensing</u>	<u>7452(SM)</u>
10.	<u>Joe Beratta</u>	<u>Security</u>	<u>2864</u>
11.	<u>Rob Temps</u>	<u>U-2 RI</u>	<u>X2529</u>
12.	<u>CARL TERRY</u>	<u>VP-Nuc. ENG.</u>	<u>428-7449</u>
13.	<u>M.J. (Dumb)</u>	<u>Manager - Operations-U2</u>	<u>7952</u>
14.	<u>DARRELL EISENSTADT</u>	<u>SRAB</u>	<u>301-258-2524</u>
15.	<u>Patricia J. INACIUS</u>	<u>MATS</u>	<u>7125</u>
16.	<u>Tom Evans</u>	<u>MATS</u>	<u>7120</u>
17.	<u>John Parkinson</u>	<u>NMP</u>	<u>426-7977</u>
18.	<u>Guy Wilkens</u>	<u>NMP</u>	<u>428-6937</u>
19.	<u>DK Greene</u>	<u>Mgr Licensing</u>	<u>428-7536</u>
20.	<u>A. K. JULKA</u>	<u>Supr. ELECT. DESIGN</u>	<u>428-7210</u>

200

WATER SUPPLY

ITEM	QUANTITY	UNIT	DESCRIPTION
1	1	PC	1000 LITER
2	1	PC	1000 LITER
3	1	PC	1000 LITER
4	1	PC	1000 LITER
5	1	PC	1000 LITER
6	1	PC	1000 LITER
7	1	PC	1000 LITER
8	1	PC	1000 LITER
9	1	PC	1000 LITER
10	1	PC	1000 LITER
11	1	PC	1000 LITER
12	1	PC	1000 LITER
13	1	PC	1000 LITER
14	1	PC	1000 LITER
15	1	PC	1000 LITER
16	1	PC	1000 LITER
17	1	PC	1000 LITER
18	1	PC	1000 LITER
19	1	PC	1000 LITER
20	1	PC	1000 LITER
21	1	PC	1000 LITER
22	1	PC	1000 LITER
23	1	PC	1000 LITER
24	1	PC	1000 LITER
25	1	PC	1000 LITER
26	1	PC	1000 LITER
27	1	PC	1000 LITER
28	1	PC	1000 LITER
29	1	PC	1000 LITER
30	1	PC	1000 LITER
31	1	PC	1000 LITER
32	1	PC	1000 LITER
33	1	PC	1000 LITER
34	1	PC	1000 LITER
35	1	PC	1000 LITER
36	1	PC	1000 LITER
37	1	PC	1000 LITER
38	1	PC	1000 LITER
39	1	PC	1000 LITER
40	1	PC	1000 LITER
41	1	PC	1000 LITER
42	1	PC	1000 LITER
43	1	PC	1000 LITER
44	1	PC	1000 LITER
45	1	PC	1000 LITER
46	1	PC	1000 LITER
47	1	PC	1000 LITER
48	1	PC	1000 LITER
49	1	PC	1000 LITER
50	1	PC	1000 LITER
51	1	PC	1000 LITER
52	1	PC	1000 LITER
53	1	PC	1000 LITER
54	1	PC	1000 LITER
55	1	PC	1000 LITER
56	1	PC	1000 LITER
57	1	PC	1000 LITER
58	1	PC	1000 LITER
59	1	PC	1000 LITER
60	1	PC	1000 LITER
61	1	PC	1000 LITER
62	1	PC	1000 LITER
63	1	PC	1000 LITER
64	1	PC	1000 LITER
65	1	PC	1000 LITER
66	1	PC	1000 LITER
67	1	PC	1000 LITER
68	1	PC	1000 LITER
69	1	PC	1000 LITER
70	1	PC	1000 LITER
71	1	PC	1000 LITER
72	1	PC	1000 LITER
73	1	PC	1000 LITER
74	1	PC	1000 LITER
75	1	PC	1000 LITER
76	1	PC	1000 LITER
77	1	PC	1000 LITER
78	1	PC	1000 LITER
79	1	PC	1000 LITER
80	1	PC	1000 LITER
81	1	PC	1000 LITER
82	1	PC	1000 LITER
83	1	PC	1000 LITER
84	1	PC	1000 LITER
85	1	PC	1000 LITER
86	1	PC	1000 LITER
87	1	PC	1000 LITER
88	1	PC	1000 LITER
89	1	PC	1000 LITER
90	1	PC	1000 LITER
91	1	PC	1000 LITER
92	1	PC	1000 LITER
93	1	PC	1000 LITER
94	1	PC	1000 LITER
95	1	PC	1000 LITER
96	1	PC	1000 LITER
97	1	PC	1000 LITER
98	1	PC	1000 LITER
99	1	PC	1000 LITER
100	1	PC	1000 LITER
101	1	PC	1000 LITER
102	1	PC	1000 LITER
103	1	PC	1000 LITER
104	1	PC	1000 LITER
105	1	PC	1000 LITER
106	1	PC	1000 LITER
107	1	PC	1000 LITER
108	1	PC	1000 LITER
109	1	PC	1000 LITER
110	1	PC	1000 LITER
111	1	PC	1000 LITER
112	1	PC	1000 LITER
113	1	PC	1000 LITER
114	1	PC	1000 LITER
115	1	PC	1000 LITER
116	1	PC	1000 LITER
117	1	PC	1000 LITER
118	1	PC	1000 LITER
119	1	PC	1000 LITER
120	1	PC	1000 LITER
121	1	PC	1000 LITER
122	1	PC	1000 LITER
123	1	PC	1000 LITER
124	1	PC	1000 LITER
125	1	PC	1000 LITER
126	1	PC	1000 LITER
127	1	PC	1000 LITER
128	1	PC	1000 LITER
129	1	PC	1000 LITER
130	1	PC	1000 LITER
131	1	PC	1000 LITER
132	1	PC	1000 LITER
133	1	PC	1000 LITER
134	1	PC	1000 LITER
135	1	PC	1000 LITER
136	1	PC	1000 LITER
137	1	PC	1000 LITER
138	1	PC	1000 LITER
139	1	PC	1000 LITER
140	1	PC	1000 LITER
141	1	PC	1000 LITER
142	1	PC	1000 LITER
143	1	PC	1000 LITER
144	1	PC	1000 LITER
145	1	PC	1000 LITER
146	1	PC	1000 LITER
147	1	PC	1000 LITER
148	1	PC	1000 LITER
149	1	PC	1000 LITER
150	1	PC	1000 LITER
151	1	PC	1000 LITER
152	1	PC	1000 LITER
153	1	PC	1000 LITER
154	1	PC	1000 LITER
155	1	PC	1000 LITER
156	1	PC	1000 LITER
157	1	PC	1000 LITER
158	1	PC	1000 LITER
159	1	PC	1000 LITER
160	1	PC	1000 LITER
161	1	PC	1000 LITER
162	1	PC	1000 LITER
163	1	PC	1000 LITER
164	1	PC	1000 LITER
165	1	PC	1000 LITER
166	1	PC	1000 LITER
167	1	PC	1000 LITER
168	1	PC	1000 LITER
169	1	PC	1000 LITER
170	1	PC	1000 LITER
171	1	PC	1000 LITER
172	1	PC	1000 LITER
173	1	PC	1000 LITER
174	1	PC	1000 LITER
175	1	PC	1000 LITER
176	1	PC	1000 LITER
177	1	PC	1000 LITER
178	1	PC	1000 LITER
179	1	PC	1000 LITER
180	1	PC	1000 LITER
181	1	PC	1000 LITER
182	1	PC	1000 LITER
183	1	PC	1000 LITER
184	1	PC	1000 LITER
185	1	PC	1000 LITER
186	1	PC	1000 LITER
187	1	PC	1000 LITER
188	1	PC	1000 LITER
189	1	PC	1000 LITER
190	1	PC	1000 LITER
191	1	PC	1000 LITER
192	1	PC	1000 LITER
193	1	PC	1000 LITER
194	1	PC	1000 LITER
195	1	PC	1000 LITER
196	1	PC	1000 LITER
197	1	PC	1000 LITER
198	1	PC	1000 LITER
199	1	PC	1000 LITER
200	1	PC	1000 LITER

07-149-91

NINE MILE POINT UNIT 2
SCRIBA OSCILLOGRAPH
AUGUST 13, 1991 EVENT

<u>CHANNEL</u>	<u>HOUSE 1</u>	<u>DAU 1</u>	<u>RECORDING</u>	<u>CALIBRATION</u>	<u>PT OR CT RATIO</u>	<u>BEFORE</u>		<u>DURING</u>		<u>AFTER</u>	
						<u>CM</u>	<u>VALUE</u>	<u>CM</u>	<u>VALUE</u>	<u>CM</u>	<u>VALUE</u>
01	$E_{(1-N)}$	345KV BUS A		50V/cm	3000/1	1.4	210KV	1.2	180KV	1.4	210KV
02	$E_{(2-N)}$	345KV BUS A		50V/cm	3000/1	1.42	213KV	.55	82.5KV	1.4	210KV
03	$E_{(3-N)}$	345KV BUS A		50V/cm	3000/1	1.4	210KV	1.2	180KV	1.4	210KV
05	$I_{(PH2)}$	345KV LINE 21		5AMPS/cm	2000/5	.32	640A	1.13	2260A	LOW	
08	$E_{(2-N)}$	345KV LINE 21		50V/cm	3000/1	1.4	210KV	.54	81KV	1.4	210KV
10	$I_{(PH3)}$	345KV LINE 23		5AMPS/cm	2000/5	.87	1740A	3.05	6100A	0	0
11	$I^{(R)}$	345KV LINE 23		5AMPS/cm	2000/5	0	0	.75	1300A	0	0
12	E_0	345KV LINE 23		20VOLTS/cm	-	-	-	.3	18KV	-	-
13	$E_{(3-N)}$	345KV LINE 23		50VOLTS/cm	3000/1	1.42	213KV	1.15	172.5KV	Generator Voltage Decay	

HOUSE 2/A RECORDING

1	$E_{(1-2)}$	345KV BUS B	80V/cm	3000/1	1.56	374.4KV	.95	228KV	1.48	355.2KV
2	$E_{(2-3)}$	345KV BUS B	80V/cm	3000/1	1.5	360KV	.85	204KV	1.47	352.8KV
3	$E_{(3-1)}$	345KV BUS B	80V/cm	3000/1	1.53	367.2KV	1.4	336KV	1.5	360KV
5	$I_{(PH3)}$	345KV LINE 20	5AMPS/cm	2000/5	.28	560A	.6	1200A	LOW	
9	$I_{(PH2)}$	345KV LINE 20	5AMPS/cm	2000/5	.28	560	.88	1760A	LOW	

123477B-1
123477B-2

07-150-91

File Copy
8/23/91

UPS NO: 2VBB-UPS1A
 FNL NO: 2VBS-PNLA101
 DIST PNL NO: 2CEC-PNL827
 BKR NO: 16

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL827


LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	VALVE POSITION	DESCRIPTION/OTHER
2CNM-68C LSK-6-3,	X	X		X		X			REACTOR FD PUMP 2FWS-P1C SUCTION FLOW/LOSS OF CONTROL OF 2FWR- FV2C
2CCP-24A/C LSK-9-1D	X	X		X					RB CLOSE LOOP COOLING WATER FROM DRYWELL 2DRS-UC2A/C TEMP
2CCP-30A/C LSK-4-1.3K	X	X		X					RBCLCW FROM DRYWELL 2DRS-UC1A/C TEMP
2CNM-38C, LSK-4-1.3K	X	X		X		X			CNST BSTR PUMP P2C SUCTION FLOW/LOSS OF CONTROL OF FV38C
2CCP-74A LSK-9-1D	X	X		X					RB CLOSE LOOP COOLING WATER FROM DRYWELL 2DRS-UC3A TEMP
2SFC-2A LSK-34-2B	X	X		X		X			SPENT FUEL POOL WATER LEVEL
2CCP-129 LSK-9-1E	X	X		X					RB CLOSE LOOP COOLING WATER PUMP P1A, P1B, P1C DISCHARGE FLOW
2HDL-4C LSK-4-2.1B	X					X	X		4TH POINT HTR 2CNM- E4C WATER LEVEL LOSS OF CONTROL OF LV4C
2HDL-35C LSK-4-2.1C	X					X			4TH POINT HTR 2CNM- E4C DRAIN PUMP P1C FLOW/LOSS OF CONTROL OF FV35C
2CCP-51A LSK-90-1D	X								RB CLOSE LOOP COOLING WATER FLOW FROM 2RCSP1A COOLERS

OK

UPS NO: 2VBB-UPS1A
 PNL NO: 2VBS-PNLA101
 DIST PNL NO: 2CEC-PNL827
 BKR NO: 16

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL827

LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	VALVE POSITION	DESCRIPTION/OTHER
2HDL-41C LSK-4-2.1B	X					X			4TH POINT HEATER NO. 2CNM-E4C DRAIN PUMP DISCHARGE PRESSURE
2CCS-149 LSK-9-7A	X					X			TB CLOSE LOOP COOLING WATER PUMP DISCHARGE HEADER PRESSURE
2CMS*178 LSK-33-2E	X					X			CONTAINMENT DW PRESSURE AROUND 12.5 TO 17 PSIA
2CMS-179 LSK-33-2E	X					X			SUPPRESSION CHAMBER PRESSURE AROUND 12.5 TO 17 PSIA
2SFC-124 LSK-34-2D						X			SFPC WATER CIRC DUMP VALVE/LOSS OF CONTROL OF FV124
2SFC-104 LSK-34-2D	X					X			SFPC TOTAL FLOW
2CCS-136 LSK-9-7C	X	X		X					TB CLOSE LOOP COOLING WATER FLOW BELOW 2 PUMP LIMIT, 1 PUMP LIMIT
2FWS-9C LSK-6.1.1D	X					X			REACTOR FEED WATER PUMP P1C DISCHARGE PRESSURE
2TML-108 LSK-16-2.3	X					X			OIL TANK OIL LEVEL
2CNM-45C LSK-4-1.1J	X		X			X	X		CONDENSER 1C VACUUM
2CNM-70C LSK-4-1.3K	X					X			REACTOR FEED WATER PUMP P1C SUCTION PRESSURE
2CCS-104 LSK-9-7B	X	X		X		X			TB COOLING WATER HEAT EXCH. DISCH TEMP HIGH/LOSS OF CONTROL OF TV104



~~02/15/91~~
02/15/91

PAGE 1 OF 2

2VBB- UPS1B


5/22/91

0 2VBS- PNL B101

- BKR#1 LOSS OF TURB Supervisory PNL ? WILL TURB TRIP
? WILL TURB RESET } i
- * □ BKR#2, BKR#3 NONE. w/ MN TURB / GEN OFFLINE.
- * □ BKR#4 * ANNUNCIATORS
- BKR#5, BKR#6 LOSS OF RCS 'B' HPU (FV17B DRAFTS SHUT) ALSO
LOSE RCS 'B' MODBUS WILL DRAFTS TO RVR MODBUS FROM A SOURCE
TO 8/32/91 MEMORY. (TEMP READ 91-067 JAMES TING)
- BKR#7 LOSE RPV TEMPERATURE INDICATION FROM RCS (B35-R650) RHR
- BKR#8 LOSE TA- & TB RCS Pump & MTR TEMP READER B35-R601 E12-R201.
- ? → □ BKR#9 LOSS RCS A/B & THERMAL SHOCK INTERLOCKS, AP SEAL #1 & 2 INP
H. D.W. TO B35-R650, RPV DOME PRESS TO THERMAL SHOCK INTERLOCK CKT., H. D.W.
PRESS INPUT TO HPU'S? WILL WE HAVE 'A' HPU? B35-R650A/B
- * □ BKR#10, BKR#11 * ANNUNCIATORS
- BKR#12 LOSC ACT Supply to RDU & DGT DISPLAY (NORMAL FEED UPS1A)
LOSE RSCLS. E12-R201
- BKR#13 LOSS OF RPV COOLANT TEMP RHR INT VS INCOT TEMP.
- BKR#14 LOSS OF F.W. TEMPERATURE B22-R643
- * □ BKR#15 LOSS OF TA RPV NARROW RANGE (RCS-A & READER, TA RPV
FWS)
HIGH LVL TRIP INPS, RCS-A'S LOCK UP AS IS, FWS TO NONE
FOR REMAINDER OF CKT. ALSO GET RCS-A FOR RUNBACK
PIN. 603/31(C33-R605→upcl), 603/39, 603/41
- * □ BKR#16 * ANNUNCIATORS
- * □ BKR#17 RWCN sys LOSS OF REJECT FLOW INPS R602 & GSS
OC Sys. FLOW INPS - R604.
- * □ BKR#18 * ANNUNCIATORS
- * □ BKR#19 & BKR#20 SPARES.

* (NOTES ON PAGE


(CONTINUED ON PAGE 2)



• 2UBS-PNLBIO (CONTINUED)

- BKR#21 Loss of: D.W. Equip Dens LR RATE REC, TR LVL REC, Pumps FwR REC; D.W. Floor Drns LR RATE REC, TR LVL REC, Pumps FwR REC; RBCLC flow to D.W. Unit CLR REC, CRD FILT. Cond. REC., CRD O₂ Conc. REC., D.W. FLOOR & EQUIP DRN. LR RATE PROGRAM CONVERGER, D.W. UNIT CLR A & B TEMP REC, D.C.O. MOIST ANALYSIS RECORDER.
- BKR#22 LOSS OF 2SST-IPNL154 ... AG. PLANT IMPACT SYSTEMS ARE SHUTDOWN.
- BKR#23 GEOTARS - NONE.
- BKR#24 NONE (SST-IPNL284 → CMO SYS MONITORING)
- BKR#25 GEOTARS RCS A & B
- BKR#26 NONE (SST-IPNL285 → HPL)
- BKR#27 GEOTARS NEW DOME PRESS., LVL & RCS A & B → Suct. Temp., Speed, Seal AP
- BKR#28 GEOTARS FWS, RCS, CRD
- BKR#29 & BKR#30 SPARE
- BKR#31 → BKR#36 LOSS OF ESSENTIAL CLOTHING TO: AND PACIFIC SYS. CONTROL BLOC 306, CONTROL BLOC 288 & 306 WEST CABLE HALL AND SSS OFFICE.
- * □ BKR#37 * ANNUNCIATOR
- * □ BKR#38 * ANNUNCIATOR
- BKR#39 LOSS OF INDICATION LITES FOR SERVICE WATER VALVES AND PULL TO OPEN / SHUT SWING
- BKR#40 SPARE

* Notes: ① NEED JOHN DOCKUM & AXEL JULKKA TO CONCERN ON PUMPING ANNUNCIATOR RATHER THAN RISK O.L. ON 'A' SIDE AREA BREAKING PUMP SUPPLIES.



2VBB- UPSIB

8/22/91

• 2VBS-PNLB102

□ BKR#1 SPARE

? □ BKR#2 LOSS OF STATION RADIOS (LEAKY WIRE → MAYBE PLUG INTO ANOTHER RECEPTACLE, R?C?)

□ BKR#3 LOSE - OXYGEN RECORDER SSR-A2130 & A2148 (RUCU),
& WES CONDUCTIVITY ALMS, TEMP IND G33-R607,

* REJECT FLOW TO CAND & RAD WASTE, RPV FLANGE TEMP RECORDER,
TURBIDITY MONITORING, * RPV LVL INDICATION → SATELLITE RANGE,
RECORDER & SSR-A2167, * NMS - RCS FLOW RECORDER B35-R614

□ BKR#4 * NO PLANT IMPACT RECOMMEND POWER SUPPLY TO 2CEC-
PNL885 IS PUR FROM 2VBS-PNLB102

* 2VBB-UPSIA IN-SERVICE AND PUR'G 2VBS-PNLB102.

□ BKR#5 LOSS OF PUR TO MAIN FIRE PANEL (2CEC-PNL849)

No fire panel in control room
NEED TO DISCUSS w/FIRE DEPT w/ LOSS OF FIRE DETECTION
IN CONTROL ROOM FOR PLANT

□ BKR#6 NO PLANT IMPACT 2CEC-PNL PURS905 FED FROM
2VBB-UPSIA

□ BKR#7 LOSE INST PUR FOR 2SSR-IPNL145 (RUCU F/D's)


□ BKR#8. LOSE ESSENTIAL LIGHTING AND POWER TO RECEPTACLES
IN 2CEC-PNL880A, B, C & D * (NEED TO CHECK PULLS TO.
CHECK IF ANYTHING IS PLUGGED IN AND EVALUATE LOSS OF SAME)
Also LOSE Comp. Inputs From Pulls 880B & D to ERF Computers
(PROCESS RAD MONITORING.)

Same switch □ BKR#9 SPARE

□ BKR#10 LOSS OF 1/2 D.W. COOLING (2DRS-UC1B, UC1D
UC2B, UC3D & UC3B)

□ BKR#11 → BKR#20 & BKR#24 SPARE.

□ BKR#21, BKR#22 & BKR#23 → REFER TO LOAD LIST FOR 2VBS-PNLB102



8/21/61

2VBB- UPS 1B

2VBS - PNL B111 (Normal SWGR BLDG BATT Room 42)

- BKR 1 → BKR 32 PARTIAL LOSS OF RADAR SYSTEM?
DEMONSTRATED IN EE-11 BK CIRCUITS RESERVED FOR NMPC RADAR SYSTEM
WHAT PART UNABLE TO FIND VISA PRINTS

NEED TO CHECK IN FIELD TO SEE IF ~~CIRCUITS~~ HAVE BEEN USED

- BKR 33 LOSS OF PAGING AREA 3 / GENERAL YARD E&DCR Y03801D

2COP - PNL U02 pg 27 OF 76

- BKR 34 ~~STATION~~ ~~TEST~~ E&DCR M40030A DETERMINED AS PER BKR 36.


- BKR 35. AS PER BKR #33

- BKR 36 E&DCR M40030A pg 7 OF 11. ESSENTIAL LOSS OF LIGHTING
~~AND RECEPTACLE POWER~~ NORMAL SWGR BLDG
EE-65 H & GS J & GS K

STAIR TOWER TOWERS
AND AREA ESSENTIAL
LIGHTING

- BKR 37 AS PER BKR #33

- BKR 38 AS PER BKR 36



2VBB- UPSIB

8/21/91

• 2VBS- PNL B107

□ BKR[#]1 → BKR[#]7 RADWASTE RAD MONITORS CLOSE INPUT
TO Acus: 851245 & RMSRC86

□ BKR[#]8 HW-CAB206 /nop.

* □ BKR[#]9 → BKR[#]13 RADWASTE RAD MONITORS CLOSE INPUT
TO Acus: 851247 & RMSRC88

□ BKR[#]14 & BKR[#]15 SOLID WASTE SLUDGE FEED TO EXTRUDER/
EVAPORATOR AND WASTE CONCENTRATE FEED TO EXTRUDER/
EVAPORATOR RAD MONITORS CLOSE INPUT TO Acus:
851255 & RMSRC79

* □ BKR[#]16 HW-CAB195 } 3 RAD WASTE BLDG EXHAUST RAD MONITORS

□ BKR[#]17 HW-CAB196 } CLOSE INPUT TO Acus:

□ BKR[#]18 HW-CAB197 }

851254 & RMSRC76

□ BKR[#]19 HW-CAB199 }

□ BKR[#]20 & BKR[#]21 } POST ACCIDENT SAMPLING PNL /nop

□ BKR[#]22 }

□ BKR[#]23 → BKR[#]28 SPARE ..

* BKR[#]10 → RMS-RU146

BKR[#]13 → RMS-RU147

BKR[#]16 → HW-CAB195 → HW-CAB195 NOT INCLUDED IN PACKAGE.




2VBB-LPS1B

8/22/91

o 2VBS-PNL B108

- BKRS[#]1 → BK[#]19 TURB. BLDG. RAD MONITORS (INCLUDING URC AREA) COMMUNICATION 851245 AND COMP. PT. RMSRC86 WILL BE OUT OF SERVICE (LOSE INPUTS TO SAME)
- BKRS[#]20 → BK[#]22 CONTROL BLDG RAD MONITORS LOSE INPUT TO ALARMS 851246 & RMSRC87
- BK[#]23 OFG-CAB13B } INOP ACUS 851253 & RMSRC75
- BK[#]24 OFG-CAB13A }
- BK[#]25 CWS CAB157
- BK[#]26 HVT-CAB206 TURB. BLDG EXHAUST RAD MONITOR
LOSE INPUT TO ALARMS: 851254 & RMSRC76
- BK[#]27 LOSS OF INPUTS FROM GENERATOR TEMP. MONITORING
AND LOGGING ON 2GMC-PNL141

P&ID - SSA



2VBB-UWS 1B

8/22/91

• 2VBS - PNL B109

□ BKR[#]1 → BKR[#]20

Reactor Building Rad. Monitors

Computer point RMS RCS4 Area Annex. 851244
will be out of service. (No Comp. Pt A/N Annex.)

□ BKR[#]21 .. 2GTS - CAB105 / RE105 Nop (SGTS Exh. Rad Monitor)
ESK 7GTS04, 7CPS06 (No of Rad Trip of/FOR Containment
Purpose Values I.V.S.) - Grant Q →

□ BKR[#]22 MAIN STACK AREA Rad monitor out of service

(No input to DRMS, No input to/fro Comp Pt RMSRC86)

RMSRC89 A/N Annexes 851245 & 851248

□ BKR[#]23 CCP-CAB115 (SFC H/T X) P#ID-13E

P#ID-13A

□ BKR[#]24 CCP-CA B131 (RWC4 Non-REGEN H/T X)

3 " WILL NOT GET Annex
Inputs
851255
(RMSRC79) TO Annex"

□ BKR[#]25 CCP-CAB142 (SFC Pumps Disch.) NO input to Ann: 851255

P#ID-38A

P#ID-52H

□ BKR[#]26 HVR-CAB-229 (R/BLOC Recirc) Loss Input to : 851254


Ann RMSRC76

□ BKR[#]27 HVR-CAB237 (RHR H/T X Room A) Loss Input to : 851254 AND

RMSCT6

□ BKR[#]28 HVR-CAB238 (RHR H/T X Room B) Loss Input to : 851254 AND
RMSCT6

Also Refer to Notes in CORA List.



87-15A-91

PAGE 1 OF 2

UPS 1B OUTAGE - ESTIMATED DURATION 4HR - 6HRS

SIGNIFICANT EQUIPMENT OUT OF SERVICE

LOSS OF TURBINE SUPERVISORY PANEL ANNUNCIATOR ONLY.

RCS 'B' MODICON - OUT OF SERVICE - REFER TO WR #194741.

RCS FLOW CONTROL, SHUTDOWN B HPU

MOTION INHIBIT, RCS RUNBACK

LOSS OF ABILITY TO MONITOR/RECORD RPV TEMPERATURE - USE 2RSS-TR10B
IN REMOTE SHUT DOWN ROOM, REFER TO N2-OSP-LOG-0001. NOTE: THIS DOES
NOT TAKE PLACE OF 12HR T.S. SHIFT CHECK - N2-OSP-LOG-S004/5.

ANNUNCIATORS - LOSS OF THE ANNUNCIATORS ON 800 AND 600 SERIES
PANEL - NON-EMERGENCY OTHERWISE FOLLOW ACTIONS OF N2-OP-91A.
HOLD OUT HUNG SECOND TO LAST

LOSE 'A' NARROW RANGE RPV LVL IND/REC.
SOURCE OF RCS RUNBACK

LOSS OF RWCU REJECT FLOW AND SYSTEM FLOW - SHUTDOWN WCS LVL
CONTROL TO RHS B. WILL INITIATE LEAK DETECTION ALARMS LOSS OF
ISOLATOR POWER

LOSS OF RWCU REJECT CONTROL


LOSS OF ESSENTIAL LIGHTING CONTROL BUILDING 288' AND 306' (WEST
CABLE HALL). MAKE ANNOUNCEMENT.

LOSS OF D.W. FLOOR/EQUIPMENT MONITORING RECORDERS - REFERENCE WR
#194740.

LOSS OF SERVICE H2O VACUUM BREAKERS

LOSS OF STATION RADIOS, LEAKY WIRE - LAST CIRCUITS TO BE POWERED
DOWN. LAST TO BE SHUT DOWN

LOSS OF PWR TO CONTROL ROOM, MAIN FIRE PANEL. 1/2 HOUR ROUNDS ON
EACH FIRE PANEL TO BE PERFORMED BY FIRE DEPT



LOSS OF ESSENTIAL LIGHTING AND POWER TO RECEPTACLES IN PANELS 880A, 880B, 880C, 880D. NOTHING IS PLUGGED IN AS OF 08/24/91.

PAGE 2 OF 2

LOSS OF 1/2 OF DRYWELL CLG. (1B, 1D, 2B, 2D, 3B WILL BE IN P&L)

LOSS OF RPV LVL INDICATION SHUTDOWN RANGE.

LOSS OF PAGING AREA 3/GENERAL YARD

LOSS OF ESSENTIAL LIGHTING NORMAL SWITCHGEAR BUILDING STAIR TOWER.
MAKE ANNOUNCEMENTS.

LOSS OF R.W. BUILDING ARM'S AND EXHAUST RAD MONITORS INCLUDING LWS-CAB206. LWS-CAB206 TO BE POWERED DOWN PER N2-RTP-109.

LOSS OF TURBINE BUILDING RAD MONITORS AND HVT-CAB206.

LOSS OF CONTROL BUILDING RAD ARM'S MONITORS.

LOSS OF RX BUILDING RAD ARM'S MONITORS AND MAIN STACK AREA RAD MONITOR.

LOSS OF SGTS EXH. RAD MONITOR GTS-CAB105 - TO BE POWERED DOWN PER N2-RTP-109, GROUP 9 VALVES WILL BE ISOLATED, GROUP 9 SIGNAL WILL OCCUR.


LOSS OF RX BUILDING CCP RAD MONITORS

A RCS MOTION INHIBIT ON A&B FLOW CONTROL VALVES WILL BE INITIATED.

RAD PROTECTION IS REQUIRED TO DO ROUNDS IF OUTAGE EXTENDS PAST 6 HRS.

OPS TO MARK CHART RECORDER ONCE UPS 1B IS POWERED DOWN

TEMP LIGHTING INSTALLED IN STAIR NNS STAIR TOWER



UPS 1B OUTAGE - ESTIMATED DURATION 4HR - 6HRS

SIGNIFICANT EQUIPMENT OUT OF SERVICE

LOSS OF TURBINE SUPERVISORY PANEL ANNUNCIATOR ONLY.

RCS 'B' MODICON - OUT OF SERVICE - REFER TO WR #194741.

RCS FLOW CONTROL, SHUTDOWN B HPU

MOTION INHIBIT, RCS RUNBACK

$\nabla A \rightarrow B$ $\nabla A \rightarrow B$

LOSS OF ABILITY TO MONITOR/RECORD RPV TEMPERATURE - USE 2RSS-TR10B
IN REMOTE SHUT DOWN ROOM, REFER TO N2-OSP-LOG-#001. NOTE: THIS DOES
NOT TAKE PLACE OF 12HR T.S. SHIFT CHECK - N2-OSP-LOG-S004/5.

ANNUNCIATORS - LOSS OF THE ANNUNCIATORS ON 800 AND 600 SERIES
PANEL - NON-EMERGENCY OTHERWISE FOLLOW ACTIONS OF N2-OP-91A.
HOLD OUT HUNG SECOND TO LAST

LOSE 'A' NARROW RANGE RPV LVL IND/REC.
SOURCE OF RCS RUNBACK

LOSS OF RWCU REJECT FLOW AND SYSTEM FLOW - SHUTDOWN WCS LVL
CONTROL TO RHS B. WILL INITIATE LEAK DETECTION ALARMS LOSS OF
ISOLATOR POWER

LOSS OF RWCU REJECT CONTROL

LOSS OF ESSENTIAL LIGHTING CONTROL BUILDING 288' AND 306' (WEST
CABLE HALL). MAKE ANNOUNCEMENT..

LOSS OF D.W. FLOOR/EQUIPMENT MONITORING RECORDERS - REFERENCE WR
#194740.

LOSS OF SERVICE H2O VACUUM BREAKERS

LOSS OF STATION RADIOS, LEAKY WIRE - LAST CIRCUITS TO BE POWERED
DOWN. LAST TO BE SHUT DOWN

LOSS OF PWR TO CONTROL ROOM, MAIN FIRE PANEL. 1/2 HOUR ROUNDS ON
EACH FIRE PANEL TO BE PERFORMED BY FIRE DEPT

8
1



4



F



LOSS OF ESSENTIAL LIGHTING AND POWER TO RECEPTACLES IN PANELS 880A,
880B, 880C, 880D. NOTHING IS PLUGGED IN AS OF 08/24/91.

PAGE 2 OF 2

LOSS OF 1/2 OF DRYWELL CLG. (1B, 1D, 2B, 2D, 3B WILL BE IN P&L)

LOSS OF RPV LVL INDICATION SHUTDOWN RANGE.

LOSS OF PAGING AREA 3/GENERAL YARD

LOSS OF ESSENTIAL LIGHTING NORMAL SWITCHGEAR BUILDING STAIR TOWER.
MAKE ANNOUNCEMENTS.

LOSS OF R.W. BUILDING ARM'S AND EXHAUST RAD MONITORS INCLUDING LWS-CAB206. LWS-CAB206 TO BE POWERED DOWN PER N2-RTP-109.

LOSS OF TURBINE BUILDING RAD MONITORS AND HVT-CAB206.

LOSS OF CONTROL BUILDING RAD ARM'S MONITORS.

LOSS OF RX BUILDING RAD ARM'S MONITORS AND MAIN STACK AREA RAD MONITOR.


LOSS OF SGTS. EXH. RAD MONITOR GTS-CAB105 - TO BE POWERED DOWN PER N2-RTP-109, GROUP 9 VALVES WILL BE ISOLATED, GROUP 9 SIGNAL WILL OCCUR.

LOSS OF RX BUILDING CCP RAD MONITORS

A RCS MOTION INHIBIT ON A&B FLOW CONTROL VALVES WILL BE INITIATED.

RAD PROTECTION IS REQUIRED TO DO ROUNDS IF OUTAGE EXTENDS PAST 6 HRS.

OPS TO MARK CHART RECORDER ONCE UPS 1B IS POWERED DOWN
TEMP LIGHTING INSTALLED IN STAIR NNS STAIR TOWER



07-153-91

File Copy 8/21/91

LESS NO: 2VBB-UPSIA


PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL884

PNL NO: 2VBS-PNL884

DIST PNL NO: 2CEC-PNL884

BKR NO: 4

LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
2ASS-6A	X	X	X	X					AUX. STEAM FLOW TO AIR REMOVAL SYSTEM.
2MSS-103	X								2TMS-T1 FIRST STAGE PRESSURE/ GROUP I DRAIN VALVES
2WTS-243	X	X	X	X	X				NEUTRALIZER TANK LEVEL HIGH / INIT THE START OF REGENERATION
2DSR-68A	X	X	X		X				'REHEATER DRAIN RECEIVER-TANK GA WATER LEVEL/ LOSS OF CONTROL OF LV68A
2FOF-101			X		X	X			FUEL OIL STORAGE TANK LEVEL/
2DSR-78A	X	X	X						SCAVENGING STEAM LINE A PRESSURE LOSS OF CONTROL OF MOV-86A
2MSS-104	X								2TMS-T1 1ST STAGE PRESSURE LOSS OF CONTROL OF AOV85A,B,C,D, 2CNM-AOV GROUP III DRAIN VALVES AND 2NM-AOV-101
2CNS-8A	X	X	X	X	X				CNDS. STOR. TKA LEVEL
2MSS-101	X								2TMS-T1 MAIN STEAM INLET HDR. PRESSURE LOSS OF 2ASS-STV112 & 2ASS-AOV145
2MSS-24A	X				X				EIA REHEATING STEAM TEMP.
2DSR-103	X								SCAVENGING STEAM HEADER PRESSURE.
2MSS-22A	X				X				MS/R REGULATED STEAM PRESSURE LOSS OF CONTROL OF 2MSS-PV28A AND 29A
2CRS-1A	X								HIGH PRESSURE TURBINE EXHAUST COLD REHEATER STEAM TO 2MSS-EIA SHELL PRESSURE
2CRS-2A	X								H.P. TURB. EXH. COLD REHEATER STEAM TO 2MSS-EIA SHELL PRESSURE.
2CRS-3A	X								HP TURB. EXH. COLD REHEATER STEAM TO 2MSS-EIA SHELL PRESSURE.
2CRS-16A	X								HP TURB. EXH COLD REHEATER STEAM TO 2MSS-EIA SHELL PRESSURE
2CRS-19A	X				X				REHEATER A COLD REHEAT PRESSURE
2ESS-1A	X				X				6 TH POINT HTR 2FWS-EGR EXTR ST. PRESS.
2ESS-4A	X								TURB. 4TH STG EXTR STEAM PRESSURE
2ESS-7A	X				X				1ST POINT HTR 2CNM-EIA SHELL PRESSURE



UPS NO: 2VBB-UPSIA

PNL NO: 2VBS-PNL A102

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL884

DIST PNL NO: 2CEC-PNL884


BKR NO: 4



UPS NO: 2VBB-UPS1B
 PNL NO: 2VBS-PNLB102
 BKR NO: 4
 UPS NO: 2VBB-UPS1A
 PNL NO: 2VBS-PNLA102
 BKR NO: 5
 DIS PNL: 2CEC-PNL885

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL885


LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
2CNS-8B	X	X	X	X	X				CNDS STOR TKIB LEVEL
2CNS-114	X	X		X	X				CNDS XFR HDR FLOW HIGH / INHIBIT AUTO START OF 2CNS-P1A OR 2CNS-P1B
2CNS-102	X				X				COND HOTWELL LEVEL
2ESS-25B	X				X				4TH PT HTR EXTR ST PRESS
2ESS-17B	X				X				3RD PT HTR EXTR ST PRESS
2ESS-12B	X				X				2NO PT HTR SHELL PRESS
2MSS-52B	X			X					EIB STEAM SUPPLY PRESS
2MSS-24B	X			X					EIB. REHEATING STEAM TEMP
2MSS-23B	X		X						EIB REHEATING STEAM FLOW
2ESS-4B	X								TURB 4TH STG EXTR ST PRESS
2ESS-31B	X				X				5TH PT HTR 2CNM-ESB EXTR ST. PRESS
2MSS-22B	X				X				MS/R REGULATED STEAM PRESS / LOSS OF CONTROL OF REHEAT CONTROL VALVES PV28B & PV29B



UPS NO: 2VBB-UPS1B
 PNL NO: 2VBS-PNLB102
 BKR NO: 4
 UPS NO: 2VBB-UPS1A
 PNL NO: 2VBS-PNLA102
 BKR NO: 5
 DIS PNL: 2CEC-PNL885

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL885

LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
2HRS - 7B	X								2TMS-T 2B LP TURBINE INL PRESS FR 2MSS-EIA
2HRS - 8B	X								2TMS-T 2B HRS FROM 2MSS-EIA
2HRS - 9B	X								2TMS-T 2B HRS FROM 2MSS-EIB
2ASS-6B	X X	X	X						AUX STM FLOW TO AIR REMOVAL
2DSR-68B	X X	X		X					DRAIN RECEIVER HIGH LEVEL/LOSS OF CONTROL OF LV68B
2DSR-65B	X				X				NORM WTR LVL DR CONTROL/ LOSS OF CNTRL OF LVX65B, LVY65B AND LVZ65B
2DSm-75B	X				X				MOISTURE SEP. DRAIN RECEIVER TK4B WTR LEVEL LOSS OF CNTRL OF LVX75B, LVY75B AND LVZ75B.
2DSm-78B	X X	X		X					MOIST SEP DR RCVR TK4B WTR LEVEL / LOSS OF CNTRL OF LV78B
2DSR-78B	X X	X							SCAVENGING STEAM LINE B PRESSURE / LOSS OF CONTROL OF MOV 86B
2ESS-7B	X			X					1ST PT HTR 2CNM-EIB SHELL PRESS
2ESS-1B	X			X					6TH PT HTR 2FWS-E6B EXTR ST. PRESS



UPS NO: 2VBB-UPS1B
PNL NO: 2VBS-PNLB102
BKR NO: 4
UPS NO: 2VBB-UPS1A
PNL NO: 2VBS-PNLA102
BKR NO: 5
DIS PNL: 2CEC-PNL885

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL885




UPS NO: 2VBB-UPS1A

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL886
PNL NO: 2VBS - PNL A102

DIST PNL NO: 2CEC - PNL886

BKR NO: 6

LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
2AAS-113	X	X		X	X				BRTHG AIR HDR PRESS
2ARC-20B	X	X		X					AIR REMOVAL PUMP-1B SEAL WTR TEMP HI
2ASS-116	X	X		X	X				CLN STM REBLR STM PRESS
2ASS-122	X	X		X	X				AIR EJECTOR ZA STM PRESS
2ASS-127	X	X		X		X			OFFGAS STM PRESS
2CMS-72E,F	X				X				CONTAINMENT DEW POINT
2CMS-168	X				X				SUPPR CHAMBER PRESS NORM
2CND-267	X	X		X	X	X			LOW CONDUCTIVITY WASTE TK13 LEVEL
2CND-281	X					X			NEUTRALIZING TK12 LEVEL
2CPS-102	X	X		X	X				ENABLES 2CPS-FN1 (DISCH TO STOP PERMISSIVES DRYWELL)
2CPS-103	X	X		X	X				ENABLES 2CPS-FN1 (DISCH TO STOP PERMISSIVES SUPPR PL)
2CPS-125					X				PRIMARY CONTAINMENT PRESS N2 INLET FLOW/LOSS OF CONTROL OF FV125
2CPS-126	X	X		X	X				PRI CONTMT INLET NITROGEN FLOW
2CPS-127	X	X		X	X				PRI CONTMT INLET NITROGEN PRESS
2GSN-138		X		X	X				PRI CONTMT N2 PURGE TEMP LOW
2HRS-7C	X								2TMS-T2C LPTURB INL FR 2MSS-EIA
2HRS-8C	X								2TMS-T2C HRS FROM 2MSS-EIA
2HRS-9C	X								2TMS-T2C HRS FROM 2MSS-EIB
2IAS-101	X	X		X	X				INSTR AIR HDR PRESS
2IAS-178	X	X		X	X				ADS CPRSR RCVR TANK *TK4 PRESSURE HIGH
2IAS-183	X	X		X	X				ADS CPRSR RCVR TANK *TK5 PRESSURE HIGH
2MWS-114	X	X		X	X	X			DMNRLZD WTR TK1A OR 1B LVL
2MWS-116	X	X		X	X	X			DMNRLZD WTR PMP DISCH FL.




UPS NO: 2VBB-UPSIA

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL886

DIST PNL NO: ZCEC-PNL886

BKR NO: 6



2VBB-UPSIA
UPS NO: 2VBB-UPSIB
PNL NO:

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL887

DIST PNL NO: 2VBS-PNLA102

BKR NO: 7

DIST PNL NO: 2VBS-PNLB102

BKR NO: 6

LOOP

PMS INDICATION
PMS ALARM

ERF INPUT
CR ANNUNCIATION

LOCAL ANNUNCIATION
CR INDICATION

LOCAL INDICATION
FIRE COMPUTER

DESCRIPTION/OTHER

	PMS INDICATION	PMS ALARM	ERF INPUT CR ANNUNCIATION	LOCAL ANNUNCIATION CR INDICATION	LOCAL INDICATION FIRE COMPUTER	AIR REM PPIA SEAL W TEMP H
2ARC-20A	X	X	X			AIR REM PPIA SEAL W TEMP H
2CNM-137				X		2FWS-PIA,B,C START UP BYPASS VALVE POSITION INDICATION
2CWS-47A	X			X		CLG TWR RETURN F.DW TO CWS
2DFR-106	X	X	X	X		DRYWELL FLOOR DRAIN LEAKAGE. ALSO LOSE CR:DW FLOOR DRAIN LEAKAGE RECORDER AND C.R. DW FLOOR DRAIN TK LEVEL RECORDER.
2DFR-137	X			X		DW FL DR PMPS PIA&PIB FLOW LOSE DW FLOOR DRAIN PUMP DISCH FLOW RECORDER (CONTROL ROOM).
2FWS-64A,B				X		FINAL FEEDWATER TEMP TO REALTOR
2GMC-110	X	X	X	X	X	GEN INL CNDCT HIGH. LOSE CR CONDUCTIVITY RCDR.
2GMC-111	X	X	X	X	X	GEN OUTLET CNDCT HIGH. CR CONDUCTIVITY RCDR.
2GMC-134	X			X		ALT CLR CLD AIR TEMP. LOSE CONTROL OF TURBINE BLDG
						CLOSED LOOP COOLING WATER VALVE 2CCS-TV32A AND B.
2GMH-105	X			X		GENERATOR GAS PURITY
2GMH-117	X			X		MACHINE GAS PRESS
2GMH-156				X		H ₂ COLD GAS TEMP. TBCLC FLOW MODULATING VALVE 2CCS-TV109
						FAILS OPEN.
2GML-103	X	X	X			GEN LEADS CLR RET AIR TEMP
2GMO-103	X			X		HYDR SEAL OIL BRG 9 PRESS
2GMO-104	X			X		HYDRAUL SEAL BRG 10 PRESS
2LOS-126	X	X	XX	X		DIRTY OIL STOR TK2 LEVEL. LOSS OF CONTROL FOR PUMP P2
2LOS-127	X	X	XX	X		CLEAN OIL STOR TK1 LVL LOSS OF CONTROL FOR PUMP P2
2TME-15A,B	X			X		2TME-EIA&EIB REBLR DISCH PRESS
2TME-103	X			X		EIA&DISCH HDR PRESS, LOSS OF CONTROL OF 2TME-MOV110, 2TME-SOV121



2VBB-UPSIA
UPS NO: 2VBB-UPSIB
PNL NO:

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL88 7


DIST PNL NO: 2VBS-PNLA102

BKR NO:7

DIST PNL NO:2VBS-PNLB102

BKR NO: 6


LOOP



UPS NO: 2VBB-UPS1A
 PNL NO: 2VBS-PNLA101
 BKR NO: 18
 UPS NO: 2VBB-UPS1B
 PNL NO: 2VBS-PNLB101
 BKR NO: 18
 DIS PNL: 2CEC-PNL888

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL888


LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
ABM-110	X	X		X	X		X		AUX BOILERS STEAM HDR PRESS.
ABM-101	X	X		X	X		X		AUX BOILER DEAR. STM INL. PRESS.
CWS-66A,B		X		X					CLG.TWR. SCREENS WATER LVL HI
CWS-109	X	X		X					CLG. TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOGS2A,B,C
CWS-135	X	X		X					CLG. TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-136	X	X		X					CLG. TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-138	X	X		X		X			CLG. TWR. FLUME WTR. TEMP.
CWS-137	X	X		X					CLG TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-147	X					X			CLG. TWR. BLOWDOWN FLOW / LOSS OF INDICATION ON 2SWP-FR602
CWS-140	X	X		X		X			CLG. TWR. BASIN WTR. LVL / LOSS OF CONTROL OF LV140
CWS-47B	X					X			CLG.TWR. RETURN FLOW TO CWS
SST-50A,B,C	X	X		X	X	X			2HDL-P1A,B,C TURBIDITY SAMPLE
SST-22A,B,C	X	X		X	X				MN COND A,B,C SHL EAST HALF CNDT
SST-21A,B,C	X	X		X	X				MN COND A,B,C SHL WEST HALF CNDT
SST-58A-J	X	X		X	X				CNDS DMNRLZR IA → IJ EFFLUENT CNDT
SST-53A,B,C	X	X		X	X				2HDL-P1A,B,C DISCH SAMPLE CNDT
SSR-156	X	X		X	X		X		CRD COM FLTR DISCH TURBIDITY
SWP-512	X					X			INTAKE CHANNEL WATER TEMP. LOSS OF CONTROL OF TV512
SWP-511	X					X			INTAKE TEMPERING WATER FLOW
SWP-509	X					X			JET MOTIVE PUMP FLOW
SST-142	X	X		X	X				COND DMNRLZR INL SAMPLE TURB.
WTS-323	X					X			DISCH FLOW TO LAKE



UPS NO: 2VBB-UPS1A
 PNL NO: 2VBS-PNL A101
 BKR NO: 18
 UPS NO: 2VBB-UPS1B
 PNL NO: 2VBS-PNL B101
 BKR NO: 18
 DIS PNL: 2CEC-PNL888

PLANT IMPACT: LOSS OF POWER TO 2CEC-PNL888

LOOP	PMS INDICATION	PMS ALARM	ERF INPUT	CR ANNUNCIATION	LOCAL ANNUNCIATION	CR INDICATION	LOCAL INDICATION	FIRE COMPUTER	DESCRIPTION/OTHER
ABM-110	X X		X X		X				AUX BOILERS STEAM HDR PRESS.
ABM-101	X X		X X		X				AUX BOILER DEAR. STM INL. PRESS.
CWS-66A,B	X	X							CLG.TWR. SCREENS WATER LVL HI
CWS-109	X X		X						CLG.TWR. BASIN WTR.. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-135	X X		X						CLG.TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-136	X X		X						CLG.TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-138	X X		X		X				CLG.TWR. FLUME WTR. TEMP.
CWS-137	X X		X						CLG.TWR. BASIN WTR. TEMP / LOSS OF CONTROL OF MOG52A,B,C
CWS-147	X				X				CLG.TWR. BLOWDOWN FLOW / LOSS OF INDICATION ON 2SWP-FR602
CWS-140	X X		X		X				CLG.TWR. BASIN WTR. LVL / LOSS OF CONTROL OF LV140
CWS-47B	X				X				CLG.TWR. RETURN FLOW TO CWS
SST-50A,B,C	X X		X X	X					2HDL-P1A,B,C TURBIDITY SAMPLE
SST-22A,B,C	X X		X X						MN COND A,B,C SHL EAST HALF CNDT
SST-21A,B,C	X X		X X						MN COND A,B,C SHL WEST HALF CNDT
SST-58A→J	X X		X X						CNDS DMNRLZR 1A → 1J EFFLUENT CNDT
SST-53A,B,C	X X		X X						2HDL-P1A,B,C DISCH SAMPLE CNDT
SSR-156	X X		X X		X				CRD COM FLTR DISCH TURBIDITY
SWP-512	X				X				INTAKE CHANNEL WATER TEMP. LOSS OF CONTROL OF TV512
SWP-511	X				X				INTAKE TEMPERING WATER FLOW
SWP-509	X				X				JET MOTIVE PUMP FLOW
SST-142	X X		X X						COND DMNRLZR INL SAMPLE TURB.
WTS-323	X				X				DISCH FLOW TO LAKE



87-15491

QUESTION/RESPONSE FORM

(Working Copy)

QUESTION # 12

DATE/TIME Aug. 24, 1991

INSPECTOR Jose Ibarra / NRC X1035

NMPC ESCORT/DEPT _____

INSPECTION CATEGORY _____

(Documentation, Walkdown, Procedures)

INSPECTOR

QUESTION/REQUEST What prevents the larval return to Fire Panels
(Tumble & Fire) ? What worked during the event?

NMPC RESPONSE:

Responding Individual: Montgomery

200



INTERNAL CORRESPONDENCE

FORM 1122 R 02-80

55-01-013

**NY NIAGARA
MM MOHAWK**

FROM A. R. Andersen *ARh*
TO Distribution

DISTRICT Nine Mile Point Nuclear Station
DATE 15 August 91 FILE CODE
SUBJECT Nine Mile Point
Fire Protection Program
Post Event Interviews

After interviews conducted today with Fire Chief Bernie Harvey, and Firemen Pat Brennan and Mark Locurcio, and concurrence with Terry Vermilyea, System Expert Fire Detection and John Pavlicko of Caution Equipment Inc., I have reached the following conclusions.


1. Of the 20 fire panels at Unit 2, 18 maintained a normal power supply.
- 2a. Two fire panels LFCP113 and 123 transferred to internal battery backup.
- 2b. These two panels while on battery will still function normally as long as the 120 VAC is available in the LFCP, which it was.


There was no interruption or decrease of fire protection/detection/suppression at the local fire panels.

Fire Panels 849 and 200/1 being fed from UPS did have a power interruption. This would have left the control switches operable at Panel 849, (as they are fed from LFCP), but Control Room with no fire annunciation. Any fire suppression/indication could also have been initiated locally.

ARA:dlc
Distribution


T. Tomlinson
A. Julka (FAX 7225 - SM)
D. Pringle





**MINE MILE POINT NUCLEAR STATION — UNIT 2
NIAGARA MOHAWK POWER CORPORATION**

NIAGARA MOHAWK POWER CORPORATION
STONE & WEBSTER ENGINEERING CORPORATION
BOSTON, MASS.



SI
APERTURE
CARD

MAIN ONE LINE DIAGRAM
BY RICHARD STA. SVCE XFMRS
DRM 13, FFM & 600V SYSTEMS

**NINE MILE POINT NUCLEAR STATION - UNIT 2
NIAGARA MOHAWK POWER CORPORATION**
STONE & WEBSTER ENGINEERING CORPORATION
BOSTON, MASS.

THE INFORMATION ON THIS DRAWING MAY NOT BE COPIED OR USED FOR OTHER THAN THE CONSTRUCTION, MAINTENANCE OR REPAIR OF THE PLANT FACILITIES SHOWN IN THE TITLE BLOCK.

DATE 10-19-61	DRAWING NUMBER 12177	18	
		Designed by C. E. E. AND Drawn by C. E. E.	Revised by C. E. E.