

CORRECTION TO LICENSE AMENDMENT NO. 154

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The corrections to the pages are identified by the marginal lines.

Remove

3.9/4.9-9
3.9/4.9-10

Insert

3.9/4.9-9
3.9/4.9-10

of this co.
days, pr
...

ENCLOSURE

9409140137 940912 P
PDR ADOCK 05000259
P PDR

LIMITING CONDITIONS FOR OPERATION

3.9.B. Operation With Inoperable Equipment

3. When one of the units 1 and 2 diesel generator is INOPERABLE, continued REACTOR POWER OPERATION is permissible during the succeeding 7 days, provided that 2 offsite power sources are available as specified in 3.9.A.1.c and all of the CS, RHR (LPCI and containment cooling) systems, and the remaining three units 1 and 2 diesel generators are OPERABLE. If this requirement cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the COLD SHUTDOWN CONDITION within 24 hours.
4. When one units 1 and 2 4-kV shutdown board is INOPERABLE, continued REACTOR POWER OPERATION is permissible for a period of 5 days provided that 2 offsite power sources are available as specified in 3.9.A.1.c and the remaining 4-kV shutdown boards and associated diesel generators, CS, RHR (LPCI and containment cooling) systems, and all 480-V emergency power boards are OPERABLE. If this requirement cannot be met, an orderly shutdown shall be initiated and the reactor shall be in the COLD SHUTDOWN CONDITION within 24 hours.

SURVEILLANCE REQUIREMENTS

4.9.B. Operation With Inoperable Equipment

3. When one of the units 1 and 2 diesel generators is found to be INOPERABLE, all of the remaining diesel generators shall be demonstrated to be OPERABLE within 24 hours, and power availability for the associated boards shall be verified within 1 hour and at least once per 8 hours thereafter.
4. When one 4-kV shutdown board is found to be INOPERABLE, all diesel generators associated with the remaining 4-kV shutdown boards shall be demonstrated to be OPERABLE within 24 hours, and power availability for the remaining 4-kV shutdown boards shall be verified within 1 hours and at least once per 8 hours thereafter.

3.9/4.9 AUXILIARY ELECTRICAL SYSTEM

LIMITING CONDITIONS FOR OPERATION

3.9.B. Operation With Inoperable Equipment

5. When one of the shutdown buses is INOPERABLE, REACTOR POWER OPERATION is permissible for a period of 7 days.
6. When one of the 480-V diesel auxiliary boards becomes INOPERABLE, REACTOR POWER OPERATION is permissible for a period of 5 days.
7. From and after the date that one of the three 250-V unit batteries and/or its associated battery board is found to be INOPERABLE for any reason, continued REACTOR POWER OPERATION is permissible during the succeeding 7 days. Except for routine surveillance testing, NRC shall be notified within 24 hours of the situation, the precautions to be taken during this period, and the plans to return the failed component to an OPERABLE state.

SURVEILLANCE REQUIREMENTS

4.9.B. Operation With Inoperable Equipment

5. When a shutdown bus is found to be INOPERABLE, all 1 and 2 diesel generators shall be proven OPERABLE within 24 hours.
6. When one units 1 and 2 diesel auxiliary board is found to be INOPERABLE, each unit 1 and 2 diesel generator shall be proven OPERABLE within 24 hours, and power availability for the remaining diesel auxiliary board shall be verified within 1 hour and at least once per 8 hours thereafter.