400 € 4123 3 40	•			OR RATED RI	DS PROC	Y Essing					
Ŷ	ĩ	EGULATOR	Y INFOR	MATION	DISTRI	BUTIO	N SYSTE	M (RID	S)		
ACCESSIO FACIL:5 5 AUTH.N SALAS,P RECIP.1	N NBR:950 0-259 Brc 0-260 Brc 0-296 Brc AME NAME	94180280 owns Ferr owns Ferr AUTHOR Tenness RECIPI Docum	DOC. Y Nucles Y Nucles Y Nucles AFFILI ee Valle ENT AFF ent Con	DATE: 9 ar Powe ar Powe ar Powe ATION ey Auth ILIATIC trol Br	5/04/1 er Stat er Stat er Stat ority N eanch (4 NO ion, 1 ion, 1 ion, 1	TARIZED Unit 1, Unit 2, Unit 3, ent Con	: NO Tenne Tenne Tenne	ssee ssee Rp7 esk)	DOCKET # 05000259 05000260 05000296	P R
SUBJECT	: Forward addl en	ls "Brown hancemen	s Ferry ts requ:	Nuclea	r Plan addre	t Muli ss vu	ti-Unit lnerabil	PRA." lities	No •		
DISTRIB TITLE: 1	UTION COD TVA Facil	E: D030D ities -	COPIES	S RECEI Corres	VED:LT		ENCL 1	SIZE	: 16	+200	R
NOTES:					-						
	RECIP ID COD	Pient De/Name	COPII LTTR	ES ENCL	RE ID	CIPIE	NT NAME	COP LTTR	IES ENCL		י ד
	WILLIAMS	, J.	1,	1	PD2-4			т т	1		Y
INTERNAL:	NRR/DSSA RES/DE/S	SEB/SES	0 1 1	,1 1	OGC/H	DS3	K UI)	1	0		4
EXTERNAL:	NOAC		1	1	NRC P	DR		1	1		I
0, rem	· ·	Ju coo	itad	in (grta	L	Files	I			D
			•				. 1				0
	2	•				, *	£				С
											U
		ĸ			·						Μ
			•				•				E
				,	;						N
,			`						i de		T
NOTE ' PL DI DI	TO ALL "RIDS ,EASE HELP U 2SK, ROOM P1 STRIBUTION	" RECIPIENT IS TO REDUC -37 (EXT. 504-2 LISTS FOR D	S: E WASTE! C 2083) TO EL OCUMENTS	CONTACT IMINATE I S YOU DON	THE DOCU YOUR NAM I'T NEED!	JMENT (IE FROM	CONTROL				
TOTAL N	UMBER OF	COPIES R	, EQUIRED	: LTTR	15	ENCL	14				

្ទ

.

•4

1. L.

•

MAZ

· · ·

-

P.

. .



Tennessee Valley Authority, Post Office Box 2000, Decatur, Alabama 35609

April 14, 1995

U.S. Nuclear Regulatory Commission ATTN: Document Control Desk Washington, D.C. 20555

Gentlemen:

9504180280 950414 () PDR ADDCK 05000259

PDR

Drawings located in Central Likes

In the Matter of)	Docket Nos.	50-259
Tennessee Valley Authority)		50-260
	-		50-296

BROWNS FERRY NUCLEAR PLANT (BFN) - MULTI-UNIT PROBABILISTIC RISK ASSESSMENT (PRA)

This letter provides the BFN Multi-Unit PRA for NRC review. The results of this multi-unit analysis indicate that the most limiting site configuration is with all three BFN units in operation. The resulting core damage frequency for Unit 2 with all three BFN units in operation is 2.8×10^{-5} , which is approximately a factor of 3.7 over the current single unit operation BFN PRA estimate of 7.6 x 10⁻⁶. These numbers still represents a very low risk from severe accidents. No single initiating event was found to dominate the total frequency of core damage. The top three categories of initiating events were scenarios involving loss of offsite power (39 percent), internal floods (22 percent), and support system failures (21 percent). No plant vulnerabilities were identified for BFN when multiple units are in operation. Therefore, no additional enhancements are required to address vulnerabilities.

The NRC's September 28, 1994 Safety Evaluation Report for the single unit BFN PRA included a request for TVA to address the feasibility of evaluating the potential benefit of two containment performance improvement items in the multi-unit As requested, TVA has evaluated the feasibility of: PRA.

U.S. Nuclear Regulatory Commission Page 2 April 14, 1995

- Using the diesel driven fire protection system pump to inject water into the reactor vessel upon loss of AC power, and
- 2. Providing an alternate source of power to the automatic depressurization system solenoid valves, to permit depressurization of the reactor following loss of AC power and depletion of batteries.

These improvements were evaluated in conjunction with the hardened wetwell vent because of the synergistic interaction each improvement has on the other. Sensitivity studies were performed using the diesel-driven fire pump, in conjunction with functional safety relief valves and the hardened wetwell vent path, to provide an open loop mode of core cooling following loss of AC power. Based on the resulting small changes in core damage frequency, TVA has no plans to provide an alternate source of power to the automatic depressurization system solenoid valves. Use of the diesel driven fire pump and the hardened wetwell vent are already discussed in BFN Emergency Operating Instructions.

A summary of the background, including the previous correspondence of this issues, and a discussion of how this submittal addressed NRC expectations/open items and meets or exceeds TVA's commitments to address multi-unit operation is provided in Enclosure 1. A separate binder containing the BFN Multi-Unit PRA is also enclosed. If you have any questions, please contact me at (205) 729-2636.

Sincerely,

<u>Pedro</u> Salas Manager of Site Licensing

Enclosures cc: see page 3 U.S. Nuclear Regulatory Commission Page 3 April 14, 1995

• •

Enclosures cc (Enclosures): Regional Administrator U.S. Nuclear Regulatory Commission Region II 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

> Mr. Mark S. Lesser, Acting Branch Chief U.S. Nuclear Regulatory Commission Region II 101 Marietta Street, NW, Suite 2900 Atlanta, Georgia 30323

NRC Resident Inspector Browns Ferry Nuclear Plant Route 12, Box 637 Athens, Alabama 35611

Mr. J. F. Williams, Project Manager U.S. Nuclear Regulatory Commission One White Flint, North 11555 Rockville Pike Rockville, Maryland 20852

. .

.

.

• •

· · ·

.

•

.

ENCLOSURE 1

TENNESSEE VALLEY AUTHORITY BROWNS FERRY NUCLEAR PLANT (BFN)

MULTI-UNIT PROBABILISTIC RISK ASSESSMENT (PRA)

I. BACKGROUND

Generic Letter 88-20, Individual Plant Examination for Severe Accident Vulnerabilities (Reference 1), dated November 23, 1988, requested all licensees perform the following for each plant:

- 1. Perform a systematic examination to identify any plant specific vulnerabilities to severe accidents,
- 2. Identify and review proposed plant improvements (design changes and changes to operating procedures, maintenance, surveillance, training, or staffing)
- 3. Decide which of these improvements will be implemented and their schedule, and
- 4. Report the results to the Commission.

In response, by letter dated October 30, 1989 (Reference 2), TVA committed to complete a Level I PRA and containment analysis for Browns Ferry by September 1, 1992.

In August of 1990 (Reference 3), NRC noted that the three units at BFN share many important safety systems. NRC expressed a concern with the potential safety implications of shared systems in the various operating modes of the BFN units (e.g., All three units operating, Units 1 and 2 operating with Unit 3 shutdown, etc.). NRC requested TVA provide:

- 1. Dependency tables for Units 1 and 3 similar to that provided for Unit 2, and
- 2. Expanded PRAs for Units 1 and 3 that evaluate the entire site as a whole, taking into account the risk significant combinations of unit operational status.

TVA responded to this request on October 12, 1990 (Reference 4). TVA committed to submit dependency matrices prior to the restart of Unit 3, which assume

· , • ۰. ۲. ۹. .

۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ . ,

۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰ ۰

•

Units 2 and 3 are operational. TVA also committed to submit dependency matrices prior to the restart of Unit 1, which assume Units 1, 2, and 3 are operational. TVA declined to pursue the development of multi-unit PRAs at that time for the following reasons:

- BFN does not significantly rely on safety systems which are specific to one unit to achieve and maintain safe shutdown of another unit.
- The Unit 2 dependency matrices did not identify any instances of cross-train dependencies that would compromise the analyzed safety-related systems.
- The subject of unit sharing and interactions was reviewed at the time of the original licensing of BFN.
- As previously discussed, Generic Letter 88-20 requested licensees perform a single unit PRA. It did not request licensees of multiple unit sites perform individual. PRAs for each plant at a multi-unit site or address the effect of shared systems between units. In response to Generic Letter 88-20, TVA committed to perform a Level 1 PRA and limited containment analysis, which assumed Unit 2 in operation and Units 1 and 3 shutdown.

In June 1991 (Reference 5), NRC acknowledged that the performance of these expanded PRAs was not required to fulfil Generic Letter 88-20. However, the staff continued to encourage TVA to perform the expanded PRAs for BFN Units 1 and 3. TVA and NRC met on September 6, 1991 to discuss the NRC's concern (Reference 6). During this meeting, the staff expressed concerns regarding the number of shared systems at BFN and the control of these systems to ensure availability.

In February 1992 (Reference 7), TVA provided a list of the systems shared between the BFN units and a description of their shared functions. TVA reviewed the systems, which are shared between the BFN units, and identified ten systems whose ability to reliably perform their safety function could be challenged due to the impact of system The most limiting configuration for the ten sharing. shared systems occurs when all three units are in operation. Loss of offsite power and loss of plant air are the two initiating events that directly result in the shutdown of all three units. Therefore, TVA committed to perform an expanded PRA, which addresses all three units in operation, that would address the impact of the ten critical shared systems during a loss of offsite power and loss of plant air transients. TVA stated that it intended to submit a summary report to NRC prior to the restart of Unit 3. However, TVA did not consider completion of this work to be a restart prerequisite. NRC's review of the

. · · · · ·

TVA approach for addressing multi-unit dependencies was provided in July 1992 (Reference 8). The Staff agreed that this report was not a prerequisite for the restart of Unit 3. However, the Staff requested TVA to provide formal notification if the completion date should slip beyond the end of 1993.

In response to Generic Letter 88-20, TVA completed and submitted the single unit BFN PRA on September 1, 1992 (Reference 9). When TVA was initially responding to the hardened vent issue, NRC requested TVA in an April 1990 teleconference to incorporate the hardened vent into the PRA. During development of the initial BFN PRA frontline event trees, it was recognized that the hardened wetwell vent would be implemented for BFN Unit 2 during the Unit 2 Cycle 6 refueling outage. Since this outage would occur following submittal of the BFN single unit PRA (September 1992), TVA decided not to model this feature in the initial version of the BFN PRA model. As discussed in Reference 10, TVA committed to incorporate the hardened vent into the next update of the BFN PRA. As discussed in Reference 11, TVA committed to summarize the impact of the hardened vent as part of the multi-unit PRA submittal.

On December 2, 1993 (Reference 12), TVA provided the Staff with an updated schedule for the submittal of the multi-unit PRA. At the time of this letter, the Unit 3 design effort had progressed to the point where the multi-unit PRA work could be supported. Based on the forecasted progression of the Unit 3 design work, TVA provided a January 18, 1995 scheduled submittal date for the multi-unit PRA.

The NRC Safety Evaluation Report (Reference 13) was issued on the single unit BFN PRA on September 28, 1994. In the Safety Evaluation, the Staff requested TVA to address the feasibility of evaluating the potential benefit of two containment performance improvement items as part of the multi-unit PRA. Due, in part, to this request from NRC to expand the scope of the multi-unit PRA, on January 19, 1995 (Reference 14), TVA rescheduled the submittal date for the multi-unit PRA to April 14, 1995.

II. TVA COMMITMENTS AND NRC EXPECTATIONS/OPEN ITEMS

Listed below are TVA's commitments with regards to the multi-unit PRA and NRC's expectations or open items. A comparison of these items to the content of the multi-unit PRA submittal is provided.

• 17

•

×

• ņ i X.

· · · · · · · · · · 3

* •

. 1

• • • • à 2 , •

, · · .

فر

1. TVA committed to perform a multi-unit PRA to evaluate the effect of the operation of the ten critical shared systems on the Unit 2 core damage frequency.

2. This will be accomplished by recalculating the core damage frequency after modifying the electric and mechanical support trees to reflect the revised unavailability of the shared systems.

MULTI-UNIT PRA SUBMITTAL

The BFN Multi-Unit PRA is enclosed. The analysis considered more than the ten shared systems considered in the original commitment. The shared systems included in the model were a result of a systematic examination of all shared systems. A basis was provided for those shared systems that were not included in the model. The basis for identifying the multiunit interacting systems is discussed in Section 2.2 of the main report. The shared systems modeled in the report are discussed in Section 2.3.

The multi-unit PRA model used to calculate the Unit 2 Core Damage Frequency (CDF) was derived from the current Unit 2 PRA model. The changes included modifying the electrical and mechanical support event trees, as well the high and low pressure event trees, to reflect the revised unavailability of shared systems.

3. The expanded PRA will include the loss of offsite power and loss of plant air as initiating events.

MULTI-UNIT PRA SUBMITTAL

Initiating events were evaluated using a failure modes and effects analysis (FMEA). Initiating events for multi-unit operation were identified using the FMEA (Table 2-6), system review (Section 2.2) and multi-unit interaction identification (Section 2.3). The multi-unit PRA includes the following initiating events that impact all units in service: loss of offsite power, loss of 500-kV grid to the plant, loss of plant air, flood in the turbine building, flood in the pumping station, and loss of raw cooling water. A new initiator category, loss of control bay ventilation, was also included.

4. The impact of severe accident scenarios occurring in Units 1 and 3 will not be specifically addressed since they do not result in the automatic shutdown of the other units. Although severe accident scenarios occurring in Units 1 and 3.do not result in automatic shutdown of the other units, the likelihood that a Unit 1/2 common accident signal is present and the likelihood that a unit (other than Unit 2) is experiencing a severe core damage event were both modeled. The common accident signal potentially impacts the availability of residual heat removal and core spray. A severe accident on another unit has the potential to restrict the ability of operators to perform remote actions in the Unit 2 reactor zone. Further discussion is provided in Section 3.2.3.

- 5. Units 1 and 3 design information will be used if it is available. Otherwise, Units 1 and 3 will be assumed to be designed similar to Unit 2 at the time of their restart.
- MULTI-UNIT PRA SUBMITTAL

The cut-off date for the use of Unit 3 design information for the Multi-Unit PRA was May 31, 1993. At this time, the design effort for Unit 3 recovery had made significant progress. It should also be noted that the BFN Design Criteria have generally been established for all three units and TVA's July 10, 1991 submittal of the overall regulatory framework for the restart of Units 1 and 3 states that any deviations to the criteria or implementation of the recovery programs will be identified to NRC. Therefore, TVA considers the multi-unit PRA to adequately reflects multi-unit operation of the BFN facility.

6. The expanded PRA will be performed on a one time basis and TVA is not committed to maintain it as a living document. No additional clarification is required.

, , , ,

.

х .

*

7. TVA committed to summarize the impact of the hardened vent as part of the multi-unit PRA submittal.

MULTI-UNIT PRA_SUBMITTAL

The hardened wetwell vent (HWWV) provides suppression pool cooling for those cases in which loss of decay heat removal was failed (TW sequence). For this class of sequences, the actuation of the HWWV results in the prevention of core damage if a long-term injection source is available such as the Condensate and/or the Control Rod Drive Hydraulic (CRDH) systems. These systems can be used for low pressure injection if the vessel remains depressurized through the use of the safety relief valves. The actuation and long-term operation of the safety relief valves for manual depressurization requires DC power supplies and limited drywell back pressure. The suppression pool was not credited as a suction source for injection following actuation due to uncertainties in the net positive suction head limitations. Credit for the HWWV was only taken for remote-manual operation from the control room.

The availability of the HWWV resulted in reducing the overall CDF) by approximately a factor of In terms of absolute release two. category group frequencies, this resulted in a reduction of Release Category Group III (Late containment failures) by approximately 80 percent, Group II (Small, early containment failures and small bypasses) by approximately 75 percent, Group I (Large, early containment failures and large bypasses) by approximately 10 percent, and an increase of Groups IVA (No release, no vessel breach) and IVB (No release, no containment failure) by 19 percent and one percent, respectively.

• •

. . . .

MULTI-UNIT PRA SUBMITTAL

(Continued)

The relative percentage of the total CDF for scenarios binned into the HWWV release category (VSCRUB) was approximately 4 percent. The Release Category Group III decreased from approximately 72 percent for Case 2 to approximately 33 percent for Case 1. This indicates that the scenario contributions for Case 2 (no vent) are reduced by a factor of approximately two. This reduction is primarily due to a decrease in \mathbb{R} scenarios in which late containment failure occurs including a significant reduction in the TW contribution. The availability of the vent resulted in the transfer of previous scenarios from Group III to scenarios in which containment failure did not occur since the vent provided the means by which other injection sources (e.g. Condensate, CRDH) could successfully mitigate the scenarios. For Case 2, no vent available, the percentage of scenarios in which no containment failure occurs or the release is scrubbed is approximately 60 percent. For Case 1, vent available, the percentage of scenarios in which no containment failure occurs or the release is scrubbed is approximately 82 percent. With respect to containment failure characteristics, the CDF probability decreased by approximately 26 percent for Case 1 as compared to Case 2. Therefore, the availability of the HWWV results in both a reduction in the overall CDF, reduction of containment failure scenarios, and a relative increase of approximately 20 percent in scrubbed releases.

. . .

۰. ۹ ر ۴ . ۴ . .

. . .

, . *<u>*</u> .

1 ri g

• • .

NRC EXPECTATIONS

- TVA assumes that BFN Units 1 and 3 are sufficiently similar to Unit 2, so that a Level I PRA and limited containment analysis of Unit 2 will be applicable to Units 1 and 3. BFN should justify this assumption.
- It is assumed that 2. analyses of the ten selected shared systems are sufficient to cover all significant vulnerabilities associated with BFN systems. It is important to look systematically at all shared systems, and to provide a basis for those that are eliminated.
- 3. Similarly, all initiators need to be evaluated and the basis for eliminating any of them should be explained. Furthermore, the effect of operations and conditions in shut down units on operating units, through the shared systems, needs to be evaluated.

MULTI-UNIT PRA SUBMITTAL

Please refer to the discussion of the design similarities between the units under TVA Commitment 5, above.

The shared systems included in the model are a result of a systematic examination of all shared systems. A basis was provided for those shared systems which are not included in the model. The basis for identifying the multi-unit interacting systems is discussed in Section 2.2 of the main report. The shared systems modeled in the report are discussed in Section 2.3. Shared systems were reviewed for potential to impact success criteria, to change the frequency of an initiating event or introduce a new initiating event, to alter or introduce new dependencies among systems, or to otherwise effect the response to an initiating event.

Initiating events were evaluated using a FMEA. Initiating events for multi-unit operation were identified using the FMEA (Table 2-6), system review (Section 2.2) and multi-unit interaction identification (Section 2.3). The effect of operations and conditions in shut down units on Unit 2, through the shared systems, is evaluated in Section 2.4 and summarized in Table 2-5. . .

¥

1

ι •

.

± т Т

• * *

NRC EXPECTATIONS

- 4. The assumption is made that the analysis can be limited to the two selected initiating events on the basis that they lead directly to the automatic shutdown of all three units. This assumption needs to be justified.
- 5. The identification and assessment of plant vulnerabilities is to be made assuming all three units are in operation, this presumes that three units operating is a bounding configuration and no significant vulnerabilities exist associated with other site operating mode configurations (e.g., two units at power). The effect of operations and conditions in shut down' units on operating units, through the shared systems, needs to be evaluated.

MULTI-UNIT PRA SUBMITTAL

Refer to the response to the item directly above.

 The effect of operations and conditions in shut down units on Unit 2, through the shared systems, is evaluated in Section 2.4 and summarized in Table 2-5.

√ + ‡

۲ ۲ ۲ ۲ ۲ ۲

,

• •

.

) . .

r

NRC OPEN ITEMS

- The feasibility of the use of the diesel driven fire protection system pump to inject water into the reactor vessel upon loss of AC power.
- 2. The feasibility of the installation of an alternate source of power to the automatic depressurization system solenoid valves to permit depressurization of the reactor following loss of AC power and depletion of batteries.

MULTI-UNIT PRA SUBMITTAL

These improvements were evaluated in conjunction with the hardened wetwell vent because of the synergistic interaction each improvement has on the other. During the preparation of the PRA Revision 0 (issued September 1992), TVA recognized the potential of utilizing the diesel-driven fire pump for vessel injection or debris bed cooling and subsequently prepared a system notebook for the high pressure fire protection However, the results have system. not been incorporated into the PRA model at this time. However, the results were used to perform a sensitivity study using the multi-unit PRA model in which the diesel-driven fire pump, in conjunction with functional safety relief valves (implicitly using a supplemental power DC supply) and the hardened wetwell vent path, were used to provide an open loop mode of core cooling following loss of AC The study showed a decrease power. in CDF for the loss of AC power initiator from 1.2 x 10⁻⁵ to 2.6 x 10^{-6} , which decreases the overall CDF from 2.8 x 10⁻⁵ to 1.9×10^{-5} . A second case was evaluated in which, in lieu of the safety relief valve supplemental power supply, the open loop path was credited only when off site power was recovered within six hours. This second case provided a similar CDF for the loss of AC initiator of 2.7×10^{-6} (versus 2.6 x 10^{-6} for the supplemental DC case). These results indicate that the use of the diesel driven fire pump in an open loop mode of core cooling reflect a reduction in the computed CDF due to loss of AC power, with no significant change in the associated CDF.

NRC OPEN ITEMS

MULTI-UNIT PRA SUBMITTAL

(Continued)

Providing an alternate source of power to the safety relief valves is not warranted. This is especially so once consideration is given to the fact that the four hour battery depletion time is based on a conservative calculation and that relatively low current is required to maintain a solenoid open to allow a safety relief valve to function Based on this, TVA has no plans to provide an alternate source of power to the automatic depressurization system solenoid valves. Use of the diesel driven fire pump to provide make-up to the reactor vessel and the hardened wetwell vent are already discussed in Emergency Operating Instructions.

III. REFERENCES

- NRC letter to All Licensees Holding Operating Licenses and Construction Permits, dated November 23, 1988, Individual Plant Examination for Severe Accident Vulnerabilities - 10 CFR §50.54(f) (Generic Letter 88-20)
- 2. TVA letter to NRC, dated October 30, 1989, Proposed Program in Response to Generic Letter 88-20 -Individual Plant Examination (IPE) for Severe Accident Vulnerabilities
- 3. NRC letter to TVA, dated August 13, 1990, PRA Concerns Regarding Operation of Browns Ferry, Units 1 and 3
- TVA letter to NRC, dated October 12, 1990, PRA Concerns Regarding Operation of Browns Ferry, Units 1 and 3
- 5. NRC letter to TVA, dated June 28, 1991, Individual Plant Examination for Severe Accident Vulnerabilities (Generic Letter 88-20), Browns Ferry Nuclear Plant, Units 1, 2, and 3
- 6. NRC letter to TVA, dated November 1, 1991, Summary of the September 6, 1991 Meeting with TVA Regarding the Appropriate Methodology for Conduction Individual Plant Examinations (IPE) at Multi-Unit Sites

• τ. •

н -, - ,

ı

• • ,e

- 7. TVA letter to NRC, dated February 7, 1992, Expanded Probabilistic Risk Assessment (PRA) Considering Operation of Browns Ferry, Units 1 and 3
- 8. NRC letter to TVA, dated July 22, 1992, TVA Approach for Addressing Inter-Unit Dependencies as part of the Individual Plant Examination for the Browns Ferry Nuclear Plant
- 9. TVA letter to NRC, dated September 1, 1992, Response to Generic Letter (GL) 88-20 - "Individual Plant Examination for Severe Accident Vulnerabilities -10 CFR 50.54(f)"
- 10. TVA letter to NRC, dated May 1, 1990, Probabilistic Risk Assessment (PRA) and Emergency Operating Procedure (EOP)
- 11. TVA letter to NRC, dated December 23, 1993, Response to Request for Additional Information Regarding the Individual Plant Examination (IPE)
- 12. TVA letter to NRC, dated December 2, 1993, Expanded Probabilistic Risk Assessment (PRA)
- 13. NRC letter to TVA, dated September 28, 1994, Individual Plant Examination Submittal for Internal Events
- 14. TVA letter to NRC, dated January 19, 1995, Schedule for Submittal of the Expanded (Multi-Unit) Probabilistic Risk Assessment (PRA) and Portions of the Individual Plant Examination of External Events

.

.

.

1 .

×

ې ۲. . •

ŧ.

а . . .

-.