



**UNITED STATES
NUCLEAR REGULATORY COMMISSION**

REGION IV
1600 EAST LAMAR BOULEVARD
ARLINGTON, TEXAS 76011-4511

February 7, 2018

Mr. Eric Larson, Site Vice President
Entergy Operations, Inc.
Grand Gulf Nuclear Station
P.O. Box 756
Port Gibson, MS 39150

**SUBJECT: GRAND GULF NUCLEAR STATION, UNIT 1, RESPONSE TO CLARIFICATION
OF INITIAL RESPONSE TO A NOTICE OF VIOLATION AND NUCLEAR
REGULATORY COMMISSION INSPECTION REPORT 05000416/2017012**

Dear Mr. Larson:

Thank you for your letter of December 21, 2017, (ML17362A041) which provided clarifying information to supplement your September 21, 2017, reply (ML17269A031) to the Notice of Violation concerning calibration of the main steam line and containment/drywell high range radiation monitors. The Notice of Violation was issued on August 22, 2017, in NRC Inspection Report 05000416/2017012 (ML17235B265).

The NRC identified several discrepancies in your initial response that required clarification. We have reviewed these clarifications in conjunction with your initial response to the Notice of Violation and find that they address the violation and the corrective actions taken. Following review of your responses to the Notice of Violation, we concluded that the surveillances performed on the main steam line and containment/drywell high range radiation monitors in response to the Notice of Violation demonstrate reasonably accurate instrument responses. However, the changes to the calibration procedures themselves warrant additional review. In particular, we noted that the procedures continue to allow tolerances significantly wider than industry norm. We will review the implementation of your corrective actions during a future inspection to determine that full compliance has been achieved and will be maintained.

In accordance with 10 CFR 2.390 of the NRC's "Rules of Practice and Procedure," a copy of this letter will be made available electronically for public inspection in the NRC Public Document Room or from the NRC's Agencywide Documents Access Management System (ADAMS), accessible from the NRC's Web site at <http://www.nrc.gov/reading-rm/adams.html>.

E. Larson

2

The NRC also includes significant enforcement actions on its Web site at <https://www.nrc.gov/reading-rm/doc-collections/enforcement/actions/>.

Sincerely,

/RA/

Heather J. Gepford, Ph.D., CHP
Chief, Plant Support Branch 2
Division of Reactor Safety

Docket No. 50-416
License No. NPF-29

cc: Electronic Distribution

GRAND GULF NUCLEAR STATION, UNIT 1, RESPONSE TO CLARIFICATION OF INITIAL
 RESPONSE TO NOTICE OF VIOLATION AND NUCLEAR REGULATORY COMMISSION
 INSPECTION REPORT 05000416/2017012 – February 7, 2017

DISTRIBUTION:

KKennedy, RA
 SMorris, DRA
 TPruett, DRP
 AVegel, DRS
 RLantz, DRP
 JClark, DRS
 SKirkwood, RC
 JKozal, DRP
 CYoung, DRP
 MYoung, DRP
 TSteadham, DRP
 NDay, DRP
 AAthar, DRP
 AElam, DRP
 JBowen, RIV/OEDO
 VDricks, ORA
 JWeil, OCA
 SLingam, NRR
 AMoreno, RIV/CAO
 BMaier, RSLO
 THipschman, IPAT
 EUribe, IPAT
 TDeBey, DRP
 MHerrera, DRMA
 R4Enforcement

DOCUMENT NAME: R:_REACTORS_GG\2017\GG2017012 Ack Ltr to GG Clarification of NOV Response.docx

ADAMS ACCESSION NUMBER: ML18038B584

SUNSI Review: ADAMS: Non-Publicly Available Non-Sensitive Keyword:
 By: JJO Yes No Publicly Available Sensitive NRC-002

OFFICE	HP:DRS/PSB2	C:DRS/PSB2	C:DRP/PBC	C:DRS/PSB2		
NAME	JO'Donnell	HGepford	JKozal	HGepford		
SIGNATURE	/RA/	/RA/	/RA/	/RA/		
DATE	2/6/18	2/6/18	2/7/18	2/7/18		

OFFICIAL RECORD COPY