



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-259

BROWNS FERRY NUCLEAR PLANT, UNIT 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 230
License No. DPR-33

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 20, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51. of the Commission's regulations and all applicable requirements have been satisfied.

9609090363 960805
PDR ADDCK 05000259
P PDR


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-33 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 230, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: August 5, 1996

ATTACHMENT TO LICENSE AMENDMENT NO. 230

FACILITY OPERATING LICENSE NO. DPR-33

DOCKET NO. 50-259

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1.0-11
1.0-12

INSERT

1.0-11
1.0-12

1.0 DEFINITIONS (Cont'd)

- GG. Site Boundary - Shall be that line beyond which the land is not owned, leased, or otherwise controlled by TVA.
- HH. Unrestricted Area - Any area at or beyond the SITE BOUNDARY to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the SITE BOUNDARY used for industrial, commercial, institutional, or recreational purposes.
- II. Dose Equivalent I-131 - The DOSE EQUIVALENT I-131 shall be the concentration of I-131 (in $\mu\text{Ci/gm}$) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factor used for this calculation shall be those listed in Table III of TID-14844 "Calculation of Distance Factors for Power and Test Reactor Sites".
- JJ. Gaseous Waste Treatment System - The charcoal adsorber vessels installed on the discharge of the steam jet air ejector to provide delay to a unit's offgas activity prior to release.
- KK. Members of the Public - An individual in a controlled or UNRESTRICTED AREA. However, an individual is not a MEMBER OF THE PUBLIC during any period in which the individual receives an occupational dose (as defined in 10 CFR 20).
- LL. Surveillance - Surveillance Requirements shall be met during the OPERATIONAL CONDITIONS or other conditions specified for individual limiting conditions for operation unless otherwise stated in an individual Surveillance Requirements. Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval. It is not intended that this (extension) provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages.

Performance of a Surveillance Requirement within the specified time interval shall constitute compliance and OPERABILITY requirements for a limiting condition for operation and associated action statements unless otherwise required by these specifications. Surveillance Requirements do not have to be performed on inoperable equipment.

If it is discovered that a surveillance was not performed within its specified frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified frequency, whichever is less. This delay period is permitted to allow performance of the surveillance.



1.0 DEFINITIONS (Cont'd)

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.


When the surveillance is performed within the delay period and the surveillance is not met, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.

MM. Surveillance Requirements for ASME Section XI Pump and Valve Program - Surveillance Requirements for Inservice Testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

1. Inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55(g) (6) (i).
2. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these technical specifications:

ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice testing activities	Required frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days

3. The provisions of Specification 1.0.LL are applicable to the above required frequencies for performing inservice testing activities.
4. Performance of the above inservice testing activities shall be in addition to other specified surveillance requirements.
5. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any technical specification.
6. The inservice inspection program for piping identified in NRC Generic Letter '88-01 shall be performed in accordance with the staff positions on schedule, methods, personnel, and sample expansion included in this generic letter.





UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-260

BROWNS FERRY NUCLEAR PLANT, UNIT 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 245
License No. DPR-52

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 20, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-52 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 245, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebbon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: August 5, 1996

ATTACHMENT TO LICENSE AMENDMENT NO.245

FACILITY OPERATING LICENSE NO. DPR-52

DOCKET NO. 50-260

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1.0-11
1.0-12

INSERT

1.0-11
1.0-12



1.0 DEFINITIONS (Cont'd)

- GG. Site Boundary - Shall be that line beyond which the land is not owned, leased, or otherwise controlled by TVA.
- HH. Unrestricted Area - Any area at or beyond the SITE BOUNDARY to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the SITE BOUNDARY used for industrial, commercial, institutional, or recreational purposes.
- II. Dose Equivalent I-131 - The DOSE EQUIVALENT I-131 shall be the concentration of I-131 (in $\mu\text{Ci/gm}$) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factor used for this calculation shall be those listed in Table III of TID-14844 "Calculation of Distance Factors for Power and Test Reactor Sites".
- JJ. Gaseous Waste Treatment System - The charcoal adsorber vessels installed on the discharge of the steam jet air ejector to provide delay to a unit's offgas activity prior to release.
- KK. Members of the Public - An individual in a controlled or UNRESTRICTED AREA. However, an individual is not a MEMBER OF THE PUBLIC during any period in which the individual receives an occupational dose (as defined in 10 CFR 20).
- LL. Surveillance - Surveillance Requirements shall be met during the OPERATIONAL CONDITIONS or other conditions specified for individual limiting conditions for operation unless otherwise stated in an individual Surveillance Requirements. Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval. It is not intended that this (extension) provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages.

Performance of a Surveillance Requirement within the specified time interval shall constitute compliance and OPERABILITY requirements for a limiting condition for operation and associated action statements unless otherwise required by these specifications. Surveillance Requirements do not have to be performed on inoperable equipment.

If it is discovered that a surveillance was not performed within its specified frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified frequency, whichever is less. This delay period is permitted to allow performance of the surveillance.

1.0 DEFINITIONS (Cont'd)

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.

When the surveillance is performed within the delay period and the surveillance is not met, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.

MM. Surveillance Requirements for ASME Section XI Pump and Valve Program
- Surveillance Requirements for Inservice Testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

1. Inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55(g) (6) (i).
2. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these technical specifications:

ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice testing activities	Required frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days

3. The provisions of Specification 1.0.LL are applicable to the above required frequencies for performing inservice testing activities.
4. Performance of the above inservice testing activities shall be in addition to other specified surveillance requirements.
5. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any technical specification.
6. The inservice inspection program for piping identified in NRC Generic Letter 88-01 shall be performed in accordance with the staff positions on schedule, methods, personnel, and sample expansion included in this generic letter.



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555-0001

TENNESSEE VALLEY AUTHORITY

DOCKET NO. 50-296

BROWNS FERRY NUCLEAR PLANT, UNIT 3

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 205
License No. DPR-68

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Tennessee Valley Authority (the licensee) dated May 20, 1996, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment and paragraph 2.C.(2) of Facility Operating License No. DPR-68 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 205, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of its date of issuance and shall be implemented within 30 days from the date of issuance.

FOR THE NUCLEAR REGULATORY COMMISSION



Frederick J. Hebdon, Director
Project Directorate II-3
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment: Changes to the Technical
Specifications

Date of Issuance: August 5, 1996



ATTACHMENT TO LICENSE AMENDMENT NO. 205

FACILITY OPERATING LICENSE NO. DPR-68

DOCKET NO. 50-296

Revise the Appendix A Technical Specifications by removing the pages identified below and inserting the enclosed pages. The revised pages are identified by the captioned amendment number and contain marginal lines indicating the area of change.

REMOVE

1.0-11
1.0-12

INSERT

1.0-11
1.0-12



1.0 DEFINITIONS (Cont'd)

- GG. Site Boundary - Shall be that line beyond which the land is not owned, leased, or otherwise controlled by TVA.
- HH. Unrestricted Area - Any area at or beyond the SITE BOUNDARY to which access is not controlled by the licensee for purposes of protection of individuals from exposure to radiation and radioactive materials or any area within the SITE BOUNDARY used for industrial, commercial, institutional, or recreational purposes.
- II. Dose Equivalent I-131 - The DOSE EQUIVALENT I-131 shall be the concentration of I-131 (in $\mu\text{Ci/gm}$) which alone would produce the same thyroid dose as the quantity and isotopic mixture of I-131, I-132, I-133, I-134, and I-135 actually present. The thyroid dose conversion factor used for this calculation shall be those listed in Table III of TID-14844 "Calculation of Distance Factors for Power and Test Reactor Sites".
- JJ. Gaseous Waste Treatment System - The charcoal adsorber vessels installed on the discharge of the steam jet air ejector to provide delay to a unit's offgas activity prior to release.
- KK. Members of the Public - An individual in a controlled or UNRESTRICTED AREA. However, an individual is not a MEMBER OF THE PUBLIC during any period in which the individual receives an occupational dose (as defined in 10 CFR 20).
- LL. Surveillance - Surveillance Requirements shall be met during the OPERATIONAL CONDITIONS or other conditions specified for individual limiting conditions for operation unless otherwise stated in an individual Surveillance Requirements. Each Surveillance Requirement shall be performed within the specified surveillance interval with a maximum allowable extension not to exceed 25 percent of the specified surveillance interval. It is not intended that this (extension) provision be used repeatedly as a convenience to extend surveillance intervals beyond that specified for surveillances that are not performed during refueling outages.

Performance of a Surveillance Requirement within the specified time interval shall constitute compliance and OPERABILITY requirements for a limiting condition for operation and associated action statements unless otherwise required by these specifications. Surveillance Requirements do not have to be performed on inoperable equipment.

If it is discovered that a surveillance was not performed within its specified frequency, then compliance with the requirement to declare the LCO not met may be delayed, from the time of discovery, up to 24 hours or up to the limit of the specified frequency, whichever is less. This delay period is permitted to allow performance of the surveillance.

1.0 DEFINITIONS (Cont'd)

If the surveillance is not performed within the delay period, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.

When the surveillance is performed within the delay period and the surveillance is not met, the LCO must immediately be declared not met, and the applicable condition(s) must be entered.

MM. Surveillance Requirements for ASME Section XI Pump and Valve Program - Surveillance Requirements for Inservice Testing of ASME Code Class 1, 2, and 3 components shall be applicable as follows:

1. Inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g) (6) (i).
2. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these technical specifications:

ASME Boiler and Pressure Vessel Code and applicable Addenda terminology for inservice testing activities	Required frequencies for performing inservice testing activities
Weekly	At least once per 7 days
Monthly	At least once per 31 days
Quarterly or every 3 months	At least once per 92 days
Semiannually or every 6 months	At least once per 184 days
Every 9 months	At least once per 276 days
Yearly or annually	At least once per 366 days

3. The provisions of Specification 1.0.LL are applicable to the above required frequencies for performing inservice testing activities.
4. Performance of the above inservice testing activities shall be in addition to other specified surveillance requirements.
5. Nothing in the ASME Boiler and Pressure Vessel Code shall be construed to supersede the requirements of any technical specification.
6. The inservice inspection program for piping identified in NRC Generic Letter '88-01 shall be performed in accordance with the staff positions on schedule, methods, personnel, and sample expansion included in this generic letter.