

QA Record

SITE ENGINEERING CALCULATIONS

Sheet i

QA RECORD

TITLE: VERIFICATION OF ANCHORAGE FOR PANEL 3-25-31 TO RESOLVE THE OUTLIER IDENTIFIED BY USI A46 EVALUATION (SSEL #39204).				PLANT/UNIT: BFN/3
PREPARING ORGANIZATION SITE ENGINEERING - CIVIL		KEY NOUNS (Consult RIMS DESCRIPTOR LIST) SEISMIC QUAL. EQPT. PANELS		
BRANCH/PROJECT IDENTIFIERS CD-Q3071-960089		Each time these calculations are issued, preparers must ensure that the original (R0) RIMS accession number is filled in. REV (for RIMS use) RIMS accession number		
		R ₀	R14 960807 104	
APPLICABLE DESIGN DOCUMENT(S) BFN-50-C-7100		R ₁	(A)	
		R ₂		
SAR SECTION(S) N/A	UNID SYSTEM(S) 071	R ₃		
REVISION 0	R ₄	R ₅	R ₆	Safety-related? Yes <input checked="" type="checkbox"/> No <input type="checkbox"/>
DCN No. (or indicate Not Applicable) T39817A				Statement of Problem:
Prepared: S. S. HAIDER <i>Syed S. Haider</i>				VERIFY ANCHORAGE ADEQUACY FOR PANEL 3-25-31 TO RESOLVE THE OUTLIER IDENTIFIED BY USI A46 AS NOTED IN SSEL # 39204. <div style="border: 2px solid black; padding: 5px; text-align: center; font-weight: bold; font-size: 1.2em;">ORIGINAL</div> LEGIBILITY EVALUATED and ACCEPTED for issue. <i>JR Glass</i> 8/6/96 Signature Date
Checked: <i>[Signature]</i>				
Reviewed: <i>[Signature]</i>				
Approved: J. VALENTE <i>J. Valente</i>				
Date: 6 Aug 96				
List all pages added by this revision				
List all pages deleted by this revision				
List all pages changed by this revision				
Calculation revision: (A) Entire Calc; (P) Selected Pages				

Abstract

These calculations contain an unverified assumption(s) that must be verified later? Yes No

THIS CALCULATION DOCUMENTS THE ADEQUACY OF ANCHORAGE FOR PANEL 3-25-31 TO RESOLVE THE OUTLIER IDENTIFIED BY USI A46 EVALUATION FOR SSEL # 39204.

9810020183 980925
PDR ADDCK 05000260
P PDR

MICROFILM AND RETURN CALCULATION TO:

cc: RIMS, SL 26 C-K



TVA

Sheet ii

TITLE: VERIFICATION OF ANCHORAGE FOR PANEL 3-25-31 TO RESOLVE THE OUTLIER IDENTIFIED BY USI A46 EVALUATION. REVISION LOG
CD-Q3071-960089

NO.	DESCRIPTION	DATE APPROVED
0	INITIAL ISSUE PER DCN T39817A TOTAL NUMBER OF SHEETS = 19	6 Aug 96




**CALCULATION DESIGN VERIFICATION (INDEPENDENT REVIEW) FORM
(PER NEP-3.1)**

Branch/Project Identifier: CD-Q3071-960089 Revision No. 0

Method of design verification (independent review) used (check method used):

- 1. Design Review X
- 2. Alternate Calculation
- 3. Qualification Test

The referenced calculation was independently reviewed for revision level indicated above and found to be adequate based on accepted sound engineering methods.



Design Verifier
(Independent Reviewer)

7-24-96
Date



Sheet iv of _____

Computed SSH Date 7/22/96

Checked awp Date 7-24-96

CD-03071-960089

TABLE OF CONTENTS

SECTION	DESCRIPTION	PAGE NO.
1.	COVER SHEET	i
2.	REVISION LOG	ii
3.	CALCULATION DESIGN VERIFICATION	iii
4.	TABLE OF CONTENTS	iv
5.0	BODY OF CALCULATION	
	5.1 PURPOSE	1
	5.2 ASSUMPTIONS	2
	5.3 SPECIAL REQUIREMENTS/LIMITING CONDITIONS	2
	5.4 DATA	2
	5.5 REFERENCES	3
	5.6 COMPUTATIONS	4
	5.7 SUMMARY & CONCLUSIONS	7
6.0	ATTACHMENTS	
	A) USI A46 - SEWS	1 - 7



Sheet 1 of _____

Computed SS1+ Date 7/23/96

CD-Q3071-960089

Checked ayp Date 7-24-96

5.1 PURPOSE:

US1 A46 EVALUATION FOR SSEL # 39204 IDENTIFIED THAT THE OVERALL ANCHORAGE SCHEME OF THE PANEL'S PEDESTAL TO THE EMBED PLATE IN THE FLOOR CAN NOT BE VERIFIED. THIS CALCULATION WILL VERIFY THE ADEQUACY OF THE ANCHORAGE OF THE PANEL.



Sheet 2 of Computed SSH Date 7/23/96CD-03071-960089Checked ayp Date 7-26-96**5.2 ASSUMPTIONS:**

THERE ARE NO UNVERIFIED ASSUMPTIONS IN THIS CALCULATION.

5.3 SPECIAL REQUIREMENTS/LIMITING CONDITIONS:

THIS CALCULATION DOES NOT GENERATE ANY SPECIAL REQUIREMENTS OR LIMITING CONDITIONS WHICH LIMIT SYSTEM OR PLANT OPERATION FROM THAT CURRENTLY DOCUMENTED IN THE DESIGN, OR PLACE SPECIAL REQUIREMENTS ON THE PHYSICAL CONFIGURATION THAT ARE GENERALLY OUTSIDE THE STATED PURPOSE OF THE CALCULATION.

5.4 DATA:

1. ATTACHMENT - A



Sheet 3 of _____Computed SSH Date 7/23/96CD-Q3071-960089Checked ep Date 7-24-96**5.5 REFERENCES:**

1. DCN T39817A
2. Drawing 0-45N370
3. Drawing 48N922
4. GENERIC IMPLEMENTATION PROCEDURE FOR SEISMIC VERIFICATION OF NUCLEAR PLANT EQUIPMENT. (RIMS # R92 930730 001)
5. MARS REPORT CEB 88-05-C R1
6. DESIGN CRITERIA BFN-50-C-7100
7. DESIGN CRITERIA BFN-50-C-7105



Sheet 4 of _____Computed SSH Date 7/23/96

CD-Q3071-960089

Checked dup Date 7-24-96

5.6 COMPUTATIONS:

ATTACHMENT-A STATES THAT THE WELD BETWEEN PANEL'S SIL-CHANNEL AND EMBED R. CAN NOT BE VERIFIED, NOR THERE IS ANY DRAWING THAT SHOWS THE PANEL ANCHORAGE DETAIL. ATTACHMENT-A ALSO STATED THAT THE WELD IN QUESTION IS VISIBLE IN PANEL 2-25-31, HENCE UNIT-2 PANEL DOES NOT HAVE AN OUTLIER. UPON VISUAL INSPECTION, IT APPEARS THAT PANEL 25-31 IN ALL 3 UNITS HAVE SIMILAR ANCHORAGE SCHEME.

THE PREPARER AND REVIEWER OF THIS CALCULATION, WITH THE HELP OF A PAINTER SCRAPED THE PAINT AROUND THE PANEL BASE AND DISCOVERED THAT ON THE EAST SIDE OF THE PANEL, THERE IS INTERMITTENT WELD SIMILAR TO UNIT-2 PANEL. ON THE WEST SIDE OF THE PANEL, THE OUTER EDGE OF THE EMB. R. IS ABOUT $7/8$ " INSIDE THE PANEL PEDESTAL. HOWEVER, ON THE SOUTH WEST CORNER THERE IS ABOUT 3" LONG WELD. ALL WELDS ARE ESTIMATED AS $3/16$ " FILLET. BY COMPARISON TO UNIT-2 PANEL, THE WELD ON THE EAST SIDE IS ESTIMATED AS 2" @ 12."



Sheet 5 of _____Computed SSH Date 7/23/96

CD-Q3071-960089

Checked ovp Date 7-24-96

COMPUTATIONS (CONT'D.):

FOR SIMPLICITY OF CALL, CONSERVATIVELY CONSIDER BASE OF PANEL AS THAT OF PANEL SIZE, I.E. 30" x 96".

PER ATTACH. A, WEIGHT OF PANEL = 1.5 X HOUSING WEIGHT; THICKNESS OF PANEL = 1/8", THICKNESS OF DOORS = 3/32".

CONSERVATIVELY, CONSIDER WHOLE PANEL AS 1/8" THICK.

∴ HOUSING WEIGHT =

$$[(2 \times 30 \times 96) + (2 \times 96 \times 96) + (30 \times 96)] \left(\frac{1}{8}\right) (0.284)$$

$$= 908 \text{ LBS.}$$

∴ PANEL + CONTENT WT = 1.5 X 908 = 1362 LBS.

SAY 1400 LBS.



CRITICAL CASE : FORCE TOWARDS EAST

CONSERVATIVELY CONSIDER C.G. OF PANEL AS SHOWN ON SKETCH AT RIGHT.


PER REF. 5, EL. 621'-3", 5% DAMPING, PEAK SSE ACCEL. COEFF. W/AMPL. FACTOR OF 1.5 ⇒

$$g_H = 1.5 \times 2 \times 1.0731 = 3.22g$$

$$g_V = 1.5 \times 2 \times 0.3285 = 0.99 \approx 1.0 \rightarrow \text{CANCELS OUT W/ GRAVITY.}$$







Sheet 7 of _____Computed SSH Date 7-23-96CD-Q3071-960089Checked ayp Date 7-24-96

COMPUTATIONS (CONT'D.):

$$\text{CAPACITY OF } \frac{3}{16} \text{ FILLET WELD} = \frac{3}{16} \times 0.4 \times 36 = 2.7 \text{ k}$$

$$\text{I.R.} = 2.95 / 2.7 = 1.09 < 10\% \text{ OVER DESIGN ALLOWABLE.}$$

IT IS ACCEPTABLE BASED ON SEVERAL CONSERVATIVE ASSUMPTIONS MADE IN THE CALC.



Sheet 8 of _____

Computed SSH Date 7-23-96

CD-Q3071-960089

Checked QJP Date 7-24-96

5.7 SUMMARY AND CONCLUSIONS:

THIS CALCULATION DOCUMENTS THE ADEQUACY OF THE ANCHORAGE OF THE PANEL TO RESOLVE THE OUTLIER IDENTIFIED BY USI A46 EVALUATION FOR SSEL # 39204.



ATTACHMENT: _____

SHEET	1	OF	...
FOR INFORMATION ONLY			
CD-03071-960089			
BY	SSH	DATE	7-23-96

INTENT

SSEL Line No. 39204

Status Y N

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 1 of 2

Equip. ID No. 3-PNLA-925-0031 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description: LOCAL PANEL 25-31

Location: Bldg. U3 RB Floor El. 621'-2" Room, Row/Col. Q,R20

Manufacturer, Model, Etc. (optional but recommended) G.I.

SEISMIC CAPACITY VS DEMAND

- | | |
|--|---|
| 1. Elevation where equipment receives seismic input | |
| 2. Elevation of seismic input below about 40' from grade | Y <input checked="" type="checkbox"/> N U (Grade @ 50') |
| 3. Equipment has fundamental frequency above about 8 Hz | <input checked="" type="checkbox"/> N U N/A (1), (4) |
| 4. Capacity based on: | |
| Existing Documentation | DOC |
| Bounding Spectrum | BS |
| 1.5 x Bounding Spectrum | <input checked="" type="checkbox"/> BS |
| GERS | GERS |
| 5. Demand based on: | |
| Ground Response Spectrum | GRS |
| 1.5 x Ground Response Spectrum | AGS |
| Conserv. Des. In-Str. Resp. Spec. | CRS |
| Realistic M-Ctr. In-Str. Resp. Spec. | <input checked="" type="checkbox"/> RS |

Does capacity exceed demand? (Indicate at right (*) and in COMMENTS if a special exception to enveloping of seismic demand spectrum is invoked per Section 4.2 of the GIP.) N U (2)*

CAVEATS - BOUNDING SPECTRUM (Identify with an asterisk (*) those caveats which are met by intent without meeting the specific wording of the caveat rule and explain the reason for this conclusion in the COMMENTS section below)

- | | |
|--|--|
| 1. Equipment is included in earthquake experience equipment class | <input checked="" type="checkbox"/> N U N/A |
| 2. No computers or programmable controllers | <input checked="" type="checkbox"/> N U N/A |
| 3. No strip chart recorders | <input checked="" type="checkbox"/> N U N/A (2), (4) |
| 4. Steel frame and sheet metal structurally adequate | <input checked="" type="checkbox"/> N U N/A (4), (8) |
| 5. Adjacent cabinets or panels which are close enough to impact, or sections of multi-bay cabinets or panels, are bolted together if they contain essential relays | <input checked="" type="checkbox"/> N U N/A (10) |
| 6. Drawers and equipment on slides restrained from falling out | <input checked="" type="checkbox"/> N U N/A (6) |
| 7. All doors secured by latch or fastener <i>door latch loose, judged ok</i> | <input checked="" type="checkbox"/> N U N/A |
| 8. Attached lines have adequate flexibility | <input checked="" type="checkbox"/> N U N/A (7) |
| 9. Anchorage adequate (See checklist below for details) | Y N <input checked="" type="checkbox"/> N/A (12) |
| 10. Relays mounted on equipment evaluated <i>AP = 4.5</i> | <input checked="" type="checkbox"/> N U N/A (1), (8) |
| 11. Have you looked for and found no other adverse concerns? | <input checked="" type="checkbox"/> N U N/A |
| the intent of all the caveats met for Bounding Spectrum? | Y N <input checked="" type="checkbox"/> N/A (12) |

ANCHORAGE

- | | |
|--|--|
| 1. Appropriate equipment characteristics determined (mass, CG, natural freq., damping, center of rotation) | <input checked="" type="checkbox"/> N U N/A (7), (7) |
| 2. Type of anchorage covered by GIP <i>welded bars to sill. sill to concrete (unknown)</i> | Y N <input checked="" type="checkbox"/> N/A (12) |
| 3. Sizes and locations of anchors determined | Y N <input checked="" type="checkbox"/> N/A (12) |



ATTACHMENT: A

SHEET 2 OF
FOR INFORMATION ONLY
CD-Q 3071-960089
BY SSH DATE 7-23-96

SSEL Line No. 39204

SCREENING EVALUATION WORK SHEET (SEWS)

Sheet 2 of 24

Equip. ID No. 3-PNLA-925-0031 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description LOCAL PANEL 25-31

ANCHORAGE (Cont'd)

- 4. Anchorage installation adequate, e.g., weld quality and length, nuts and washers, expansion anchor tightness visible with 0 panel to site intervention N U N/A
 - 5. Factors affecting anchorage capacity or margin of safety considered: embedment length, anchor spacing, free-edge distance, concrete strength/condition, and concrete cracking N U N/A
 - 6. For bolted anchorages, gap under base less than 1/4-inch Y N U N/A
 - 7. Factors affecting essential relays considered: gap under base, capacity reduction for expansion anchors N U N/A
 - 8. Base has adequate stiffness and effect of prying action on anchors considered N U N/A
 - 9. Strength of equipment base and load path to CG adequate N U N/A
 - 10. Embedded steel, grout pad or large concrete pad adequacy evaluated Y N N/A (12)
- Are anchorage requirements met? Y N (12)

INTERACTION EFFECTS

- 1. Soft targets free from impact by nearby equipment or structures N U N/A (5), (11)
 - 2. If equipment contains sensitive relays, equipment free from all impact by nearby equipment or structures N U N/A
 - 3. Attached lines have adequate flexibility N U N/A (7)
 - 4. Overhead equipment or distribution systems are not likely to collapse N U N/A
 - 5. Have you looked for and found no other adverse concerns? N U N/A
- Is equipment free of interaction effects? N U

IS EQUIPMENT SEISMICALLY ADEQUATE?

N U (12)

COMMENTS

- For notes 1 & 2 see notes 7 & 8 on SEW for 3-PNLA-925-0031 (SSEL 9074).
- See pages 3 & 4 for notes 3-12.

Evaluated by: Fangji Boir
John O. Dizon

Date: 9/2/95
9/16/95



ATTACHMENT: A

EQE INTERNATIONAL

SHEET <u>3</u> OF <u> </u>
FOR INFORMATION ONLY
<u>CD-Q3071-960089</u>
BY <u>SSH</u> DATE <u>7-23-96</u>

SHEET NO. 341

JOB NO. 50147 JOB TVA/BFNP A-46/INSTR. BY SSH DATE 7-23-96
 CALC. NO. N/A SUBJECT Attch. to SELV for ... CHK'D SSH DATE 7-23-96

SSEL No. : 39204

Component ID: 3-PNLA-925-003

- 3) Panel almost empty. Use 1.5 x housing w/ for unbalanced interaction
- 4) size : 96" x 30" x 10" , door thickness : 3/8" panel thickness : 1/2"
- 5) Internal fluorescent lights are in the back of the panel no potential interaction. ok
- 6) Equipment on slides (strip charts & recorders) have adequate support and locking mechanism. ok
- 7) 1" of conduit @ top has adequate finability.
- 8) Front face of the panel when the equipment (e.g., relays) are mounted is stiffened w/ 1/4" x 2" w. or d. bar slats. Typical in-cabinet amplification factor for this type of panel is 4.5
- 9) stripcharts are in bay 2 and are cantilevered. They are properly mounted. Their frequency may not be greater than 8 Hz. However, since bay 3 is independent of bay 2 which has relays, the effect of stripcharts on the cabinet sensitivity is insignificant. Also, the stripcharts are low in the cabinet and its effect on the overall frequency of the cabinet is minimal/insignificant. ok
- 10) Bays 1 & 2 are bolted together.
- 11) Miscellaneous items near or on empty dinette covers, garbage can, SLC Drum w/ locked wheels; are 5" away from the panel potential interaction is judged not credible. ok



ATTACHMENT: A



EQE INTERNATIONAL

SHEET 4 OF 6
 FOR INFORMATION ONLY
CD-Q3071-960089
 BY SSH DATE 7-23-96


SHEET NO. 4 of 6

JOB NO. 50147 JOB TVA/BFPN A-46 / IPBEE BY FJai DATE 7.16.98

CALC. NO. N/A SUBJECT Panel to SEW's for SSEL 9074 - 9075 - 9076 (SSEL 9074) CHK'D J.O.P. DATE 9/16/98

SSEL: 39204 (cont'd)

12) This panel is similar to panel 2-905-3 (SSEL 9074), except that it is not clear as to how the interior concrete pedestal, that this panel is sitting on, is connected to the floor (@ EL. 62'). [The Unit 2 panel's pedestal has a 1.5" channel that is welded to an embed plate.] The connection of the panel to the metal framing around the pedestal (sill channel) is adequate by comparison to panel 2-905-3. Since the overall anchorage scheme of the panel's pedestal to the concrete floor or the embed plate in the floor can not be verified, this panel is called an outlier SSEL-39204 w.r.t. its anchorage.



dotted lines indicate assumed potential configuration which can not be verified.
 (If it could be verified that the pedestal is anchored to the floor by dowels/rebars then the anchorage config. of this panel is adequate.)

Ellevation
 (See SEW's for SSEL 9074, for plan of the bay anchorage to the pedestal)



ATTACHMENT: A

SHEET <u>5</u> OF <u> </u>
FOR INFORMATION ONLY.
<u>ED-23071-960089</u>
BY <u>SSH</u> DATE <u>7-23-96</u>

SSEL Line No. 39204

Status Y N

Sheet 1 of 1

IPEEE SUPPLEMENTAL SCREENING EVALUATION WORKSHEET

Equip. ID No. 3-PNLA-925-0031 Equip. Class 20 - Instr. & Control Panels & Cabinets

Equipment Description LOCAL PANEL 25-31

RELAY WALKDOWN

1. Does spot check of essential relays indicate relays present and properly mounted? Y N U N/A

2. Are essential relays required to function during earthquake screened out? Y N U N/A

If no, attach list of relays with locations in cabinet and general dimensions, thicknesses and details of mounting plates that support relays for later analysis.

3. No other relay concerns? Y N N/A

Requirements for relays satisfied? Y N (1)

SYSTEM INTERACTION EFFECTS

1. No potential sources could flood or spill onto cabinet? Y N U N/A

DESCRIBE POTENTIAL PROBLEMS INDICATED BY NO OR UNSATISFACTORY (Use additional sheets if necessary)

1) Anchorage of the 6" concrete pedestal to the floor is unknown (see outline OSVC-39204)

EQUIPMENT FREE OF NEED FOR FURTHER INVESTIGATION, EXCLUDING RELAY CHATTER? YES NO (see note 1 above)


IS EQUIPMENT FREE OF NEED FOR FURTHER RELAY CHATTER INVESTIGATION? YES NO

Evaluated by: Fazili Bey

Date: 9/16/95

Evaluated by: J. A. D...

Date: 9/16/95



ATTACHMENT: A

SHEET <u>6</u> OF _____
FOR INFORMATION ONLY
<u>CD-Q3071-96089</u>
BY <u>CSH</u> DATE <u>7-23-96</u>

Sheet 1 of 2

SSEL Line No. 39204

OSVS-39204

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

1. OUTLIER IDENTIFICATION, DESCRIPTION, AND LOCATION

Equipment ID Number 3-PILA-925-003: Equipment Class 20-Instr. & control panels

Equipment Location: Bldg. RA3 Floor Elevation 621'-3"

Room or Row/Column Q, R20 Base Elevation 621'-8"

Equipment Description Local panel 25-31. RCIC Backup Control Panel

2. OUTLIER ISSUE DEFINITION


a. Identify all the screening guidelines which are not met. (Check more than one if several guidelines could not be satisfied.)

<u>Mechanical and Electrical Equipment</u>	_____	<u>Tanks and Heat Exchangers</u>	_____
Capacity vs. Demand	_____	Shell Buckling*	_____
Caveats	_____	Anchor Bolts and Embedment	_____
Anchorage	_____	Anchorage Connections	_____
Seismic Interaction	<input checked="" type="checkbox"/>	Flexibility of Attached Piping*	_____
Other	_____	Other	_____
<u>Essential Relays</u>	_____	<u>Cable and Conduit Raceways</u>	_____
Capacity vs. Demand	_____	Inclusion Rules	_____
Mounting, Type, Location	_____	Other Seismic Performance Concerns	_____
Other	_____	Limited Analytical Review	_____
		Other	_____

* Shell buckling and flexibility of attached piping only apply to large, flat-bottom, vertical tanks.

b. Describe all the reasons for the outlier (i.e., if all the listed outlier issues were resolved, then the signatories would consider this item of equipment to be verified for seismic adequacy):

The anchorage of the 5" high concrete pedestal
under this panel to the concrete floor can
not be verified.



Sheet 2 of ATTACHMENT: A

SSEL Line No. 39204

OUTLIER SEISMIC VERIFICATION SHEET (OSVS)

Equipment ID Number 3-PNLA-425-003

SHEET <u>7</u> OF <u>7</u>
FOR INFORMATION ONLY
<u>CD-Q3071-960089</u>
BY <u>CSH</u> DATE <u>7-23-96</u>

3. PROPOSED METHOD OF OUTLIER RESOLUTION (OPTIONAL)

a. Define proposed method(s) for resolving outlier.

- Provide adequate weld to connect the perimeter "sill channel" to the "concrete" diaphragm.
- or alternatively determine the engineering capacity of the pedestal to concrete through an extensive drawing search.

b. Provide information needed to implement proposed method(s) for resolving outlier (e.g., estimate of fundamental frequency).

NA

4. CERTIFICATION:

The information on this OSVS is, to the best of our knowledge and belief, correct and accurate, and resolution of the outlier issues listed on the previous page will satisfy the requirements for this item of equipment to be verified for seismic adequacy:

Approved by: (For Equipment Classes #0 - #22, all the Seismic Capability Engineers on the Seismic Review Team (SRT) should sign; there should be at least two on the SRT. One signatory should be a licensed professional engineer. For Relays, the Lead Relay Reviewer should sign.)

FARZIN R BEIGI
 Print or Type Name

JOHN O. DIZON, PE
 Print or Type Name

 Print or Type Name

Farzi R. Bai
 Signature

John O. Dizon
 Signature

 Signature

7-16-95
 Date

9/16/95
 Date

 Date

