

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow < 10% rated core flow:

THERMAL POWER shall be \leq 25% RTP.

2.1.1.2 With the reactor steam dome pressure \geq 785 psig and core flow \geq 10% rated core flow:

MCPR shall be \geq 1.10 for two recirculation loop operation,

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be \leq 1325 psig.

or \geq 1.12 for single loop operation.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

2.2.1 Restore compliance with all SLs; and

2.2.2 Insert all insertable control rods.

NO CHANGE

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

| FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | CONDITIONS REFERENCED FROM REQUIRED ACTION D.1 | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|-----------------------------------|--|--|-----------------------------------|
| 1. Intermediate Range Monitors | | | | | |
| a. Neutron Flux - High | 2 | 3 | G | SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.5 SR 3.3.1.1.6 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| | 5(a) | 3 | H | SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| b. Inop | 2 | 3 | G | SR 3.3.1.1.3 SR 3.3.1.1.14 | NA |
| | 5(a) | 3 | H | SR 3.3.1.1.4 SR 3.3.1.1.14 | NA |
| 2. Average Power Range Monitors | | | | | |
| a. Neutron Flux - High, Setdown | 2 | 2 | G | SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 15% RTP |
| b. Flow Biased Simulated Thermal Power - High | 1 | 2 | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.11 SR 3.3.1.1.14 | ≤ 0.58 W + 62% RTP and ≤ 120% RTP |
| c. Neutron Flux - High | 1 | 2 | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120% RTP |

(continued)

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(b) [0.58 W + 62% - 0.58 ΔW] RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating".

no change

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT A

APPLICABILITY: MODES 1 and 2.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|---|
| A. Reactor operation with core flow as a function of THERMAL POWER inside of Region I of Figure 3.4.1-1. | A.1 Place mode switch in the shutdown position. | Immediately |
| B. Reactor operation with core flow as a function of THERMAL POWER inside of Region II of Figure 3.4.1-1. | B.1 Place mode switch in the shutdown position. | Immediately upon discovery of thermal hydraulic instability |
| | <u>AND</u> B.2 Exit Region II. | 2 hours |
| C. One recirculation loop not in operation. | C.1 Restore two recirculation loops to operation. | 12 hours |

(continued)

Substitute Insert B

NO CHANGE

1
2
3



Insert A

OR

One recirculation loop may be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1 and provided the following limits are applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Flow Biased Simulated Thermal Power - High), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation;
- d. LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 1.a (Rod Block Monitor Upscale (Flow Biased)), Allowable Value of Table 3.3.2.1-1 is reset for single loop operation.

Insert B

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| C. Requirements of the LCO not met for reasons other than A or B. | C.1 Satisfy the requirements of the LCO. | 24 hours |


NO CHANGE

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

LOCA analyses are then performed to ensure that the above determined APLHGR limits are adequate to meet the PCT and maximum oxidation limits of 10 CFR 50.46. The analysis is performed using calculational models that are consistent with the requirements of 10 CFR 50, Appendix K. A complete discussion of the analysis code is provided in Reference 5. The PCT following a postulated LOCA is a function of the average heat generation rate of all the rods of a fuel assembly at any axial location and is not strongly influenced by the rod to rod power distribution within an assembly. The APLHGR limits specified are equivalent to the LHGR of the highest powered fuel rod assumed in the LOCA analysis divided by its local peaking factor. A conservative multiplier is applied to the LHGR assumed in the LOCA analysis to account for the uncertainty associated with the measurement of the APLHGR.

INSERT
C
as new H



The APLHGR satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

The APLHGR limits specified in the COLR are the result of the fuel design, DBA, and transient analyses.

INSERT D



no change

(continued)

Insert C

For single recirculation loop operation, an APLHGR multiplier is applied to the APLHGR limit (Ref. 5 and Ref. 7). The multiplier is documented in the COLR. This multiplier is due to the conservative analysis assumption of an earlier departure from nucleate boiling with one recirculation loop available, resulting in a more severe heatup during a LOCA.

Insert D

With only one recirculation loop in operation, in conformance with the requirements of LCO 3.4.1, "Recirculation Loops Operating," the limit is determined by multiplying the exposure dependent limit by an APLHGR correction factor (Ref. 5 and Ref. 7). ←

Cycle specific APLHGR correction factors for single recirculation loop operation are documented in the COLR.

BASES (continued)

REFERENCES

1. NEDE-24011-P-A-13 "General Electric Standard Application for Reactor Fuel," August 1996.
2. FSAR, Chapter 3.
3. FSAR, Chapter 14.
4. FSAR, Appendix N.
5. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," Revision 2, February 1996. 2 December 1997
6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.

DIS-100
REVISION

7. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

no change

BASES (continued)

APPLICABLE
SAFETY ANALYSES

The analytical methods and assumptions used in evaluating the abnormal operational transients to establish the operating limit MCPR are presented in References 2, 3, 4, and 5. To ensure that the MCPR SL is not exceeded during any transient event that occurs with moderate frequency, limiting transients have been analyzed to determine the largest reduction in critical power ratio (CPR). The types of transients evaluated are loss of flow, increase in pressure and power, positive reactivity insertion, and coolant temperature decrease. The limiting transient yields the largest change in CPR (Δ CPR). When the largest Δ CPR is added to the MCPR SL, the required operating limit MCPR is obtained.

Flow dependent correction factor for MCPR limits are determined by steady state thermal hydraulic methods with key physics response inputs benchmarked using the three dimensional BWR simulator code (Ref. 6) to analyze slow flow runout transients. The flow dependent correction factor is dependent on the maximum core flow limiter setting in the Recirculation Flow Control System.

The MCPR satisfies Criterion 2 of the NRC Policy Statement (Ref. 7).

LCO

The MCPR operating limits specified in the COLR are the result of the Design Basis Accident (DBA) and transient analysis.

no change

(continued)



BASES

SURVEILLANCE
REQUIREMENTS
(continued)

SR 3.2.2.2

Because the transient analysis takes credit for conservatism in the scram speed performance, it must be demonstrated that the specific scram speed distribution is consistent with that used in the transient analysis. SR 3.2.2.2 determines the value of τ , which is a measure of the actual scram speed distribution compared with the assumed distribution. The MCPR operating limit is then determined based on an interpolation between the applicable limits for Option A (scram times of LCO 3.1.4, "Control Rod Scram Times") and Option B (realistic scram times) analyses. The parameter τ must be determined once within 72 hours after each set of scram time tests required by SR 3.1.4.1 and SR 3.1.4.2 because the effective scram speed distribution may change during the cycle. The 72 hour Completion Time is acceptable due to the relatively minor changes in τ expected during the fuel cycle.

REFERENCES

1. NUREG-0562, "Fuel Rod Failure As a Consequence of Departure from Nucleate Boiling or Dryout," June 1979.
 2. NEDE-24011-P-A-13, "General Electric Standard Application for Reactor Fuel," August 1996.
 3. FSAR, Chapter 3.
 4. FSAR, Chapter 14.
 5. FSAR, Appendix N.
 6. NEDO-30130-A, "Steady State Nuclear Methods," May 1985.
 7. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
-

8. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.



BASES

APPLICABLE
SAFETY ANALYSES
(continued)

INSERT
E
TWO NEW
IPs

Safety analyses performed for FSAR Chapter 14 implicitly assume core conditions are stable. However, at the high power/low flow corner of the power/flow map, an increased probability for limit cycle oscillations exists (Ref. 3) depending on combinations of operating conditions (e.g., power shape, bundle power, and bundle flow). Generic evaluations indicate that when regional power oscillations become detectable on the APRMs, the safety margin may be insufficient under some operating conditions to ensure actions taken to respond to the APRMs signals would prevent violation of the MCPR Safety Limit (Ref. 4). NRC Generic Letter 86-02 (Ref. 5) addressed stability calculation methodology and stated that due to uncertainties, 10 CFR 50, Appendix A, General Design Criteria (GDC) 10 and 12 could not be met using analytic procedures on a BWR 4 design. However, Reference 5 concluded that operating limitations which provide for the detection (by monitoring neutron flux noise levels) and suppression of flux oscillations in operating regions of potential instability consistent with the recommendations of Reference 3 are acceptable to demonstrate compliance with GDC 10 and 12. The NRC concluded that regions of potential instability could occur at calculated decay ratios of 0.8 or greater by the General Electric methodology.

Stability tests at operating BWRs were reviewed to determine a generic region of the power/flow map in which surveillance of neutron flux noise levels should be performed. A conservative decay ratio was chosen as the basis for determining the generic region for surveillance to account for the plant to plant variability of decay ratio with core and fuel designs. This decay ratio also helps ensure sufficient margin to an instability occurrence is maintained. The generic region has been

no change

(continued)

Insert E

Plant specific LOCA analyses have been performed assuming only one operating recirculation loop. These analyses have demonstrated that, in the event of a LOCA caused by a pipe break in the operating recirculation loop, the Emergency Core Cooling System response will provide adequate core cooling, provided the APLHGR requirements are modified accordingly (Refs. 7 and 8).

The transient analyses of Chapter 14 of the FSAR have also been performed for single recirculation loop operation (Ref. 7) and demonstrate sufficient flow coastdown characteristics to maintain fuel thermal margins during the abnormal operational transients analyzed provided the MCPR requirements are modified. During single recirculation loop operation, modification to the Reactor Protection System (RPS) average power range monitor (APRM) instrument and RBM setpoints is also required to account for the different relationships between recirculation drive flow and reactor core flow. The APLHGR and MCPR setpoints for single loop operation are specified in the COLR. The APRM Flow Biased Simulated Thermal Power-High setpoint is in LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation" and the RBM Flow Biased Upscale setpoint is in the COLR as referenced by LCO 3.3.2.1, "Control Rod Block Instrumentation."

NO CHANGE

BASES

APPLICABLE SAFETY ANALYSES
(continued)

determined to be bounded by the 80% rod line and the 45% core flow line. BFN conservatively implements this generic region with the "Operation Not Permitted" Region and Regions I and II of Figure 3.4.1-1. This conforms to Reference 3 recommendations. Operation is permitted in Region II provided neutron flux noise levels are verified to be within limits. The reactor mode switch must be placed in the shutdown position (an immediate scram is required) if Region I is entered.

Recirculation loops operating satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

Two recirculation loops are required to be in operation with their flows matched within the limits specified in SR 3.4.1.1 to ensure that during a LOCA caused by a break of the piping of one recirculation loop the assumptions of the LOCA analysis are satisfied. With the limits specified in SR 3.4.1.1 not met, the recirculation loop with the lower flow must be considered not in operation. In addition, the core flow expressed as a function of THERMAL POWER must be outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT
F

APPLICABILITY

In MODES 1 and 2, requirements for operation of the Reactor Coolant Recirculation System are necessary since there is considerable energy in the reactor core and the limiting design basis transients and accidents are assumed to occur.

In MODES 3, 4, and 5, the consequences of an accident are reduced and the coastdown characteristics of the recirculation loops are not important.

(continued)

BFN-UNIT 1

NO
CHANGE

B 3.4-5

Revision 0

Insert F

With only one recirculation loop in operation, modifications to the required APLHGR Limits (LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)"), MCPR limits (LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)"), APRM Flow Biased Simulated Thermal Power-High Setpoint (LCO 3.3.1.1), and RBM Flow Biased Upscale Setpoint (LCO 3.3.2.1) may be applied to allow continued operation consistent with the assumptions of References 7 and 8.

No Change

BASES

ACTIONS —

B.1 and B.2 (continued)

1. A sustained increase in APRM and/or LPRM peak-to-peak signal noise level, reaching two or more times its initial level at reduced core flow conditions. Any noticeable increase in noise level warrants closer monitoring of the LPRM signals.

The increased noise occurs with a characteristic period of less than 3 seconds.

2. LPRM and or APRM upscale and/or downscale annunciators that alarm with a characteristic period of less than 3 seconds.

C.1

With the requirements of the LCO not met, the recirculation loops must be restored to operation with matched flows within ~~12~~ hours. A recirculation loop is considered not in operation when the pump in that loop is idle or when the mismatch between total jet pump flows of the two loops is greater than required limits. The loop with the lower flow must be considered not in operation. Should a LOCA occur with one recirculation loop not in operation, the core flow coastdown and resultant core response may not be bounded by the LOCA analyses. Therefore, only a limited time is allowed to restore the inoperable loop to operating status.

24

The ~~12~~ hour Completion Time is based on the low probability of an accident occurring during this time period, on a reasonable time to complete the Required Action, and on frequent core monitoring by operators allowing abrupt changes in core flow conditions to be quickly detected.

INSERT G
as new P

(continued)

NO CHANGE

Insert G

Alternatively, if the single loop requirements of the LCO are applied to the operating limits and RPS setpoints, operation with only one recirculation loop would satisfy the requirements of the LCO and the initial conditions of the accident sequence.

NO CHANGE



BASES

SURVEILLANCE
REQUIREMENTS

(continued)

SR 3.4.1.2

This SR ensures the reactor THERMAL POWER and core flow are within appropriate parameter limits to prevent uncontrolled power oscillations. At low recirculation flows and high reactor power, the reactor exhibits increased susceptibility to thermal hydraulic instability. Figure 3.4.1-1 is based on guidance provided in Reference 3, which is used to respond to operation in these conditions. Performance immediately after any increase of more than 5% RTP while initial core flow is < 45% of rated and immediately after any decrease of more than 10% rated core flow while initial thermal power is > 40% of rated is adequate to detect power oscillations that could lead to thermal hydraulic instability.

REFERENCES

1. FSAR, Section 14.6.3.
 2. FSAR, Section 4.3.5.
 3. GE Service Information Letter No. 380, "BWR Core Thermal Hydraulic Stability," Revision 1, February 10, 1984.
 4. NRC Bulletin 88-07, "Power Oscillations in Boiling Water Reactors (BWRs)," Supplement 1, December 30, 1988.
 5. NRC Generic Letter 86-02, "Technical Resolution of Generic Issue B-19, Thermal Hydraulic Stability," January 22, 1986.
 6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
-

7. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.
8. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," Revision ² February 1996. ² December 1997

Reference
change
to
latest
revision

BFN-UNIT 1

B 3.4-10

Revision 0



BASES (continued)

SURVEILLANCE
REQUIREMENTS

SR 3.4.2.1

This SR is designed to detect significant degradation in jet pump performance that precedes jet pump failure (Ref. 2). This SR is required to be performed only when the loop has forced recirculation flow since surveillance checks and measurements can only be performed during jet pump operation. The jet pump failure of concern is a complete mixer displacement due to jet pump beam failure. Jet pump plugging is also of concern since it adds flow resistance to the recirculation loop. Significant degradation is indicated if the specified criteria confirm unacceptable deviations from established patterns or relationships. The allowable deviations from the established patterns have been developed based on the variations experienced at plants during normal operation and with jet pump assembly failures (Refs. 2 and 3). Each recirculation loop must satisfy one of the performance criteria provided. Since refueling activities (fuel assembly replacement or shuffle, as well as any modifications to fuel support orifice size or core plate bypass flow) can affect the relationship between core flow, jet pump flow, and recirculation loop flow, these relationships may need to be re-established each cycle. During the initial weeks of operation under such conditions, while baselining new "established patterns," engineering judgment of the daily surveillance results is used to detect significant abnormalities which could indicate a jet pump failure.

The recirculation pump speed operating characteristics (pump flow and loop flow versus pump speed) are determined by the flow resistance from the loop suction through the jet pump nozzles. A change in the relationship indicates a plug, flow restriction, loss in pump hydraulic performance, leakage, or new flow path between the recirculation pump discharge and jet pump nozzle. For this criterion, the pump flow and loop flow versus pump speed relationship must be verified.

Similarly, initial entry into extended single loop operation may also require establishment of these relationships.

(continued)

NO CHANGE

Unit 2 TS

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow < 10% rated core flow:

THERMAL POWER shall be \leq 25% RTP.

2.1.1.2 With the reactor steam dome pressure \geq 785 psig and core flow \geq 10% rated core flow:

MCPR shall be \geq 1.10 for two recirculation loop operation

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be \leq 1325 psig.

or \geq 1.12
for single
loop operation.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

2.2.1 Restore compliance with all SLs; and

2.2.2 Insert all insertable control rods.

NO CHANGE

EXISTING
TS PAGE

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

| FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | CONDITIONS REFERENCED FROM REQUIRED ACTION D.1 | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|-----------------------------------|--|---|-----------------------------------|
| 1. Intermediate Range Monitors | | | | | |
| a. Neutron Flux - High | 2 | 3 | G | SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.5 SR 3.3.1.1.6 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| | 5(a) | 3 | H | SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| b. Inop | 2 | 3 | G | SR 3.3.1.1.3 SR 3.3.1.1.14 | NA |
| | 5(a) | 3 | H | SR 3.3.1.1.4 SR 3.3.1.1.14 | NA |
| 2. Average Power Range Monitors | | | | | |
| a. Neutron Flux - High, (Setdown) | 2 | 3(b) | G | SR 3.3.1.1.1 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 15% RTP |
| b. Flow Biased Simulated Thermal Power - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 0.66 W + 71% RTP and ≤ 120% RTP |
| c. Neutron Flux - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 120% RTP |

(continued)

- (a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.
- (b) Each APRM channel provides inputs to both trip systems.

EQUATION CHANGE DUE TO PRNM ARTS MELL

(c) $[0.66 W + 71\% - 0.66 \Delta W]$ RTP when reset for single loop operation per LCO 3.4.1, "Recirculation Loops Operating".



Power Operator
Approved Page

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

| -FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | CONDITIONS REFERENCED FROM REQUIRED ACTION D.1 | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|-----------------------------------|--|---|---------------------------------------|
| 1. Intermediate Range Monitors | | | | | |
| a. Neutron Flux - High | 2 | 3 | G | SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.5 SR 3.3.1.1.8 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| | 5(a) | 3 | H | SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| b. Inop | 2 | 3 | G | SR 3.3.1.1.3 SR 3.3.1.1.14 | NA |
| | 5(b) | 3 | H | SR 3.3.1.1.4 SR 3.3.1.1.14 | NA |
| 2. Average Power Range Monitors | | | | | |
| a. Neutron Flux - High, (Setdown) | 2 | 3(b) | G | SR 3.3.1.1.1 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 15% RTP |
| b. Flow Biased Simulated Thermal Power - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 0.66 W + 66% RTP and ≤ 120% RTP (c) |
| c. Neutron Flux - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 120% RTP |

(continued)

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(b) Each APRM channel provides inputs to both trip systems.

(c) $[-.66W + 66\% - .66 \Delta W]$ RTP when reset
for single loop operation
per LCO 3.4.1, "Recirculation
Loops Operating"
3.3-7 Amendment No. 254

BFN-UNIT 2

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT A

APPLICABILITY: MODES 1 and 2.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|---|
| A. Reactor operation with core flow as a function of THERMAL POWER inside of Region I of Figure 3.4.1-1. | A.1 Place mode switch in the shutdown position. | Immediately |
| B. Reactor operation with core flow as a function of THERMAL POWER inside of Region II of Figure 3.4.1-1. | B.1 Place mode switch in the shutdown position. | Immediately upon discovery of thermal hydraulic instability |
| | <u>AND</u> B.2 Exit Region II. | 2 hours |
| C. One recirculation loop not in operation. | C.1 Restore two recirculation loops to operation. | 12 hours |

(continued)

substitute insert B

NO CHANGE

Insert A

OR

One recirculation loop may be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1 and provided the following limits are applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Flow Biased Simulated Thermal Power - High), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation;
- d. LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 1.a (Rod Block Monitor Upscale (Flow Biased)), Allowable Value of Table 3.3.2.1-1 is reset for single loop operation.

DELETED
Due
TO
PRNM/ARTS
implementation

Insert B

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| C. Requirements of the LCO not met for reasons other than A or B. | C.1 Satisfy the requirements of the LCO. | 24 hours |



BASES

APPLICABLE SAFETY ANALYSES
(continued)

rod power distribution within an assembly. The APLHGR limits specified are equivalent to the LHGR of the highest powered fuel rod assumed in the LOCA analysis divided by its local peaking factor. A conservative multiplier is applied to the LHGR assumed in the LOCA analysis to account for the uncertainty associated with the measurement of the APLHGR.

INSERT
as new P

The APLHGR satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

The APLHGR limits specified in the COLR are the result of the fuel design, DBA, and transient analyses. For operation at other than 100% power and 100% recirculation flow conditions, the APLHGR operating limit is determined by multiplying the smaller of the $MAPFAC_p$ and $MAPFAC_t$ factors times the exposure dependent APLHGR limits.

← insert P

APPLICABILITY

The APLHGR limits are primarily derived from fuel design evaluations and LOCA and transient analyses that are assumed to occur at high power levels. Design calculations (Ref. 4) and operating experience have shown that as power is reduced, the margin to the required APLHGR limits increases. This trend continues down to the power range of 5% to 15% RTP when entry into MODE 2 occurs. When in MODE 2, the intermediate range monitor scram function provides prompt scram initiation during any significant transient, thereby effectively removing any APLHGR limit compliance concern in MODE 2. Therefore, at THERMAL POWER levels $\leq 25\%$ RTP, the reactor is operating with substantial margin to the APLHGR limits; thus, this LCO is not required.

NO CHANGE

(continued)


Insert C

For single recirculation loop operation, an APLHGR multiplier is applied to the APLHGR limit (Ref. 5 and Ref. ②). The multiplier is documented in the COLR. This multiplier is due to the conservative analysis assumption of an earlier departure from nucleate boiling with one recirculation loop available, resulting in a more severe heatup during a LOCA.

10

Insert D

With only one recirculation loop in operation, in conformance with the requirements of LCO 3.4.1, "Recirculation Loops Operating," the limit is determined by multiplying the exposure dependent limit by an APLHGR correction factor (Ref. 5 and Ref. ②).



10

Reference number change only.

BASES (continued).

REFERENCES

1. NEDE-24011-P-A-13 "General Electric Standard Application for Reactor Fuel," August 1996.
2. FSAR, Chapter 3.
3. FSAR, Chapter 14.
4. FSAR, Appendix N.
5. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," Revision ~~1~~, February 1996. December 1997
6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
7. NEDC-32433P, "Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Units 1, 2, and 3," April 1995.
8. NEDO-30130-A, "Steady State Nuclear Methods," May 1985.
9. NEDO-24154, "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," October 1978.

Reference
change to
latest
revision

10. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

10

no change
except #

B 3.2 POWER DISTRIBUTION LIMITS

B 3.2.2 MINIMUM CRITICAL POWER RATIO (MCPR)

BASES

BACKGROUND

MCPR is a ratio of the fuel assembly power that would result in the onset of boiling transition to the actual fuel assembly power. The MCPR Safety Limit (SL) is set such that 99.9% of the fuel rods avoid boiling transition if the limit is not violated (refer to the Bases for SL 2.1.1.2). The operating limit MCPR is established to ensure that no fuel damage results during abnormal operational transients. Although fuel damage does not necessarily occur if a fuel rod actually experienced boiling transition (Ref. 1), the critical power at which boiling transition is calculated to occur has been adopted as a fuel design criterion.

The onset of transition boiling is a phenomenon that is readily detected during the testing of various fuel bundle designs. Based on these experimental data, correlations have been developed to predict critical bundle power (i.e., the bundle power level at the onset of transition boiling) for a given set of plant parameters (e.g., reactor vessel pressure, flow, and subcooling). Because plant operating conditions and bundle power levels are monitored and determined relatively easily, monitoring the MCPR is a convenient way of ensuring that fuel failures due to inadequate cooling do not occur.

APPLICABLE SAFETY ANALYSES

The analytical methods and assumptions used in evaluating the abnormal operational transients to establish the operating limit MCPR are presented in References 2, 3, 4, 5, and 8. To ensure that the MCPR SL is not exceeded during any transient event that occurs with moderate frequency, limiting transients have been analyzed to determine the largest reduction in

and 10

(continued)

BASES (continued)

REFERENCES

1. NUREG-0562, "Fuel Rod Failure As a Consequence of Departure from Nucleate Boiling or Dryout," June 1979.
 2. NEDE-24011-P-A-13, "General Electric Standard Application for Reactor Fuel," August 1996.
 3. FSAR, Chapter 3.
 4. FSAR, Chapter 14.
 5. FSAR, Appendix N.
 6. NEDO-30130-A, "Steady State Nuclear Methods," May 1985.
 7. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
 8. NEDC-32433P, "Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Units 1, 2, and 3," April 1995.
 9. NEDO-24154, "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," October 1978.
-

10 → * NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

No change
except #

BASES

APPLICABLE
SAFETY ANALYSES
(continued)

Safety analyses performed for FSAR Chapter 14 implicitly assume core conditions are stable. However, at the high power/low flow corner of the power/flow map, an increased probability for limit cycle oscillations exists (Ref. 3) depending on combinations of operating conditions (e.g., power shape, bundle power, and bundle flow). Generic evaluations indicate that when regional power oscillations become detectable on the APRMs, the safety margin may be insufficient under some operating conditions to ensure actions taken to respond to the APRMs signals would prevent violation of the MCPR Safety Limit (Ref. 4). NRC Generic Letter 86-02 (Ref. 5) addressed stability calculation methodology and stated that due to uncertainties, 10 CFR 50, Appendix A, General Design Criteria (GDC) 10 and 12 could not be met using analytic procedures on a BWR 4 design. However, Reference 5 concluded that operating limitations which provide for the detection (by monitoring neutron flux noise levels) and suppression of flux oscillations in operating regions of potential instability consistent with the recommendations of Reference 3 are acceptable to demonstrate compliance with GDC 10 and 12. The NRC concluded that regions of potential instability could occur at calculated decay ratios of 0.8 or greater by the General Electric methodology.

Stability tests at operating BWRs were reviewed to determine a generic region of the power/flow map in which surveillance of neutron flux noise levels should be performed. A conservative decay ratio was chosen as the basis for determining the generic region for surveillance to account for the plant to plant variability of decay ratio with core and fuel designs. This decay ratio also helps ensure sufficient margin to an instability occurrence is maintained. The generic region has been

INSERT

Two
New

RS

no change

(continued)



Insert E

Plant specific LOCA analyses have been performed assuming only one operating recirculation loop. These analyses have demonstrated that, in the event of a LOCA caused by a pipe break in the operating recirculation loop, the Emergency Core Cooling System response will provide adequate core cooling, provided the APLHGR requirements are modified accordingly (Refs. 7 and 8).

The transient analyses of Chapter 14 of the FSAR have also been performed for single recirculation loop operation (Ref. 7) and demonstrate sufficient flow coastdown characteristics to maintain fuel thermal margins during the abnormal operational transients analyzed provided the MCPR requirements are modified. During single recirculation loop operation, modification to the Reactor Protection System (RPS) average power range monitor (APRM) instrument, ~~and RBM setpoints~~ is also required to account for the different relationships between recirculation drive flow and reactor core flow. The APLHGR and MCPR setpoints for single loop operation are specified in the COLR. The APRM Flow Biased Simulated Thermal Power-High setpoint is in LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation", ~~and the RBM Flow Biased Upscale setpoint is in the COLR as referenced by LCO 3.3.2.1.~~
~~Control Rod Block Instrumentation.~~

DELETED DUE TO
PRNM/ARTS
IMPLEMENTATION

CURRENT
TS

BASES

APPLICABLE SAFETY ANALYSES
(continued)

determined to be bounded by the 80% rod line and the 50% core flow line. BFN conservatively implements this generic region with the "Operation Not Permitted" Region and Regions I and II of Figure 3.4.1-1. This conforms to Reference 3 recommendations. Operation is permitted in Region II provided neutron flux noise levels are verified to be within limits. The reactor mode switch must be placed in the shutdown position (an immediate scram is required) if Region I is entered.

Recirculation loops operating satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

INSERT
F

Two recirculation loops are required to be in operation with their flows matched within the limits specified in SR 3.4.1.1 to ensure that during a LOCA caused by a break of the piping of one recirculation loop the assumptions of the LOCA analysis are satisfied. With the limits specified in SR 3.4.1.1 not met, the recirculation loop with the lower flow must be considered not in operation. In addition, the core flow expressed as a function of THERMAL POWER must be outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

APPLICABILITY

In MODES 1 and 2, requirements for operation of the Reactor Coolant Recirculation System are necessary since there is considerable energy in the reactor core and the limiting design basis transients and accidents are assumed to occur.

In MODES 3, 4, and 5, the consequences of an accident are reduced and the coastdown characteristics of the recirculation loops are not important.

(continued)

NO
CHANGE

Power Upgrade
TS

BASES

APPLICABLE SAFETY ANALYSES
(continued)

determined to be bounded by the 76.2% rod line and the 50% core flow line. BFN conservatively implements this generic region with the "Operation Not Permitted" Region and Regions I and II of Figure 3.4.1-1. This conforms to Reference 3 recommendations. Operation is permitted in Region II provided neutron flux noise levels are verified to be within limits. The reactor mode switch must be placed in the shutdown position (an immediate scram is required) if Region I is entered.

Recirculation loops operating satisfies Criterion 2 of the NRC Policy Statement.(Ref. 6).

LCO

Two recirculation loops are required to be in operation with their flows matched within the limits specified in SR 3.4.1.1 to ensure that during a LOCA caused by a break of the piping of one recirculation loop the assumptions of the LOCA analysis are satisfied. With the limits specified in SR 3.4.1.1 not met, the recirculation loop with the lower flow must be considered not in operation. In addition, the core flow expressed as a function of THERMAL POWER must be outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT
F

APPLICABILITY

In MODES 1 and 2, requirements for operation of the Reactor Coolant Recirculation System are necessary since there is considerable energy in the reactor core and the limiting design basis transients and accidents are assumed to occur.

In MODES 3, 4, and 5, the consequences of an accident are reduced and the coastdown characteristics of the recirculation loops are not important.

(continued)

Power upgrade change

end

Insert F

With only one recirculation loop in operation, modifications to the required APLHGR Limits (LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)"), MCPR limits (LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)"), APRM Flow Biased Simulated Thermal Power-High Setpoint (LCO 3.3.1.1) and ~~RBM Flow Biased Upscale Setpoint (LCO 3.3.2.1)~~ may be applied to allow continued operation consistent with the assumptions of References 7 and 8.

Deleted due to PRNM/ARTS
IMPLEMENTATION

BASES

ACTIONS ——— B.1 and B.2 (continued)

1. A sustained increase in APRM and/or LPRM peak-to-peak signal noise level, reaching two or more times its initial level at reduced core flow conditions. Any noticeable increase in noise level warrants closer monitoring of the LPRM signals.

The increased noise occurs with a characteristic period of less than 3 seconds.

2. LPRM and or APRM upscale and/or downscale annunciators that alarm with a characteristic period of less than 3 seconds.

C.1

With the requirements of the LCO not met, the recirculation loops must be restored to operation with matched flows within ~~12~~ hours. A recirculation loop is considered not in operation when the pump in that loop is idle or when the mismatch between total jet pump flows of the two loops is greater than required limits. The loop with the lower flow must be considered not in operation. Should a LOCA occur with one recirculation loop not in operation, the core flow coastdown and resultant core response may not be bounded by the LOCA analyses. Therefore, only a limited time is allowed to restore the inoperable loop to operating status.

The ~~12~~ hour Completion Time is based on the low probability of an accident occurring during this time period, on a reasonable time to complete the Required Action, and on frequent core monitoring by operators allowing abrupt changes in core flow conditions to be quickly detected.

24

INSERT
NEW IP

(continued)

NO CHANGE

Insert G

Alternatively, if the single loop requirements of the LCO are applied to the operating limits and RPS setpoints, operation with only one recirculation loop would satisfy the requirements of the LCO and the initial conditions of the accident sequence.

no change

BASES

SURVEILLANCE
REQUIREMENTS

(continued)

SR 3.4.1.2

This SR ensures the reactor THERMAL POWER and core flow are within appropriate parameter limits to prevent uncontrolled power oscillations. At low recirculation flows and high reactor power, the reactor exhibits increased susceptibility to thermal hydraulic instability. Figure 3.4.1-1 is based on guidance provided in Reference 3, which is used to respond to operation in these conditions. Performance immediately after any increase of more than 5% RTP while initial core flow is < 50% of rated and immediately after any decrease of more than 10% rated core flow while initial thermal power is > 40% of rated is adequate to detect power oscillations that could lead to thermal hydraulic instability.

REFERENCES

1. FSAR, Section 14.6.3.
2. FSAR, Section 4.3.5.
3. GE Service Information Letter No. 380, "BWR Core Thermal Hydraulic Stability," Revision 1, February 10, 1984.
4. NRC Bulletin 88-07, "Power Oscillations in Boiling Water Reactors (BWRs)," Supplement 1, December 30, 1988.
5. NRC Generic Letter 86-02, "Technical Resolution of Generic Issue B-19, Thermal Hydraulic Stability," January 22, 1986.
6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.

7. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.
8. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," Revision 1, February 1996.

BFN-UNIT 2

B 3.4-10

Revision 0

2

December 1997

Reference
change
to
latest
revision

BASES (continued)

SURVEILLANCE
REQUIREMENTS

SR 3.4.2.1

This SR is designed to detect significant degradation in jet pump performance that precedes jet pump failure (Ref. 2). This SR is required to be performed only when the loop has forced recirculation flow since surveillance checks and measurements can only be performed during jet pump operation. The jet pump failure of concern is a complete mixer displacement due to jet pump beam failure. Jet pump plugging is also of concern since it adds flow resistance to the recirculation loop. Significant degradation is indicated if the specified criteria confirm unacceptable deviations from established patterns or relationships. The allowable deviations from the established patterns have been developed based on the variations experienced at plants during normal operation and with jet pump assembly failures (Refs. 2 and 3). Each recirculation loop must satisfy one of the performance criteria provided. Since refueling activities (fuel assembly replacement or shuffle, as well as any modifications to fuel support orifice size or core plate bypass flow) can affect the relationship between core flow, jet pump flow, and recirculation loop flow, these relationships may need to be re-established each cycle. During the initial weeks of operation under such conditions, while baselining new "established patterns," engineering judgment of the daily surveillance results is used to detect significant abnormalities which could indicate a jet pump failure.

The recirculation pump speed operating characteristics (pump flow and loop flow versus pump speed) are determined by the flow resistance from the loop suction through the jet pump nozzles. A change in the relationship indicates a plug, flow restriction, loss in pump hydraulic performance, leakage, or new flow path between the recirculation pump discharge and jet pump nozzle. For this criterion, the pump flow and loop flow versus pump speed relationship must be verified.

Similarly, initial entry into extended single loop operation may also require establishment of these relationships.

(continued)

no change

Unit 3 TS

2.0 SAFETY LIMITS (SLs)

2.1 SLs

2.1.1 Reactor Core SLs

2.1.1.1 With the reactor steam dome pressure < 785 psig or core flow $< 10\%$ rated core flow:

THERMAL POWER shall be $\leq 25\%$ RTP.

2.1.1.2 With the reactor steam dome pressure ≥ 785 psig and core flow $\geq 10\%$ rated core flow:

MCPR shall be ≥ 1.10 for two recirculation loop operation

2.1.1.3 Reactor vessel water level shall be greater than the top of active irradiated fuel.

2.1.2 Reactor Coolant System Pressure SL

Reactor steam dome pressure shall be ≤ 1325 psig.

or ≥ 1.12 for
single loop
operation.

2.2 SL Violations

With any SL violation, the following actions shall be completed within 2 hours:

2.2.1 Restore compliance with all SLs; and

2.2.2 Insert all insertable control rods.

NO CHANGE

Table 3.3.1.1-1 (page 1 of 3)
Reactor Protection System Instrumentation

| FUNCTION | APPLICABLE MODES OR OTHER SPECIFIED CONDITIONS | REQUIRED CHANNELS PER TRIP SYSTEM | CONDITIONS REFERENCED FROM REQUIRED ACTION D.1 | SURVEILLANCE REQUIREMENTS | ALLOWABLE VALUE |
|---|--|-----------------------------------|--|---|---------------------------------------|
| 1. Intermediate Range Monitors | | | | | |
| a. Neutron Flux - High | 2 | 3 | G | SR 3.3.1.1.1 SR 3.3.1.1.3 SR 3.3.1.1.5 SR 3.3.1.1.6 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| | 5(a) | 3 | H | SR 3.3.1.1.1 SR 3.3.1.1.4 SR 3.3.1.1.9 SR 3.3.1.1.14 | ≤ 120/125 divisions of full scale |
| b. Inop | 2 | 3 | G | SR 3.3.1.1.3 SR 3.3.1.1.14 | NA |
| | 5(a) | 3 | H | SR 3.3.1.1.4 SR 3.3.1.1.14 | NA |
| 2. Average Power Range Monitors | | | | | |
| a. Neutron Flux - High, (Setdown) | 2 | 3(b) | G | SR 3.3.1.1.1 SR 3.3.1.1.6 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 15% RTP |
| b. Flow Biased Simulated Thermal Power - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 0.66 W + 66% RTP and ≤ 120% RTP (c) |
| c. Neutron Flux - High | 1 | 3(b) | F | SR 3.3.1.1.1 SR 3.3.1.1.2 SR 3.3.1.1.7 SR 3.3.1.1.13 SR 3.3.1.1.16 | ≤ 120% RTP |

(continued)

(a) With any control rod withdrawn from a core cell containing one or more fuel assemblies.

(b) Each APRM channel provides inputs to both trip systems.

(c) $[0.66 \text{ W} + 66\% - 0.66 \Delta \text{ W}]$ RTP when reset for single loop operation per LCO 3.4.2, "Recirculation Loops Operating"

EQUATION CHANGE DUE TO PRM ARTS MELT/POWER UPDATE

3.4 REACTOR COOLANT SYSTEM (RCS)

3.4.1 Recirculation Loops Operating

LCO 3.4.1 Two recirculation loops with matched flows shall be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT A

APPLICABILITY: MODES 1 and 2.

ACTIONS

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|---|---|
| A. Reactor operation with core flow as a function of THERMAL POWER inside of Region I of Figure 3.4.1-1. | A.1 Place mode switch in the shutdown position. | Immediately |
| B. Reactor operation with core flow as a function of THERMAL POWER inside of Region II of Figure 3.4.1-1. | B.1 Place mode switch in the shutdown position. | Immediately upon discovery of thermal hydraulic instability |
| | <u>AND</u> B.2 Exit Region II. | 2 hours |
| C. One recirculation loop not in operation. | C.1 Restore two recirculation loops to operation. | 12 hours |

(continued)

substitute insert B

NO CHANGE



Insert A

OR

One recirculation loop may be in operation with core flow as a function of THERMAL POWER outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1 and provided the following limits are applied when the associated LCO is applicable:

- a. LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)," single loop operation limits specified in the COLR;
- b. LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)," single loop operation limits specified in the COLR;
- c. LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation," Function 2.b (Average Power Range Monitors Flow Biased Simulated Thermal Power - High), Allowable Value of Table 3.3.1.1-1 is reset for single loop operation;
- d. LCO 3.3.2.1, "Control Rod Block Instrumentation," Function 1.a (Rod Block Monitor Upscale (Flow Biased)), Allowable Value of Table 3.3.2.1-1 is reset for single loop operation.

Deleted
due to
NM/ARTS
implementation

Insert B

| CONDITION | REQUIRED ACTION | COMPLETION TIME |
|---|--|-----------------|
| C. Requirements of the LCO not met for reasons other than A or B. | C.1 Satisfy the requirements of the LCO. | 24 hours |



BASES

APPLICABLE SAFETY ANALYSES
(continued)

rod power distribution within an assembly. The APLHGR limits specified are equivalent to the LHGR of the highest powered fuel rod assumed in the LOCA analysis divided by its local peaking factor. A conservative multiplier is applied to the LHGR assumed in the LOCA analysis to account for the uncertainty associated with the measurement of the APLHGR.

INSERT C
new P

The APLHGR satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

The APLHGR limits specified in the COLR are the result of the fuel design, DBA, and transient analyses. For operation at other than 100% power and 100% recirculation flow conditions, the APLHGR operating limit is determined by multiplying the smaller of the $MAPFAC_p$ and $MAPFAC_r$ factors times the exposure dependent APLHGR limits.

INSERT D

10/1/98

APPLICABILITY

The APLHGR limits are primarily derived from fuel design evaluations and LOCA and transient analyses that are assumed to occur at high power levels. Design calculations (Ref. 4) and operating experience have shown that as power is reduced, the margin to the required APLHGR limits increases. This trend continues down to the power range of 5% to 15% RTP when entry into MODE 2 occurs. When in MODE 2, the intermediate range monitor scram function provides prompt scram initiation during any significant transient, thereby effectively removing any APLHGR limit compliance concern in MODE 2. Therefore, at THERMAL POWER levels $\leq 25\%$ RTP, the reactor is operating with substantial margin to the APLHGR limits; thus, this LCO is not required.

NO CHANGE

(continued)

Insert C

For single recirculation loop operation, an APLHGR multiplier is applied to the APLHGR limit (Ref. 5 and Ref. ⑩). The multiplier is documented in the COLR. This multiplier is due to the conservative analysis assumption of an earlier departure from nucleate boiling with one recirculation loop available, resulting in a more severe heatup during a LOCA.

Insert D

With only one recirculation loop in operation, in conformance with the requirements of LCO 3.4.1, "Recirculation Loops Operating," the limit is determined by multiplying the exposure dependent limit by an APLHGR correction factor (Ref. 5 and Ref. ⑩).

⑩. ←
⑩
Cycle specific APLHGR correction factors for single recirculation loop operation are documented in the COLR.

BASES (continued)

REFERENCES

1. NEDE-24011-P-A-13 "General Electric Standard Application for Reactor Fuel," August 1996.
2. FSAR, Chapter 3.
3. FSAR, Chapter 14.
4. FSAR, Appendix N.
5. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis," Revision 1, February 1996, December 1997
6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
7. NEDC-32433P, "Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Units 1, 2, and 3," April 1995.
8. NEDO-30130-A, "Steady State Nuclear Methods," May 1985.
9. NEDO-24154, "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," October 1978.

Reference
change to
latest
revision

10. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

No change
except #

B 3.2 POWER DISTRIBUTION LIMITS

B 3.2.2 MINIMUM CRITICAL POWER RATIO (MCPR)

BASES

BACKGROUND

MCPR is a ratio of the fuel assembly power that would result in the onset of boiling transition to the actual fuel assembly power. The MCPR Safety Limit (SL) is set such that 99.9% of the fuel rods avoid boiling transition if the limit is not violated (refer to the Bases for SL 2.1.1.2). The operating limit MCPR is established to ensure that no fuel damage results during abnormal operational transients. Although fuel damage does not necessarily occur if a fuel rod actually experienced boiling transition (Ref. 1), the critical power at which boiling transition is calculated to occur has been adopted as a fuel design criterion.

The onset of transition boiling is a phenomenon that is readily detected during the testing of various fuel bundle designs. Based on these experimental data, correlations have been developed to predict critical bundle power (i.e., the bundle power level at the onset of transition boiling) for a given set of plant parameters (e.g., reactor vessel pressure, flow, and subcooling). Because plant operating conditions and bundle power levels are monitored and determined relatively easily, monitoring the MCPR is a convenient way of ensuring that fuel failures due to inadequate cooling do not occur.

APPLICABLE SAFETY ANALYSES

The analytical methods and assumptions used in evaluating the abnormal operational transients to establish the operating limit MCPR are presented in References 2, 3, 4, 5, and 8. To ensure that the MCPR SL is not exceeded during any transient event that occurs with moderate frequency, limiting transients have been analyzed to determine the largest reduction in

and 10

(continued)

BASES (continued)

REFERENCES

1. NUREG-0562, "Fuel Rod Failure As a Consequence of Departure from Nucleate Boiling or Dryout," June 1979.
2. NEDE-24011-P-A-13, "General Electric Standard Application for Reactor Fuel," August 1996,
3. FSAR, Chapter 3.
4. FSAR, Chapter 14.
5. FSAR, Appendix N.
6. NEDO-30130-A, "Steady State Nuclear Methods," May 1985.
7. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.
8. NEDC-32433P, "Maximum Extended Load Line Limit and ARTS Improvement Program Analyses for Browns Ferry Nuclear Plant Units 1, 2, and 3," April 1995.
9. NEDO-24154, "Qualification of the One-Dimensional Core Transient Model for Boiling Water Reactors," October 1978.

10. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

no change except #

BASES

APPLICABLE SAFETY ANALYSES
(continued)

INSERT E
Two new
IPs

Safety analyses performed for FSAR Chapter 14 implicitly assume core conditions are stable. However, at the high power/low flow corner of the power/flow map, an increased probability for limit cycle oscillations exists (Ref. 3) depending on combinations of operating conditions (e.g., power shape, bundle power, and bundle flow). Generic evaluations indicate that when regional power oscillations become detectable on the APRMs, the safety margin may be insufficient under some operating conditions to ensure actions taken to respond to the APRMs signals would prevent violation of the MCPR Safety Limit (Ref. 4). NRC Generic Letter 86-02 (Ref. 5) addressed stability calculation methodology and stated that due to uncertainties, 10 CFR 50, Appendix A, General Design Criteria (GDC) 10 and 12 could not be met using analytic procedures on a BWR 4 design. However, Reference 5 concluded that operating limitations which provide for the detection (by monitoring neutron flux noise levels) and suppression of flux oscillations in operating regions of potential instability consistent with the recommendations of Reference 3 are acceptable to demonstrate compliance with GDC 10 and 12. The NRC concluded that regions of potential instability could occur at calculated decay ratios of 0.8 or greater by the General Electric methodology.

Stability tests at operating BWRs were reviewed to determine a generic region of the power/flow map in which surveillance of neutron flux noise levels should be performed. A conservative decay ratio was chosen as the basis for determining the generic region for surveillance to account for the plant to plant variability of decay ratio with core and fuel designs. This decay ratio also helps ensure sufficient margin to an instability occurrence is maintained. The generic region has been

no change

(continued)

Insert E

Plant specific LOCA analyses have been performed assuming only one operating recirculation loop. These analyses have demonstrated that, in the event of a LOCA caused by a pipe break in the operating recirculation loop, the Emergency Core Cooling System response will provide adequate core cooling, provided the APLHGR requirements are modified accordingly (Refs. 7 and 8).

The transient analyses of Chapter 14 of the FSAR have also been performed for single recirculation loop operation (Ref. 7) and demonstrate sufficient flow coastdown characteristics to maintain fuel thermal margins during the abnormal operational transients analyzed provided the MCPDR requirements are modified. During single recirculation loop operation, modification to the Reactor Protection System (RPS) average power range monitor (APRM) instrument ~~and RBM setpoints~~ is also required to account for the different relationships between recirculation drive flow and reactor core flow. The APLHGR and MCPDR setpoints for single loop operation are specified in the COLR. The APRM Flow Biased Simulated Thermal Power-High setpoint is in LCO 3.3.1.1, "Reactor Protection System (RPS) Instrumentation" and the RBM Flow Biased Upscale setpoint is in the COLR as referenced by LCO 3.3.2.1, "Control Rod Block Instrumentation."

Deleted due to
PRNM/ARTS
IMPLEMENTATION

BASES

APPLICABLE SAFETY ANALYSES
(continued)

determined to be bounded by the 76.2% rod line and the 45% core flow line. BFN conservatively implements this generic region with the "Operation Not Permitted" Region and Regions I and II of Figure 3.4.1-1. This conforms to Reference 3 recommendations. Operation is permitted in Region II provided neutron flux noise levels are verified to be within limits. The reactor mode switch must be placed in the shutdown position (an immediate scram is required) if Region I is entered.

Recirculation loops operating satisfies Criterion 2 of the NRC Policy Statement (Ref. 6).

LCO

Two recirculation loops are required to be in operation with their flows matched within the limits specified in SR 3.4.1.1 to ensure that during a LOCA caused by a break of the piping of one recirculation loop the assumptions of the LOCA analysis are satisfied. With the limits specified in SR 3.4.1.1 not met, the recirculation loop with the lower flow must be considered not in operation. In addition, the core flow expressed as a function of THERMAL POWER must be outside Regions I and II and the Operation Not Permitted Region of Figure 3.4.1-1.

INSERT
F

APPLICABILITY

In MODES 1 and 2, requirements for operation of the Reactor Coolant Recirculation System are necessary since there is considerable energy in the reactor core and the limiting design basis transients and accidents are assumed to occur.

In MODES 3, 4, and 5, the consequences of an accident are reduced and the coastdown characteristics of the recirculation loops are not important.

(continued)

BFN-UNIT 3

NO
change

B 3.4-5

Amendment No. 214
September 08, 1998

Insert F

With only one recirculation loop in operation, modifications to the required APLHGR Limits (LCO 3.2.1, "AVERAGE PLANAR LINEAR HEAT GENERATION RATE (APLHGR)"), MCPR limits (LCO 3.2.2, "MINIMUM CRITICAL POWER RATIO (MCPR)"), APRM Flow Biased Simulated Thermal Power-High Setpoint (LCO 3.3.1.1) ~~and RBM Flow Biased Upscale Setpoint (LCO 3.3.2.1)~~ may be applied to allow continued operation consistent with the assumptions of References 7 and 8.

and

Deleted due to PRM/ARTS implementation

BASES

ACTIONS

B.1 and B.2 (continued)

1. A sustained increase in APRM and/or LPRM peak-to-peak signal noise level, reaching two or more times its initial level at reduced core flow conditions. Any noticeable increase in noise level warrants closer monitoring of the LPRM signals:

The increased noise occurs with a characteristic period of less than 3 seconds.

2. LPRM and or APRM upscale and/or downscale annunciators that alarm with a characteristic period of less than 3 seconds.

C.1

With the requirements of the LCO not met, the recirculation loops must be restored to operation with matched flows within 12 hours. A recirculation loop is considered not in operation when the pump in that loop is idle or when the mismatch between total jet pump flows of the two loops is greater than required limits. The loop with the lower flow must be considered not in operation. Should a LOCA occur with one recirculation loop not in operation, the core flow coastdown and resultant core response may not be bounded by the LOCA analyses. Therefore, only a limited time is allowed to restore the inoperable loop to operating status.

The 12 hour Completion Time is based on the low probability of an accident occurring during this time period, on a reasonable time to complete the Required Action, and on frequent core monitoring by operators allowing abrupt changes in core flow conditions to be quickly detected.

24

insert G
as new IP

(continued)

NO CHANGE



Insert G

Alternatively, if the single loop requirements of the LCO are applied to the operating limits and RPS setpoints, operation with only one recirculation loop would satisfy the requirements of the LCO and the initial conditions of the accident sequence.

no change

BASES

**SURVEILLANCE
REQUIREMENTS**
(continued)

SR 3.4.1.2

This SR ensures the reactor THERMAL POWER and core flow are within appropriate parameter limits to prevent uncontrolled power oscillations. At low recirculation flows and high reactor power, the reactor exhibits increased susceptibility to thermal hydraulic instability. Figure 3.4.1-1 is based on guidance provided in Reference 3, which is used to respond to operation in these conditions. Performance immediately after any increase of more than 5% RTP while initial core flow is < 50% of rated and immediately after any decrease of more than 10% rated core flow while initial thermal power is > 40% of rated is adequate to detect power oscillations that could lead to thermal hydraulic instability. ⊕

REFERENCES

1. FSAR, Section 14.6.3.
2. FSAR, Section 4.3.5.
3. GE Service Information Letter No. 380, "BWR Core Thermal Hydraulic Stability," Revision 1, February 10, 1984.
4. NRC Bulletin 88-07, "Power Oscillations in Boiling Water Reactors (BWRs)," Supplement 1, December 30, 1988.
5. NRC Generic Letter 86-02, "Technical Resolution of Generic Issue B-19, Thermal Hydraulic Stability," January 22, 1986.
6. NRC No. 93-102, "Final Policy Statement on Technical Specification Improvements," July 23, 1993.

7. NEDO-24236, "Browns Ferry Nuclear Plant Units 1, 2, and 3, Single-Loop Operation," May 1981.

8. NEDC-32484P, "Browns Ferry Nuclear Plant Units 1, 2, and 3, SAFER/GESTR-LOCA Loss-of-Coolant Accident Analysis,"
Revision 1, February 1996.

December 1997

Reference
change
to
latest
revision

BFN-UNIT 3

B 3.4-10

Amendment No. 213
September 03, 1998 ⊕

BASES (continued)

SURVEILLANCE
REQUIREMENTS

SR 3.4.2.1

This SR is designed to detect significant degradation in jet pump performance that precedes jet pump failure (Ref. 2). This SR is required to be performed only when the loop has forced recirculation flow since surveillance checks and measurements can only be performed during jet pump operation. The jet pump failure of concern is a complete mixer displacement due to jet pump beam failure. Jet pump plugging is also of concern since it adds flow resistance to the recirculation loop. Significant degradation is indicated if the specified criteria confirm unacceptable deviations from established patterns or relationships. The allowable deviations from the established patterns have been developed based on the variations experienced at plants during normal operation and with jet pump assembly failures (Refs. 2 and 3). Each recirculation loop must satisfy one of the performance criteria provided. Since refueling activities (fuel assembly replacement or shuffle, as well as any modifications to fuel support orifice size or core plate bypass flow) can affect the relationship between core flow, jet pump flow, and recirculation loop flow, these relationships may need to be re-established each cycle. During the initial weeks of operation under such conditions, while baselining new "established patterns," engineering judgment of the daily surveillance results is used to detect significant abnormalities which could indicate a jet pump failure.

The recirculation pump speed operating characteristics (pump flow and loop flow versus pump speed) are determined by the flow resistance from the loop suction through the jet pump nozzles. A change in the relationship indicates a plug, flow restriction, loss in pump hydraulic performance, leakage, or new flow path between the recirculation pump discharge and jet pump nozzle. For this criterion, the pump flow and loop flow versus pump speed relationship must be verified.

Similarly, initial entry into extended single loop operation may also require establishment of these relationships.

(continued)

no change

ENCLOSURE 2

TENNESSEE VALLEY AUTHORITY BROWNS FERRY NUCLEAR PLANT (BFN) UNITS 1, 2, and 3

PROPOSED TECHNICAL SPECIFICATIONS (TS) CHANGE TS-387 SINGLE LOOP OPERATION (SLO) SUPPLEMENT 1 DISCUSSION OF CHANGES

I. Reasons for Updated TS/BASES Changes

Provided below is a description of each requested change that is different than originally requested in the TS-387 package submitted on June 2, 1997. Refer to Enclosure 1 for the revised marked-up copies of the TS and TS Bases.

1. Table 3.3.1.1-1, Reactor Protection System Instrumentation

In footnote (c), the Average Power Range Monitor (APRM) Flow Biased Simulated Thermal Power - High, SLO equation has been modified to correspond to the equation values in the current Unit 2 and 3 TS. On Unit 2 (page 3.3-7), the required SLO change is also marked-up against the presently NRC approved but not yet implemented Power Uprate TS page. Power Uprate TS are presently in effect on Unit 3.

2. LCO 3.4.1, Recirculation Loops Operating

On Units 2 and 3, subitem d of Insert A is deleted. The Power Range Neutron Monitor System (PRNM) Upgrade with implementation of APRM and Rod Block Monitor (RBM) TS (ARTS) improvements have been incorporated which eliminated the flow biased RBM function. Hence, the RBM hardware function previously referenced in subitem d no longer exists. The PRNM/ARTS/Maximum Extended Load Line Limit (MELLL) TS changes were approved by NRC for Unit 2 in Amendment 253 on July 14, 1998, and for Unit 3 in Amendment 213 on September 3, 1998.

3. BASES Section 3.2.1, Average Planar Linear Heat Generation Rate (APLHGR)

For Units 2 and 3, Reference 7, which was added by TS-387, is renumbered to Reference 10 since three new references were added by the PRNM/ARTS/MELLL TS change. Also, in Insert D for all three units, an additional sentence is added to the Limiting Condition for Operation (LCO) Bases which stipulates that the cycle specific SLO APLHGR correction factor will be included in the Core Operating Limits Report (COLR). Hence, a commitment to document the SLO APLHGR multiplier is being proposed in the TS Bases.

The existing TS Reference 5, SAFER/GESTR Loss-of-Coolant Accident (LOCA) analysis, is modified from Revision 1 to Revision 2, NEDC-32484P, December 1997, which is the most recently issued LOCA analysis reference for all three units.

4. BASES Section 3.2.2, Minimum Critical Power Ratio (MCPR)

For Units 2 and 3, Reference 8, which was added by TS-387, is renumbered to Reference 10 since two new references were added by the PRNM/ARTS/MELLL TS change. The current Reference 8 in the Units 2 and 3 Bases is maintained as a reference since it is also a valid source document for MCPR value derivation methods.

5. BASES Section 3.4.1, Recirculation Loops Operating

For Units 2 and 3, in the APPLICABLE SAFETY ANALYSES Bases, Insert E is modified to remove the reference to the flow biased RBM function which was eliminated by the PRNM/ARTS implementation. The same change is made for Insert F for the proposed TS 3.4.1 LCO Bases. Also, in the REFERENCES listing, Reference 8 which was added by proposed TS-387 is being modified to NEDC-32484P Revision 2, December 1997, SAFER/GESTR Loss-of-Coolant Accident analysis, which is the most recently issued LOCA analysis reference for all three units.

Also, on Unit 2 (page B 3.4.5), the required SLO change is marked-up against the presently approved,

but not yet implemented, Power Uprate TS page.
Power Uprate TS are presently in effect on Unit 3.

II. Updates to June 2, 1997, TS-387 Submittal

Below is a synopsis of changes to the June 2, 1997, TS-387 submittal package resulting from SLO analyses revisions since the original TS-387 submittal. The affected page number from the TS-387 package is included. On Units 2 and 3, the SLO cycle-specific transient and accident analyses evaluations are now being performed using Power Uprate parameters

Safety Limit Minimum Critical Power Ratio (SLMCPR)

Page E1-16, second paragraph: at the time of the TS-387 submittal, the Unit 2 cycle-specific core reload analysis showed a .02 SLMCPR adder for SLO and the Unit 3 core reload analysis showed a .01 adder. The current reload analysis for Unit 2 has a .01 adder and Unit 3 has a .02 adder. Hence, the more recent analyses also support that the .02 SLO SLMCPR adder value proposed in TS-387 for all units should be bounding for future considerations.

Core Operating Transients

On page E1-17 in the third paragraph, in the last paragraph on page E1-18, and in the second paragraph on page E1-19, the discussion of the recirculation drive flow correction factor related to the RBM rod block equation is no longer pertinent for Unit 2 and 3 since the RBM flow biased function was eliminated by PRNM/ARTS implementation.

Accident Evaluation

On Page E1-19, in the third paragraph of this section, it was noted that BFN had transitioned to the improved SAFER/GESTR codes for performing LOCA analyses and referenced NEDC-32484P, Revision 1, "Browns Ferry Nuclear Plant, Units 1, 2, and 3, SAFER/GESTR-LOCA, Loss-of-Coolant Accident (LOCA) Analysis." The NEDC-32484P analysis has since been updated and reissued as Revision 2, December 1997. This LOCA document was submitted to NRC on July 24, 1998. There were no changes in the SLO LOCA section (Section 5.3.4) between Revision 1 and 2 of NEDC-32484P.

01 - 2
2



On Page E1-20, in the second paragraph, it was noted that with the application of a .9 APLHGR multiplier, the LOCA peak clad temperature (PCT) for SLO was always lower than that for two-loop operation. Recently, General Electric's Technical Design Procedure for LOCA analyses was changed to also require that single loop nominal (realistic based inputs) PCT LOCA values be kept less than the two loop nominal LOCA PCTs. This ensures that the single loop LOCA nominal results are always bounded by the two-loop SLO LOCA nominal results, and hence, the two-loop nominal case remains the limiting basis for derivation of the upper bound PCT for comparison with the Licensing basis PCT. Refer to Section 3.0 of NEDC-32484P for a discussion of the relationships between the PCT types and compliance with LOCA analysis acceptance criteria.

This new methodology was used for the current Unit 3 reload analysis (Unit 3 Cycle 9) and results in an .84 APLHGR multiplier for SLO. This new methodology will also apply to future reload analyses. The SLO APLHGR multiplier is documented in the cycle-specific reload analyses and, as specified in the proposed Bases changes for TS 3.2.1, will also be provided in the COLR for each unit every fuel cycle. The COLRs and revisions thereto are transmitted to NRC per TS 5.6.5.

JET PUMP SURVEILLANCE

At the bottom of Page E1-22, one line of text was missing from the original submittal at the page break. The complete text is as follows with the missing text shown in italics.

..BFN custom TS and the TS-362 ISTS already require daily monitoring of jet pumps operability, therefore, no new TS changes are needed to ensure SLO does not adversely *affect jet pump performance*. The applicable TS provisions are 3.6.E, Jet Pumps, in custom format and LCO 3.4.2, Jet Pumps, in ISTS format. ISTS ..

NO SIGNIFICANT HAZARDS CONSIDERATION DETERMINATION

On Page E1-24, in the last paragraph, the reference to the flow biased RBM equation is no longer pertinent since the function has been eliminated by the PRNM/ARTS modification on Units 2 and 3.

100-100-100



On Page E1-25, in the second paragraph, the most recently issued reference LOCA analysis is now Revision 2, NEDC-32484P, December 1997.

On Page E1-25, in the third paragraph, it was noted that an APLHGR multiplier of 0.9 was applicable for all fuel types being used at the time of the TS-387 submittal. For the current Unit 3 cycle, this multiplier is .84 based on a newer approach to the SLO LOCA analysis method as discussed earlier. The SLO APLHGR multiplier is evaluated for each reload cycle and documented in each cycle-specific reload analysis report and in the COLR.

REFERENCES

Reference 9 is revised as follows.

9. Letter from TVA to NRC dated July 24, 1998 (Includes NEDC-32484P, Browns Ferry Nuclear Plant, Units 1, 2 and 3, SAFER/GESTR-LOCA, Loss-of-Coolant Accident Analysis, Revision 2, December 1997.)

0 2 1 2

