

### Plant St. Lucie Post NRC Exam Question Response

**Question 1: Based on the initial conditions presented for the administrative JPM related to E-Plan determination and notification the answer key stated no release in progress.**

**Station Response:** Based on the initial conditions presented the station concurs that the administrative JPM answer key should state – Block 9 – (release) In Progress and Block 10 – Under Evaluation.

**Action:** Revise JPM key to reflect release in progress and the release is under evaluation.

**Question 2: During a scenario the running charging pump tripped and the scenario guide did not contain the applicable technical specification for 2 charging pumps inoperable.**

**Station Response:** When the 2A charging pump tripped, station electricians were aligned to the 'A' train of station power. Prior to taking the 2A charging pump control switch to OFF the 2C charging pump should be considered inoperable since it will not get a Safety Injection Actuation System (SIAS) start signal until the 2A charging pump is in OFF. Therefore T.S 3.1.2.4 and 3.5.2 Action 2 would apply prior to the 2A charging pump control switch being taken to OFF.

**Action:** Revise simulator exercise guide D-2 to reflect T.S 3.1.2.4 and 3.5.2 Action 2 for the period of time when the 2A charging pump control switch is not in OFF and electricians aligned to 'A' train.

**Question 3: With a steam generator tube rupture occurring, the simulator exercise guide only listed the steam generator tube leakage technical specification and did not include the steam generator tube integrity technical specification.**

**Station Response:** Based on a review of technical specification basis T.S action 3.4.5 the tube integrity specification should also have been entered.

**Action:** Revise simulator exercise guide D-2 to add technical specification 3.4.5 for the tube rupture event.

**Question 4: With Containment Cooling Water Valve HCV-14-1 overridden open, is there a technical specification applicable?**

**Station Response:** Yes T.S 3.6.3 is applicable.

**Action:** None, T.S 3.6.3 is specified in the simulator exercise guide D-2 form.

All changes to the applicable documents have been completed and listed as attachment 1 on the data submittal disk.