

CATEGORY 1

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9703100006 DOC. DATE: 97/02/28 NOTARIZED: NO DOCKET #
FACIL: 50-220 Nine Mile Point Nuclear Station, Unit 1, Niagara Powe 05000220
AUTH. NAME AUTHOR AFFILIATION
MCCORMICK, M.J. Niagara Mohawk Power Corp.
RECIP. NAME RECIPIENT AFFILIATION
Document Control Branch (Document Control Desk)

SUBJECT: Provides supplemental info re three relief requests
VG-2, LP-RR-2 & CRD-RR-3.

DISTRIBUTION CODE: A047D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 2
TITLE: OR Submittal: Inservice/Testing/Relief from ASME Code - GL-89-04

NOTES:

	RECIPIENT		COPIES		
	ID CODE/NAME	LTR	ENCL	COPIES	
	PD1-1 LA HOOD, D	1	1	1	
INTERNAL:	ACRS	1	1	1	
	<u>FILE CENTER 01</u>	1	1	1	
	NUDOCS-ABSTRACT	1	1	1	
	RES/DET/EIB	1	1	1	
EXTERNAL:	LITCO ANDERSON	1	1	1	
	NRC PDR	1	1	1	
	NRR/DE/ECGB	1	1	1	
	NRR/DSSA/SCSB	1	1	1	
	Res/DE/SEB	1	1	1	

NOTE TO ALL "RIDS" RECIPIENTS:
PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK,
ROOM OWFN 5D-5 (EXT. 415-2083) TO ELIMINATE YOUR NAME FROM
DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!


TOTAL NUMBER OF COPIES REQUIRED: LTR 17 ENCL 0

C
A
T
E
G
O
R
Y

1

D
O
C
U
M
E
N
T

1 9603 3 1 11511
1 9602 2001 11511
1 9601 2001 11511



NIAGARA MOHAWK

GENERATION
BUSINESS GROUP

NINE MILE POINT NUCLEAR STATION/LAKE ROAD, P.O. BOX 63, LYCOMING, NEW YORK 13093/TELEPHONE (315) 349-2660
FAX (315) 349-2605

February 28, 1997
NMP1L 1189

MARTIN J. McCORMICK JR. P.E.
Vice President
Nuclear Engineering

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
Washington, DC 20555

RE: Nine Mile Point Unit 1
Docket No. 50-220
DPR-63

Subject: Relief Requests

Gentlemen:

This letter provides supplemental information to three relief requests submitted in a letter dated August 9, 1996 (NMP1L 1110). These relief requests were VG-2 (Rev. 1), LP-RR-2 (Rev. 1), and CRD-RR-3 (Rev. 1). The supplemental information provided by this letter is in response to matters discussed with the Staff during recent telephone conferences.


With regard to relief request VG-2 (Rev. 1), primary containment isolation valves will be leak tested in accordance with Option B of Appendix J of 10CFR50 and Part 10 of ASME/ANSI OMa-1988 (OM-10) Sections 4.2.2.2, 4.2.2.3(e) and 4.2.2.3(f).

Regarding relief requests LP-RR-2 (Rev. 1) and CRD-RR-3 (Rev. 1), Niagara Mohawk has proposed to verify valve closure during each refueling outage, either by performing a 10CFR50 APPENDIX J leak test or by applying differential pressure across the valve. This proposal is consistent with OM-10 Paragraph 4.3.2, which allows full-stroke exercising that is not practical during power operation or cold shutdown to be deferred to refueling outages. Furthermore, the relief requests also document the justification for deferral of closure testing in accordance with OM-10, Paragraph 6.2(d). These two relief requests involve four check valves, and therefore, the provisions of OM-10 Paragraph 4.2.1, related to stroke time testing, is not applicable. Accordingly, Niagara Mohawk will revise the IST Program to reference paragraph 3.1.1.3 of NUREG-1482, "De-inerting Containment of Boiling Water Reactors to Allow Cold Shutdown Testing," for these two relief requests, except that Paragraph 4.2.1 of OM-10, related to stroke time testing, does not apply.

ADD: NAR/DE/ECGD
NAR/DSSA/SCSD
RES/DE/SEM

AD47 1/0

070102
9703100006 970228
PDR ADCK 05000220
P PDR





If additional information is needed with regard to these three relief requests, please contact Anthony Zallnick (315) 349-2428 of our Licensing staff.

Very truly yours,



M. J. McCormick Jr.
Vice President Nuclear Engineering

AFZ/kap

xc: Mr. H. J. Miller, NRC Regional Administrator, Region I
Mr. S. S. Bajwa, Acting Director, Project Directorate I-1, NRR
Mr. B. S. Norris, Senior Resident Inspector
Mr. D. S. Hood, Senior Project Manager, NRR
Records Management



Handwritten scribbles and marks in the top right corner, possibly including the number '2'.