

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION Nbr: 8311020133 DOC. DATE: 83/10/28 NOTARIZED: NO  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylvania  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania  
 AUTH. NAME CURTIS, N.W. AUTHOR AFFILIATION Pennsylvania Power & Light Co.  
 RECIP. NAME SCHWENCER, A. RECIPIENT AFFILIATION Licensing Branch 2

DOCKET #  
 05000387  
05000388

SUBJECT: Requests approval of ASME Code Case N-253-2, "Const of Class 2 or 3 Components for Elevated Temp Svc Section III, Div 1," for application to diesel engine exhaust gas expansion joint for addl new diesel generator.

DISTRIBUTION CODE: 80015 COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
 TITLE: Licensing Submittal: PSAR/FSAR Amots & Related Correspondence

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys.  
 1cy NMSS/FCAF/PM. LPDR 2cys.

05000387  
 05000388

	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTTR ENCL
	NRR/DL/ADL	1	NRR LB2 BC	1
	NRR LB2 LA	1	PERCH, R. 01	1
INTERNAL:	ELD/HDS4	1	IE FILE	1
	IE/DEPER/EPB 36	3	IE/DEPER/IRB 35	1
	IE/DEQA/QAB 21	1	NRR/DE/AEAB	1
	NRR/DE/CEB 11	1	NRR/DE/EHEB	1
	NRR/DE/EQB 13	2	NRR/DE/GB 28	2
	NRR/DE/MES 18	1	NRR/DE/MTEB 17	1
	NRR/DE/SAB 24	1	NRR/DE/SGEB 25	1
	NRR/DHFS/HFEB40	1	NRR/DHFS/LQB 32	1
	NRR/DHFS/PSRB	1	NRR/DL/SSPB	1
	NRR/DSI/AEB 20	1	NRR/DSI/ASB	1
	NRR/DSI/CPB 10	1	NRR/DSI/CSB 09	1
	NRR/DSI/ICSB 10	1	NRR/DSI/METB 12	1
	NRR/DSI/PSB 19	1	NRR/DSI/RAB 22	1
	NRR/DSI/RSB 23	1	<u>REG FILE</u> 04	1
	RGNI	3	RM/DDAMI/MIB	1
EXTERNAL:	ACKS 41	0	BNL (AMDTIS ONLY)	1
	DMB/DSS (AMDTIS)	1	FEMA-REP DIV 39	1
	LPDR 03	2	NRC POR 02	1
	NSIC 05	1	NTIS	1
NOTES:		3		

TOTAL NUMBER OF COPIES REQUIRED: LTTR 57 ENCL



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis  
Vice President-Engineering & Construction-Nuclear  
215/770-7501

OCT 28 1983

Director of Nuclear Reactor Regulation  
Attention: Mr. A. Schwencer, Chief  
Licensing Branch No. 2  
Division of Licensing  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
REQUEST FOR APPROVAL OF CODE CASE N-253-2  
ER 100450 FILE 841-1  
PLA-1879

Docket Nos. 50-387  
50-388

Dear Mr. Schwencer:

The purpose of this letter is to request approval by the NRC of Code Case N-253-2 entitled "Construction of Class 2 or Class 3 Components for Elevated Temperature Service Section III, Division I". This Code Case will be applied to the diesel engine exhaust gas expansion joint for the additional new diesel generator at Susquehanna SES.

The diesel engine exhaust gas expansion joint is subjected to 930°F gas at a pressure of 20 inches of water. This elevated gas temperature requires the application of this Code Case since the material temperature listed in Appendix 1, Table 1.7.1 of the ASME Code does not exceed 800°F.

We request your approval by November 18, 1983 in order to meet our production schedule.

Very truly yours,

N. W. Curtis  
Vice President-Engineering & Construction-Nuclear

cc: R. L. Perch

8311020133 831028  
PDR ADOCK 05000387  
P PDR

Boel  
1/0