

TABLE 3.3.7.1-1

RADIATION MONITORING INSTRUMENTATION

<u>INSTRUMENTATION</u>	<u>MINIMUM CHANNELS OPERABLE</u>	<u>APPLICABLE CONDITIONS</u>	<u>ALARM/TRIP SETPOINT</u>	<u>MEASUREMENT RANGE</u>	<u>ACTION</u>
1. Main Control Room Outside Air Intake Radiation Monitor (RR-D12-R610)	2/intake	1,2,3,5 and *	5 mR/hr	0.01 to 100 mR/hr	70
2. Area Monitors					
a. Criticality Monitors					
1) New Fuel Storage Vault (Channel #13)	1 2	(a)	≤ 15 mR/hr	10^{-1} to 10^3 10^{-2} to 10^2 mR/hr	71
2) Spent Fuel Storage Pool (Channel #14)	1 2	(b)	≤ 15 mR/hr	10^{-1} to 10^3 mR/hr	71

* When irradiated fuel is being handled in the secondary containment.

(a) With fuel in the new fuel storage vault.

(b) With fuel in the spent fuel storage pool.

B409270256 B40924
PDR ADDCK 05000387
PDR