

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NO: 8504180543 DOC. DATE: 85/04/11 NOTARIZED: YES DOCKET #
 FACIL: 50-367 Susquehanna Steam Electric Station, Unit 1, Pennsylvania 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylvania 05000388
 AUTH. NAME: CURTIS, M.W. AUTHOR AFFILIATION: Pennsylvania Power & Light Co.
 RECIP. NAME: SCHWENCKER, A. RECIPIENT AFFILIATION: Licensing Branch 2

SUBJECT: Forwards application for proposed Amends 66 & 19 to
 Licenses NPF-14 & NPF-22, respectively. Amends change Tech
 Specs to support operation w/one recirculation loop out of
 svc. Fee paid.

DISTRIBUTION CODE: A001L COPIES RECEIVED: LTR 3 ENCL 40 ON SIZE: 4+59
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAP/PM. LPDR 2cys Transcripts. 05000387
 OL: 07/17/82
 1cy NMSS/FCAP/PM. LPDR 2cys Transcripts. 05000388
 OL: 03/23/84

RECIPIENT ID CODE/NAME	COPIES LTR ENCL	RECIPIENT ID CODE/NAME	COPIES LTR ENCL
NRK LB2 BC 01	7		
INTERNAL: ACRS 09	6	ADM/LFNB	1 0
ELO/RDS4	1	NRK/DE/MTED	1 1
NRK/OL DIR	1	NRK/OL/GRAS	1 0
NRK/OL/TSRG	1	NRK/DSI/MTED	1 1
NRK/DSI/RAB	1	REG FILE 04	1 1
RCN1	1		
EXTERNAL: LGSG BRUSKE, S	1	LPDR 03	2 2
ARC PDR 02	1	NSIC 05	1 1
NOTES:	3		

Rec'd w/ check #150-
 #555461



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Norman W. Curtis
Vice President-Engineering & Construction-Nuclear
215/770-7501

APR 11 1985

Director of Nuclear Reactor Regulation
Attention: Mr. A., Schwencer, Chief
Licensing Branch No. 2
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION

PROPOSED AMENDMENTS 66 TO NPF-14 AND 19 to NPF-22
ER 100450 FILE 841-8
PLA-2440

Docket Nos. 50-387
50-388

Dear Mr. Schwencer:

The purpose of this letter is to request changes to the Susquehanna SES Units 1 and 2 Technical Specifications in order to support operation with one recirculation loop out of service.

A marked-up copy of the current SSES Units 1 and 2 Technical Specifications is attached; a description of each of the changes is provided below. Also attached is a summary report on the analyses performed to provide the justification for the proposed changes.

DESCRIPTION OF PROPOSED CHANGES

1. p.2-1 (U1 and U2): A reference to the new single loop operation (SLO) Specification, which provides the appropriately revised requirement, is provided.
2. p.2-4 (U1 and U2): See p.2-1 above.
3. p.3/4 2-1 (U1): The reference to Exxon fuel was previously proposed in Amendment 59, which has not yet been issued. (U1 and U2): see p.2-1 above.
4. p.3/4 2-5 (U1): The changes to the definition of "T" were previously proposed in Amendment 59, which has not yet been issued. (U1 and U2): see p.2-1 above.
5. Figures 3.2.3-1 a and b (U1 and U2): These figures were proposed in Amendments 45 and 7 to Licenses NPF-14 and 22, respectively. The changes indicated here are contingent upon those amendments first being issued as originally proposed.

8504180543 850411
PDR ADOCK 05000387
P PDR

Rec'd w/ checks
555461 for 150

A001
3/40

APR 11 1985

Page 2

SSES PLA-2440
ER 100450 File 841-8
Mr. A. Schwencer

6. p.3/4 3-54 (U1 and U2): The revised trip setpoint and allowable value and footnote "#" were proposed in Amendments 45 and 7 to Licenses NPF-14 and 22, respectively. The changes indicated here and on the insert following 3/4 3-54 are contingent upon those amendments first being issued as originally proposed. A reference to the new SLO Specification, which provides the appropriate trip setpoint and allowable value for SLO is also provided.
7. p. 3/4 4-1 (U1 and U2):
 - a. The heading is changed to designate this specification as two loop only.
 - b. LCO numbering is changed to allow the addition of the SLO Specification.
 - c. The figure number is changed to be consistent with the LCO number.
 - d. The APPLICABILITY is revised to apply only to two loop operation, and a reference to the SLO Specification is provided.
 - e. ACTION a is revised to reference the new SLO Specification and uses the previous 12 hours to be in HOT SHUTDOWN as the time to comply with the SLO Specification or be in HOT SHUTDOWN.
 - f. In ACTIONS b and c, the Figure number is revised as discussed above.
8. p. 3/4 4-1a (U1 and U2):
 - a. The SURVEILLANCE REQUIREMENTS are revised consistent with the LCO renumbering.
 - b. Footnote *** is deleted. With respect to the thermal-hydraulic stability issue, PP&L intends to monitor all LPRM detectors to establish the neutron flux noise baseline.
9. Figure 3.4.1.1.1-1 (U1 and U2): the figure number was revised consistent with the new LCO numbering.
10. Specification 3.4.1.1.2 (U1 and U2):
 - a. A pump speed limitation based on vessel internals vibration is added in the LCO; note that this limitation is 80% of rated for Unit 1 and 90% of rated for Unit 2. This is due to different jet pump gaps as discussed in the summary report.
 - b. Existing limits revised for SLO are listed in the LCO so that they are easy to access.

APR 11 1985

Page 3

SSES PLA-2440
ER 100450 File 841-8
Mr. A. Schwencer

- c. The neutron flux noise limit is provided in the LCO.
 - d. ACTION a references the two loop operation requirements for loss of both loops.
 - e. ACTION b requires that if any of the revised limits are violated, the normal ACTION required (as if both loops were in operation) shall be taken.
 - f. ACTION c provides thermal hydraulic stability requirements.
 - g. ACTION d provides a response equivalent to the two-loop specification (3.4.1.2) if any jet pump is not OPERABLE.
 - h. SURVEILLANCE REQUIREMENTS are provided to ensure the LCO requirements are met.
- 11. p.3/4 4-2 (U1 and U2): An appropriate reference to the revised SURVEILLANCE REQUIREMENTS to show jet pump OPERABILITY during single loop operation is provided.
 - 12. p. 3/4 4-3 (U1 and U2): The APPLICABILITY is revised to apply to two loop operation only; revised Specification Numbering is provided in ACTION b.
 - 13. Appropriate BASES changes are provided. In the Unit 1 Technical Specifications, some of the BASES changes are as provided in proposed Amendment 59 to NPF-14.

NO SIGNIFICANT HAZARDS CONSIDERATIONS

Based on the analysis provided in the attached summary report on SLO, this proposed amendment is an example of an amendment considered not likely to involve significant hazard considerations per 48FR14870, paragraph (vi).

IMPLEMENTATION

Please provide 30 days after this amendment is approved for it to become effective, in order to provide time for appropriate procedures to be written or updated.

APR 11 1985

Page 4

SSES
ER 100450
Mr. A. Schwencer

PLA-2440
File 841-8

Any questions on this proposed amendment should be directed to Mr. R. Sgarro at (215) 770-7855. Pursuant to 10CFR170.22, the appropriate fee is enclosed.

Very truly yours,



N. W. Curtis
Vice President-Engineering & Construction-Nuclear

Attachments

cc: M. J. Campagnone - USNRC
R. H. Jacobs - USNRC

T. M. Gerusky, Director
Bureau of Radiation Protection
Pa. Dept. of Environmental Resources
P.O. Box 2063
Harrisburg, PA 17120

