

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8604020425 DOC. DATE: 86/03/27 NOTARIZED: NO DOCKET #  
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387  
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388  
 AUTH. NAME AUTHOR AFFILIATION  
 KEISER, H. W. Pennsylvania Power & Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 ADENSAM, E. BWR Project Directorate 3

SUBJECT: Forwards application for amends to Licenses NPF-14 & NPF 22,  
 revising Tech Specs to provide editorial correction to  
 approved change for Unit 1 & support mods which enhance  
 capability of drywell cooling sys for Unit 2. Fee paid.

DISTRIBUTION CODE: A001D COPIES RECEIVED: LTR 3 ENCL 40 SIZE: 3+2  
 TITLE: OR Submittal: General Distribution

NOTES: 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000387  
 1cy NMSS/FCAF/PM. LPDR 2cys Transcripts. 05000388

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	BWR ADTS		1	0		BWR EB		1	1
	BWR EICSB		2	2		BWR FOB		1	1
	BWR PD3 PD	01	5	5		CAMPAGNONE		1	1
	BWR PSB		1	1		BWR RSB		1	1
INTERNAL:	ACRS	09	6	6		ADM/LFMB		1	0
	ELD/HDS4		1	0		NRR/DHET/TSCB		1	1
	NRR/ORAS		1	0		<u>REG. FILE</u>	04	1	1
	RGN1		1	1					
EXTERNAL:	24X		1	1		EG&G BRUSKE, S		1	1
	LPDR	03	2	2		NRC PDR	02	1	1
	NSIC	05	1	1					

NOTES: 3 3

Rec'd w/check \$150.00

TOTAL NUMBER OF COPIES REQUIRED: LTR 34 ENCL 30



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

Harold W. Keiser  
Vice President-Nuclear Operations  
215/770-7502

MAR 27 1986

Director of Nuclear Reactor Regulation  
Attention: Ms. E. Adensam, Project Director  
BWR Project Directorate No. 3  
Division of BWR Licensing  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

SUSQUEHANNA STEAM ELECTRIC STATION  
PROPOSED AMENDMENTS 81 TO NPF-14  
AND 34 TO NPF-22  
ER 100450 FILE 841-8  
PLA-2602

Docket Nos. 50-387  
50-388

Dear Ms. Adensam:

The purpose of this letter is to propose changes to the Susquehanna SES Unit 1 and Unit 2 Technical Specifications. The Unit 2 change supports modifications which enhance the capability of the Drywell Cooling system; the Unit 1 change provides an editorial correction to a previously approved change on the same subject.

Attached to this letter are the proposed changes (which are described below) in marked-up form.

A. Unit 2 Specification 3/4.6.6.2

The LIMITING CONDITION FOR OPERATION has been editorially revised to reflect the replacement of one unit cooler subsystem (consisting of 2 unit cooler fans) with 2 recirculation fans. The subject unit cooler subsystem will now be serving the general drywell area and the new recirculation fans will be replacing them with respect to their safety-related function of post-LOCA drywell atmosphere mixing. The ACTION and SURVEILLANCE REQUIREMENTS have been altered to reflect these changes in a consistent manner.

B. Unit 2 Table 3.8.4.1-1

Two pairs of Type HFB-TM circuit breakers have been added to the table to support recirculation fans 2V418A and B which are being added as discussed in A above. Due to the pending changes to the format of this table as described in proposed amendment 25 (ref. PLA-2544, dated October 10, 1985), an additional mark-up of how these changes affect that proposal has been provided.

8604020425 860327  
PDR ADDCK 05000387  
PDR

Rec'd w/checked 3/15/86

Appl  
3/40



11

[The body of the document contains several paragraphs of text that are extremely faint and illegible due to the quality of the scan. The text appears to be organized into sections, possibly separated by headings or sub-headings, but the specific content cannot be discerned.]

MAR 27 1986

Page 2

SSES PLA-2602  
ER 100450 FILE 841-8  
Ms. E. Adensam

C. Unit 1 Specification 3/4.6.6.3

This Specification was revised for the reasons described in A above via Amendment 46 to NPF-14. However, during the review of the Unit 2 changes described above, it was determined that the ACTION had been inadvertently changed on Unit 1 to allow as many as all six fans to be inoperable for up to 30 days. Therefore, this ACTION is being revised to ensure that at least one fan from each pair will be OPERABLE if the ACTION has been entered; otherwise Specification 3.0.3 will be followed.

NO SIGNIFICANT HAZARD CONSIDERATIONS

- I. The proposed changes do not involve a significant increase in the probability or consequence of an accident previously evaluated.
  - A. Unit 2 Specification 3/4.6.6.2: These changes support design improvements to the Drywell Cooling System. The only safety-related aspect of the change is that of post-LOCA hydrogen mixing, and the air flow capability of the new recirculation fans is the same as that of the unit cooler fans formerly used for the same purpose.
  - B. Unit 2 Table 3.8.4.1-1: The additional circuit breakers were added to meet design criteria specified for the additional recirculation fans, i.e., to provide overcurrent protection for primary containment penetration conductors. Therefore, no previous evaluations are affected.
  - C. Unit 1 Specification 3/4.6.6.3: As described, this change corrects an error which if left uncorrected, would have allowed a previous evaluation, that of post-LOCA hydrogen mixing, to be improperly supported. Therefore, this change ensures that the probability or consequences of an accident previously evaluated will not be degraded.
- II. The proposed changes do not create the possibility of a new or different kind of accident from any accident previously evaluated.
  - A. Unit 2 Specification 3/4.6.6.2: This equipment change is in accordance with existing design criteria and will not adversely affect the function of any system; therefore, new events are not of concern.
  - B. Unit 2 Table 3.8.4.1-1: The addition of these thermal magnetic breakers is in accordance with existing design criteria and will not adversely affect the function of any system; therefore, new events are not of concern.
  - C. Unit 1 Specification 3/4.6.6.3: This change is editorial and ensures the validity of a related analysis. It does not create concerns of a new event.

Faint header text at the top of the page, possibly including a date or reference number.

### Section Header

Paragraph 1: The first main body paragraph, containing several lines of faint text.

### Section Header

Paragraph 2: The second main body paragraph, continuing the text.

Paragraph 3: The third main body paragraph.

Paragraph 4: The fourth main body paragraph.

Paragraph 5: The fifth main body paragraph.

Paragraph 6: The sixth main body paragraph.

Paragraph 7: The seventh main body paragraph.

Paragraph 8: The eighth main body paragraph.

Faint footer text at the bottom of the page.

MAR 27 1986

Page 3

SSES PLA-2602  
ER 100450 FILE 841-8  
Ms. E. Adensam

III. The proposed changes do not involve a significant reduction in a margin of safety.


- A. Unit 2 Specification 3/4.6.6.2: As described above, these changes maintain the safety margin currently provided.
- B. Unit 2 Table 3.8.4.1-1: These changes ensure the safety margin currently provided for other primary containment penetration conductors.
- C. Unit 1 Specification 3/4.6.6.3: As described above, this change will require the intended level of safety margin to be achieved.

IMPLEMENTATION SCHEDULE

The modifications discussed in this proposal will be performed during the Unit 2 first refueling and inspection outage. We therefore request that NRC approval of the Unit 2 changes be issued prior to the start of that outage with the condition that they become effective prior to startup following the outage. We request that the Unit 1 change be issued no later than the Unit 2 change; we will control it administratively until issuance.

Any questions on this proposal should be directed to Mr. R. Sgarro, (215) 770-7855. Pursuant to 10CFR170.22 the appropriate fee is enclosed.

Very truly yours,

  
H. W. Keiser  
Vice President-Nuclear Operations

Attachments

cc: M. J. Campagnone USNRC  
R. H. Jacobs USNRC

T. M. Gerusky, Director  
Bureau of Radiation Protection  
PA Dept. of Environmental Resources  
P.O. Box 2063  
Harrisburg, PA 17120

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954

1954