

PRIORITY 1

(ACCELERATED RIDS PROCESSING)

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 9508070114 DOC. DATE: 95/07/31 NOTARIZED: NO DOCKET #
 FACIL: 50-387 Susquehanna Steam Electric Station, Unit 1, Pennsylv 05000387
 50-388 Susquehanna Steam Electric Station, Unit 2, Pennsylv 05000388
 AUTH. NAME AUTHOR AFFILIATION
 KELLY, E.M. Region 1 (Post 820201)
 RECIP. NAME RECIPIENT AFFILIATION
 BYRAM, R.G. Pennsylvania Power & Light Co.

SUBJECT: Forwards insp repts 50-387/94-12 & 50-388/94-13 on 940620-0915 & 950728. Violations noted but not cited.

DISTRIBUTION CODE: IE01D COPIES RECEIVED: LTR 1 ENCL 1 SIZE: 3+23
 TITLE: General (50 Dkt)-Insp Rept/Notice of Violation Response

NOTES: 05000387

	RECIPIENT		COPIES		RECIPIENT		COPIES		
	ID CODE/NAME	PD1-2 PD	LTR	ENCL	ID CODE/NAME	LTR	ENCL		
			1	1	POSLUSNY, C	1	1		
INTERNAL:	ACRS		2	2	AEOD/DEIB	1	1		
	AEOD/SPD/RAB		1	1	AEOD/TTC	1	1		
	DEDRO		1	1	<u>FILE CENTER</u>	1	1		1
	NRR/DISP/PIPB		1	1	NRR/DORS/OEAB	1	1		
	NRR/DRCH/HHFB		1	1	NUDOCS-ABSTRACT	1	1		
	OE DIR		1	1	OGC/HDS2	1	1		D
	RGN1 FILE 01		1	1					
EXTERNAL:	LITCO BRYCE, J H		1	1	NOAC	1	1		O
	NRC PDR		1	1					

NOTES: 1 1

NOTE TO ALL "RIDS" RECIPIENTS:

PLEASE HELP US TO REDUCE WASTE! CONTACT THE DOCUMENT CONTROL DESK, ROOM OWFN 5D8 (415-2083) TO ELIMINATE YOUR NAME FROM DISTRIBUTION LISTS FOR DOCUMENTS YOU DON'T NEED!

TOTAL NUMBER OF COPIES REQUIRED: LTR 20 ENCL 20

July 31, 1995

DLD

Docket Nos. 50-387
50-388

Mr. Robert G. Byram
Senior Vice President - Nuclear
Pennsylvania Power & Light Company
2 North Ninth Street
Allentown, Pennsylvania 18101

Dear Mr. Byram:

SUBJECT: SUSQUEHANNA COMBINED REPORT NOS. 94-12 AND 94-13

The enclosed report documents a safety inspection conducted by Mr. L. Prividy from June 20-24, July 26-29, and September 14-15, 1994, at the Susquehanna Steam Electric Station (SSES), Salem Township, Pennsylvania and at your corporate office in Allentown, Pennsylvania. Our inspection was focused on issues important to public health and safety. We specifically reviewed test records, modifications, and safety and reportability evaluations in support of the NRC Spent Fuel Pool (SFP) Task Action Plan developed to resolve the concerns identified in a report filed on November 27, 1992, under 10 CFR Part 21. We discussed the preliminary findings with Mr. G. Jones and other members of your staff on June 24, July 29, September 15, 1994, and, finally, on July 28, 1995. The issuance of this report was delayed to ensure consistency with the NRC staff's safety evaluation, which was recently issued on June 19, 1995.

Overall, your responses to our inspector's requests for information were thorough and timely. Your responses allowed us to clarify previous information regarding preoperational and inservice test results, as well as reportability evaluations. Our inspector did identify two apparent violations of regulatory requirements concerning the transmittal of inaccurate information to the NRC and the inservice testing requirements regarding manually-operated valves provided for SFP cooling and makeup. We considered these issues as not significant since there were no safety consequences; the valves were promptly and successfully cycled, and subsequently found to be in good material condition. The valves are also in a low pressure/temperature service condition, and have since been added to the Susquehanna Inservice Testing Program. Although the transmittal of the inaccurate information was clearly an administrative error due to an apparent lack of attention to detail, we concluded that it was not indicative of a process problem and was, therefore, an isolated occurrence. Your response to our concerns and your resultant corrective actions were found to be prompt and thorough. Therefore, in accordance with the provisions of 10 CFR 2, Appendix C, Section VII.B.(1) of the NRC Enforcement Policy, these violations are not being cited.

070000
9508070114 950731
PDR ADOCK 05000387
PDR

IE01

14

Mr. Robert G. Byram

2

July 31, 1995

No response to this letter is required, and your cooperation with us in this matter is appreciated.

Sincerely,

Eugene M. Kelly, Chief
Systems Section
Division of Reactor Safety

Enclosure: Combined Inspection Report Nos.
50-387/94-12 and 50-388/94-13
w/Attachment 1

cc w/encl:

H. G. Stanley, Vice President - Nuclear Operations
J. M. Kenny, Nuclear Licensing
G. T. Jones, Vice President - Nuclear Engineering
M. M. Urioste, Nuclear Services Manager, General Electric
C. D. Lopes, Manager - Nuclear Security
W. Burchill, Manager, Assessment Services
H. D. Woodshick, Special Office of the President
R. Wehry, Nuclear Licensing
J. C. Tilton, III, Allegheny Electric Cooperative, Inc.
Nuclear Safety Information Center (NSIC)
Commonwealth of Pennsylvania

Mr. Robert G. Byram

3

July 31, 1995

Distribution w/encl:
 Region I Docket Room (with concurrences)
 J. Wiggins, DRS
 E. Kelly, DRS
 D. Screnci, PAO (2)
 NRC Resident Inspector
 K. Gallagher, DRP
 PUBLIC
 DRS Files (2)

Distribution w/encl: (Via E-Mail)
 W. Dean, OEDO
 C. Poslusny, Project Manager, NRR
 J. Stolz, PDI-2, NRR
 Inspection Program Branch, NRR (IPAS)
 P. Campbell, NRR
 S. Jones, NRR
 Joseph Shea, NRR

DOCUMENT NAME: A:SU941213.INS

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	E	NRR	NRR	NRR	RI/DRP
NAME	PRIVIDY <i>LD</i>		JShea <i>per telecon</i>	MVirgilio <i>for per</i>	CMcCracken <i>per</i>	JWhite <i>[Signature]</i>
DATE	07/31/95		07/31/95	07/31/95 <i>telecon w/S Jones</i>	07/31/95 <i>telecon w/S Jones</i>	07/31/95

To receive a copy of this document, indicate in the box: "C" = Copy without attachment/enclosure "E" = Copy with attachment/enclosure "N" = No copy

OFFICE	RI/DRS	C	RI/	RI/	RI/	RI/
NAME	EKelly <i>[Signature]</i>					
DATE	07/28/95		07/ /95	07/ /95	07/ /95	07/ /95

OFFICIAL RECORD COPY