

REGULATORY INFORMATION DISTRIBUTION SYSTEM (RIDS)

ACCESSION NBR: 8605190099 DDC. DATE: 86/05/13 NOTARIZED: YES DOCKET #  
 FACIL: 50-412 Beaver Valley Power Station, Unit 2, Duquesne Light C 05000412  
 AUTH. NAME AUTHOR AFFILIATION  
 CAREY, J. J. Duquesne Light Co.  
 RECIP. NAME RECIPIENT AFFILIATION  
 DENTON, H. R. Office of Nuclear Reactor Regulation, Director (post 851125  
 TAM, P. Division of Pressurized Water Reactor Licensing - A (post 8

SUBJECT: Confirms 860417 telcon agreements SER (NUREG-1057) Open  
 Item 4 concerning preservice insp program, including  
 (augmented inservice insp) exam of 2-inch welds & smaller.

DISTRIBUTION CODE: B001D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 3  
 TITLE: Licensing Submittal: PSAR/FSAR Amdts & Related Correspondence

NOTES: LPDR 2cys Transcripts. LPDR 2cys PDR Documents. 05000412  
 Application for permit renewal filed.

	RECIPIENT		COPIES			RECIPIENT		COPIES	
	ID CODE/NAME		LTR	ENCL		ID CODE/NAME		LTR	ENCL
	PWR-A ADTS		1	1		PWR-A EB		1	1
	PWR-A EICSB		2	2		PWR-A FOB		1	1
	PWR-A PD2 LA		1	1		PWR-A PD2 PD		1	1
	TAM, P 01		2	2		PWR-A PSB		1	1
	PWR-A RSB		1	1					
INTERNAL:	ACRS 41		6	6		ADM/LFMB		1	0
	ELD/HDS3		1	0		IE FILE		1	1
	IE/DEPER/EPB 36		1	1		IE/DQAVT/GAB 21		1	1
	NRR BWR ADTS		1	0		NRR PWR-A ADTS		1	0
	NRR PWR-B ADTS		1	0		NRR ROE, M. L		1	1
	NRR/DHET/HFIB		1	1		NRR/DHFT/MTB		1	1
	<u>REG FILE</u> 04		1	1		RGN1		3	3
	RM/DDAMI/MIB		1	0					
EXTERNAL:	24X		1	1		BNL (AMDTS ONLY)		1	1
	DMB/DSS (AMDTS)		1	1		LPDR 03		1	1
	NRC PDR 02		1	1		NSIC 05		1	1
	PNL GRUEL, R		1	1					
NOTES:			2	2					

TOTAL NUMBER OF COPIES REQUIRED: LTR 42 ENCL 0  
~~25~~

ACCESSION NBR: 8605170077 DDC DATE: 86\05\13 NOTARIZED: YES DOCKET # 05000412  
FACIL: 50-415 Beaver Valley Power Station, Unit 5, Dupuene Light C 05000412  
AUTHOR AFFILIATION  
DUPUENE LIGHT CO.  
RECIPIENT AFFILIATION  
DENTON, H. R. OFFICE OF NUCLEAR REACTOR REGULATION, DIRECTOR (POST 851125)  
TAM, P. DIVISION OF PRESSURIZED WATER REACTOR LICENSING - A (POST 8

SUBJECT: Confirms 860417 fission agreements SER (NURSE-1057) Open  
Item a concerning preservice insp program, including  
(augmented preservice insp) exam of 2-inch welds & smaller.

DISTRIBUTION CODE: B01D COPIES RECEIVED: LTR 1 ENCL 0 SIZE: 1  
TITLE: Licensing Submittal: PSAR\FAR Amdts & Related Correspondence

NOTES: LPDR Scgs Transcripts. LPDR Scgs PDR Documents.  
Application for permit renewal filed. 05000412

COPIES		RECIPIENT		COPIES		RECIPIENT	
LTR	ENCL	ID	CODE\NAME	LTR	ENCL	ID	CODE\NAME
1	1	PWR-A	ADTS	1	1	PWR-A	ADTS
1	1	PWR-A	EICSB	2	2	PWR-A	EICSB
1	1	PWR-A	PDS LA	1	1	PWR-A	PDS LA
1	1	PWR-A	PDS PD	2	2	PWR-A	PDS PD
1	1	PWR-A	PDS	1	1	PWR-A	PDS
0	1	ADM\LFMB		0	0	ADM\LFMB	
1	1	IE	FILE	0	0	IE	FILE
1	1	IE\DAV\GAB	51	1	1	IE\DAV\GAB	51
1	1	NRR	PWR-A ADTS	0	0	NRR	PWR-A ADTS
1	1	NRR	ROE.M.L	0	0	NRR	ROE.M.L
1	1	NRR	DHF\MTD	1	1	NRR	DHF\MTD
0	0	RGN1		1	1	RGN1	
1	1	BNL (AMDT	ONLY)	1	1	BNL (AMDT	ONLY)
1	1	LPDR		1	1	LPDR	
1	1	NSIC		1	1	NSIC	
1	1	NSIC		1	1	NSIC	

NOTES:



# Duquesne Light

Nuclear Construction Division  
Robinson Plaza, Building 2, Suite 210  
Pittsburgh, PA 15205

2NRC-6-047  
(412) 787-5141  
(412) 923-1960  
Telecopy (412) 787-2629  
May 13, 1986

Mr. Harold R. Denton, Director  
Office of Nuclear Reactor Regulation  
United States Nuclear Regulatory Commission  
Washington, DC 20555

ATTENTION: Mr. Peter Tam, Project Manager  
Division of PWR Licensing - A  
Office of Nuclear Reactor Regulation

SUBJECT: Beaver Valley Power Station - Unit No. 2  
Docket No. 50-412  
SER Open Item (4)

REFERENCE: 1) BVPS-2 Safety Evaluation Report, NUREG-1057,  
October 1985  
2) DLC Letter 2NRC-5-154, dated December 26, 1985  
3) NRC Letter to DLC, dated January 24, 1986  
4) DLC Letter 2NRC-6-034, dated April 9, 1986

GENTLEMEN:

As a follow-on to submittal of the BVPS-2 Preservice Inspection Program (reference 2), Duquesne Light Company (DLC) held a telecon with your staff (Messrs. P. Tam, G. Johnson and S. Lee) on April 17, 1986 relative to PSI examination of component supports and Break Exclusion Zone (Augmented ISI) examination of welds 2 inch and smaller size. Agreements reached on the examinations relative to the above are as follows:

1. Preservice Inspection of Component Supports  
Applicable to IWF - 2200(b)

The ASME Section XI Code, 1980 Edition through Winter 1980 Addenda (BVPS-2 PSI Program Baseline) states in IWF-2200(b): "All examinations shall be performed following the initiation of hot functional tests."

In the DLC submittal PSI Program Document No. NCDP 2.13, paragraph 6.7.3, the following was stated as a clarification: "DLC applies the IWF-2200(b) criteria to "Hot" (>200°F) systems."

The discussion with your staff established and clarified that the concern for application of IWF-2200(b) was for component supports subject to thermal stresses and/or movements, and was therefore

8605190099 860513  
PDR ADOCK 05000412  
E PDR

13001  
1/0

1954

MEMORANDUM FOR THE RECORD

On 10/15/54, the following information was received from the [redacted] regarding the [redacted] of the [redacted] in the [redacted] area.

The [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

It is noted that the [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

The [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

It is noted that the [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

The [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

It is noted that the [redacted] was [redacted] by [redacted] on [redacted] at [redacted]. The [redacted] was [redacted] and [redacted] by [redacted].

10/15/54

Page 2

applicable to those systems which are subjected to "Hot" temperatures. The establishment of a system operating temperature of ">200°F" as being "Hot" was agreed upon. Therefore no change to NCDP 2.13 is necessary.

2. Preservice Inspection Examination Requirements of Component Supports applicable to IWF-2200(a) vs. IWF-2510(a) and (b)

The ASME Section XI Code, 1980 Edition through Winter 1980 Addenda (BVPS-2 PSI Baseline) states in IWF-2200(a): "All examinations listed in IWF-2500-2 shall be performed completely, once, as preservice examination."

In the DLC PSI Program procedures for component supports (not including snubbers, which are examined 100% in PSI) and in DLC Program Procedure NCDP 2.13.6, paragraph 6.1.2 (submitted with BVPS-2 PSI Program, reference 2), selection of component supports utilizes IWF-2510(a) and IWF-2510(b).

The discussion with your staff established and clarified that the selection of components supports for PSI utilizing IWF-2510(a) and (b) will meet the intent of providing an examination baseline for In-service Inspection. DLC also indicated that in addition to utilizing multiple stream (train) and multiple components criteria for establishment of "all in one train" of component supports, all Class 1 component (piping) supports applicable to Class 1 integral (piping) attachments, which were selected from any of the multiple trains, would also be included in the examination requirements. Procedure 2.13.7 will be changed to reflect the above.

3. Preservice Inspection of 2 inch and Smaller Welds in Break Exclusion Zone (Augmented Inspection)

The BVPS-2 FSAR (section 6.6.8) and DLC submitted PSI Procedure NCDP 2.13, paragraph 6.5.5 identified Break Exclusion Zone (Augmented ISI) and extent of examinations. DLC submitted PSI Procedure NCDP 2.13.5, step 6.2.2.5, "Limitations/Clarifications", further indicated that: "Miscellaneous branch connections and socket welds (1 1/2 inch. and 2 inch. sizes) are not included in the PSI examination."

The agreement reached is based on the following:

- (a) The specific requirements for Break Exclusion Zone piping welds is for a "volumetric only" examination (ultrasonic methods at BVPS-2).
- (b) Obtaining meaningful results by ultrasonic methods for miscellaneous branch connections and socket welds (1 1/2 inch and 2 inch sizes) is highly improbable.
- (c) The intent of PSI examination as a baseline for ISI is to provide for trending service-induced degradation.



Handwritten marks and scribbles in the top right corner.

Main body of the document containing extremely faint and illegible text, possibly a list or table of contents.

Page 3

The agreement reached is to perform surface examination with sampling criteria compatible with Class 2 weld selection criteria for PSI (i.e. 10% sampling, prorated).

An FSAR Amendment to paragraph 6.6.8 and revision to NCDP 2.13.5 will be forthcoming to incorporate the above clarifications. In-process examination of Break Exclusion Zone piping welds will also incorporate this criteria.

The above items should be considered part of the PSI Program submittal which is presently under staff review and for which a confirmatory status of the part of SER Open Item (4) concerning PSI has been requested by July 1, 1986 (reference 4).

DUQUESNE LIGHT COMPANY


By

  
\_\_\_\_\_  
J. J. Carey  
Vice President

JJS/jdw  
AR/NAR

cc: Mr. P. Tam, Project Manager  
Mr. J. M. Taylor, Director (3)  
Mr. W. Troskoski, Sr. Resident Inspector  
Mr. L. Privity NRC Resident Inspector  
INPO Records Center  
NRC Document Control Desk

SUBSCRIBED AND SWORN TO BEFORE ME THIS  
9th DAY OF May, 1986.

  
\_\_\_\_\_  
Notary Public

SHEILA M. FATTORE, NOTARY PUBLIC  
SHIPPINGPORT BORO, BEAVER COUNTY  
MY COMMISSION EXPIRES OCT. 23, 1989.  
Member, Pennsylvania Association of Notaries

First line of faint, illegible text in the upper section of the document.

Second line of faint, illegible text in the upper section of the document.

Third line of faint, illegible text in the upper section of the document.

A small, faint line of text, possibly a signature or a specific reference.

A block of faint, illegible text located in the middle-right portion of the page.

A block of faint, illegible text located in the lower-left portion of the page.

A circular stamp or logo in the bottom left corner, containing some illegible text.