



Wisconsin Electric POWER COMPANY
231 W. MICHIGAN, P.O. BOX 2046, MILWAUKEE, WI 53201

(414) 221-2345

VPNPD-87-511
NRC-87-118

10 CFR 50.73

November 20, 1987

U. S. NUCLEAR REGULATORY COMMISSION
Document Control Desk
Washington, D. C. 20555

Gentlemen:

DOCKET 50-266
LICENSEE EVENT REPORT 87-004-01
LOSS OF THE RED INSTRUMENT BUS
POINT BEACH NUCLEAR PLANT, UNIT 1


Attached is Licensee Event Report 87-004-01 for Point Beach Nuclear Plant, Unit 1, detailing the loss of the red instrument bus during a replacement of a battery cell. The battery and associated DC bus are common to both units.

LER 87-004-01 is filed pursuant to 10 CFR 50.73(a)(2)(iv), "Any operation or condition that resulted in manual or automatic actuation of any engineered safety feature (ESF), including the reactor protection system (RPS)."

We had noted in the original LER that we expected this supplement to be filed by October 1, 1987. The depth of the investigation has caused the report to be delayed. We discussed the timing with the senior Resident Inspector.

If any further information is required, please contact us.

Very truly yours,


C. W. Fay
Vice President
Nuclear Power

Enclosure

Copies to NRC Resident Inspector
NRC Regional Administrator, Region III

8712010218 871120
PDR ADBEK 05000266
S PDR

IB22
11

