

Palisades

NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | M | I | P | A | L | 1 | 2 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5

CON'T
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 5 | 5 | 7 | 1 | 1 | 2 | 8 | 7 | 8 | 8 | 0 | 1 | 1 | 2 | 7 | 9 | 9

0 2 | During load reduction in preparation for plant shutdown, the volume control
0 3 | tank was being vented to the waste gas surge tank in order to degas the PCS.
0 4 | Leakage from the open surge tank sightglass drain valve resulted in a
0 5 | gaseous release w/o the 15-day hold-up required by T.S. 3.1.17. Upon
0 6 | discovery, VCT venting was halted. Total activity released was 4.3 Ci,
0 7 | which corresponds to 5.7 percent of the allowable average annual release
0 8 | rate. No hazard to public health or safety resulted.

0 9 | SYSTEM CODE | M | B | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | A | C | C | U | M | U | 14 | COMP. SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

17 | LER/RO REPORT NUMBER | 7 | 8 | 21 | EVENT YEAR | 7 | 8 | 22 | SEQUENTIAL REPORT NO. | 0 | 4 | 0 | 24 | OCCURRENCE CODE | 0 | 1 | 28 | REPORT TYPE | X | 30 | REVISION NO. | 2 | 32

ACTION TAKEN | X | 18 | FUTURE ACTION | X | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | N | 23 | NPRD-4 FORM SUB. | N | 24 | PRIME COMP. SUPPLIER | Z | 25 | COMPONENT MANUFACTURER | Z | 9 | 9 | 9 | 9 | 26

1 0 | The surge tank sightglass drain was being used to drain excess water from
1 1 | the waste gas surge tank, T-67, because the drain trap in the discharge
1 2 | line was inoperable. The drain trap was disassembled and cleaned and is
1 3 | now functioning properly. Operators have been instructed as to proper
1 4 | draining procedures. The tank draining problem will be investigated to

1 5 | FACILITY STATUS | D | 28 | % POWER | 0 | 9 | 0 | 29 | OTHER STATUS | N/A | 30 | METHOD OF DISCOVERY | A | 31 | DISCOVERY DESCRIPTION | Annunicator | 32

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | G | 33 | N | 34 | AMOUNT OF ACTIVITY | 3.019 curie Xe-133 | 35 | LOCATION OF RELEASE | Waste gas surge tank to atmosphere
45 to stack. | 36

1 7 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | N/A | 39

1 8 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | N/A | 41

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | N/A | 43

2 0 | PUBLICITY ISSUED | N | 44 | DESCRIPTION | N/A | 45 | NRC USE ONLY

7901160245