

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

January 3, 1979

Mr. James P. O'Reilly, Director  
U.S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Region II  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

REGULATORY DOCKET FILE COPY

Dear Mr. O'Reilly:

TENNESSEE VALLEY AUTHORITY - BROWNS FERRY NUCLEAR PLANT UNIT 1 - DOCKET  
NO. 50-259 - FACILITY OPERATING LICENSE DPR-33 - REPORTABLE OCCURRENCE  
REPORT BFRO-50-259/7836

The enclosed report provides details concerning scram accumulator level  
switch LS-1-85-34 for CRD 18-07 which would not operate to give  
annunciation for high accumulator level as required by technical  
specification 3.3.A.2.e. This report is submitted in accordance with  
Browns Ferry unit 1 technical specification 6.7.2.b(1).

Very truly yours,

TENNESSEE VALLEY AUTHORITY

H. S. Fox  
Director of Power Production

Enclosure (3)

cc (Enclosure):

Director (3)

Office of Management Information and Program Control  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

Director (40)

Office of Inspection and Enforcement  
U.S. Nuclear Regulatory Commission  
Washington, D.C. 20555

A002  
S  
1/1

7901100214