

NRR-DMPSPeM Resource

From: Green, Kimberly
Sent: Wednesday, January 24, 2018 11:08 AM
To: Lashley, Phil H.
Cc: Lentz, Thomas A. (Licensing); Heintz, Calvin J.
Subject: Acceptance of License Amendment Request to Adopt TSTF-500, Revision 2 (EPID L-2017-LLA-0438)

Follow Up Flag: Follow up
Flag Status: Flagged

Dear Mr. Lashley:

By letter dated December 20, 2017, FirstEnergy Nuclear Operating Company submitted an amendment request for the Perry Nuclear Power Plant, Unit No. 1. The proposed amendment would revise technical specification (TS) requirements related to direct current electrical systems, specifically limiting conditions for operation (LCOs) 3.8.4, 3.8.5, and 3.8.6. The proposed amendment would also add a new Battery and Monitoring Maintenance Program to TS Section 5.5, "Programs and Manuals." The proposed changes are consistent with Technical Specifications Task Force (TSTF) Traveler TSTF-500, Revision 2, "DC Electrical Rewrite - Update to TSTF-360."

The purpose of this email is to provide the results of the U.S. Nuclear Regulatory Commission (NRC) staff's acceptance review of the proposed license amendment request. The acceptance review was performed to determine if there is sufficient technical information in scope and depth to allow the NRC staff to complete its detailed technical review. The acceptance review is also intended to identify whether the application has any readily apparent information insufficiencies in its characterization of the regulatory requirements or the licensing basis of the plant.

Consistent with Section 50.90 of Title 10 of the *Code of Federal Regulations*, an amendment to the license (including the TSs) must fully describe the changes requested, and following as far as applicable, the form prescribed for original applications.

The NRC staff has reviewed your application and concluded that it does provide technical information in sufficient detail to enable the NRC staff to complete its detailed technical review and make an independent assessment regarding the acceptability of the proposed amendment in terms of regulatory requirements and the protection of public health and safety and the environment. Given the lesser scope and depth of the acceptance review as compared to the detailed technical review, there may be instances in which issues that impact the NRC staff's ability to complete the detailed technical review are identified despite completion of an adequate acceptance review. If additional information is needed, you will be advised by separate correspondence.

Based on the information provided in your submittal, the NRC staff has estimated that this licensing request will take approximately 290 hours to complete. The NRC staff expects to complete this review by the requested date of December 31, 2018. If there are emergent complexities or challenges in our review that would cause changes to the initial forecasted completion date or significant changes in the forecasted hours, the reasons for the changes, along with the new estimates will be communicated, during the routine interactions.

These estimates are based on the staff's initial review of the application and they could change, due to several factors including requests for additional information, unanticipated addition of scope to the review, and review by NRC advisory committees or hearing-related activities.

If you have any questions, please contact me at (301) 415-1627.

Sincerely,
Kimberly J. Green, Senior Project Manager
Plant Licensing Branch III
Division of Operating Reactor Licensing
Office of Nuclear Reactor Regulation

Hearing Identifier: NRR_DMPS
Email Number: 159

Mail Envelope Properties (SN6PR0901MB2447C7912007522FD9A0656E8FE20)

Subject: Acceptance of License Amendment Request to Adopt TSTF-500, Revision 2
(EPID L-2017-LLA-0438)
Sent Date: 1/24/2018 11:08:15 AM
Received Date: 1/24/2018 11:08:00 AM
From: Green, Kimberly

Created By: Kimberly.Green@nrc.gov

Recipients:
"Lentz, Thomas A. (Licensing)" <talentz@firstenergycorp.com>
Tracking Status: None
"Heintz, Calvin J." <cjheintz@firstenergycorp.com>
Tracking Status: None
"Lashley, Phil H." <phlashley@firstenergycorp.com>
Tracking Status: None

Post Office: SN6PR0901MB2447.namprd09.prod.outlook.com

Files	Size	Date & Time
MESSAGE	3320	1/24/2018 11:08:00 AM

Options
Priority: Standard
Return Notification: No
Reply Requested: No
Sensitivity: Normal
Expiration Date:
Recipients Received: Follow up