

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M T P A L I 1 2 0 0 - 0 0 0 0 0 0 - 0 0 3 4 1 1 1 1 1 4 5
7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58 5

CONT
01 REPORT SOURCE I 6 0 5 1 0 0 0 2 5 1 5 7 1 1 0 1 0 2 7 1 9 8 4 1 1 5 7 1 9 9
7 8 90 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 During refueling operations, a PCS Boron sample was not performed during
03 one shift on 10/2/79, as required by TS 3.8.1g Occurrence reportable
04 per TS 6.9.2.b3 Boron sample taken on following shift was within
05 specs; therefore no threat to public health or safety existed. Event
06 is not repetitive. Event classified reportable on 10/19/79.
07
08

09 SYSTEM CODE R R 11 CAUSE CODE A 12 CAUSE SUBCODE X 13 COMPONENT CODE Z Z Z Z Z Z 14 COMP. SUBCODE Z 15 VALVE SUBCODE Z 16
17 LER/RO REPORT NUMBER 7 9 21 EVENT YEAR 7 9 22 SEQUENTIAL REPORT NO. 0 4 3 24 OCCURRENCE CODE 0 3 28 REPORT TYPE L 30 REVISION NO. 0 32
ACTION TAKEN H 18 FUTURE ACTION Z 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. N 24 PRIME COMP. SUPPLIER Z 25 COMPONENT MANUFACTURER Z 9 9 9 9 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 The failure to draw the sample was oversight by the individual assigned
11 to perform the analysis. The significance of obtaining PCS boron samples
12 during refueling has been reviewed with chemistry dept personnel. Because
13 of the isolated nature of this occurrence, no further corrective action
14 is contemplated.

15 FACILITY STATUS H 28 % POWER 0 0 0 29 OTHER STATUS NA 30 METHOD OF DISCOVERY D 31 DISCOVERY DESCRIPTION Audit 32

16 ACTIVITY CONTENT Z 33 RELEASED OF RELEASE Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43

20 ISSUED N 44 DESCRIPTION NA 45
PUBLICITY
NRC USE ONLY