

REGULATORY DOCKET FILE COPY

Docket No. 50-255

DISTRIBUTION

Docket
 NRC PDR
 Local PDR
 ORB #2 Reading
 NRR Reading
 DEisenhut
 RHVo1lmer
 OELD
 OI&E (3)
 DLZiemann
 RDSilver
 HSmith
 NSIC
 TERA
 ACRS (16)
 DCrutchfield
 TTelford

CNelson
 GCwalina
 EImbro
 CAnderson
 JIbarra (c/oCNelson)

FEB 05 1980

Mr. David P. Hoffman
 Nuclear Licensing Administrator
 Consumers Power Company
 212 West Michigan Avenue
 Jackson, Michigan 49201

Dear Mr. Hoffman:

On January 17 and 18, 1980, we visited Palisades Plant to review your implementation of the Category A lessons learned requirements. Specific items which we determined needed further licensee action/clarification were discussed and a list of these items is enclosed. Additional detail has been provided in some cases.

Since it is our intent to complete the review of Category A lessons learned implementation prior to the restart of your facility, please provide a written response addressing each of the items within 10 days from the date of this letter.

Sincerely,

Original signed by
 Dennis L. Ziemann
 Dennis L. Ziemann, Chief
 Operating Reactors Branch #2
 Division of Operating Reactors

Enclosure:
 Request for Additional
 Information

cc w/enclosure:
 See next page

T
 App
 3
 30.02220 143 P

DR

OFFICE ▶	DOR:ORB #2	LLTF	DOR:ORB #2		
SURNAME ▶	RDSilver:ah	CNelson	DLZiemann		
DATE ▶	2/5/80	2/5/80	2/5/80		



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

February 5, 1980

Docket No. 50-255

Mr. David P. Hoffman
Nuclear Licensing Administrator
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Dear Mr. Hoffman:

On January 17 and 18, 1980, we visited Palisades Plant to review your implementation of the Category A lessons learned requirements. Specific items which we determined needed further licensee action/clarification were discussed and a list of these items is enclosed. Additional detail has been provided in some cases.

Since it is our intent to complete the review of Category A lessons learned implementation prior to the restart of your facility, please provide a written response addressing each of the items within 10 days from the date of this letter.

Sincerely,

A handwritten signature in cursive script that reads "Dennis L. Ziemann".

Dennis L. Ziemann, Chief
Operating Reactors Branch #2
Division of Operating Reactors

Enclosure:
Request for Additional
Information

cc w/enclosure:
See next page

February 5, 1980

cc-w/enclosure:

M. I. Miller, Esquire
Isham, Lincoln & Beale
Suite 4200
One First National Plaza
Chicago, Illinois 60670

Mr. Paul A. Perry, Secretary
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Judd L. Bacon, Esquire
Consumers Power Company
212 West Michigan Avenue
Jackson, Michigan 49201

Myron M. Cherry, Esquire
Suite 4501
One IBM Plaza
Chicago, Illinois 60611

Ms. Mary P. Sinclair
Great Lakes Energy Alliance
5711 Summerset Drive
Midland, Michigan 48640

Kalamazoo Public Library
315 South Rose Street
Kalamazoo, Michigan 49006

Township Supervisor
Covert Township
Route 1, Box 10
Van Buren County, Michigan 49043

Office of the Governor (2)
Room 1 - Capitol Building
Lansing, Michigan 48913

Director, Technical Assessment
Division
Office of Radiation Programs
(AW-459)
U. S. Environmental Protection
Agency
Crystal Mall #2
Arlington, Virginia 20460

U. S. Environmental Protection
Agency
Federal Activities Branch
Region V Office
ATTN: EIS COORDINATOR
230 South Dearborn Street
Chicago, Illinois 60604

Charles Bechhoefer, Esq., Chairman
Atomic Safety and Licensing Board
Panel
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Dr. George C. Anderson
Department of Oceanography
University of Washington
Seattle, Washington 98195

Dr. M. Stanley Livingston
1005 Calle Largo
Santa Fe, New Mexico 87501

Resident Inspector
c/o U. S. NRC
P. O. Box 87
South Haven, Michigan 49090

Palisades Plant
ATTN: Mr. J. G. Lewis
Plant Manager
Covert, Michigan 49043

PALISADES

IMPLEMENTATION OF SHORT TERM LESSONS LEARNED REQUIREMENTS ITEMS TO BE COMPLETED PRIOR TO PLANT STARTUP

2.1.1 EMERGENCY POWER SUPPLIES

- Provide sufficient pressurizer heater capacity, powered from both onsite emergency power supplies, to operate in the natural circulation mode.
- Complete PORV and block valve power supply modifications.

2.1.3a VALVE POSITION INDICATION

- Complete installation of valve position indicators.
- Provide alarm (actuation) setpoints for acoustic monitors.
- Provide justification for alarm setpoints including demonstration that acoustic monitors on a closed relief line will not alarm during relief through another line.
- Identify non-qualified parts of the valve position indication system and provide schedule for qualification.
- Incorporate use of valve position indicators in operating procedures.

2.1.3b INSTRUMENTATION FOR INADEQUATE CORE COOLING

- Complete installation of subcooling meters.
- Develop and implement procedures for determining subcooled margin using meters as well as backup methods.
- Provide a commitment to upgrade qualifications and ranges of the subcooling meters (including pressure and temperature inputs) to RG1.97. Provide schedule.

2.1.4 CONTAINMENT ISOLATION

- Justify the acceptability of installed radiation detection as a diverse containment isolation signal (Bechtel Report).
- Justify the lack of automatic isolation of the component cooling water system although it is classified as a non-essential system
- Inadequate justification has been presented to support the acceptability of the check valve outside containment meeting the automatic isolation requirement for the non-safety grade instrument air system.

- Update documents submitted to NRC.

2.1.5c HYDROGEN RECOMBINER PROCEDURES

- Revise procedures to provide basis for recombiner operation in addition to containment air sample.

2.1.6a SYSTEMS INTEGRITY

- Include CVCS and Gaseous Waste System in the leak reduction and preventative maintenance programs or justify why these systems will not be used for accident mitigation or recovery.
- Include the RCS sample system in leak reduction and preventative maintenance program.
- Provide individual system leakage rates for all systems tested.
- Assure the long term leak reduction (preventative maintenance) program is incorporated into the plant operating procedures.

2.1.6b PLANT SHIELDING

- If necessary, pending review for 2.1.6a, include CVCS and Gaseous Waste System in this design review.
- Include RCS sampling system in this design review.

Note - These items not required for startup.

2.1.7b AFW FLOW INDICATION

- Complete installation of modifications.

2.1.8a SAMPLING

- Implement procedures for obtaining RCS sample.
- Complete modifications and implement procedures for obtaining containment air samples.

2.1.8b EFFLUENT MONITORS

- The October 30, 1979 letter from H. Denton (pgs. 33-35) contains a list of specific information required for estimating Noble Gas and Radioiodine and Particulate Effluents. Provide the required information for all monitored locations.
- Assure that steam release monitoring will provide adequate estimates of releases from all steam dumps. (Note: steam release is to be monitored for noble gases only.)

2.1.8c PORTABLE IODINE INSTRUMENTATION

- Implement procedures to specify that iodine samples be taken in all areas occupied by essential personnel following an accident.

2.2.1a SHIFT SUPERVISOR RESPONSIBILITIES

- Justify allowing the shift supervisor to leave the control room during an accident.
- Modify Administrative Procedures to clearly specify the requirements of part 2.c of this item.
- Update documents submitted.

2.2.1b SHIFT TECHNICAL ADVISOR

- STA should evaluate LER's from other plants.

2.2.2b TECHNICAL SUPPORT CENTER

- Install phone jacks in TSC (both locations).
- Provide plant data in TSC.
- Illustrate lines of communication (onsite) during accident in Emergency Plan Implementation Procedures.
- Implement procedures for accomplishing TSC function should one portion of TSC become uninhabitable.
- Implement procedures for monitoring radiation per item 2.1.8c.

2.2.2c OPERATIONAL SUPPORT CENTER

- Update submittal to show OSC in actual location.
- Implement procedures for monitoring radiation per item 2.1.8c.
- Provide communications between control room and OSC.