

NRC FORM 356
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 M I P A L 1 2 0 0 - 0 0 0 0 0 0 - 0 0 0 3 4 1 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
01 REPORT SOURCE L 6 0 5 0 0 0 2 5 5 7 0 8 1 2 8 0 8 0 9 1 7 8 0 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)
02 During venting of the quench tank to the waste gas surge tank, an
03 unplanned gaseous release occurred w/o 15 day minimum holdup required by
04 TS 3.9.17. Release represented approx. 11 percent of release rate limit
05 of TS 3.9.12. Event reportable per TS 6.9.2A2. Venting of quench tank
06 was stopped upon receipt of stack monitor alarm.
07
08

09 SYSTEM CODE M B 11 CAUSE CODE E 12 CAUSE SUBCODE B 13 COMPONENT CODE V A L V E X 14 COMP. SUBCODE D 15 VALVE SUBCODE D 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 8 0 23 SEQUENTIAL REPORT NO. 0 2 7 27 OCCURRENCE CODE 0 1 28 REPORT TYPE X 31 REVISION NO. 1 32
18 ACTION TAKEN A 33 FUTURE ACTION Z 34 EFFECT ON PLANT Z 35 SHUTDOWN METHOD Z 36 HOURS 0 0 0 0 37 ATTACHMENT SUBMITTED N 41 NRPD-4 FORM SUB. N 42 PRIME COMP. SUPPLIER A 43 COMPONENT MANUFACTURER V 1 3 5 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)
10 The closed isolation valve to waste gas compressor C-50B leaked,
11 permitting leakage from WGST to atmos. (C-50B was disassembled for
12 repairs). Disassembly of valve revealed pin holding diaphragm to
13 operating shaft was broken. Condition prevented diaphragm movement.
14 Pin was replaced.

15 FACILITY STATUS E 28 % POWER 0 8 8 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Stack monitor alarms 32
7 8 9 10 12 13 44 45 46

16 ACTIVITY CONTENT RELEASED OF RELEASE G 33 M 34 AMOUNT OF ACTIVITY Approx 42 Ci Total 35 LOCATION OF RELEASE Main Stack 36
7 8 9 10 11 44 45 80

17 PERSONNEL EXPOSURES NUMBER 0 0 0 37 TYPE Z 38 DESCRIPTION NA 39
7 8 9 11 12 13 80

18 PERSONNEL INJURIES NUMBER 0 0 0 40 DESCRIPTION NA 41
7 8 9 11 12 13 80

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z 42 DESCRIPTION NA 43
7 8 9 11 12 13 80

20 PUBLICITY ISSUED Y 44 DESCRIPTION News release 8-13-80 45 NRC USE ONLY
7 8 9 10 45 68 69 80

8009230618