PALISADES PLANT

NRC FORM 366 (7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | LICENSEE CODE: M I P A L 1 (2) | LICENSE NUMBER: 0 0 - 0 0 0 0 0 - 0 0 (3) | LICENSE TYPE: 4 1 1 1 1 (4) | CAT (5)

CON'T 01 | REPORT SOURCE: L (6) | DOCKET NUMBER: 0 5 0 0 0 2 5 5 (7) | EVENT DATE: 0 8 2 6 8 0 (8) | REPORT DATE: 0 9 2 6 8 0 (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 With the plant in hot shutdwon, preparations were being made to conduct
03 check valve ISI surveillance per procedure QO-8. During pre-test review
04 of the procedure it was determined that one portion of the procedure
05 required closing and reopening the SIRW tank outlet valves. (One at a time).
06 Performance of the procedure would have resulted in ESF equipment being
07 made inoperable (redundant equipment would not have been simultaneously
08 affected by the test). Reportable per TS 6.9.2.B3.

09 | SYSTEM CODE: S F (11) | CAUSE CODE: D (12) | CAUSE SUBCODE: Z (13) | COMPONENT CODE: Z Z Z Z Z Z (14) | COMP. SUBCODE: Z (15) | VALVE SUBCODE: Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR: 8 0 | — | SEQUENTIAL REPORT NO.: 0 3 4 | / | OCCURRENCE CODE: 0 3 | REPORT TYPE: L | — | REVISION NO.: 0

ACTION TAKEN: G (18) | FUTURE ACTION: G (19) | EFFECT ON PLANT: Z (20) | SHUTDOWN METHOD: Z (21) | HOURS (22): 0 0 0 0 | ATTACHMENT SUBMITTED: N (23) | NPRD-4 FORM SUB.: N (24) | PRIME COMP. SUPPLIER: Z (25) | COMPONENT MANUFACTURER: Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Procedure did not adequately address plant conditions required for per-
11 formance of test. Procedure has been revised to require plant to be in
12 cold shutdown prior to performing the portion necessitating stroking
13 SIRW tank outlet valves. The portion of the test in question will be
14 incorporated into a separate procedure having proper initial conditions.

15 | FACILITY STATUS: G (28) | % POWER: 0 0 0 (29) | OTHER STATUS (30): Hot Shutdown | METHOD OF DISCOVERY: A (31) | DISCOVERY DESCRIPTION (32): Review of procedure prior to use

16 | ACTIVITY RELEASED: Z (33) | CONTENT OF RELEASE: Z (34) | AMOUNT OF ACTIVITY (35): NA | LOCATION OF RELEASE (36): NA

17 | PERSONNEL EXPOSURES NUMBER: 0 0 0 (37) | TYPE: Z (38) | DESCRIPTION (39): NA

18 | PERSONNEL INJURIES NUMBER: 0 0 0 (40) | DESCRIPTION (41): NA

19 | LOSS OF OR DAMAGE TO FACILITY (43) TYPE: Z (42) | DESCRIPTION: NA

20 | PUBLICITY ISSUED: N (44) | DESCRIPTION (45): NA | NRC USE ONLY

8009300499

SEP 29 1980