

# REGULATORY DOCKET FILE COPY

Docket No. 50-255

Mr. David P. Hoffman  
 Nuclear Licensing Administrator  
 Consumers Power Company  
 212 West Michigan Avenue  
 Jackson, Michigan 49201

**DISTRIBUTION:**  
 Docket  
 NRC PDR  
 LPDR  
 TERA  
 NSIC  
 NRR Reading  
 ORB #5 Reading  
 DEisenhut  
 RPurple  
 TNovak  
 GLainas  
 DKragh (11 - SEP Files)

RTedesco  
 JOlshinski  
 DCrutchfield  
 RScholl  
 DAllison  
 WRussell, SEPB  
 OELD  
 OI&E (3)  
 HSmith  
 Project Mgr.  
 ACRS (16)  
 JHeltemes

Dear Mr. Hoffman:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C,  
 VI-10, VII-3, VIII-2 AND VIII-3 (PALISADES PLANT)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,

Dennis M. Crutchfield, Chief  
 Operating Reactors Branch #5  
 Division of Licensing, NRC

Enclosure:  
 Request for Additional  
 Information on SEP  
 Topics

cc w/enclosure:  
 See next page

8010150631

OFFICE	DL: ORB #5/LA	DL: ORB #5/PM	DL: ORB #5/C		
SURNAME	HSmith: rj	TWambach	DCrutchfield		
DATE	9/19/80	9/12/80	9/16/80		



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555

September 16, 1980

Docket No. 50-255

Mr. David P. Hoffman  
Nuclear Licensing Administrator  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Dear Mr. Hoffman:

RE: REQUEST FOR ADDITIONAL INFORMATION ON SEP TOPICS VI-7.B, VI-7.C,  
VI-10, VII-3, VIII-2 AND VIII-3 (PALISADES PLANT)

We are continuing our review of SEP Topics VI-7.B, ESF Switchover from Injection to Recirculation Mode; VI-7.C, ECCS Single Failure Criteria; VI-10.A, Testing of Reactor Trip System and ESF; VI-10.B, Shared Engineered Safety Features; VII-3, Systems Required for Safe Shutdown; VIII-2, Onsite Emergency Power Systems - Diesel Generator; VIII-3.A, Station Battery Test Requirements and VIII-3.B, DC Power System Bus Voltage Monitoring and Annunciation. We have found that additional information described in the enclosure to this letter is needed.

We request your response within 45 days of your receipt of this letter.

Sincerely,

  
Dennis M. Crutchfield, Chief  
Operating Reactors Branch #5  
Division of Licensing

Enclosure:  
Request for Additional  
Information on SEP  
Topics

cc w/enclosure:  
See next page

cc w/enclosure:

M. I. Miller, Esquire  
Isham, Lincoln & Beale  
Suite 4200  
One First National Plaza  
Chicago, Illinois 60670

Mr. Paul A. Perry, Secretary  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Judd L. Bacon, Esquire  
Consumers Power Company  
212 West Michigan Avenue  
Jackson, Michigan 49201

Myron M. Cherry, Esquire  
Suite 4501  
One IBM Plaza  
Chicago, Illinois 60611

Ms. Mary P. Sinclair  
Great Lakes Energy Alliance  
5711 Summerset Drive  
Midland, Michigan 48640

Kalamazoo Public Library  
315 South Rose Street  
Kalamazoo, Michigan 49006

Township Supervisor  
Covert Township  
Route 1, Box 10  
Van Buren County, Michigan 49043

Office of the Governor (2)  
Room 1 - Capitol Building  
Lansing, Michigan 48913

Director, Technical Assessment  
Division  
Office of Radiation Programs  
(AW-459)  
U. S. Environmental Protection  
Agency  
Crystal Mall #2  
Arlington, Virginia 20460

U. S. Environmental Protection  
Agency  
Federal Activities Branch  
Region V Office  
ATTN: EIS COORDINATOR  
230 South Dearborn Street  
Chicago, Illinois 60604

Charles Bechhoefer, Esq., Chairman  
Atomic Safety and Licensing Board  
Panel  
U. S. Nuclear Regulatory Commission  
Washington, D. C. 20555

Dr. George C. Anderson  
Department of Oceanography  
University of Washington  
Seattle, Washington 98195

Dr. M. Stanley Livingston  
1005 Calle Largo  
Santa Fe, New Mexico 87501

Resident Inspector  
c/o U. S. NRC  
P. O. Box 87  
South Haven, Michigan 49090

Palisades Plant  
ATTN: Mr. J. G. Lewis  
Plant Manager  
Covert, Michigan 49043

William J. Scanlon, Esquire  
2034 Pauline Boulevard  
Ann Arbor, Michigan 48103

Mr. Richard E. Schaffstall  
KMC, Incorporated  
1747 Pennsylvania Avenue, N. W.  
Washington, D. C. 20006

REQUEST FOR ADDITIONAL INFORMATION  
ON SEP TOPICS  
VI-7.B, VI-7.C, VI-10, VII-3, VIII-2  
AND VIII-3

As a result of our preliminary review of the subject topics, we will need the information described below in order to determine: (1) how many inverters may be placed on a single power supply during operation or while shutdown, and (2) the potential consequences of losing such power supplies.

1. Quantify the number of instrument inverters in your plant and for each inverter:
  - a) identify the inverter and its power supplies; and
  - b) describe the switching features that are provided to switch inverter power supplies and inverter loads (including synchronization circuits).
2. Provide the requirements for:
  - a) testing the transfer path's described in your responses to 1 above, and
  - b) limiting the number of redundant load groups that may be placed on any maintenance power source during each operating condition.
3. Describe the consequence of one or more load groups on a single dc source losing power (e.g. automatic initiation of ECCS, automatic initiation of transfer from ECCS injection made to recirculation mode, loss of indication in the control room, loss of annunciators, loss of plant communications, loss of emergency telephones).