

MANAGEMENT ASSESSMENT PROCESS in STORAGE - DRAFT
ML 17289A 237 PDF

Mail Cindy Bladley TWEN-8-D-36 M/NRC20555.c
LINE 15-23 is a ~~statement~~ ^{JUSTIFICATION} as to what maybe

3.1

THIS is a review which attempts to look at all combinations and environments which might cause severe degradation.

Although this approach is very time and expertise intensive this approach has a history of failure to expose the obvious at Fukushima ARKANSAS ONE, GINNA ad naseum, ad infinitum (argument to nausea and pain repetition) There is NO REASON to believe that this approach will be more ~~acceptable~~ predictive for MAPS.

At Fukushima this approach failed to foresee a 9+ Earthquake and a Tsunami greater than 35' which allowed several reactors to fail catastrophically.

Arkansas #1 experienced a crane drop when in a crane site dropped a 1/2 million pound stator thru a floor and the ceiling of a switchgear room. The ~~sub~~ SG room flooded and remained flooded for 11 HOURS. Courageous work by electricians ~~stop~~ RESTARTED THE COOLING FLUID FLOW BEFORE THE LIQUID LEVEL IN THE SPENT FUEL POOL ~~was~~ ~~fell~~ ~~fell~~ DROPPED TO THE POINT OF ALLOWING A FIRE TO START there in.

Conversely the approach of looking at history to learn ~~app~~ lessons is a abandoned in this draft, a serious deficiency. History is a great teacher. If we fail to learn from history surely we ~~are~~ will repeat the mistakes of the past.


At Fukushima management refused to see the possibility of a 9+ Earthquake. IT HAPPENED.

At ARKANSAS No.1 crane maintenance was delayed for economic considerations. A half million pound stator PROPPED.

I hope that all reactors have separated ~~that~~ electrical runs properly.

12/7/17

Mr. Lewis E.P.E
(Retired)



SUNSI Review Complete
Template = ADM - 013
E-RIDS = ADM-03
Add = John Wisec (RWD)

62 FEL 49233 (6)
11/21/17

RECEIVED MAA

ALKALI-SILICA Reaction


Since much of this storage is in concrete overfalls, THE CHANCE OF SILICA ALKALI REACTIONS ARE ABUNDANT.

My concern is that Alkali silica reactions CAN often ~~be~~ mistaken for other processes and N.P. These CONFOUNDING processes include, BUT ARE NOT LIMITED TO

1. POOR quality causing degradation & failures. High quality concrete is in short supply, a condition money is often used to cure. When money is short, low quality concrete flows!
2. DEGRADATION due to acid exposure, resembles Alkali-Silica reaction. The "cure" for Alkali-concrete reaction & acid exposure will degrade concrete further and faster.
3. POOR quality handling or production can produce concrete that appears as Alkali-Silica problem. "Cures" ARE ineffective over a length of time.

These possibilities seem to be outside this NOREG, but are not outside the scope of reality.

12/7/17



Mr. Marvin Lewis
3133 Fairfield St
Philadelphia, PA 19136

Mr. Lewis PE
(Retired)