## Appendix A

## NOTICE OF VIOLATION

Consumers Power Company

Docket No. 50-255

Based on the inspection conducted on October 20-24, 1980, it appears that certain of your activities were in noncompliance with NRC requirements, as noted below. Items 1 through 4 are deficiencies.

Technical Specification 6.9.3.1.C states, in part, that an annual report
of the results of the aquatic, terrestrial, and meteorological environmental monitoring program performed during the previous twelve months of
operation shall be submitted to the NRC within 90 days after January 1
of each preceding calendar year.

Contrary to the above, the report for 1979 was not submitted until October 23, 1980.

2. Technical Specification 6.9.3.C.1. states, in part, that the Nonradio-logical Environmental Monitoring Program report shall include data and narrative summaries, interpretations, ... of the nonradiological environmental monitoring programs required in Section 4.11. For each medium sampled during the year, a list and map of the sampling locations and total number of samples shall be included.

Contrary to the above, the 1979 Nonradiological Environmental Monitoring Report submitted did not contain narrative summaries, a list and map of sampling locations, and the results of all programs required in Section 4.11.

3. Technical Specification 4.11.4 states that aquatic samples shall be taken according to the following schedule: (b) Mixing basin water temperature prior to discharge to the lake - measure continuously during cooling system operation and record hourly.

Contrary to the above, no hourly recordings of water temperature prior to discharge to the lake were performed during the period April 28, 1980 through July 31, 1980.

4. Technical Specification 6.9.3.1.A.2.c(4) states, in part, that "Total curies for each of the radionuclides in particulate form determined to be released based on analyses performed" shall be included in a semiannual report on the radioactive discharges released from the site.

Contrary to the above, the licensee has not accurately reported the curie content of the particulates released from the site.