



**Consumers  
Power  
Company**

General Offices: 212 West Michigan Avenue, Jackson, Michigan 49201 • (517) 788-0550

March 18, 1981



DSB

Mr James G Keppler  
Office of Inspection and Enforcement  
Region III  
U S Nuclear Regulatory Commission  
799 Roosevelt Road  
Glen Ellyn, IL 60137

DOCKET 50-255 - DPR-20 - PALISADES  
PLANT - SPECIAL NONRADIOLOGICAL  
ENVIRONMENTAL MONITORING REPORT

On the reverse side is an NPDES Notification issued by Consumers Power Company on March 16, 1981. It is being submitted to you in accordance with Technical Specification 6.9.3.1.D.

David P Hoffman  
Nuclear Licensing Administrator

CC Director, Office of Nuclear Reactor Regulation  
Director, Office of Inspection and Enforcement  
NRC Resident Inspector-Palisades

A007  
S  
1/1

MAR 20 1981

8103240412  
5

NPDES NOTIFICATION  
Apparent Difference From Daily Average/Maximum Limitation

March 16, 1981

Plant: Palisades Plant Permit No: MI-0001457  
Outfall Description: Turbine Sump Oil Separator Waste (OOG) Outfall No: 800218  
Parameter: Oil and Grease (Freeon) Parameter No: 00556

1. Date of Incident: February 28, 1981
2. Identification of specific effluent limitation or monitoring requirement affected:  
  
Daily average oil and grease limitation of 15 mg/l.
3. Description of Incident:  
  
For February the daily average oil and grease concentration was 62.4 mg/l
4. Apparent Cause:  
  
High values recorded on 2/3/81, 2/23/81 and 2/24/81 as previously explained in the Company's reports dated 2/13/81 and 3/3/81.
5. If not immediately corrected, the anticipated time the condition is expected to continue:  
  
NA
6. Corrective Action - The following corrective action was taken or will be taken to reduce, eliminate and prevent recurrence:  
  
Each case was handled separately. The cause was identified and corrective action was taken as previously reported.
7. Additional Comments:  
  
NA
8. Signed: Ronald L Fobes

Revised 1/19/81

rp0381-0195a-57

11  
16