

CONSUMERS POWER COMPANY
Docket 50-255
Request for Change to the Technical Specifications
License DPR-20

For the reasons hereinafter set forth, it is requested that the Technical Specifications contained in the Provisional Operating License DPR-20, Docket 50-255, issued to Consumers Power Company on October 16, 1972, for the Palisades Plant be changed as described in Section I below:

I. Change

Add Section 4.18 "Integrity of Systems Outside Containment Likely to Contain Radioactive Fluids" as shown on attached proposed page.

II. Discussion

The above proposed Technical Specifications change is requested by the NRC and fulfills the requirement specified in NUREG-0737, Item III.D.1.1. This change provides a preventative maintenance program to reduce leakage to as-low-as-practical levels for systems outside containment.

III. Conclusion

Based on the foregoing, both the Palisades Plant Review Committee and the Safety and Audit Review Board have reviewed this change and find it acceptable.

CONSUMERS POWER COMPANY

BY

R B DeWitt

R B DeWitt, Vice President
Nuclear Operations

Sworn and subscribed to before me this 12th day of November 1981.

Helen I. Dempski

Helen I. Dempski, Notary Public
Jackson County, Michigan

My commission expires December 14, 1983.

811170293 811112
PDR ADOCK 05000255
PDR