



Consumers
Power
Company

General Offices: 212 West Michigan Avenue, Jackson, MI 49201 • (517) 788-0550

January 4, 1982

Dennis M Crutchfield, Chief
Operating Reactors Branch No 5
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555



DOCKET 50-255 - LICENSE DPR-20
PALISADES PLANT - SEP TOPIC VI-4, CONTAINMENT ISOLATION SYSTEM

By letter dated June 9, 1981, the NRC transmitted a draft evaluation of Topic VI-4 for the Palisades Plant. Consumers Power Company's detailed comments on the staff evaluation were provided in a letter dated August 10, 1981. In early December, by a telephone conversation between SBrown, et.al., of the NRC and RAVincent, CPCo, several questions were raised concerning the information submitted in CPCo's August 10 letter. The following information is provided in response to those questions.

Attached is a revised table of containment penetrations which shows the isolation valve positions under various conditions and any automatic closure signals which are provided. This table has been modified to correct some apparent inconsistencies in previous versions, and to reflect changes in the plant which were made during the 1981 refueling outage. In addition, notes have been added to clearly define each of the symbols which appear in the table. This revised table should address most of the questions raised.

The other general question raised during the telephone conversation concerned the need for instrument or service air to maintain long term core cooling in a post-accident condition. The question was oriented toward the possible need to reposition containment isolation valves in this situation.

Post-accident long-term cooling has been discussed with the staff on numerous occasions over the past several years. The most recent CPCo actions were the installation of extensive modifications during the 1981 refueling outage, and the submission of the long-term cooling design report by CPCo letter of October 9, 1981.

With respect to the containment isolation valves, loss of instrument or service air will not jeopardize the ability of the plant to maintain long-term cooling. With respect to portions of other systems or piping needed for long-term cooling, some air-operated valves do exist which could affect preferred long-term cooling flow paths if air were lost (e.g. loss of air to CV-3025 and CV-3006 could prevent use of the shutdown cooling system flow path for long-term cooling following a postulated small break LOCA). Alternative methods exist, however, which in

A035
S
1/1

8201130150/820104
PDR ADDCK 05000255
P PDR

DMCrutchfield
Palisades Plant
January 4, 1982

2

the aggregate provide a single failure proof means of assuring long-term cooling. For a more detailed discussion of the above, your attention is directed to CPCo letter of October 9, 1981. It should be noted that long-term cooling is still an active issue under NRC review outside the SEP.

Robert A Vincent

Robert A Vincent
Senior Licensing Engineer

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

Attachments

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 1 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC	IC	POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS	
							NOR- MAL	SHUT- DN	POST LOCA				
1	Purge Air Supply (48"Ø)	A1	CV1807 CV1808 508VAS -	AO BUTF VLV AO BUTF VLV MAN GL TEST VLV TEST CONNECT	X X X X		NC NC LC CAP	O/C O/C C C	C C C -	N	CIS CIS -	Blank Flanged; Vent. Syst. Valves Presently Not Used in Modes 1-4	
2	Main Stm Line (SGE50A) (36"Ø)	C1	CV0510 MOVO510A	POS CH'K VLV MO BYPASS VLV	X X		NO NC	C C	C C	C C	Y	LOW S/G PRESS RM	Loss of Air, CV-0510 Remains in Position Due to Cross Connections with High Press Air and Accumulators
3	Main Stm Line (SGE50B) (36"Ø)	C1	CV0501 MOVO501A	POS CH'K VLV MO BYPASS VLV	X X		NO NC	C C	C C	C C	Y	LOW S/G PRESS RM	Loss of Air, CV-0501 Remains in Position Due to Cross Connection with High Press Air and Accumulators
4	Purge Air Exhaust (48"Ø)	A1	CV1803 CV1805 CV1806 506VAS	AO BUTF VLV AO BUTF VLV AO BUTF VLV MAN GL TEST VLV	X X X X		NC NC NC LC	O/C O/C O/C C	C C C C	C C C -	N	CIS CIS CIS	Blank Flanged; Vent. Syst. Valves Presently Not Used in Modes 1-4
4a	Purge Air Exhaust Sample Line (3"Ø)	A1	100VAS 101VAS 507VAS -	MAN GA VLV MAN GA VLV MAN GL TEST VLV TEST CONN /w CAP	X X X X		LC LC LC C	C C C C	C C C -	-	N	-	
5	SIG (E50A) Bottom Blow Down (2"Ø)	C2	CV0767 CV0771 567MS -	AO ANGLE VLV AO ANGLE VLV MAN GL TEST VLV TEST CONN /w CAP	X X X X		NO NO LC C	C C C C	C C C -	N	CIS CIS -		
6	S/G (E50B) Bottom Blow Down (2"Ø)	C2	CV0768 CV0770 568MS -	AO ANGLE VLV AO ANGLE VLV MAN GL TEST TEST CONN /w CAP	X X X X		NO NO LC C	C C C C	C C C -	N	CIS CIS -		
7	Feedwater to S/G (E50A) (18"Ø)	C1	746FW 6" N218R-704 18" N218R-702	MAN GL VLV CHECK VLV CHECK VLV	X X X		LC C O	C C O	C C C	- - -	N Y Y	- REVΔP REVΔP	Aux FW Main FW

TABLE 1

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

PAGE 2 OF 13

PENE-TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC	LOCATION IC	NOR-MAL	SHUT DN	POST LOCA	PWR FAIL.	ESS-EN-TIAL	ACTUA-TION	REMARKS
8	Feedwater to S/G (E50B)	C1 18"	747FW N218R-701 N218R-703	MAN GL DRAIN VLV CHECK VLV CHECK VLV	X X X		LC O C	C C C	C C C	- - -	N Y Y	-REV ^A P REV ^A P	Main FW Aux FW
9	Spare	-											
10	Service Air (2" ϕ)	A2	122CAS 401CAS 142CA T	MAN GA VLV CHECK VLV MAN GL TEST VLV TEST CONN /w CAP	X X X X		LC C LC C	O/C O/C C C	C C C C	- - - -	N	-REV ^A P	
11	Condensate to Shield Cooling Surge Tank (1 $\frac{1}{2}$ " ϕ)	C2	CV0939 401CDS 536CDS 536ACD T	AO GA VLV CHECK VLV MAN GL TEST VLV MAN GL TEST VLV TEST CONN /w CAP	X X X X X		NO O LC LC C	O O/C C C C	C C C C C	C - - - -	N	CIS REV ^A P - -	
12	Service Water Supply (16" ϕ)	X	CV0847 CV0869 CV0865 CV0862 CV0870 571SWS 570SW 508SW 560SW 266SW 265SW	AC BUTF VLV AC BUTF VLV AC BUTF VLV AC BUTF VLV AC BUTF VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV	X X X X X X X X X X X		NO NO NO NO NO LC LC LC LC LC	O O O O O C C C C C	O O O O O C C C C C	O O O O O - - - - -	Y Y Y Y Y N N N N N	MAN MAN MAN MAN MAN - - - - -	
13	Service Water Return (16" ϕ)	X	CV0824 572SWS CV0867 CV0843 CV0864 CV0863 CV0861 CV0838 CV0873 CV0872	AC BUTF VLV MAIN GA TEST VLV AC BUTF VLV AO GL VLV AC BUTF VLV AO GL VLV AC BUTF VLV AO GL VLV AC BUTF VLV AO GL VLV	X X X X X X X X X X X		NO LC NC NO NC NO NC NO NC NO	O C C O C O C O C O	O - O O O O O O O O	O - C C O O C O I	Y N Y N Y N Y N Y N	MAN -SIS TC SIS TC SIS TC SIS TC TC	SIS Trips Normal Fan Which in Turn Opens Valve

TABLE 1

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1PAGE 3 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS	
					OC	IC	NOR- MAL	SHUT DN	POST LOCA	PWR FAIL.			
14	Component Cooling Water in (10"Ø)	C2	CV0910 257-0910CC 507CC -	AC BUTF VLV CHECK VLV MAN GL TEST VLV TEST CONN /w CAP	X X X X		NO O LC C	NO O LC C	C C C C	O - - -	N	SIS REV^P -	Auto Reopen on SIS Reset
15	Component Cooling Water Out (10"Ø)	C2	CV0911 CV0940 508CC -	AC BUTF/HD OP AC BUTF/HD OP MAN GL TEST VLV TEST CONN /w CAP TEST CONN /w CAP	X X X X X		NO NO LC C C	O O C C C	C AI AI - -	N	SIS SIS	Auto Reopen on SIS Reset CV-0911 & 0940 has Accumulator for Loss of Air	
16	SIG (E50A) Surface Blow Down (2"Ø)	C1	CV0739	AO ANGLE VLV	X		O	O/C	C	.C	N	CIS	
17	Containment Pressure Instrumentation (4-½"Ø)	N/A	1802 1802A 1802B 1802C 1804 1804A 1804B 1804C 1812 1812A 1812B 1812C 1814 1814A 1814B 1814C		X X X X X X X X X X X X X X X X X X		LO LO LC LC LO LO LC LC LO LC LO LC LO LC LO LC LO LC LO LC LO LC	O O C C O O C C O C O C O C O C O C O C O C	O O C C O O C C O C O C O C O C O C O C O C	- - - - - - - - - - - - - - - - - - - -	Y		PS-1802 (SIS & CIS Initiation) PS-1802A (SIS & CIS Initiation) PS-1804 (SIS & CIS Initiation) P-S-1804 (SIS & CIS Initiation) PT-1812 PT-1812A PT-1814
17a	Containment Sump Level Instrumenta- tion		1814E 618B-DRW 1814F 1814G TEST /wCAP		X X X X X		LO C LC LC LC CAP	O C C C C	O C C C C	- - - - -	N		

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 4 OF 13

TABLE 1

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

PAGE 5 OF 13

PENE-TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS-EN-TIAL	ACTUA-TION	REMARKS	
					OC	IC	NOR-MAL	SHUT DN	POST LOCA	PWR FAIL.			
23	High Pressure Safety Injection	X	MO3007	MO GL VLV	X	X	NC	C	O	AI	Y	SIS	ESF Related Actuation Signal Initiated By Chp or Per/Owp ($\geq 1593\text{Psi}$) Actuation Signal Initiated By Chp or Per/Owp ($\geq 1593\text{Psi}$) Actuation Signal Initiated By Chp or Per/Owp ($\geq 1593\text{Psi}$)
			3104	CH'K VLV	X	X	C	C	O	-		SIS	
			MO3009	MO GL VLV	X	X	NC	C	O	AI		SIS	
			3119	CH'K VLV	X	X	C	C	O	-		SIS	
			MO3011	MO GL VLV	X	X	NC	C	O	AI		SIS	
			3134	CH'K VLV	X	X	C	C	O	-		SIS	
			MO3013	MO GL VLV	X	X	NC	C	O	AI		SIS	
			3149	CH'K VLV	X	X	C	C	O	-			
			RV3165	RELIEF VLV	X	X	C	C	O	-			
			CV3059	AC GA VLV	X	X	NO	O	O	O			
			CV3037	AO GA VLV	X	X	NC	O	O/C	O			
			3337	MAN GL TEST VLV	X	X	O	O	O	-			
			3337A	MAN GL TEST VLV	X	X	O	C	O	-			
			3180	MAN GL VLV	X	X	NO	O	O	-		PT-0318	
			3180A	MAN GL VLV	X	X	NO	O	O	-		PT-0318	
24	Spare	-											
25	Clean Waste Receiver Tank Vent to Stack (2" ϕ)	C2	CV1064	AO GL VLV	X		NO	O	C	C	N	CIS	PT-1065
			CV1065	AO GL VLV	X		NO	O	C	C		CIS	
			512CRW	MAN GL TEST VLV	X		LC	C	C	-			
			-	TEST CONN /W CAP	X		C	O	O	-			
			647CRW	MAN GL VLV	X		NO	O	O	-			
			1358	DRAIN CONN/W CAP	X		C	O	O	-			
26	Nitrogen to Quench Tank	C2	CV1358	AO GA VLV	X		NC	C	C	C	N	CIS	
			400N2	CHECK VLV	X		C	C	C	-			
			581N2	MAN GA TEST VLV	X		LC	C	C	-			
			-	TEST CONNECT	X		C	O	O	-			
27	Int Leak Rate Test Fill Line (6" ϕ)	A2	MOV-P1	MO BUTF VLV	X		NC	C	C	C	N	MAN	Flanged w/Gasket Inside Containment Flanged w/Gasket Inside Containment
			604 VAS	MAN GL VLV	X		LC	C	C	-			
			605 VAS	MAN GL VLV	X		LC	C	C	-			
			-	TEST CONN /W CAP	X		C	O	O	-			

TABLE 1

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
 PLANT: PALISADES NDP UNIT #1

PAGE 6 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS	
					OC	IC	NOR- MAL	SHUT DN	POST LOCA	PWR FAIL.			
28	Containment Air Sample Line ($\frac{1}{2}$ "Ø)		140 VAS 141 VAS 142 VAS 510 VAS -	TEST CAP	X		LO LC LC LC C	O C C C C	O C C C C	- - - - -	N		
29	Capped Spare	-	- -	PIPE FLANGE PIPE END /W CAP	X	X	C C				N		
30	Containment Spray	X	CV3001 3258 3226 3344ES - 3227ES	AC GL VLV MAN GATE VLV CHECK VLV GLOBE VLV TEST CONN /W CAP GLOBE VLV	X X X X X		NC LO C LC LC	C O C C C	O O O C C	O - - - -	Y	CHP	ESF Related Auto Open On Chp
31	Containment Spray	X	CV3002 3259 3216 3217ES 3346ES -	AC GL VLV MAN GA VLV CHECK VLV MAN GL VLV M GL TEST VLV TEST CONN /W CAP	X X X X X X		NC LO C LC LC C	C O C C C C	O O O C C C	O - - - - -	Y	CHP	ESF Related Auto Open on Chp
32	Low Pressure Safety Injection (12"Ø)	X	M03008 3103ES MO3010 3118ES MO3012 3133ES MO3014 3148ES 3163ES 3196 3197 CV3006 CV3025 3336 3108ES 3107ES	MO GL VLV CHECK VLV MO GL VLV CHECK VLV MO GL VLV CHECK VLV MO GL VLV CHECK VLV MAN GA VLV MAN GA VLV MAN GA VLV AC GL VLV AO GL VLV MAN GA VLV MAN GA VLV MAN GA VLV	X X X X X X X X X X X X X X X X		NC C NC C NC C NC C LC NO NO NO NC C O O	C C C C C C C C C O O O O C C O O	O O O O O O O O C O O O O/C C O O	AI - AI - AI - N - - - - - O C - -	Y	SIS SIS SIS SIS SIS SIS SIS SIS SIS SIS SIS SIS MAN MAN	ESF Related FT-0307 FT-0307

TABLE 1

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

PAGE 7 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS
					OC	IC	NOR- MAL	SHUT DN	POST LOCA			
32 cont.	Low Pressure Safety Injection		1155PC	MAN GA VLV	X	C	C	C	C	-	Y	
			3123ES	MAN GA VLV	X	O	O	O	O	-		FT-0309
			3122ES	MAN GA VLV	X	O	O	O	O	-		FT-0309
			1156PC	MAN GA VLV	X	C	C	C	C	-		
			3138ES	MAN GA VLV	X	O	O	O	O	-		FT-0311
			3137ES	MAN GA VLV	X	O	O	O	O	-		FT-0311
			1157PC	MAN GA VLV	X	C	C	C	C	-		
			3153ES	MAN GA VLV	X	O	O	O	O	-		FT-0314
			3152ES	MAN GA VLV	X	O	O	O	O	-		FT-0314
			1158PC	MAN GA VLV	X	C	C	C	C	-		
			RV-3162	RELIEF	X	C	C	C	C	-		
33	Safety Injection Tank Drain (2"Ø)	C3	3234ES	MAN GA VLV	X		LC	C	C	-	N	
			3237ES	MAN GA VLV	X		LC	C	C	-		
			3348FS	MAN GL TEST VLV	X		LC	C	C	-		
			-	TEST CONN /W CAP	X		C	C	C	-		
			3227ES	MAN GL VLV	X		LC	C	C	-		
			3236ES	MAN GA VLV	X		LC	C	C	-		
			3235ES	M SAMPL LINE GAV	X		LC	C	C	-		
			3217ES	MAN GL VLV	X		LC	C	C	-		
34	Spare	-										
35	Shutdown Cooling Return (14"Ø)	B2	MOV3016	MO GA VLV	X	ELC	O	O/C	C	N	MAN	Manual Control
			MOV3015	MO GA VLV	X	ELC	O	O/C	C			
			RV3164	RELIEF VLV	X	NC	C	C	-			
			RV0401	RELIEF VLV	X	NC	C	C	-			
			3204ES	MAN GL VLV	X	LC	C	C	-			
			3205	MAN GA VLV	X	LC	C	C	-			
			-	PIPE FLANGE	X	C	C	C	-			
			MO-3190	MO GA VLV	X	ELC	O	O	AI			
			MO-3199	MO GL VLV	X	ELC	O	O	AI			
			3163	MAN GA VLV	X	C	C	C	-			
36	Letdown To Purification Ion Exchanger (1½"Ø)	B1	CV2009	AO GL VLV	X		NO	O	C	C	N	CIS
			2320CVC	MAN GL TEST VLV	X		LC	C	C	-		
			-	TEST CONN /W CAP	X		C	C	C	-		
			2010CVC	MAN GA VLV	X		NO	O	O	-		

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 8 OF 13

PENE-TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION				ESS-EN-TIAL	ACTUA-TION	REMARKS
					OC	IC	NOR-MAL	SHUT DN	POST LOCA	PWR FAIL.			
36 cont.	Letdown To Purification Ion Exchanger (1½"Ø)	B1	2148A CV2012 2149A CV2122	MAN GA VLV AO GL VLV MAN GA VLV AO GL VLV	X X X X		NO NO NO NC	O O O C	O O/C O C	- C - C	N		
37	Primary System Drain Pump Recirc (1½"Ø)	C2	CV1001 403CRW 503CRW -	AO GL VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP	X X X X		NC C LC C	C C C C	C C C -	C C -	N	CIS	
38	Condensate Return From Steam Heating Units (2"Ø)	C2	CV1501 CV1502 502VA - -	AO GA VLV AO GA VLV MAN GL TEST VLV VENT CONN /W CAP TEST CONN /W CAP	X X X X X		NC NC LC C C	O/C O/C C C C	C C C C C	C C -	N	CIS	
39	Containment Heating System (4"Ø)	X	CV1503 - 503VA - -	AO GA VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP VENT CONN /W CAP	X X X X X		NC LC C C	C C C -	C C -	C -	N	CIS	Check Valve Replaced w/Blank Flange When At Power
40	Pri-Cooling System Sample Line (½"Ø)	B1	CV1910 CV1911 1170A 1170B	AO GL VLV AO GL VLV MAN GL TEST VLV MAN GL TEST VLV TEST CONN /W CAP	X X X X X		O/C O/C LC LC C	O/C O/C C C C	C C C C C	C C -	N	CIS	
40a	Hydrogen Monitoring Return Line (Degasifier Room) (½"Ø)		SV-2414A SV-2414B 729WGS -	SOLENOID SOLENOID MAN GL VLV TEST CONN /W CAP	X X X X		C C C C	C C C C	O/C O/C C C	C C -	N	MAN MAN	
40b	Hydrogen Monitor Supply Line (Degasifier Room) ½"Ø		SV-2412A SV-2412B 728WGS -	SOLENOID SOLENOID MAN GL VLV TEST CONN /W CAP	X X X X		C C C C	C C C C	O/C O/C C C	C C -			

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 9 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS	
					OC	IC	NOR- MAL	SHUT DN	POST LOCA				
41	Degassifier Pump Discharge (3"Ø)	C2	CV1004 407CRW 506CRW -	AO GL VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP	X		NO O LC C	O O C C	C C C C	C - - -	N	CIS	
42	Demineralized Water To Quench Tank (2"Ø)	C2	CV0155 VO155B 1126PC -	AO GL VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP	X		NC C LC C	C C C C	C C C C	C - - -	N	CIS	
43	Spare												
44	Controlled Bleed Off From RCP'S (3/4"Ø)	C2	CV2083 2084 2083 2083A -	AO GL VLV MAN GL VLV MAN GA TEST VLV MAN GA TEST VLV TEST CONN /W CAP	X		NO NO LC LC C	O O C C C	C O C C C	C - - - -	N	CIS	
45	Charging Pump Discharge (2"Ø)	B1	2110 CV2111	CHECK VLV AC GL VLV (W/ HD OPERATOR)	X		O NO	O O	O O	O	Y	- MAN	
46	Containment Vent Header (4"Ø)	C2	CV1101 CV1102 511WGS -	AO GL VLV AO GL VLV MAN GL TEST VLV TEST CONN /W CAP	X		NO NO LC C	O O C C	C C C C	C C - -	N	CIS	
47	Primary System Drain Tank Pump Suction	C2	CV1002 CV1007 502CRW -	AO GL VLV AO GL VLV MAN GL TEST VLV TEST CONN /W CAP	X		NO NO LC C	O O C C	C C C C	C C - -	N	CIS	
48	Containment Pressure Instrumentation (4-½"Ø Lines)	X	V-1801 V-1801A V-1801B V-1801C V-1803 V-1803A	MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV MAN GA VLV	X		LO LO LC LC LO LO	O O C C O O	O O C C O O	- - - - - -		PS-1801 (SIS & CIS Initiation) PS-1801A (SIS & CIS Initiation) PS-1803 (SIS & CIS Initiation) PS-1803A (SIS & CIS Initiation)	

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
 PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 10 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION			ESS- EN- TIAL	ACTUA- TION	REMARKS	
					OC	IC	NOR- MAL	SHUT- DN	POST LOCA	PWR FAIL.			
48 cont.	Containment Pressure Instrumentation (4-½"Ø Lines)	X	V-1803B	MAN GA VLV	X		LC	C	C	-			
			V-1803C	MAN GA VLV	X		LC	C	C	-			
			V-1805	MAN GA VLV	X		LO	O	O	-			PT-1805
			V-1805A	MAN GA VLV	X		LC	C	C	-			PT-0105A
			V-1805B	MAN GA VLV	X		LO	O	O	-			
			V-1805C	MAN GA VLV	X		LC	C	C	-			
			V-1815	MAN GA VLV	X		LO	O	O	-			PT-1815
			V-1815A	MAN GA VLV	X		LC	C	C	-			
			V-1815B	MAN GA VLV	X		LC	C	C	-			
			V-1815C	MAN GA VLV	X		LC	C	C	-			
49	Clean Waste Receiver Tank Circulation Pump Suction (3"Ø)	C2	CV1038 CV1036 513CRW - 514CRW	AO GL VLV AO GL VLV MAN GL TEST VLV TEST CONN /W CAP MAN DRAIN VLV	X X X X X		NO NO LC C LC	O O C C C	C C -	N	AUTO BY CIS		
50	Emergency Access Inside Cmtt Outside Cmtt	X	- - - - - P6VA -	PRES EQUAL VLV PRESS TUBE PRESS TUBE PRESS EQUAL VLV PRESS GAGE PRESS TUBE MAN G TEST VLV TEST CONN /W CAP O-RING TEST CONN	X X X X X X X X X	X X X	NC CAP CAP NC C LC C C			N			
51	Equipment Door	X	-	O-RING TEST CONNECT /W CAP		X	C						½" Tube Between The Seals Capped
52	Containment Sump Drain to Sump Tank	A1	CV1103 CV1104 500DRW	AO GL VLV AO GL VLV MAN GL TEST VLV TEST CONN VLV	X X X X		NC NC LC C	C C C C	C C -	N	SIS CHR		

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 11 OF 13

PENE-TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION		POSITION				ESS-ENTIAL	ACTUA-TION	REMARKS
					OC	IC	NOR-MAL	SHUT-DN	POST LOCA	PWR FAIL.			
52a	Containment Sump Level Instrumentation (3/8"Ø)		618DRW	MAN GA VLV	X		LO	O	O	-			LT-0382
			618FDRW	MAN GA VLV	X		LC	C	C	-			
			618HDRW	MAN GA VLV	X		LC	C	C	-			
			618EDRW	MAN GA VLV	X		LC	C	C	-			
			618GDRW	MAN GA VLV	X		LC	C	C	-			
			618ADRW	MAN GA VLV	X		LO	O	O	-			
			618BDRW	MAN GA VLV	X		LC	C	C	-			
			618CDRW	MAN GA VLV	X		LC	C	C	-			
			618DDRW	MAN GA VLV	X		LC	C	C	-			
			-	3 TEST CONN/WCAP	X		LC	C	C	-			
52b	Containment Sump Level Instrumentation		619DRW	MAN GA VLV	X		LO	O	O	-			LT-0383
			619FDRW	MAN GA VLV	X		LC	C	C	-			
			619HDRW	MAN GA VLV	X		LC	C	C	-			
			619EDRW	MAN GA VLV	X		LC	C	C	-			
			619GDRW	MAN GA VLV	X		LC	C	C	-			
			619ADRW	MAN GA VLV	X		LO	O	O	-			
			619BDRW	MAN GA VLV	X		LC	C	C	-			
			619CDRW	MAN GA VLV	X		LC	C	C	-			
			619DDRW	MAN GA VLV	X		LC	C	C	-			
			-	3 TEST CONN/WCAP	X		LC	C	C	-			
53	Containment Spray Pump Suction	X	CV3029 3182ES	AIR OP VLV MAN GL TEST VLV TEST CONN /W CAP	X X X		NC LC C	C C C	O C	AI -	Y	SIRWT LL	Post Loca Open On Sirw LL
54	Containment Spray Pump Suction	X	CV3030 3167ES	AIR OP VLV MAN TEST VLV TEST CONN /W CAP	X X X		NC LC C	C C C	O C	AI -	Y	SIRWT LL	Post Loca Open On Sirw LL
55	SIG (E50B) Surface Blowdown (2"Ø)	C1	CV0738	AO VLV W/ HAND OPERATOR	X		O	O/C	C	C	N	CIS	
56	Containment Sump Level Instrumentation		606A-VAS 619B-DRW 606B-VAS 606C-VAS		X X X X		LO C LC LC	O C C C	O C C C	-		LT-0383	
57	Spare	-		TEST CONN /W CAP	X		LC	C	C	-			

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 12 OF 13

PENE- TRATION NO.	SYSTEM NAME AND SERVICE LINE SIZE	PENE CLASS NO.	VALVE IDENT. NUMBER	VALVE TYPE OR DESCRIPTION	LOCATION OC IC	POSITION				ESS- EN- TIAL	ACTUA- TION	REMARKS
						NOR- MAL	SHUT DN	POST LOCA	PWR FAIL.			
58	Spare	-			X							
59	Spare	-			X							
60	Spare	-			X							
61	Spare	-			X							
62	Spare	-			X							
63	Spare	-			X							
64	Reactor Cavity Fill & Recirc (6"Ø)	A2	121SFP 120SFP 514SFP -	MAN GA VLV MAN GA VLV MAN GL TEST VLV TEST CONN /W CAP	X X X X	X LC LC LC C	C C C C	C C C C	- - - -			
65	Instrument Air (2"Ø)	A2	CV1211 400CAS 612CAS - 611CAS	AC GL VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP MAN GA VLV	X X X X X		NO O O LC C	O O C C O	O O C C O	- - - - -	N MAN	PS1220
66	ILRT Instrument Line (1½"Ø)	X	601VAS L6VAS 603VAS - 602VA	MAN GA VLV MAN GA VLV MAN GL TEST VLV TEST CONN /W CAP MAN GL TEST VLV TEST CONN /W CAP	X X X X X X	X LC LC LC C LC C	C C C C C C	C C C C C C	- - - - - -	N		
67	Clean Waste Receiver Tank Pump Recirc (3"Ø)	C2	CV1037 410-CRW 515CRW -	AO GL VLV CHECK VLV MAN GL TEST VLV TEST CONN /W CAP	X X X X		NO O O LC C	O O C C C	C C C C C	- - - - -	N CIS	

CONTAINMENT ISOLATION SYSTEM SEP REVIEW ITEMS
PLANT: PALISADES NDP UNIT #1

TABLE 1

PAGE 13 OF 13

TABLE 1 NOTES

1. Valve Type or Description - AO means air-to-open and AC means air-to-close.
2. Normal Position -
 - NO - Normally open
 - NC - Normally closed
 - BC - Bolted Closed (e.g. flange)
 - LO - Locked Open
 - LC - Locked Closed
 - ELO - Electrically Locked Open (key lock switch)
 - ELC - Electrically Locked Closed (key lock switch)
3. Shutdown Position - Assumes normal shutdown with the plant on shutdown cooling.
4. Power Failure Position - Position shown is for either loss of power or loss of air unless otherwise noted.
5. Actuation - Signal which automatically causes valve to reposition unless otherwise specified. Symbols are:
 - CIS - Containment Isolation Signal
 - SIS - Safety Injection Signal
 - CHP - Containment High Pressure Signal
 - CHR - Containment High Radiation Signal
 - MAN - Remotely actuated by Manual Operator action