




**Consumers
Power
Company**

General Offices: 212 West Michigan Avenue, Jackson, MI 49201 • (517) 788-0550

February 9, 1982



Dennis M Crutchfield, Chief
Operation Reactor Branch No 5
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - SEP TOPIC III-6, SEISMIC DESIGN CONSIDERATIONS

On January 29, 1982, a telephone conference call was held between the NRC, Consumers Power Company, and their respective consultants to discuss several open items in SEP Topic III-6. One of the items discussed concerned an NRC request for additional calculations which addressed selected reactor internal components. This analysis was telecopied to the NRC and its consultant prior to the conference call.

By this letter, the analysis discussed during the call is formally submitted. As you will note, the attached sketches and pages 1 through 4 provide the compression flange buckling analysis for the lower support beam. Pages 5 and 6 provide a stability analysis for the core support columns. We believe that submission of this information now closes the last remaining questions on reactor internals seismic design.



Robert A Vincent

Robert A Vincent
Staff Licensing Engineer

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades


A035
3
1/1

ATTACHMENTS - 8 Pages




36 EQUALLY SPACED
SUBSETS
OF 1/2 TYPICAL

X
Sketch 2




DETAIL Z
DIMS SHOWING TYP
FOR ALL DIMENSIONS
SCALE: EIGHTH



VIEW C-C
SCALE: EIGHTH

NOTE: THE DIA 1 1/2 DEEP
1-5/8 DIA 1 1/2 IN DEPTH FULL
THO. TO LOCATED TO DIA OR
HOLES LOCATED TO SATISFY
REQUIREMENT SET BY NOTE
"Y" ON PLAN VIEW

Sketch 1



Sketch 2-Detail X
 taken from Sketch 1

STABILITY OF LOWER SUPPORT BEAMS

VERTICAL LOAD ON COLUMN DUE TO SSE:

$$V = 5585 (.34) = 1899 \text{ LBS.}$$

TOTAL VERT. LOAD = 5585 + 1899 = 7,484 LBS.

BENDING MOMENT ON BEAM

$$= 7,484 (65.89 + 48.92 + 31.95 + 19.98)$$


$$= 1,210,462 \text{ IN LBS.}$$

$$\sigma_b = \frac{1,210,462 (10)}{2,139} = 5,659 \text{ psi.}$$

STABILITY OF LONGEST (CENTER) BEAM:

WHEN M_0 ACTS IN THE LATERAL DIRECTION TO THE BEAM:


MAX. UNBRACED SPAN IS 32 INS.



REF. 3, PAGE 194

$$M_z = 2(5170) + 2(2094)10$$

$$= 52,220 \text{ IN LBS.}$$



BEAM SECTION

$$b = 5 \text{ INS.} \quad t = 2 \text{ INS.} \quad w = 1.5 \text{ INS.} \quad L = 32 \text{ INS}$$

$$d = 20 - 2 = 18 \text{ INS.} \quad h = 20 \text{ INS}$$

$$I_y = \frac{2(5)^3(2)}{12} + \frac{16(1.5)^3}{12} = 46 \text{ IN}^4$$

$$K_T = \frac{1}{3} [2bt^3 + (h-2t)w^3] = \frac{1}{3} [2(5)2^3 + 16(1.5)^3]$$

$$= 45 \text{ IN.}^4$$

$$I_w = \frac{I_y d^2}{4} = \frac{46(18)^2}{4} = 3726 \text{ IN.}^6$$

$$\lambda = \sqrt{\frac{G K_T}{E I_w}} = \sqrt{\frac{45}{2.6(3726)}} = .0682 \frac{1}{\text{IN.}}$$

FLANGE BENDING STRESS AT CENTER OF SPAN:

$$\sigma_{bw} = \frac{bd}{8} \frac{E}{G} \frac{\lambda}{K_T} M_z \text{ TANH } \frac{\lambda L}{2}$$

$$= \frac{5(18)}{8} (2.6) \frac{(.0682)}{45} (52,220) \text{ TANH } 1.0912$$

$$= 1,846 \text{ psi.}$$

FLANGE SHEAR STRESS DUE TO WARPING:

$$J_{vw} = \frac{b^2 d}{16} \frac{E}{G} \frac{\lambda^2}{K_T} M_z$$

$$= \frac{5^2(18)}{16} (2.6) \frac{(.0682)^2}{45} (52,220)$$

$$= 395 \text{ psi.}$$

ST. VENANT SHEAR AT MID WIDTH OF FLANGE AT CENTER OF SPAN:

$$J_{vs} = \frac{M_z t}{K_T} \left[1 - \frac{\cosh \lambda L}{\cosh \lambda L} \right] = 0$$

FLANGE BENDING DUE TO VERTICAL LOADS: (PAGE 7.)

$$\sigma_b = 5,659 \text{ psi.}$$

FLANGE BENDING DUE TO LATERAL LOAD:

$$H = 2,094 \text{ LBS.}$$

REF. 2 PAGE 2-125 #17

$$a = 29.485 \text{ IN.} \quad b = 7.515 \text{ IN.}$$

$$R_1 = \frac{Hb^2}{L^3} (3a + b) = \frac{H(7.515)^2}{32^3} [3(29.485) + 7.515]$$

$$= .14 H$$

$$M \text{ AT CENTER} = 2 \left[.14 H \frac{L}{2} - \frac{H a b^2}{L^2} \right]$$

$$= 2 \left[.14 (16) H - \frac{29.485 (7.515)^2}{32^2} H \right]$$

$$= 2 (2.24 H - 1.35 H) = 1.78 H$$

$$= 1.78 (2,094) = 3,727 \text{ IN LBS.}$$

$$\sigma_b = \frac{M c}{I} = \frac{3,727 (1.5)}{465} = 122 \text{ psi.}$$

MAX. STRESS IN BEAM COMPRESSION FLANGE:

$$\sigma_b = 1,846 + 5,659 + 122$$

$$= 7,627 \text{ psi.}$$

PER XVII-2110 OF REF. 4, TO AVOID COMPRESSION FLANGE BUCKLING, THE ALLOWABLE STRESS MUST BE LIMITED TO TWO-THIRDS OF THE CRITICAL BUCKLING STRESS.

PER SECT. XVII-2214.1, REF. A, THE BEAM MEETS ALL REQUIREMENTS FOR A COMPACT SECTION (AS FOLLOWS):

1. FLANGE IS CONTINUOUSLY WELDED TO WEB.

2. WIDTH THICKNESS RATIO

$$= \frac{.5(5)}{2} = 1.25 < \frac{65}{\sqrt{17}} = 15.8$$

3. NOT APPLICABLE

$$4. \frac{20}{1.5} = 13 < \frac{257}{\sqrt{17}} = 62$$

5. LATERALLY UNSUPPORTED LENGTH = 32 IN.

$$32 < \frac{76(5)}{\sqrt{17}} = 92$$

6. NOT APPLICABLE

$$\text{THEN } F_b = .66 S_y \left(\frac{4}{3} \right) = .88 S_y$$

$$\text{ALLOWABLE STRESS} = \frac{2}{3} F_b = \frac{2}{3} (.88) 17,000$$

$$= 9,973 \text{ psi.}$$

$$\text{CALCULATED STRESS} = 7,627 \text{ psi.}$$

FLANGE WILL NOT BUCKLE.

$$C.S. COLUMN: \frac{1}{2} \\ C_c = \left(\frac{2\pi^2 E}{S_y} \right)^{\frac{1}{2}} = \left(\frac{2\pi^2 (25.2) 10^3}{17} \right)^{\frac{1}{2}} = 171$$

AT UNDERCUT:

$$A = \frac{\pi}{4} (1.8125)^2 = 2.58 \text{ IN}^2$$

$$I = \frac{\pi}{64} (1.8125)^4 = .53 \text{ IN}^4$$

$$r = \sqrt{\frac{I}{A}} = \sqrt{\frac{.53}{2.58}} = .453 \text{ INS}$$

$$\frac{KL}{r} = \frac{1.2(9.875)}{.453} = 26$$

EQ. 4 REF. 4

$$F_a = \frac{\left[1 - \left(\frac{KL}{r} \right)^2 / 2 C_c^2 \right] S_y}{\frac{5}{3} + \frac{3 \left(\frac{KL}{r} \right)}{E C_c} - \frac{\left(\frac{KL}{r} \right)^3}{E C_c^3}}$$

$$= \frac{\left(1 - \frac{26^2}{2(171)^2} \right) 17}{\frac{5}{3} + \frac{3(26)}{E(171)} - \frac{26^3}{E(171)^3}} = \frac{16.8}{1.72}$$

$$= 9.767 \text{ ksi}$$

FOR SOLID ROUND BARS

$$F_b = .75 F_y \text{ (XVII 2214.3)}$$

CORE SUPPORT COLUMN.
COMBINED AXIAL COMPRESSION AND
BENDING - REF, 4 - XVII-2215

AT UNDERCUT:

SINCE ENDS ARE RESTRAINED $C_m = .85$

$K = 1.2$ REF. 2 TABLE C.1.8.1

$f_a = 2,900 \text{ psi}$ $f_b = 8,837 \text{ psi}$

Eq. 20:

$$\frac{f_a}{F_a} + \frac{C_m f_b}{\left(1 - \frac{f_a}{F_e'}\right) F_b} \leq 1$$

$$F_e' = \frac{12 \pi^2 E}{23 \left(\frac{K L_b}{r_b}\right)^2} = \frac{12 \pi^2 (25.2) 10^3}{23 \left(\frac{(1.2)(9.875)}{.453}\right)^2}$$

= 190 ksi

INCREASE 1/3 FOR SSE CONDITIONS:

$$F_e' = \frac{4}{3} (190) = 301 \text{ ksi}$$

$$\text{Eq. 20: } \frac{2,900}{\frac{4}{3}(9767)} + \frac{.85(8837)}{\left(1 - \frac{2,900}{301,000}\right) .75(17,000)^{1.53}}$$

= .22 + .45 = .67 < 1.0

COLUMN IS STABLE

LICENSING CORRESPONDENCE - RECORD SUMMARY

DATE:

DOCKET 50-255 LICENSE DPR-20
PALISADES PLANT

SUMMARY: SEP TOPIC III-6, Seismic Design
Provides CE calculations for two items
in the reactor internals.

COMMITMENTS MADE:

none

Previous NRC/CPCo Correspondence:

Phone call 1/29/82
Meeting with NRC 11/6/81

AIR No.:

UFI No.:

Individuals Providing Information:

CE (Davison)

Concurrences:

Originator:

BA Vincent

Special Distribution:

Individuals Assigned Responsibility
for Implementing Commitments:

NA

Cost/Budget Impact:

	Actual/Potential
Year(s)	NA
Materials/Parts	_____
Labor	_____
Capital	_____
Contractors	_____