



CROSBY REPORT NO. 3920 REVISION 1

JUSTIFICATION REPORT  
OF  
EPRI TESTING  
OF  
CROSBY STYLE HB-BP-86  
PRESSURIZER SAFETY VALVES

PREPARED BY: *D. G. Thibault*  
D. G. THIBAUT  
PROJECT ENGINEER *STP*

REVIEWED BY: *D. R. Taylor*  
D. R. TAYLOR  
SENIOR PROJECT ENGINEER

APPROVED BY: *J. R. Zahorsky*  
J. R. ZAHORSKY  
CHIEF ENGINEER-SAFETY VALVES

DATE: OCTOBER 13, 1981

**1. Scope**

- 1.1 The purpose of this report is to provide within a single document the information listed below:
- 1.1.1 A summary of the Crosby models and the quantity of such models used in or intended for use in domestic PWR Nuclear Power Plants as pressurizer safety valves.
  - 1.1.2 A concise listing of all Crosby Safety Valves used in or intended for use in PWR Plants for pressurizer safety valves. The listing includes the utility, station, valve size, model number, Crosby Order Number, quantity per plant, reactor manufacturer, drawing number, body construction, flange ratings, seat material and internal material variations within valve orifice size.
  - 1.1.3 A brief description of valve performance including a description of the main internal parts. A drawing of the generic valve model is also included.
  - 1.1.4 A listing of the valves selected for the EPRI tests which includes the valves origin and data sheet drawings.
  - 1.1.5 A listing of all design variations between selected test valves and valves used in or intended for use in PWR Plants as pressurizer safety valves. An explanation of effects on performance due to each specific design variation is included.
  - 1.1.6 An explanation of validity of selected test valves to represent all or a specific portion of all Crosby Valves used as pressurizer safety valves.



2. Introduction

2.1 Tabulated below is the quantity of each valve model provided by Crosby for use as pressurizer safety valves. The complete valve listing of Paragraph 2.2 of this report tabulates the specific design variations of each model. The Crosby Assembly Number denotes the model number. All valves listed below are the Crosby Style HB-BP-86 Safety Valve.

K Orifice		K2 Orifice		M1 Orifice		M Orifice		N Orifice	
Assem. No.	Quan. of Plants	Assem. No.	Quan. of Plants	Assem. No.	Quan. of Plants	Assem. No.	Quan. of Plants	Assem. No.	Quan. of Plants
50646-1	1	47469-1 and N51185-2	1	52137	3	51250-1	1	N60491	2
N54495	1	51249	6	N54891 and N59303	1	51688	10	N60582	2
N59336	1	51185	1	N56963-1	2	51688-1	1	N61894	2
		51689	2	N56963	1	N56964-4	3		
				N56264	2	N56964	18		
						N56964-1	1		
						N55366	1		
						N55605	1		
						N56925	2		
						N56499	2		
						N60446	5		

2.2 The following tabulation is a detailed breakout by orifice size of all models of Crosby Style HB-BP-86 Safety Valves supplied for use on or intended use on PWR Nuclear Power Plants as pressurizer safety valves.

Special Component

Disc Holder Material and Constructive Type

Material 19-9M (Note 1)

Seal No. 1 2 3

Loop Seal

Size 300 lbs. 4" 6" 8"

Quiet Flange Rating

Size 300 lbs. 4" 6" 8"

Inlet Flange Rating

Size 2400 lbs. 4" 6" 8"

Body Construction

Flanged Studed

Crumbly Drawing No.

Assembly No.

Qty. of Valves

Manufacturer

Serial No.

Disc Holder

Material

Seal No.

Loop Seal

Quiet Flange Rating

Inlet Flange Rating

Body Construction

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

Note 1

1. Disc Holder for waste forging - ASTM A377 Gr. 651  
 2. Disc Holder for disc holder - ASTM A418 Gr. 651  
 3. Disc Holder at 19-9M, may have problems (see Crumbly Drawing)

1. Disc Holder with Seal  
 2. Disc Holder without Seal  
 3. Disc Holder with Seal and Disc Holder

CRONBY PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN DESIGNATED PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

CRONBY

Cronby Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Cronby Assembly No.	Cronby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion			Special Comments					
							Flanged	Studded	1500 Lbs.			2500 Lbs.			300 Lbs.			600 Lbs.		Yes	No		Stellite	19-9DL	*Type		
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"						8"	1	2
000006	Southern Cal. Ed. Company	San Onofre Unit No. 1	W	2	47469-1	H-47469-1	X		X						X			X	X		Note 1						
000011	Electric Co. and Electric Company	Robert Egan Glenn	W	2	51249	H-51249	X			X					X		X		X								
000020	Carolina Power and Light Co.	H.H. Robin- son No. 2	W	3	51249	H-51249	X			X					X		X		X								
000029	Florida Power and Light Co.	Turkey Point No. 4	W	3	51249	H-51249	X			X					X		X		X								
000030	Connecti- cut Yankee Atomic Power Co.	Connecti- cut Yankee	W	3	51185	H-50447-1	X			X					X		X		X								
000032	Kansas and Okla- homa Power Company	Point Beach No. 1	W	2	51249	H-51249	X			X					X		X		X								
000058	Florida Power and Light Co.	Turkey Point No. 3	W	3	51249	H-51249	X			X					X		X		X								
000030	Kansas and Okla- homa Power Company	Point Beach No. 2	W	2	51249	H-51249	X			X					X		X		X								

\*Type

- 1 - 1/2" NPT With Stellite Inlets and Disc Bushing
- 2 - Inconel 718 Without Bushing
- 3 - Inconel 718 With Bushing

Notes

- 1 - Valve heads converted to 19-9DL material in field.
- 2 - Spare valve.

Test Report No. 3920 Revision 1

Special Comments

Disc  
Holder  
Material  
and  
Construct-  
ion  
Type  
1 2 3

Sealing  
Material  
Stellite 19-9DL  
X X

Loop Seal  
Yes No  
X X

Outlet Flange Rating  
300 lbs. 400 lbs.  
Size 6" 6" 8"  
X X X

Inlet Flange Rating  
1500 lbs. 2500 lbs.  
Size 6" 8" 10"  
X X X

Body Construction  
Blank Sanded  
X

Creep  
Drawing  
No.  
U-51689

Creep  
Assembly  
No.  
51689

Qty.  
Assembled  
No.  
3

Receptor  
Mfg.  
No.  
M-51689

Station  
No.  
M-51689

Material  
No.  
M-51689

Note 2  
X X

Note 3  
X X

Note 4  
X X

Note 5  
X X

Note 6  
X X

Note 7  
X X

Note 8  
X X

Note 9  
X X

Note 10  
X X

Note 11  
X X

Note 12  
X X

Note 13  
X X

Note 14  
X X

Note 15  
X X

Note 16  
X X

THIS IS THE DESIGNATION SAVER VALVES SUPPLIED FOR USE  
IN THE RESEARCH REACTOR NUCLEAR POWER PLANTS

Note 1  
Test with Stellite Bands and Disc Bushing  
Note 2  
Test with Stellite Bands and Disc Bushing  
Note 3  
Test with Stellite Bands and Disc Bushing  
Note 4  
Test with Stellite Bands and Disc Bushing  
Note 5  
Test with Stellite Bands and Disc Bushing  
Note 6  
Test with Stellite Bands and Disc Bushing  
Note 7  
Test with Stellite Bands and Disc Bushing  
Note 8  
Test with Stellite Bands and Disc Bushing  
Note 9  
Test with Stellite Bands and Disc Bushing  
Note 10  
Test with Stellite Bands and Disc Bushing  
Note 11  
Test with Stellite Bands and Disc Bushing  
Note 12  
Test with Stellite Bands and Disc Bushing  
Note 13  
Test with Stellite Bands and Disc Bushing  
Note 14  
Test with Stellite Bands and Disc Bushing  
Note 15  
Test with Stellite Bands and Disc Bushing  
Note 16  
Test with Stellite Bands and Disc Bushing

Note 1  
Values were converted to 19-9DL material in field.  
Note 2  
Values were converted to 19-9DL material in field.

CROSBY PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

00000000

Crosby Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion			Special Comments			
							Flanged	Studded	1500 Lbs.			2500 Lbs.			300 Lbs.			Yes	No	Stellite	19-9DL		Type		
									3"	4"	6"	3"	4"	6"	4"	6"	8"						4"	6"	8"
001607	Missouri Public Service Corp.	Kennecott Station	W	2	52137	H-52137	X			X				X		X									
001650	Northern States Power Co.	Prairie Inland No. 1	W	2	52137	H-52137	X			X			X	X		X									
001661	Northern States Power Co.	Prairie Inland No. 2	W	2	52137	H-52137	X			X			X	X		X									
001711A	Ishida Lithon Co.	Davis Besse Unit No. 1	B&W	2	N54891	H-54891	X				X		X		See Special Notes				X			Note 1			
001751	Northern States Power Co.	Prairie Inland No. 1	W	2	N57872	DS-C-57872	X			X			X	X		X					X	Note 3			
001762	Alabama Power Co.	Joseph H. Larley Nuclear Plant 1	W	3	N56963-1	DS-C-56963-1		X		X			X	X		X					X				
001763	Alabama Power Co.	Joseph H. Larley Nuclear Plant 2	W	3	N56963-1	DS-C-56963-1		X		X			X	X		X					X				
001911	Virginia Electric and Power Company	North Anna 3	B&W	2	N56264	DS-C-56264	X				X		X	X		X					X				

- Notes:  
 1 - Design 71B With Stellite Lunds and Disc Bushing  
 2 - Design 71B Without Bushing  
 3 - Design 71B With Bushing

- Remarks:  
 1 - Utility considering removal of valves from loop seal. Utility provided with  
 19-9DL Inerts.  
 2 - Valves cancelled after completion. Valves shipped for use in EPRI testing on 9/80.  
 3 - Spare valves.

ROCKET VALVE FOR PRESSURIZED SAFETY VALVES SUPPLIED FOR USE  
IN THE DESIGN OF THE PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

(SEE DRAWING)

Company Drawing No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal Yes No	Seating Materials		Disc Holder Material and Construc- tion Type			Special Comments			
							Flanged	Studded	1500 lbs. Size			2500 lbs. Size				300 lbs. Size			19-90L			1 2 3		
									3"	4"	6"	3"	4"	6"		4"	6"	8"	Stellite	19-90L		1	2	3
000010	Virginia Electric and Power Company	North Anna 4	B&W	2	N56264	DS-C-56264	X				X			X	X									
000015	Virginia Electric and Power Company	Surry Unit No. 1 (Unit Never Held)	B&W	2	N56264	DS-C-56264	X				X			X	X						Note 2			
000017	Suppcon Light Company	Beaver Valley Power Station	M	3	N56963	DS-C-56963		X						X	X						Note 4			
000018	Valley Electric Company	David Bruce Unit No. 1	B&W	2	N39303	DS-C-39303	X				X			X	X						Note 1			
000019	Atlantic Coast Electric	Joseph M. Casley Northern Plant	M	1	N56963-2	DS-C-56963-2		X						X	X						Note 3			

- 1 - 1/2" 316 With Stellite Lense and Disc Bushing
- 1 - Insect 713 Without Bushing
- 1 - Insect 713 With Bushing

- 1 - Utility considering removal of valves from loop seal. Utility provided with 19-90L.
- 1 - Valves cancelled after completion. Valves shipped for use in EPRF testing on 9/80.
- 1 - Special valve.
- 1 - 1/2" 316, lense sourced from N56963-2.

Test Report No. 3920 Revision 1



CRONBY PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN DOMESTIC PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

CRONBY

Crosby  
Factory  
Order  
No.

Crosby Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion Type			Special Comments			
							Flanged	Studded	1500 Lbs.			2500 Lbs.			300 Lbs.			300 Lbs.		600 Lbs.			1	2	3
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"	8"	Yes				
901512	Consolidated Edison Co. of N.Y.	Indian Point No. 2	W	3	51250-1	H-51250-1	X		X						X			X	X		No problem on disc insert.				
901509	Public Service Electric and Gas Company	Salem Station Unit No. 1	W	3	51688	H-51688-1	X		X					X	X		X	X							
901511	Commonwealth Edison Co.	Zion No. 1	W	3	51688	H-51688-1	X		X					X	X		X	X							
901516	Commonwealth Edison Co.	Zion No. 2	W	3	51688	H-51688-1	X		X					X	X		X	X							
901511	Indiana and Michigan Electric Co.	Donald C. Cook No. 1	W	3	51688	H-51688	X		X					X	X		X	X							
901512	Indiana and Michigan Electric Co.	Donald C. Cook No. 2	W	3	51688	H-51688	X		X					X	X		X	X							
901600	Public Gas and Electric Company	Diablo Canyon No. 1	W	3	51688	H-51688	X		X					X	X		X	X							
901515	Tennessee Valley Authority	Seymour No. 1	W	3	51688	H-51688-1	X		X					X	X		X	X							

- Notes:  
 1 - Model 717 with Stellite Landa and Disc Bushing.  
 2 - Model 718 Without Bushing.  
 3 - Model 718 With Bushing.

- Notes:  
 1 - Plant Cancelled

Test Report No. 3920 Revision 1

CRUICKSHANK PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

Continued on next page

Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating				Outlet Flange Rating				Loop Seal		Seating Materials		Disc Holder Material and Construction			Special Comment
							Flanged	Studded	1500 lbs.		2500 lbs.		300 lbs.		600 lbs.		Yes	No	Stellite	19-9DL	Type			
									3"	4"	3"	4"	3"	4"	3"	4"					1	2	3	
900001	Public Service and Electric Company	Doble Canyon No. 2	M	3	51680	M-51680	X								X				X					
900001	Public Service and Gas Company	Salem Station Unit No. 2	M	3	51680	M-51680	X							X					X					
901100	Tramontana Valley Authority	Sequoiah No. 2	M	3	51680	M-51680	X							X					X					
900002	Public Service Co. of N.Y.	Indian Point No. 3	M	3	51680-B	M-51680-B	X							X					X					
900100	Public Service Company	Hillstone Nuclear Power Unit No. 1	M	3	DS6966-6	DS-C-56966-6		X						X					X					
900100	Public Service and Light Co.	Shoreham Nuclear Unit No. 1	M	3	DS6966	DS-C-56966		X						X					X					
900100	Public Service and Light Co.	Shoreham Nuclear Unit No. 2	M	3	DS6966	DS-C-56966		X						X					X					
900100	Public Service and Light Co.	Shoreham Nuclear Unit No. 2	M	3	DS6966	DS-C-56966		X						X					X					

- \*/1: 0 - Not SRT With Stellite Bands and Disc Bushing.  
1 - Insect 7/8 Without Bushing.  
2 - Insect 7/8 With Bushing.

Note:  
0 - Plant Cancelled

**CROSBY STYLE HB PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN DOMESTIC PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS**

**M ORIFICE (CONTINUED)**

Crosby Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion *Type			Special Comments						
							Flanged	Studded	1500 Lbs. Size			2500 Lbs. Size			300 lbs. Size			600 Lbs. Size			Yes		No	Stellite	19-9DL	1	2	3
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"	8"								
N303151	Common- wealth Edison Co.	Byron Station Unit No. 1	W	3	N56964	DS-C-56964	X		X				X		X		X				X							
N303153	Tennessee Valley Authority	Watts Bar Unit No. 2	W	3	N56964	DS-C-A56964	X		X				X		X		X				X							
N303154	Georgia Power and Light Co.	Vogtle Unit No. 1	W	3	N56964	DS-C-56964	X		X				X		X		X				X							
N303155	Georgia Power and Light Co.	Vogtle Unit No. 2	W	3	N56964	DS-C-56964	X		X				X		X		X				X							
N54020	Pacific Gas and Electric Company	Diablo Canyon	W	1	N51688	H-51688	X		X				X		X		X				X							
N303169-A	Public Service of Indiana	Marble Hill Unit No. 1	W	3	N56964	DS-C-56964	X		X				X		X		X				X							
N303102	Public Service of N.H.	Seabrook Unit No. 2	W	3	N56964	DS-C-56964	X		X				X		X		X				X							
N303145-B	South Carolina Electric and Gas Company	Virgil C. Summer Station	W	3	N56964-1	DS-C-56964-1	X		X				X		X		X				X							

**\*Type**

- 1 - 347 SST With Stellite Lands and Disc Bushing.
- 2 - Inconel 718 Without Bushing.
- 3 - Inconel 718 With Bushing.

**Notes**

- 1 - Plant Cancelled

**PROPERTY LIST OF PRESSURIZER SAFETY VALVES SUPPLIED FOR USE  
IN THE SIX PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS**

(Continued)

Company Drawing No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crooby Assembly No.	Crooby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion			Special Comments				
							Flanged	Studded	7500 Lbs.			2500 Lbs.			100 Lbs.		600 Lbs.		Yes	No	Stellite		18-8DL	Type		
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"						6"	8"	1
000000	Portland General Electric Company	Trojan No. 1	W	3	N55366	N-55366	X			X				X		X			X							
000000	Portland General Electric Company	Comanche Peak Unit No. 1	W	3	N56964	DS-C-56964		X		X			X	X		X			X							
000000	Portland General Electric Company	Matco Bay Unit No. 1	W	3	N56964	DS-C-A56964		X		X			X	X		X			X							
000000	Arkansas Electric and Light Co.	Arkansas Nuclear Unit No. 2	CZ	2	N55603	N-55603	X				X			X			X		X							
000000	Duke Power Company	McGuire Nuclear Station Units 1 & 2	W	6	N56925	DS-C-56925	X		X				X	X		X			X							
000000	Commonwealth Edison Co.	Xion	W	3	N56499	DS-C-56499	X		X				X	X		X			X		Note 2					
000000	Indiana and Michigan Electric Co.	D.C. Cook Unit No. 1	W	3	N56499	DS-C-56499	X		X				X	X		X			X		Note 2					
000000	Commonwealth Edison Co.	Bradwood Station Unit No. 2	W	3	N56964	DS-C-56964		X		X			X	X		X			X							

\*Type  
 1 1/2" x 1" with Stellite lands and Disc Bushing.  
 2 1/2" x 1" without Bushing.  
 3 1/2" x 1" with Bushing.

Notes  
 1 Plant cancelled  
 2 Spare Valves

CRITICAL LIST OF DEMONSTRIZER SAFETY VALVES SUPPLIED FOR USE  
ON THE VARIOUS SODIUM WATER REACTOR NUCLEAR POWER PLANTS

DATE: 01/01/70

Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Bolter Material and Construction			Special Comments			
							Flanged	Studded	1500 Lbs. Size			2500 Lbs. Size			300 Lbs. Size			Yes	No	Stellite	19-9DL		Type		
									3"	4"	6"	3"	4"	6"	4"	6"	8"						4"	6"	8"
000000	Consolidated Electric Co.	Shearon Holt No. 3	W	3	N56964	DS-C-56964	X		X				X	X		X					X				
000000	Consolidated Electric Co.	Comanche Peak Unit No. 2	W	3	N56964	DS-C-56964	X		X				X	X		X					X				
000000	Public Service Co. of Mo.	Scabrook Unit No. 1	W	3	N56964	DS-C-56964	X		X				X	X		X					X				
000000	Consolidated Electric Co.	Braidwood Station Unit No. 1	W	3	N56964	DS-C-56964	X		X				X	X		X					X				
000000	Loop Island Electric	Jamesport Unit No. 2	W	3	N56964-4	DS-C-56964-4	X		X				X	X		X					X	3			
000000	Loop Island Electric	Jamesport Unit No. 1	W	3	N56964-4	DS-C-56964-4	X		X				X	X		X					X	3			
000000	Consolidated Electric Company	Bolt Creek Unit No. 1	W	3	N60446	DS-C-60446	X		X				X	X		X						X			
000000	Public Service Company	Calloway Station No. 1	W	3	N60446	DS-C-60446	X		X				X	X		X						X			

\*Type  
 1 - 157-218 With Stellite Lands and Disc Bushing.  
 2 - 157-218 Without Bushing.  
 3 - 157-218 With Bushing.

Notes  
 1 - Plant Cancelled  
 2 - Spare Valves  
 3 - Plant Cancelled After Shipment of Valves.

INVENTORY OF STANDARDIZED SAFETY VALVES SUPPLIED FOR USE  
IN THE UNITED STATES OF AMERICA AT REACTOR NUCLEAR POWER PLANTS

(Continued)

Crosby Valve No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating						Outlet Flange Rating			Loop Seal		Seating Materials			Disc Holder Material and Construc- tion			Special Comments	
							Flanged	Studded	1500 Lbs.			2500 Lbs.			300 Lbs.			600 Lbs.			Yes	No	Stellite	19-9DL			
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"	8"				1	2		3
60411	Washington State Authority	Stealing Station	W	3	N60446	DS-C-60446	X										X						X	Note 1			
60412	Washington State Authority	Tyone Station	W	3	N60446	DS-C-60446		X									X						X	Note 1			
60413	Washington State Authority	Callaway No. 2	W	3	N60446	DS-C-60446		X									X						X				
60414	Washington State Authority	H. G. Galt Nuclear Units 1 & 2	W	3	N56925	DS-C-56925	X										X						X	Note 2			
60415	Washington State Authority	Hardie Nuclear Units No. 2	W	3	N56964	DS-C-56964		X									X						X	Note 2			
60417	Washington State Authority	Watts Bar Nuclear Units	W	1	N56964	DS-C-A56964		X									X						X	Note 2			
60418	Washington State Authority	Sequoyah Nuclear Units	W	2	N51688	N-51688	X										X						X	Note 2			
60419	Washington State Authority	Sequoyah Nuclear Units	W	1	N51688	N-51688	X										X						X	Note 2			

Notes:  
1 - Valves with Stellite lands and Disc Bushing.  
2 - Inconel 718 Without Bushing.  
3 - Inconel 718 With Bushing.

Notes:  
1 - Plant cancelled.  
2 - Spare valves.

CROSBY SAFETY VALVES SUPPLIED FOR USE  
IN PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

(Continued)

Crosby Factory Order No.	Utility	Station	Reactor Mfr.	Qty. of Valves	Crosby Assembly No.	Crosby Drawing No.	Body Construction		Inlet Flange Rating			Outlet Flange Rating			Loop Seal		Seating Materials		Disc Holder Material and Construc- tion			Special Comments			
							Flanged	Studded	1500 Lbs. Size			2500 Lbs. Size			300 Lbs. Size			600 Lbs. Size		Stellite	19-9DL		Type		
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"				8"	Yes	No
201500	Union Carbide	Watts Bar	W	2	N56966	DS-C-56964		X							X		X				Note 2				
200552	Portland General Electric Company	Trojan No. 1	W	1	N55366	DS-C-55366	X			X					X		X				Note 2				
200107	General Electric Light Co.	Shearon Barrie No. 4	W	3	N56966	DS-C-56966		X						X		X		X							

- Notes:  
 1 - WJ 554 With Stellite Leds and Disc Bushing.  
 2 - Inconel 718 Without Bushing.  
 3 - Inconel 718 With Bushing.

- Notes:  
 1 - Plant Cancelled  
 2 - Spare valves.

TEST REPORT NO. 3720

LIST OF STATE OF PENNSYLVANIA SAFETY VALVES SUPPLIED FOR USE  
IN DOMESTIC PRESSURIZED WATER REACTOR NUCLEAR POWER PLANTS

County No. Group No. Valve	Utility	Station	Reactor Mfr. No.	Qty. of Valves	Grooby Assembly No.	Grooby Drawing No.	Body Construction		Inlet Flange Rating						Outlet Flange Rating						Loop Seal		Seating Materials		Special Comments
							Flanged	Studded	1500 lbs.			2500 lbs.			300 lbs.			600 lbs.			Yes	No	Stellite	19-9DL	
									3"	4"	6"	3"	4"	6"	4"	6"	8"	4"	6"	8"					
000145	Bluebonnet Lighting and Power Company	South Texas Unit No. 1	M	3	N60491	DS-C-60491	X										X	X	X		Note 2				
000146	Bluebonnet Lighting and Power Company	South Texas Unit No. 2	M	3	N60491	DS-C-60491	X										X	X	X		Note 2				
000171	Washington Electric Power Company	WPPSS Unit No. 3	CE	4	N60582	DS-C-60582	X										X	X	X		Note 2				
000174	Washington Electric Power Company	WPPSS Unit No. 3	CE	4	N60582	DS-C-60582	X										X	X	X		Note 2				
000178	Trumbull Valley Authority	Yellow Creek Unit No. 1	CE	4	N61894	DS-C-61894	X										X	X	X	Note 1	Note 2				
000180	Trumbull Valley Authority	Yellow Creek Unit No. 2	CE	4	N61894	DS-C-61894	X										X	X	X	Note 1	Note 2				

- Notes:  
 1 - Inlet 7/8" with Stellite lands and Disc Bushing.  
 2 - Inlet 7/8" Without Bushing.  
 3 - Inlet 7/8" With Bushing.

- Notes:  
 1 - Inlet disc design. Nozzle material ASME SA-382 Gr. 316. Disc insert material -  
 ASME A 197 Gr. 718.  
 2 - Nozzle ring material - 304 SST with Stellite lands. Disc holder construction -  
 Inlet 7/8" with Stellite Bushing.



### 3. Description of Valve

#### 3.1 Valve Construction

- 3.1.1 Figure 1 is a generic illustration of the Crosby Style HB-BP-86 Safety valve. Use part numbers noted in following description to locate parts in Figure 1.
- 3.1.2 Inside the body (1) is housed the upper portion of the nozzle (2), nozzle ring (3), disc ring (7), adjusting ring (12), eductor (11), and the bellows assembly consisting of the bellows (8) to which is welded the disc holder (5). The disc insert (9) is held in place in the disc holder (5) by insert pin (10).
- 3.1.3 The eductor (11), bellows assembly and the bonnet adapter (15) are retained between the valve body (1) and the bonnet (18) by bonnet studs (38) and bonnet stud nuts (39).
- 3.1.4 Housed in the bonnet (18) is the spring (19) and spring washers (20) carried by the spindle assembly (14), the lower end of which is positioned on the bushing (6) in the disc holder (5).
- 3.1.5 Adjusting bolt (29) is locked in place by the adjusting bolt nut (30) at the top of the bonnet (18), within the cap (21).
- 3.1.6 Manual lifting means is provided by lever (28), dog shaft (23), dog (22) and spindle nut (16) and spindle nut cotter (17).
- 3.1.7 Cap plug (31) is screwed into the top of cap (21) or cap top (43) when gagging screw is not in use.

#### 3.2 Valve Operation


- 3.2.1 A typical valve operating cycle on steam is as follows: As pressure in the pressurizer vessel increases to the safety valve set point, the valve will open to a lifted position. After the valve opens, steam passes through the annular openings between the nozzle ring (3) and adjusting ring (12) and a series of annular flow passages between the disc ring (7) and the adjusting ring (12) and the eductor (11) and the adjusting ring (12). This flow of steam through these annular passages and the exhaust through the openings in the adjusting ring (12), controls the pressure in the chamber above the disc ring (7) and between the eductor (11) and bellows (8). As pressure in the pressurizer vessel decays, the dynamic forces on the lower face of the disc ring (7) and disc insert (9) are reduced and the safety valve will close by the force developed by the spring which is also assisted by the pressure in the chambers above the disc ring (7).



3. Description of Valve (Continued)


3.2 Valve Operation (Continued)

3.2.2 The primary purpose of the nozzle ring (3) is to control the popping action of the valve. This ring is factory set for a minimum warn and sharp popping action and is seldom field adjusted. The primary function of the adjusting ring (12) is to control the valve blowdown. Raising the adjusting ring (12) decreases the blowdown and conversely lowering this ring increases the blowdown.




ALTERNATE CONSTRUCTION WITHOUT CAP TOP

FIG. 1b




STYLE HB (WITHOUT PISTON)

FIG. 1c




WELDED INLET CONSTRUCTION

FIG. 1d



VIEW SHOWING VALVE GAGGED

FIG. 1e



STYLE HB-BP (WITH PISTON)

FIG. 1a

FIG. 1

Crosby Valve & Gage Company  
Wrentham, Massachusetts

<u>Piece No.</u>	<u>Part Name</u>
1	Body
2	Nozzle
3	Nozzle Ring
4	Nozzle Ring Set Screw
*5	Disc Holder
*6	Disc Bushing
*7	Disc Ring
*8	Bellows
*9	Disc Insert
*10	Disc Insert Pin
11	Eductor
12	Adjusting Ring
13	Adjusting Ring Set Screw
14	Spindle Assembly
14A	Spindle Point
14B	Spindle Rod
15	Bonnet Adapter
16	Spindle Nut
17	Spindle Nut Cotter
18	Bonnet
19	Spring
20	Spring Washer
21	Cap
22	Dog
23	Dog Shaft
24	Dog Shaft Bearing
*25	Dog Shaft "O" Ring
26	Dog Lever Nut
27	Dog Lever Lockwasher
28	Lever
29	Adjusting Bolt
30	Adjusting Bolt Nut
31	Cap Plug
*32	Cap Plug Gasket
*33	Bonnet Adapter Gasket
*34	Eductor Gasket
*35	Nozzle Ring and Adjusting Ring Set Screw Gasket
*36	Dog Shaft Bearing Gasket
*37	Cap Gasket
38	Bonnet Stud

Crosby Valve & Gage Company  
Wrentham, Massachusetts

<u>Piece No.</u>	<u>Part Name</u>
38A	Cap Stud
39	Bonnet Stud Nut
39A	Cap Stud Nut
40	Piston
41	Piston Lockclip
42	Gag Screw
43	Gag Top
*44	Cap Top Gasket
45	Canopy Ring
46	Gasket (Special)
47	Nameplate and Identification Plate
48	Caution Plate
49	Drive Screws


\*Parts noted with an asterisk (\*) are manufacturer's recommended spare parts. Note Pieces No. 5, 6, 7 and 8 are purchased as an assembly.



4. Selected Test Valves

4.1 Tabulated below are the Crosby Style HB-BP-86 Safety Valves selected for the EPRI testing at Combustion Engineering-KDL Labs. Also included in this section are data sheet drawings for each of the selected test valves.



<u>Selected Test Valve</u>	<u>Valve Origin</u>	<u>Valve Drawing No.</u>
3xKx6 HB-BP-86	Crosby Test Valve	SK-3658-V
6xMx6 HB-BP-86 Crosby Assembly No. N56964	Crosby Factory Order No. N303167 Shearon Harris Unit No. 4	DS-C-56964
6xNx8 HB-BP-86 Crosby Assembly No. N61894	Crosby Factory Order Nos. N80518 or N80520 TVA Yellow Creek 1 and 2	DS-C-61894



**HB**  
WITH BELLOWS

CROSBY VALVE & GAGE CO.  
Wrentham, Mass.

Style HB-BP-86 TYPE C	Drawing SK-3658-V
--------------------------	----------------------



**LIST OF MATERIALS**

PCNO	DESCRIPTION	NO REQD	MATERIAL	MAT'L SPEC.	SEE NOTES	REMARKS
1	NOZZLE	1	SST	ASTM A102 F 316	2.3	
2	NOZZLE RING	1	SST	ASTM A502 TYPE 416 COND T	2.3	STEELITE SEAT
3	NOZZLE RING	1	SST	ASTM A502 TYPE 416 COND T		
4	SET SCREW	1	NICHR ALLOY	ASTM A637 GR 718	12.3	HEAT TREATED
A	NOZZLE ADAPTER	1	NICHR ALLOY	ASTM A637 GR 718		
5	DISC RING	1	SST	ASTM A179 TYPE 304		
6	DISC RING	1	BRONZE	BRONZE 718		
7	DISC RING	1	HAYNES ALLOY	HAYNES STEELITE NO 6B	12.3	
8	DISC RING	1	HAYNES ALLOY	HAYNES ALLOY NO 25		
9	DISC RING	1	HAYNES ALLOY	HAYNES ALLOY NO 6		
10	PIN	1	SST	ASTM A502 TYPE 416 COND T		
11	FRONT PIN	1	SST	ASTM A502 TYPE 416 COND T		
12	FRONT PIN	1	SST	ASTM A502 TYPE 416 COND T		
13	FRONT PIN	1	SST	ASTM A502 TYPE 416 COND T		
A	FRONT POINT	1	SST	ASTM A502 TYPE 416 COND T	2.3	
B	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
C	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
D	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
E	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
F	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
G	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
H	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
I	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
J	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
K	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
L	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
M	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
N	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
O	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
P	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
Q	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
R	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
S	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
T	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
U	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
V	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
W	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
X	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
Y	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
Z	NOZZLE BEARING	1	SST	ASTM A502 TYPE 416 COND T	2.3	
14	IRONITE	1	CARBON STEEL	ASTM A108 GR II	2.3	
15	SPRING	1	ALLOY STEEL	ASTM A304 GR 316	2.3	
16	WASHER	2	CARBON STEEL	ASTM A108 GR II	2.3	
17	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
18	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
19	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
20	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
21	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
22	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
23	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
24	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
25	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
26	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
27	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
28	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
29	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
30	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
31	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
32	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
33	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
34	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
35	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
36	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
37	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
38	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
39	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
40	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
41	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
42	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
43	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
44	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
45	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
46	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
47	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
48	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
49	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
50	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
51	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
52	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
53	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
54	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		
55	DOG	1	ALLOY STEEL	ASTM A502 TYPE 416 COND A		

NOTES:  
 1. RECOMMENDED SHARP PEECE.  
 2. PRESSURE RIVETING PEECE.  
 3. CHECK AREA OF MATERIAL AND NON-DESTRUCTIVE TESTING IN ACCORDANCE WITH CHOSBY QAT 34.0.  
 4. VALVE ACCESSORIES FURNISHED ONLY WHEN REQUESTED BY CUSTOMER.  
 5. WELD DIMENSIONS MUST BE RECORDED.

OUTLET 600# ANSI STD.

ENLARGED VIEW OF SEAT AREA

TOLERANCES - DECIMAL DIM 1/10 UNLESS OTHERWISE NOTED

WH'S IDENT NO 6-RVUB-MSB

CROSBY CUST. WESTINGHOUSE

ORDER NO.

CROSBY F.O.

PREPARED BY E.E.S. DATE 9/15/47

CHECKED BY DATE 2/1/48

CERTIFIED BY DATE



ASME SECT III CLASS I WEIGHT 900 LBS APPROX. SIZE 6 M 6 STYLE NR-6P 86 TYPE E ASSEMBLY NO 1444964

CHOSBY

DRIVING TITLE NOZZLE TYPE SALT VALVE

DRAWING NO. DSC-56964 REV C





C.E. CONTRACT NOS. 14074 & 14174	CROSBY CUST. COMBUSTION ENGINEERING	VALVE MFG. TO ASME BOILER & PRESSURE VESSEL CODE 1977 EDITION & NO ADDENDA	ASME SECT. III CL. I
CUSTOMER TENNESSEE VALLEY AUTHORITY	ORDER NO. 9773214 & 9773215	WEIGHT HOOD LBS. APPROX	<b>CROSBY</b> CROSBY VALVE & GAGE CO. WILMINGTON, MASS. 02093
PLANT NAME YELLOW CREEK UNIT 2	CROSBY F.O. N80518 & N80520	SIZE 6 N 8 STYLE 18-66-BP	DRAWING NOZZLE TYPE SAFETY VALVE
	PREPARED BY RB 11-9-77	TYPE E ASSEMBLY NO NG1694	TITLE DSC-61894
	CHECKED BY E.E.S 11-21-77		DRAWING NO. SHEET 1 OF 2
	APPROVED BY [Signature]		REV. D

REVISION	BY	CHK	APPROVED
1	HCN		
2	KM		
3	HCN		
4	HCN		
5	HCN		
6	HCN		

- NOTES**
- RECOMMENDED SPARE PIECE
  - PRESSURE RETAINING PIECE
  - CERTIFICATION OF MATERIAL AND NON-DESTRUCTIVE TESTING IN ACCORDANCE WITH CROSBY QAI-32095
  - VALVE ACCESSORIES FURNISHED ONLY WHEN ORDERED BY CUSTOMER
  - NIPPLE TO BE 1/2 IPS SC100 6" LONG, SOCKET WELDED TO BODY
  - THE DISCHARGE FORCE ACTING ALONG THE OUTLET CENTERLINE DEVELOPED WHEN THE VALVE IS FLOWING SATURATED STEAM AT 3% ABOVE SET PRESSURE & DISCHARGING TO ATMOSPHERE IS 47,306 LBS (INCLUDES MOMENTUM COMPONENT & DESIGN OUTLET PRESSURE UNBALANCE & DLE OF 1.1).

**LIST OF MATERIALS**

PC.NO	DESCRIPTION	NO. REQ'D	MATERIAL	MAT'L SPEC.	SEE NOTES	REMARKS
1	BODY	1	SST	ASME SA351 GR CF8M	2.3	
2	NOZZLE	1	"	ASME SA312 GR F316	2.3	
3	" RING	1	"	ACT CF8M		
4	" SCREW	1	"	ASTM A276 TYPE 316		
5	" DISC	1	INCONEL	ASME SA337 GR 718	2.3	
6	" HOUSING	1	CO-CR-ALLOY	STELLITE 4068	2.3	
7	" RING	1	SST	ASME SA375 TYPE 304		
8	BELLOWS	1	IN-CR-FE	INCONEL 718		OR EQUIVALENT
9	DIAPHRAGM	1	"	ASME SA337 GR 718	2.3	HEAT TREATED
10	" PIN	1	CO-CR-ALLOY	STELLITE 4072		
11	" TOP RING	1	"	STELLITE 4066		
12	ADJUSTING RING	1	SST	ACT CF8M		
13	" SCREW	1	"	ASTM A276 TYPE 316		
14	SPINDLE POINT	1	"	ASME SA316 GR B6	2.3	
15	" BALL (RING)	1	"	ASTM A276 TYPE 316 C	2.3	
16	" ROD	1	"	ASME SA316 GR B6		
17	" PIN	1	"	400 SERIES		
18	SPRING	1	ALLOY STEEL	A1M A401	2.3	CADMIUM PLATED
19	" WASHER	2	CARBON STEEL	ASME SA516	2.3	
20	" BUSH	1	"	"	2.3	
21	" STUD	12	ALLOY STEEL	ASME SA193 GR B7	2.3	
22	" NUT	12	STEEL	ASME SA194 GR 2H	2.3	
23	" ADAPTER	1	SST	ASTM A276 TYPE 316/304		
24	ADJUSTING BOLT	1	"	ASME SA193 GR B6	2.3	
25	" NUT	1	"	ASTM A276 TYPE 316/304		
26	FRITCH	1	CO-CR-ALLOY	STELLITE 4068		
27	" LOCKCLIP	1	SST	300 SERIES		
28	ORING GASKET	1	STEEL	AISI 1010-1030		
29	DIAPHRAGM GASKET	1	"	"		
30	NOZZLE GASKET	2	"	"		
31	CAP	1	CARBON STEEL	ASME SA216 GR WCB		
32	" STUD	6	ALLOY STEEL	ASME SA193 GR B7		
33	" NUT	6	STEEL	ASME SA194 GR 2H		
34	" GASKET	1	"	AISI 1010-1030		
35	" TOP	1	CARBON STEEL	ASME SA216 GR WCB		
36	" GASKET	1	STEEL	AISI 1010-1030		
37	SPINDLE NUT	1	SST	ASTM A276 TYPE 316/304		
38	" COYTER	1	STEEL	COMMERCIAL		
39	DOG	1	ALLOY STEEL	ASTM A514 CL 100-125		HEAT TREATED
40	" SHAFT	1	SST	ASTM A276 TYPE 316/304		
41	" O-RING	1	NYLON A	RODUR		
42	" LEADING	1	STEEL	AISI 113-1120		
43	" GSKT	1	"	AISI 1010-1030		
44	LEVER	1	CARBON STEEL	ASME SA216 GR WCB		
45	" NUT	1	STEEL	ASME SA194 GR 2H		
46	" LOCKWASHER	1	"	COMMERCIAL		
47	CAP PLING	1	"	AISI 1010-1030		
48	" GASKET	1	"	"		
49	GAG BOLTER	1	SST	ASTM A276 TYPE 316/304		
50	SEAL O WIRE	2	IFAN-SST	COMMERCIAL		
51	" O-RING	2	SST	"		
52	DATA PLATE	1	"	"		
53	DATA PLATE	1	"	"		
54	IDENTIFICATION PLATE	2	"	"		
55	CARBON PLATE	1	"	"		
56	NOZZLE GASKET	1	COMMERCIAL-FLEXIBLE SPIRAL WOUND	PHS-101	4	OR EQUIVALENT
57	FRITCH	1	SST	ASME SA312 TYPE 316	5	

**GENERAL INFORMATION**  
VALVE IS COMPATIBLE WITH THE FOLLOWING  
MATERIALS, CODES, AND STANDARDS

- CONSTRUCTION: ENGRILLING
- ASME SECTION III DIV 1 CLASS 1
- ASME SECTION VIII DIV 1 CLASS 1
- ASME SECTION VIII DIV 2 CLASS 1
- ASME SECTION VIII DIV 2 CLASS 2
- ASME SECTION VIII DIV 2 CLASS 3
- ASME SECTION VIII DIV 2 CLASS 4
- ASME SECTION VIII DIV 2 CLASS 5
- ASME SECTION VIII DIV 2 CLASS 6
- ASME SECTION VIII DIV 2 CLASS 7
- ASME SECTION VIII DIV 2 CLASS 8
- ASME SECTION VIII DIV 2 CLASS 9
- ASME SECTION VIII DIV 2 CLASS 10
- ASME SECTION VIII DIV 2 CLASS 11
- ASME SECTION VIII DIV 2 CLASS 12
- ASME SECTION VIII DIV 2 CLASS 13
- ASME SECTION VIII DIV 2 CLASS 14
- ASME SECTION VIII DIV 2 CLASS 15
- ASME SECTION VIII DIV 2 CLASS 16
- ASME SECTION VIII DIV 2 CLASS 17
- ASME SECTION VIII DIV 2 CLASS 18
- ASME SECTION VIII DIV 2 CLASS 19
- ASME SECTION VIII DIV 2 CLASS 20
- ASME SECTION VIII DIV 2 CLASS 21
- ASME SECTION VIII DIV 2 CLASS 22
- ASME SECTION VIII DIV 2 CLASS 23
- ASME SECTION VIII DIV 2 CLASS 24
- ASME SECTION VIII DIV 2 CLASS 25
- ASME SECTION VIII DIV 2 CLASS 26
- ASME SECTION VIII DIV 2 CLASS 27
- ASME SECTION VIII DIV 2 CLASS 28
- ASME SECTION VIII DIV 2 CLASS 29
- ASME SECTION VIII DIV 2 CLASS 30
- ASME SECTION VIII DIV 2 CLASS 31
- ASME SECTION VIII DIV 2 CLASS 32
- ASME SECTION VIII DIV 2 CLASS 33
- ASME SECTION VIII DIV 2 CLASS 34
- ASME SECTION VIII DIV 2 CLASS 35
- ASME SECTION VIII DIV 2 CLASS 36
- ASME SECTION VIII DIV 2 CLASS 37
- ASME SECTION VIII DIV 2 CLASS 38
- ASME SECTION VIII DIV 2 CLASS 39
- ASME SECTION VIII DIV 2 CLASS 40
- ASME SECTION VIII DIV 2 CLASS 41
- ASME SECTION VIII DIV 2 CLASS 42
- ASME SECTION VIII DIV 2 CLASS 43
- ASME SECTION VIII DIV 2 CLASS 44
- ASME SECTION VIII DIV 2 CLASS 45
- ASME SECTION VIII DIV 2 CLASS 46
- ASME SECTION VIII DIV 2 CLASS 47
- ASME SECTION VIII DIV 2 CLASS 48
- ASME SECTION VIII DIV 2 CLASS 49
- ASME SECTION VIII DIV 2 CLASS 50
- ASME SECTION VIII DIV 2 CLASS 51
- ASME SECTION VIII DIV 2 CLASS 52
- ASME SECTION VIII DIV 2 CLASS 53
- ASME SECTION VIII DIV 2 CLASS 54
- ASME SECTION VIII DIV 2 CLASS 55
- ASME SECTION VIII DIV 2 CLASS 56
- ASME SECTION VIII DIV 2 CLASS 57
- ASME SECTION VIII DIV 2 CLASS 58
- ASME SECTION VIII DIV 2 CLASS 59
- ASME SECTION VIII DIV 2 CLASS 60
- ASME SECTION VIII DIV 2 CLASS 61
- ASME SECTION VIII DIV 2 CLASS 62
- ASME SECTION VIII DIV 2 CLASS 63
- ASME SECTION VIII DIV 2 CLASS 64
- ASME SECTION VIII DIV 2 CLASS 65
- ASME SECTION VIII DIV 2 CLASS 66
- ASME SECTION VIII DIV 2 CLASS 67
- ASME SECTION VIII DIV 2 CLASS 68
- ASME SECTION VIII DIV 2 CLASS 69
- ASME SECTION VIII DIV 2 CLASS 70
- ASME SECTION VIII DIV 2 CLASS 71
- ASME SECTION VIII DIV 2 CLASS 72
- ASME SECTION VIII DIV 2 CLASS 73
- ASME SECTION VIII DIV 2 CLASS 74
- ASME SECTION VIII DIV 2 CLASS 75
- ASME SECTION VIII DIV 2 CLASS 76
- ASME SECTION VIII DIV 2 CLASS 77
- ASME SECTION VIII DIV 2 CLASS 78
- ASME SECTION VIII DIV 2 CLASS 79
- ASME SECTION VIII DIV 2 CLASS 80
- ASME SECTION VIII DIV 2 CLASS 81
- ASME SECTION VIII DIV 2 CLASS 82
- ASME SECTION VIII DIV 2 CLASS 83
- ASME SECTION VIII DIV 2 CLASS 84
- ASME SECTION VIII DIV 2 CLASS 85
- ASME SECTION VIII DIV 2 CLASS 86
- ASME SECTION VIII DIV 2 CLASS 87
- ASME SECTION VIII DIV 2 CLASS 88
- ASME SECTION VIII DIV 2 CLASS 89
- ASME SECTION VIII DIV 2 CLASS 90
- ASME SECTION VIII DIV 2 CLASS 91
- ASME SECTION VIII DIV 2 CLASS 92
- ASME SECTION VIII DIV 2 CLASS 93
- ASME SECTION VIII DIV 2 CLASS 94
- ASME SECTION VIII DIV 2 CLASS 95
- ASME SECTION VIII DIV 2 CLASS 96
- ASME SECTION VIII DIV 2 CLASS 97
- ASME SECTION VIII DIV 2 CLASS 98
- ASME SECTION VIII DIV 2 CLASS 99
- ASME SECTION VIII DIV 2 CLASS 100

● FURNISHED AS SUB-ASSEMBLY ONLY

C.E. CONTRACT NOS. 14074 & 14174	COMBUSTION ENGINEERING	VALVE MFG. TO ASME BOILER & PRESSURE VESSEL CODE 1977 EDITION & NO ADDENDA	ASME SECT. III CL. I
TENNESSEE VALLEY AUTHORITY	CROSBY CUSTOMER		CROSBY VALVE & GAGE CO. WINTHAM, MASS. 02093
PLANT NAME YELLOW CREEK UNIT 1B2	ORDER NO. 977341 02/7/77		DRAWING TITLE NOZZLE TYPE SAFETY VALVE
	CROSBY P.O. NUMBER 6 2100220		DRAWING NO. DSC-61894
	PREPARED BY RB 11-9-77		SHEET 2 FINAL
	CHECKED BY E.C. 11-11-77	SIZE 6 N D	REV D
	APPROVED BY RB 11-11-77	STYLE 110-66-UP	
		ASSEMBLY NO. 11066	



5. Design Variations and Effects On Operability

- 5.1 Included in this section is a justification report sheet for each valve orifice size of the Crosby Style HB-BP-86 Safety Valve. The purpose of these justification sheets is to outline the reasoning involved in selecting a particular valve model to represent each valve size. Note from the previous section that a valve for each orifice size was not selected for the EPRI testing. Refer to Section 6 of this report for justification of chosen test valves across orifice sizes.
- 5.2 The left most column of each justification sheet groups into arrays all valve assemblies with identical significant design features. Each remaining column identifies and selects the specific design features chosen for testing. The reasoning for selection which includes effects of design parameters on valve operability is included in the notes at the lower end of each justification sheet. Each sheet is separated into non-loop seal and loop seal installations.

JUSTIFICATION OF TEST VALVE DESIGN

CROSBY STYLE HB-BP-86 PRESSURIZER SAFETY VALVE  
K ORIFICE

CROSBY VALVE & GAGE COMPANY  
WRENTHAM, MASSACHUSETTS

Complete Listing of Design Arrays Note 1	Justification Note for Selection of Inlet Flange Rating	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Outlet Flange Rating	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Disc Holder Construction	Final Design Arrays Considered for Test Selection	Selected Test Valve
NON-LOOP SEAL							
Assembly Nos. 50646 and N54495 Cast Body-Flanged Inlet Flange-3" 2500 Lbs. Outlet Flange-6" 300 Lbs. Seating Material - 19-9DL SST Type 1 Disc Holder Quantity: 2 Plants	Note 2	Cast Body-Flanged Inlet Flange-3" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder	Note 3	Cast Body-Flanged Inlet Flange-3" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder	Note 4	Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder	Note 5
Assembly No. N59336 Cast Body-Flanged Inlet Flange - 3" 2500 Lbs. Outlet Flange - 6" 300 Lbs. Seating Material - 19-9DL SST Type 3 Disc Holder Quantity: 1 Plant		Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - 19-9DL Type 3 Disc Holder		Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - 19-9DL Type 3 Disc Holder			
LOOP SEAL							
Crosby R&D Test Valve Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - Stellite 6B Type 1 or 3 Disc Holder Quantity: 0 Plants	Note 2	Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - Stellite 6B Type 1 or 3 Disc Holder	Note 3	Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - Stellite 6B Type 1 or 3 Disc Holder	Note 4	Cast Body-Flanged Inlet Flange - 3" 1500 Lbs. Outlet Flange - 6" 600 Lbs. Seating Material - Stellite 6B Type 1 Disc Holder	Note 5

NOTES:

- 1 - This listing groups into arrays all assemblies which are identical in all significant design parameters. The quantity of domestic plants having each array are included in the listing. See the attached Crosby listing of all Crosby Style HB Safety Valves installed in domestic PWR Nuclear Power Plants.
- 2 - The 1500 lb. inlet flange rating has been selected. Use of a 1500 lb. rating as compared to a 2500 lb. rating would be the most rigorous test on the valve design based on possible effects on valve performance during possible applications of external loads to the valve.
- 3 - The 600 lb. outlet flange rating has been selected for test. The rating of the outlet flange (600 lbs. versus 300 lbs.) will have negligible effect on valve performance. The 600 lb. outlet flange rating is the only rating presently available with the 1500 lb. inlet flange rating.
- 4 - The Type 1 disc holder construction has been selected for test since this construction is installed in two (2) of the three (3) domestic plants having K Orifice Valves.
- 5 - The selected test valve for non-loop seal applications is the Crosby R&D Test Valve purchased by EPRI. The valves flange ratings, seating material and disc holder construction are as listed in the final design array column for non-loop seal testing. For loop seal testing the same valve will be utilized with the nozzle, disc insert and disc holder assembly replaced with the material and construction listed under the final design array column for loop seal testing. There are some dissimilarities in design between the selected test valve and the K Orifice Valves installed in the field. The design differences are as follows:
  - 5.1 The test valve has an open bonnet and cap construction whereas the K Orifice Valves installed in the field have closed bonnet and cap assemblies. The differences in bonnet construction will have minimal effect on valve performance.
  - 5.2 The contours of the valve body for the test valve are dissimilar to the K Orifice Valves installed in the field. The radii making up the shape of the test valve body are somewhat sharper. The difference in body shape will not effect valve performance except possibly during application of nozzle loads to the valve with the test valve body being the most stringent test.
  - 5.3 The valve body is constructed of cast carbon steel versus cast stainless steel used in valves installed in the field.

DISC HOLDER CONSTRUCTION TYPES:

- Type 1 - 347 Stainless Steel With Stellite Lands and Stellite Disc Bushing.
- Type 2 - SA637 Grade 718 Without Bushing.
- Type 3 - SA637 Grade 718 With Stellite Disc Bushing.

JUSTIFICATION OF TEST VALVE DESIGN

CROSBY STYLE HB-BP-86 PRESSURIZER SAFETY VALVE  
K2 ORIFICE

CROSBY VALVE & GAGE COMPANY  
WRENTHAM, MASSACHUSETTS

Complete Listing of Design Arrays Note 1	Justification Note For Selection Of Inlet Flange Size	Final Design Array Considered for Test Selection	Selected Test Valves
NON-LOOP SEAL			
Assembly Nos. 47479-1, 51185 and N51185-2 Cast Body - Flanged Inlet Flange-3" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder Quantity: 2 Plants		Cast Body - Flanged Inlet Flange-3" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder	Either Assembly No. 47469-1, 51185 or N51185-2 Cast Body - Flanged Inlet Flange-3" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - 19-9DL Type 1 Disc Holder <div style="float: right; border: 1px solid black; padding: 2px;">Note 2</div>
LOOP SEAL			
Assembly No. 51249 Cast Body - Flanged Inlet Flange-4" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite 6B Type 1 Disc Holder Quantity: 6 Plants		Cast Body - Flanged Inlet Flange-4" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite 6B Type 1 Disc Holder	Assembly No. 51249 Cast Body - Flanged Inlet Flange-4" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite 6B Type 1 Disc Holder
Assembly No. 51689 Cast Body - Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite 6B Type 1 Disc Holder Quantity: 2 Plants	<div style="border: 1px solid black; padding: 5px; display: inline-block;">Note 3</div>		

NOTES:

- 1 - This column groups into arrays all assemblies which are identical in all significant design parameters. The quantity of domestic plants having each design array are included in the listing. For further details see the attached Crosby listing of all Crosby Style HB Safety Valves installed in domestic PWR Nuclear Power Plants.
- 2 - The three (3) listed assembly numbers are all identical in design and materials and are the only K2 Orifice Valves installed on non-loop seal installations. Therefore, any one of the three (3) assemblies can be selected for test.
- 3 - The only dissimilar parameter between the two (2) designs is the valve inlet size. The valves have equal nozzle bore diameters and the ratio of nozzle bore to inlet size are maintained within a given value to assure choked flow at the nozzle bore section. Therefore, the flow coefficient, and valve operation will not be effected by the different inlet sizes. The smaller inlet size (4") would be the most stringent test on the valve design. Also, the 4" valve design is found in greater amounts in the field. Therefore, the design the the 4" inlet has been selected for test.

DISC HOLDER CONSTRUCTION TYPES:

Type 1 - 347 Stainless Steel with Stellite Lands and Stellite Disc Bushing.

JUSTIFICATION OF TEST VALVE DESIGN

CROSBY STYLE HB-BP-86 PRESSURIZER SAFETY VALVE  
M1 ORIFICE

CROSBY VALVE & GAGE COMPANY  
WRENTHAM, MASSACHUSETTS

Complete Listing of Design Arrays Note 1	Justification Note for Selection of Inlet Flange Rating	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Body Construction	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Disc Holder Construction	Final Design Arrays Considered for Test Selection	Selected Test Valve
NON-LOOP SEAL							
Assembly No. N54891 Cast Body-Flanged Inlet Flange-4" 2500 Lbs. Outlet Flange-6" 600 Lbs. Seat Material - See Note 2 Type 1 Disc Holder Quantity: 1 Plant					Note 3	Cast Body - Flanged Inlet Flange-4" 2500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material 19-9DL Type 2 Disc Holder	Note 4
Assembly No. N59303 Cast Body-Flanged Inlet Flange-4" 2500 Lbs. Outlet Flange-6" 600 Lbs. Seat Material - See Note 2 Type 2 Disc Holder Quantity: 1 Plant							
LOOP SEAL							
Assembly No. 52137 Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material- Stellite Type 1 Disc Holder Quantity: 3 Plants							
Assembly No. N57872 Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material- Stellite Type 2 Disc Holder Quantity: 1 Plant	Note 5	Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite Type 1 Disc Holder	Note 6	Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seat Material- Stellite Type 1 Disc Holder	Note 7	Assembly No. N57872 Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material- Stellite Type 2 Disc Holder	Note 8
Assembly No. N56264 Cast Body-Flanged Inlet Flange-4" 2500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material- Stellite Type 2 Disc Holder Quantity: 3 Plants		Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite Type 2 Disc Holder		Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite Type 2 Disc Holder			
Assembly Nos. N56963 and N56963-1 Forged Body- Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material- Stellite Type 2 Disc Holder Quantity: 3 Plants		Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material - Stellite Type 2 Disc Holder					

NOTES:

- 1 - This column groups into arrays all assemblies which are identical in all significant design parameters. The quantity of domestic plants having each design array are included in the listing, For further details see the attached Crosby listing of all Crosby Style HB Safety Valves installed in domestic PWR Nuclear Power Plants.
  - 2 - Assembly Nos. N54591 and N59303 (spare valve) are installed only at Toledo Edison-Davis Besse I. The valves are presently installed on loop seals with Stellite seating material. Toledo Edison has considered removing the valve from the loop seal and replacing the seating material with 19-9DL Stainless Steel material. Therefore, these two (2) assemblies will be considered for non-loop seal testing with 19-9DL seating material.
  - 3 - The Type 2 Disc Holder has been selected for M1 Orifice non-loop seal testing since the Type 1 Disc Holder was selected for non-loop seal testing for both the K and K2 Orifice.
  - 4 - Either assembly may be used for test providing the nozzle and disc insert are of 19-9DL Stainless Steel material.
  - 5 - The 1500 lb. inlet flange rating has been selected for test. Use of a 1500 lb. rating as compared to a 2500 lb. rating would be the most rigorous test on the valve design based on possible effects on valve performance during possible applications of external loads to the valve.
  - 6 - The cast body construction has been selected for test based on the following reasoning:
    - 6.1 The greater quantity of cast body M1 Orifice Valves installed in the field.
    - 6.2 The cast body design would be the most rigorous test on the valve style based on possible effects on valve performance during application of nozzle loads to the valve.
  - 7 - The Type 2 Disc Holder construction has been selected for test due to the greater quantity in the field. Also, the Type 1 Disc Holder types have been selected for loop seal tests on the K and K2 Orifice Valves respectively.
  - 8 - Assembly No. N57872 possesses all the selected design parameters and therefore is the selected test valve for M1 Orifice loop seal testing.
- DISC HOLDER CONSTRUCTION TYPES:  
 Type 1 - 347 Stainless Steel with Stellite Lands and Stellite Disc Bushing.  
 Type 2 - SA637 Grade 718 without bushing.  
 Type 3 - SA637 Grade 718 with Stellite Disc Bushing.

JUSTIFICATION OF TEST VALVE DESIGN

CROSBY STYLE HB-BP-86 PRESSURIZER SAFETY VALVE  
M ORIFICE

CROSBY VALVE & GAGE COMPANY  
WRENTHAM, MASSACHUSETTS

Complete Listing of Design Arrays Note 1	Justification Note for Selection of Inlet Flange Rating and Size	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Body Construction	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Disc Holder Construction	Final Design Arrays Considered for Test Selection	Selected Test Valve
NON-LOOP SEAL							
Assembly No. 51250-1 Cast Body-Flanged Inlet Flange-4" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 1 Disc Holder Quantity: 1 Plant	Note 2	Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 1 Disc Holder	Note 3	Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 1 Disc Holder	Note 4	Forged Body - Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 2 Disc Holder	Note 5
Assembly No. N55605 Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 2 Disc Holder Quantity: 1 Plant		Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 2 Disc Holder		Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-19-9DL Type 2 Disc Holder			
LOOP SEAL							
Assembly Nos. 51688 and 51688-1 Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 1 Disc Holder Quantity: 11 Plants	Note 3		Note 3	Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 1 Disc Holder	Note 4	Assembly No. N56964 Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 2 Disc Holder	Note 5
Assembly Nos. N55366, N56925 and N56499 Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 2 Disc Holder Quantity: 5 Plants				Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 2 Disc Holder			
Assembly No. N56964 Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 2 Disc Holder Quantity: 21 Plants				Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 3 Disc Holder			
Assembly No. N60446 Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 3 Disc Holder Quantity: 5 Plants				Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-6" 600 Lbs. Seating Material-Stellite Type 3 Disc Holder			

NOTES:

- 1 - This column groups into arrays all assemblies which are identical in all significant design parameters. The quantity of domestic plants having each design array are included in the listing. For further details see the attached Crosby listing of all Crosby Style HB Safety Valves installed in domestic PWR Nuclear Power Plants.
- 2 - The 1500 lb. inlet flange rating has been selected for test. Use of a 1500 lb. rating as compared to a 2500 lb. rating would be the most rigorous test on the valve design based on possible effects on valve performance during possible application of external loads to the valve. The valves have equal nozzle bore diameters and the ratio of nozzle bore to inlet size are maintained within a given value to assure choked flow at the nozzle bore. Therefore, the flow coefficient and valve operation will not be effected by the different inlet flange sizes. The 6" size was selected for test based on the greater amount installed in the field.
- 3 - The cast body construction has been selected for K, K2, M1 and N Orifice testing. Therefore, to assure testing of both body designs, the forged body construction has been selected for M Orifice testing.
- 4 - The Type 2 disc holder construction has been selected for test based on a larger quantity installed in the field and also Crosby considers the use of the Type 2 design material combination the most stringent test selection. In addition, the Type 1 disc holder designs have been selected for test for other orifice sizes.
- 5 - The valve design per Crosby Assembly No. N56964 possesses all the selected design parameters and will be used for test. The disc insert and nozzle will be removed and replaced with parts of 19-9DL material for non-loop seal testing.

DISC HOLDER CONSTRUCTION TYPES:

- Type 1 - 347 Stainless Steel with Stellite Lands and Stellite Disc Bushing.
- Type 2 - SA637 Grade 718 without bushing.
- Type 3 - SA637 Grade 718 with Stellite Disc Bushing.

JUSTIFICATION OF TEST VALVE DESIGN

CROSBY STYLE HB-BP-86 PRESSURIZER SAFETY VALVE  
N ORIFICE

CROSBY VALVE & GAGE COMPANY  
WRENTHAM, MASSACHUSETTS

Complete Listing of Design Arrays Note 1	Justification Note for Selection of Body Construction	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Inlet Flange Rating and Size	Remaining Design Arrays Considered for Test Selection	Justification Note for Selection of Seating Materials	Final Design Arrays Considered for Test Selection	Selected Test Valve
NON-LOOP SEAL							
Assembly No. N60582 Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-8" 600 Lbs. Seating Material-19-9DL Guiding-Stellite on Stellite Quantity: 2 Plants							
Assembly No. N61894 Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-8" 600 Lbs. Seating Design-Flexi-Disc Disc Insert-SA637 Grade 718 Nozzle-SA182 Grade 316 Guiding-Stellite on Stellite Quantity: 2 Plants					Note 2	Assembly No. N61894 Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-8" 600 Lbs. Seating Design-Flexi-Disc Disc Insert-SA637 Grade 718 Nozzle-SA182 Grade 316 Guiding-Stellite on Stellite	Note 3
LOOP SEAL							
Assembly No. N60491 Forged Body-Studded Inlet Flange-6" 1500 Lbs. Outlet Flange-8" 600 Lbs. Seating Material-Stellite Guiding-Stellite on Stellite Quantity: 2 Plants	Note 4	Cast Body-Flanged Inlet Flange-6" 1500 Lbs. Outlet Flange-8" 600 Lbs. Seating Material-Stellite Guiding-Stellite on Stellite	Note 5	Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-8" 600 Lbs. Seating Material-Stellite Guiding-Stellite on Stellite		Cast Body-Flanged Inlet Flange-6" 2500 Lbs. Outlet Flange-8" 600 Lbs. Seating Material-Stellite Guiding-Stellite on Stellite	Note 6

NOTES:

- 1 - This column groups into arrays all assemblies which are identical in all significant design parameters. The quantity of domestic plants having each design array are included in the listing. For further details see the attached Crosby listing of all Crosby Style HB Safety Valves installed in domestic PWR Nuclear Power Plants.
- 2 - The two (2) designs for non-loop seal installations are identical except for seating designs. The 19-9DL material has been selected for tests for all other orifice sizes. Therefore, the Flexi-disc design has been selected for the N Orifice testing.
- 3 - Assembly No. N61894 possesses all the selected design parameters and will be used as the test valve.
- 4 - The cast body design would be the most rigorous test on the valve style based on possible effects on valve performance during application of nozzle loads to the valve.
- 5 - Crosby has never manufactured a cast body N Orifice HB Pressurizer Safety Valve with a 1500 lb. inlet flange rating. Therefore, the 2500 lb. inlet flange rating has been selected.
- 6 - Assembly No. N61894 shall be used as the test valve with the nozzle and disc insert removed and replaced with parts having Stellite seats.

DISC HOLDER CONSTRUCTION TYPES:

- Type 1 - 347 Stainless Steel with Stellite Lands and Stellite Disc Bushing.
- Type 2 - SA637 Grade 718 without bushing.
- Type 3 - SA637 Grade 718 with Stellite Disc Bushing.





6. Conclusion

6.1 Summary of Design Differences

Listed below is a summary of the design differences delineated in the justification sheets of Section 5 of this report.

6.1.1 Valve Size

Listed below are all the sizes of Crosby Pressurizer Safety Valves presently installed or to be installed in domestic PWR Plants.

<u>Letter Designation</u>	<u>Nozzle Bore Diameter (Inch)</u>
K	1.531
K2	1.800
M1	1.952
M	2.154
N	2.362

6.1.2 Seat Material

The following list of seal material combinations are used in Crosby Pressurizer Safety Valves installed in or to be installed in domestic PWR Plants.

6.1.2.1 Valves Installed On Loop Seals

Stellite 6B disc insert against hard faced Stellite 6 nozzle.

6.1.2.2 Valves Installed Without Loop Seal

6.1.2.2.1 Disc insert and nozzle constructed of 19-9DL Stainless Steel, ASTM A458 Grade 651 or ASTM A477 Grade 651.

6.1.2.2.2 Flexi-disc design (N Orifice only) - disc insert of ASME SA637 Grade 718 against nozzle of ASME SA182 Grade F316.

6.1.3 Disc Holder Construction

The following disc holder constructions are used in the Crosby Pressurizer Safety Valves installed in or to be installed in domestic PWR Plants.

## 6. Conclusion (Continued)

### 6.1 Summary of Design Differences (Continued)

#### 6.1.3 Disc Holder Construction (Continued)

Type 1 (Used in K, K2, M1 and M Orifice Valves) - 347 Stainless Steel disc holder with Stellite lands and disc bushing.

Type 2 (Used in M1 and M Orifice) - ASME SA637 Grade 718 disc holder without disc bushing.

Type 3 (Used in K and M Orifice Valves) - ASME SA637 Grade 718 disc bushing with Stellite disc bushing.

6.1.3.1 All N Orifice Valves have an identical disc holder construction which is a different design from those listed above. Guiding surfaces are constructed of Stellite. See Drawing No. DS-C-61894 on Page 25 for detail of construction.

#### 6.1.4 Valve Body Construction

The following body constructions are used in the Crosby Pressurizer Safety Valves installed in or to be installed in domestic PWR Plants.

##### 6.1.4.1 Cast Body Construction

All valve sizes integral cast inlet and outlet flanges. See justification sheets in Section 5 of this report for detail breakout of flange ratings.

##### 6.1.4.2 Forged Body Construction (M1, M, and N Orifice)

Studded inlet and outlet flange connections. See justification sheets in Section 5 of this report for detail breakout of flange ratings.

### 6.2 Selected Design Parameters

6.2.1 The following three (3) valve sizes have been selected for test.

K Orifice - Represents smallest valve size.

M Orifice - Represents the intermediate size with the greatest population.

N Orifice - Represents largest valve size.

**6. Conclusion (Continued)****6.2 Selected Design Parameters (Continued)****6.2.2 Selected Disc Holder Constructions**

The Type 1 disc holder construction was selected for the K Orifice testing. The Type 2 disc holder construction was selected for the M Orifice testing. Therefore, both materials will undergo testing. The Type 3 disc holder construction will not undergo testing since it is identical to the Type 2 except for the addition of a disc bushing. Crosby recommends tests with the Type 2 rather than the Type 3 since the Type 1 construction which has a disc bushing has been selected for test in the K Orifice Valve. The N Orifice Valve disc holder construction is unique to the other valve disc holder constructions and will undergo tests with the N Orifice Valve.

**6.2.3 Seating Materials**

All seating material combinations will undergo testing as delineated in the justification sheets of Section 5 to this report. A brief summary is listed below.

K Orifice - Loop Seal - Stellite Seats  
          - Non-loop Seal - 19-9DL Stainless Steel Seats

M Orifice - Loop Seal - Stellite Seats  
          - Non-loop Seal - 19-9DL Seats

N Orifice - Loop Seal - Stellite Seats  
          - Non-loop Seal - Flexi-disc construction

6.2.4 The K and N Orifice Valves will be tested with the cast body construction. The M Orifice Valve will be tested with the forged body construction. Therefore, both body designs will undergo testing.

6.3 The selected test valves represent the Crosby Valves installed on or to be installed in PWR Plants and the EPRI test results are fully applicable to the Crosby Valves installed or to be installed in PWR Plants.

A2 - DRESSER INDUSTRIES