



**Consumers
Power
Company**

General Offices: 1945 West Parnall Road, Jackson, MI 49201 • (517) 788-0550

October 13, 1982

Dennis M Crutchfield, Chief
Operating Reactors Branch No 5
Nuclear Reactor Regulation
US Nuclear Regulatory Commission
Washington, DC 20555

DOCKET 50-255 - LICENSE DPR-20 -
PALISADES PLANT - SEP TOPIC III-6, SEISMIC DESIGN CONSIDERATIONS

The attached enclosure provides a summary of the actions taken to date by Consumers Power Company to address specific NRC concerns as documented in the April 12, 1982 draft of NUREG-0820 regarding eccentric loads and valve functionability in small bore piping. Also summarized are Consumers Power Company plans to perform additional analysis on control valve CV-3003 piping to more accurately assess pipe stress. It is the opinion of Consumers Power Company that this enclosure adequately responds to the above stated NRC concerns.

Kerry A Toner

Kerry A Toner
Senior Licensing Engineer

CC Administrator, Region III, USNRC
NRC Resident Inspector - Palisades

Enclosure

A 028

8210190535 821013
PDR ADOCK 05000255
P PDR

ENCLOSURE

CONSUMERS POWER COMPANY

PALISADES SEP TOPIC III-6

Evaluation Of Valve Operator Eccentric Loads And
Functionability In Small Bore Piping

This is a summary of the actions taken by Consumers Power Company to resolve NRC concerns about valve operator eccentric loads and valve functionability during seismic conditions in piping 2-inch and smaller.

A list of all Q-listed, 2-inch and smaller air operated control valves and motor operated valves was made up from the Palisades equipment data base. This list was then reduced by eliminating valves in non-critical services and valves without significant operator weight. Critical services were defined to be: 1) valves forming part of the primary coolant system boundary, 2) valves affecting the ability to maintain a stable shutdown condition (i.e., decay heat removal, reactivity control, primary coolant system inventory control), 3) valves required for emergency core cooling system function and 4) valves required for containment isolation. The result was a total of 62 valves to be considered for evaluation of eccentric loads.

The majority of these valves are 1-inch and 2-inch control valves and 2-inch motor operated valves. There are also two 3/4-inch control valves and five 1/2-inch control valves on the list. The five 1/2-inch control valves are primary coolant sample system valves.

The pipe stresses resulting from valve operator eccentric loads were evaluated on a sample basis and by review of some of the work done under IE Bulletin 79-14. The piping systems associated with three 2-inch control valves and one 1-inch control valve were analyzed as part of the 79-14 work. In these analyses the operators were modeled as eccentric masses and deadweight thermal and seismic loadings were included. One of the three 2-inch control valves (PCV-2164) is installed with its operator in the horizontal position and with a support on the operator itself. This is not typical of other control valves at Palisades so no conclusions were drawn from the analysis of this valve. The other two 2-inch control valves (CV-2130 and CV-2136) are installed with their operators in the vertical position and with no supports attached to the operators. Pipe span lengths from these valves to the nearest supports are typical of other 2-inch control valves in the Palisades Plant. The 79-14 analysis showed the piping to be acceptable without addition of supports to the valve operators or any other modifications due to valve operator eccentric loads. Similarly, the analysis of the piping to 1-inch control valve CV-2153 showed the piping stresses to be within FSAR limits without the addition of any supports to the piping or the valve.

Analyses of three additional valves were performed to confirm that 2-inch motor operated valves are adequately supported and to obtain more data on the piping to air operated control valves. Calculation summaries are attached (see Attachment #1). The analyses were done in accordance with FSAR requirements considering pressure, deadweight and seismic loadings. The valves to be analyzed were chosen based on piping spans between the valve and the nearest supports. Maximum span lengths were chosen since this would likely result in the highest pipe stresses. The results show that valve MO-3072 and CV-0438B are supported adequately.

Since MO-3072 is of the same design as the other 2-inch motor operated valves, all of these valves can be considered to be adequately supported. The analysis of CV-0438B along with the 79-14 analyses of the 2-inch control valves as discussed above, demonstrates adequate support for the 2-inch air operated control valves. The third analysis, on 1-inch control valve CV-3003, was not completed because of lack of information on piping support locations. A section of the piping was modeled as unsupported because support locations were not known. As a result the piping was overstressed. It is expected that the actual support arrangement would result in stresses within allowable limits at the valve. This piping is inaccessible during plant operation, so the actual support locations have not been determined. During the next refueling outage, the supports will be located and CV-3003 pipe stress will be determined. Any overstress will be reported to the NRC.

In summary, analysis of seven Palisades piping systems containing 2-inch motor operated valves and 1-inch and 2-inch control valves has shown no overstresses resulting from valve operator eccentric loads except in one case where there was insufficient information on support locations. These analyses included limiting cases in terms of operator weights and piping span lengths. Based on these results, we believe that there is no pipe stress problem at Palisades associated with valve operator eccentric loads in small bore piping.

The second NRC concern relative to eccentric loads in small bore piping is valve functionability. In this regard, we are enclosing two analysis reports (see Attachments 2 and 3) on stresses in 1-inch and 2-inch control valves due to seismic loadings. In both reports the seismic stresses are quite low, indicating that valve function would not be impaired by accelerations up to 3.0 g's. Based on these reports, we believe that air operated control valves will function during and after a seismic event.

Although functionability of the 2-inch motor operated valves has not been analyzed specifically for this SEP Topic, Consumers Power Company does not expect that such valves will fail to function during a seismic event. This expectation primarily results from the analyses performed on the 1-inch and 2-inch control valves. The results of such analyses provide an indication of procurement and design practices which were generally employed during initial construction and subsequent modification of the Plant. Any further functionability evaluation at this time is unwarranted since functionability as an issue is being evaluated generically by the NRC as part of Unresolved Safety Issue No. A-46, Seismic Qualification of Equipment In Operating Plants. The results of the NRC evaluation will be to establish an explicit set of guidelines that could be used to judge the adequacy of the seismic qualification of mechanical and electrical equipment at all operating plants (ie, equipment required to safely shutdown the plant and equipment whose function is not required for safe shutdown but whose failure could result in adverse conditions which might impair shutdown functions) and to requalify equipment whose seismic qualification is found to be inadequate.

ATTACHMENT #1

Consumers Power Company

PALISADES SEP TOPIC III-6

October 13, 1982

Bechtel Associates Professional Corporation

777 East Eisenhower Parkway
Ann Arbor, Michigan

Mail Address: P.O. Box 1000, Ann Arbor, Michigan 48106



September 16, 1982

Mr. A. K. Smith
Consumers Power Company
1945 West Parnall Road
Jackson, Michigan 49201

Consumers Power Company
Palisades Plant
CPCO-GWO-9561
Bechtel Job 12447-060
ECCENTRIC PIPE LOADS IN
SMALL BORE (2" &
SMALLER) PIPING
File: 0275
82-12447/060-07

Reference: AKR 11-82, dated July 29, 1982

Dear Mr. Smith:

Consumers Power Company requested Bechtel to perform a computer pipe stress analysis on three small bore (2" & smaller) piping systems as part of their SEP program with regard to eccentric loads.

Bechtel's analysis of stress packages (S/N) 318, (S/N) 337 & (S/N) 320 included pressure, dead weight, and seismic effects only, in accordance with Appendix A of the FSAR. Computer program number ME101 was used in the performance of this request and the results are as follows:

1. S/N 318 Valve MO-3072 is determined to be supported adequately to meet acceleration limits and stress allowables in Appendix A of the FSAR. Valve acceleration does not exceed 3g's. Pipe stresses in the vicinity of the valve are acceptable based on assumptions and valve data listed in the calculation summary (attached) and walkdown information related to piping configuration per drawings 12447-033-SP-FSK-CC-7-2, 3, 4, 5, 6, & 7.

Bechtel Associates Professional Corporation


Mr. Smith
September 16, 1982
Page -2-

2. S/N 337 Valve CV-0438B is adequately supported and stresses meet FSAR allowables. Valve acceleration is less than 3g's. Stresses in the vicinity of the valve are acceptable based on assumptions and valve data listed in the calculation summary (attached) and walkdown information related to piping configuration per drawings 12447-033-SP-HCC-102-1 & SP-HBC-31-1.

3. S/N 320 Valve CV-3003 is located in a piping system which involves ten isometrics. Additionally, a portion of the pipe was not verified during walkdown because it was deemed inaccessible. The model for this analysis includes only a portion of the ten isometrics (piping beyond the model limits would not have a significant effect on pipe stresses near CV-3003), however, the model does include the piping which was not verified. The piping not verified was assumed to be unsupported which is a conservative assumption. The resulting analysis shows calculated stresses in the immediate area of the valve do not meet the FSAR allowable stresses. We note that if the inaccessible portion of the piping is found to be adequately supported, the stress levels are expected to drop sufficiently in the area of valve CV-3003 and associated piping to permit an acceptable condition without the need for any modifications.

If you have any questions, please advise.

Very truly yours,



P. K. Smith
Project Engineer

TP/PKS/lah

Enclosure

BECHTEL

CALCULATION SUMMARY COVER SHEET

12447

PROJECT DALISADES JOB NO. 12447-060 DISCIPLINE _____
SUBJECT CHEMICAL AND VOLUME CONTROL CHARACTERISTICS FILE NO. _____
PUMP HEADER; ECCENTRIC LOADS VALUE MO3072 CALC NO. 0423120
ORIGINATOR Heidi Valente DATE 8-25-82
CHECKER C. HERRON DATE 8/31/82 NO. OF SHEETS _____

RECORD OF ISSUES

NO.	DESCRIPTION	BY	DATE	CHKD	DATE	APPROV.	DATE
△	INITIAL REVIEW	Heidi V	8-25-82	CH	8/31/82	CL	11/18-
△							
△							
△							
△							
△							

FINAL CALC COMMITTED PRELIMINARY DESIGN CALC

CALCULATION SUMMARY PREPARATION INSTRUCTIONS

1. ORIGINATOR RESPONSIBILITIES

- Complete all title blocks with the following information: project, job number (include subjob), discipline, calculation number, revision, originator (include full name of all originators), date originated, total number of sheets comprising the summary (enter on cover sheet only), and pagination of all sheets excluding cover sheet.
- Complete all summary sheets appropriately to include all assumptions, methods used (e.g., computer program and revision, etc), design input, results, and conclusions.
- Complete cover sheet revision block with revision, description, and originator's initials and date.

2. CHECKER RESPONSIBILITIES

- Check the summary against the calculation to verify completeness and adequacy. (Checker cannot be the originator.)
- Initial and date all pages including the cover sheet.
- Initial and date cover sheet revision block.

3. REVIEW AND APPROVAL

- The discipline group supervisor or designee reviews for completeness and initials and dates the cover sheet revision block to indicate concurrence.



CALCULATION SUMMARY SHEET

12447-060 CALC NO. 0103'80 REV NO. 0

ORIGINATOR Heidi Valenta DATE 8/25/82 CHECKED CEH DATE 8/31/82

PROJECT PALISADES JOB NO. 12447-060

SUBJECT CHEMICAL AND VOLUME CONTROL CHESSING SHEET NO. 1/4
PUMP HEADER; ECCENTRIC LOADS VALUE 103072

DESIGN INPUT AND ASSUMPTIONS

INPUT

- | | | |
|-----------------------------------|-------------|----|
| 1. PIPING CLASS _____ | CC | HC |
| 2. MATERIAL SPEC. _____ | SA376-TP316 | |
| 3. PIPE NOM. WALL THICKNESS _____ | * | |
| 4. OPER. TEMP _____ | 120 | |
| 5. OPER. PRESS. _____ | 2200 | |
| 6. DESIGN TEMP _____ | 250 | |
| 7. DESIGN PRESS. _____ | 2735 | |
| 8. PIPE WEIGHT _____ | * | |
| 9. CONTENT WEIGHT _____ | * | |
| 10. INSULATION WEIGHT _____ | — | |
| 11. TOTAL WEIGHT _____ | * | |
| 12. S _C _____ | 12700 | |
| 13. S _H _____ | 15500 | |
| 14. S _Y _____ | 30,000 | |

15. PIPING CODE _____ PER FSAR APPENDIX A

16. * SEE ATTACHED SHEET 2

ASSUMPTIONS

SEE ATTACHMENTS I, II & III

PROJECT: PALISADES NUCL. PLANT

SHEET 2 OF 4

JOB NO. 12447-D-20 PLANT DESIGN GROUP

SYSTEM: CHEMICAL + VOLUME CONTROL CHEMICAL PUMP HEADS

CALC. NO. 00000 ISO NO. SP-FSK-CC7-234567 REV NO. 5, 2, 2, 0, 2, 5

A. PIPING STRESS ANALYSIS DATA

a. Safety-Related Non Safety Related

1) Pipe Program - Revision ME101 - J2 Preliminary Final

2) Thermal Condition Analysed N/A

3) Other Conditions: Weight Seismic Inertia

Seismic Anchor Movement Dynamic/Transients

b. Piping Data

	2"	1 1/2"	1"	3/4"	1/2"	2"	1 1/2"	
1) Piping Classification	CC	CC	CC	CC	CC	HC		✓
2) Material Specification	SA376-TP316	SA376-TP316	SA376-TP316	SA376-TP316	SA376-TP316	SA376-TP304		✓
3) Mod. of Elasticity (x 10 ⁶ psi)	29.2	29.2	29.2	29.2	29.2	29.2		✓
4) Expansion Coef. (in/100 ft)	-	-	-	-	-	-		✓
5) Expansion Coef. (mil. in/in)	-	-	-	-	-	-		✓
6) Pipe OD (in)	2.375	1.9	1.315	1.05	.84	2.375	1.315	✓
7) Pipe Nom. Wall Thickness (in)	.343	.281	.25	.218	.187	.154	.133	✓
8) Operating Temp (°F)	120	120	120	120	120	120	120	✓
9) Operating Pressure (PSI)	2200	2200	2200	2200	2200	2200	2200	✓
10) Design Temperature (°F)	250	250	250	250	250	250	250	✓
11) Design Pressure (PSI)	2735	2735	2735	2735	2735	2735	2735	✓
12) Pipe Weight (lbs/ft)	7.444	4.859	2.844	1.937	1.304	3.153	1.679	✓
13) Content Weight (lbs/ft)	.971	.608	.226	.1284	.074	1.455	.374	✓
14) Insulation Weight (lbs/ft)	-	-	-	-	-	-	-	✓
15) Total Weight (lbs/ft)	8.415	5.467	3.07	2.065	1.378	5.102	2.053	✓
16) Sc (PSI)	18700	18700	18700	18700	18700	18700	18700	✓
17) Sh (PSI)	14800	14800	14800	14800	14800	15350		✓
18) Sy (PSI)	30000	30000	30000	30000	30000	30000		✓

CHECK

c. INPUT SOURCE DOCUMENTS:

- 1) Piping specifications CC ✓
- 2) Response Spectra Curve Identification ENVELOPE ME909PCH318. ✓
- 3) Piping Class Summary 5935-M-259 Rev 9
- 4) Piping Class Sheets 5935-M-260 Rev 7
- 5) Piping Code USAS B31.1-67, USAS B31.7-69 & FSAR
- 6) P & ID
- 7) Piping Drawing
- 8) Modal Damping Factor 0.5 % of critical damping
- 9) Reference Calculation No. 03310

9/12/77

ACTION	NAME	SIGNATURE	DATE
CALCULATION BY	HEIDI VALENTA	Heidi Valenta	8-25-72
CHECKED BY	CURT HERRON	Curt Herron	8/31/82
APPROVED BY	P.C. GUPTA	Prem C. Gupta	9/2/82



CALCULATION SUMMARY SHEET

12447

CALC NO. 060312D

REV NO. 0

ORIGINATOR H. D. Valpant

DATE 2/25/82

CHECKED CEH

DATE 8/31/82

PROJECT PARISADES

JOB NO. 12447-01

SUBJECT CHEMICAL AND VOLUME CONTROL

SHEET NO. 3/4

CHARGING PUMP HEADER; ECCENTRIC LOADS VALUE M03072

RESULTS AND CONCLUSIONS

RESULTS

ALL STRESSES MEET CODE ALLOWABLES AS DEFINED IN B31.1 69² CODE.

VALUE ACCELERATION IS $< 3g$ IN ALL DIRECTIONS FOR SSE.

NODE POINT	STRESS COMBINATION (PSI)		ALLOWABLE STRESS (PSI)
178	PRESS + WT.	9158	15350
181	PRESS + WT + OBE	15603	18420
—	THERMAL		—
181	PRESS + WT + SSE	23158	33000

CONCLUSIONS

VALUE M03072 IS SUPPORTED ADEQUATELY TO MEET ACCELERATION LIMITS AND STRESS ALLOWABLES FSAR, APPENDIX A

IT IS SUGGESTED THAT SUPPORT H4.7, LINE HC-26-Y2, ISO. SP-FSK-CCT-4 IS VERIFIED BY THE FIELD TO ACT IN THE NORTH-SOUTH DIRECTION. IF NOT, PLEASE PROVIDE A SHIM TO DECREASE CLEARANCE TO $\frac{3}{16}$ " OR LESS. HOWEVER, IT DOES NOT AFFECT THE STRESS IN THE VICINITY OF THE VALUE M0-3072



CALCULATION SUMMARY SHEET

12447


ORIGINATOR H. D. Valente DATE 2/25/82 CALC NO. 060377 P REV NO. 0
 PROJECT DM ISADES JOB NO. 12447-01-6 CHECKED CEH DATE 8/31/82
 SUBJECT CHEMICAL AND VOLUME CONTROL SHEET NO. 4/4
CHARGING PUMP HEAD DEE; ECCENTRIC LOOPS VALVE M03072

METHODS USED

PROGRAM ME101 VERSION J2 WAS IMPLEMENTED FOR THE ANALYSIS. DEADWEIGHT AND SEISMIC ANALYSIS WERE PERFORMED USING AN ENVELOPE OF AUXILIARY BUILDING ELEVATIONS 529+0, 601+0, 610+0 AND CONTAINMENT SHELL AT 608+9 FOR THE SEISMIC SPECTRA.

VALUE INFORMATION WAS PROVIDED BY VELAN ENGINEERING. FOR VALUE M0-3072.

SUPPORTS WERE MODELED AS PER FIELD WALK-DOWN INFORMATION.



- VALVE BODY C.G. 4.25" FROM Φ OF VALVE.
- OPERATOR FROM Φ OF VALVE.
- COH BINED C.G. 12.125" ON VERTICAL Φ OF
- BODY WT. 75 #
- OPER. WT. 195 #

THE FOLLOWING INFORMATION WAS RECEIVED FROM MR. KUBIS CIT RAYMOND REGARDING VALVE

514-748-7743 X 311

CALC. # 0603120

BY HEIDI VALENTA OF BECHTEL

TO KUBIS CIT RAYMOND OF VALAND ENGR.

DATE 8-6 " 82 TIME

SUBJECT VALVE MO-3072 S/N 318

JOB NO. 12447-060

ROUTE _____

Telephone call



ATTACHMENT I)



CALCULATION SHEET
(ATTACHMENT I)

ORIGINATOR HEIDI VALENTA DATE 8-25-82 CHECKED CET DATE 9/1/82
 PROJECT PALISADES JOB NO. 12447-060
 SUBJECT VALVES MO-3072 SHEET NO. 31/31

S/N 318, VALVE MO-3072

ISOMETRIC:

THE FOLLOWING DRAWINGS WERE SUPPLIED:

VELAN ENGINEERING COMPANIES

BODY: P-3345-6

OPERATOR: PHILADELPHIA GEAR CORP. - LIMITORQUE VALVE CONTROL
 02-405-0085-4
 9504173*MI-N(A) SH.794-1

THE FOLLOWING INFORMATION WAS OBTAINED FROM
 MR. KUBIS CIT RAYMOND, VELAN ENGINEERING LTD,
 MONTREAL ON 8-6-82.

VALUE BODY WT. 75#

OPERATOR WT. 195#

COMBINED C.G. (BODY + OPERATOR) 12.125" ON
 & OF OPERATOR FROM
 & OF VALVE.

C.G. VALVE 4.25" FROM & OF VALVE



CALCULATION SHEET (ATTACHMENT III)

ORIGINATOR Heidi Valenti DATE 7/25/82 CALC. NO. 2-23120 REV. NO. 0
 PROJECT PALISADES JOB NO. 12447-060
 SUBJECT _____ SHEET NO. 29/31

ASSUMPTIONS: FOR SUPPORTS

SP-FSK-CC7-2 ALL SUPPORTS ACTING AS INSTALLED

SP-FSK-CC7-3

D.P. 89 H3.13 NOT A RESTRAINT

D.P. 94 H3.11 NOT AN AXIAL — GAP $> 3/16$ " IF LIGHT WT.
U-BOLT USED.

D.P. 196 H3.8 NOT A RESTRAINT

SP-FSK-CC7-4


D.P. 178 H4.7 INSURE LATERAL CLEARANCE $< 3/16$ "

SP-FSK-CC7-5

D.P. 42/234 H5.2 NOT A RESTRAINT

SP-FSK-CC7-6 ALL SUPPORTS ACTING AS INSTALLED

SP-FSK-CC7-7 ALL SUPPORTS ACTING AS INSTALLED





CALCULATION SUMMARY COVER SHEET

12447

PROJECT DALISADES JOB NO. 12447-060 DISCIPLINE STIFF STRESS
 SUBJECT ECCENTRIC PIPE LOADS IN SMALL FILE NO. _____
BORE PIPING - VALVE CV04322 CALC NO. 0603370
 ORIGINATOR Heidi Valantus DATE 8-19-82
 CHECKER CURT HERRON DATE 9/1/82 NO. OF SHEETS 4

RECORD OF ISSUES

NO.	DESCRIPTION	BY	DATE	CHKD	DATE	APPD	DATE
△	INITIAL REVIEW	CEH	8-19-82	CEH	9/1/82	PCG	9/2/82
△							
△							
△							
△							
△							

FINAL CALC COMMITTED PRELIMINARY DESIGN CALC

CALCULATION SUMMARY PREPARATION INSTRUCTIONS

1. ORIGINATOR RESPONSIBILITIES

- Complete all title blocks with the following information: project, job number (include subjob), discipline, calculation number, revision, originator (include full name of all originators), date originated, total number of sheets comprising the summary (enter on cover sheet only), and pagination of all sheets excluding cover sheet.
- Complete all summary sheets appropriately to include all assumptions, methods used (e.g., computer program and revision, etc), design input, results, and conclusions.
- Complete cover sheet revision block with revision, description, and originator's initials and date.

2. CHECKER RESPONSIBILITIES

- Check the summary against the calculation to verify completeness and adequacy. (Checker cannot be the originator.)
- Initial and date all pages including the cover sheet.
- Initial and date cover sheet revision block.

3. REVIEW AND APPROVAL

- The discipline group supervisor or designee reviews for completeness and initials and dates the cover sheet revision block to indicate concurrence.

REVISION

CALCULATION SUMMARY SHEET

12447

CALC NO. 267337 D

REV NO. 0

ORIGINATOR Heidi Valente

DATE 8-19-82

CHECKED CEH

DATE 9/1/82

PROJECT PALISADES

JOB NO. 12447-060

SUBJECT ELECTRIC PIPE LOADS IN SHALL

SHEET NO. 1 of 4

CORE PIPING - VALUE CVD432B

DESIGN INPUT AND ASSUMPTIONS

INPUT

- | | | |
|-----------------------------|-------|------------------------|
| 1. PIPING CLASS | _____ | HCC/HBC |
| 2. MATERIAL SPEC. | _____ | SA312 TP304L / SA106-B |
| 3. PIPE NOM. WALL THICKNESS | _____ | 154 / 218 |
| 4. OPER. TEMP. | _____ | 90 / 90 |
| 5. OPER. PRESS. | _____ | 10 / 10 |
| 6. DESIGN TEMP. | _____ | 110 / 110 |
| 7. DESIGN PRESS. | _____ | 16 / 16 |
| 8. PIPE WEIGHT | _____ | 3.653 / 5.022 |
| 9. CONTENT WEIGHT | _____ | 1.455 / 1.28 |
| 10. INSULATION WEIGHT | _____ | N/A |
| 11. TOTAL WEIGHT | _____ | 5.108 / 6.302 |
| 12. SC | _____ | 13300 / 15000 |
| 13. SH | _____ | 13100 / 15000 |
| 14. SY | _____ | 25,000 / 35,000 |
| 15. PIPING CODE | _____ | PER FSAR APPENDIX A |
| 16. | _____ | |

ASSUMPTIONS

SEE ATTACHMENTS I & II



CALCULATION SUMMARY SHEET

12447

CALC NO. 0623370

REV NO. 0

ORIGINATOR H. N. Valente

DATE 2-19-82

CHECKED CEH

DATE 9/1/82

PROJECT PALISADES

JOB NO. 12447-060

SUBJECT EXCENTRIC PIPE LOADS IN SMALL BORE PIPING - VALVE CV0432B

SHEET NO. 2 OF 4

RESULTS AND CONCLUSIONS

D.P. 5-245A

RESULTS

THIS ANALYSIS REFLECTS ACCEPTABLE STRESSES UNDER THE WEIGHT AND SEISMIC LOAD CASE UPSET AND FAULTED. SEE SHEET 3 FOR MORE INFORMATION REGARDING INACCESSIBLE PIPING. THE SYSTEM MAX. STRESS VALUES AND LOCATIONS ARE AS FOLLOWS:

NODE POINT	STRESS COMBINATION (PSI)	ALLOWABLE STRESS (PSI)
245A	PRESS + WT. 5039	15,000
195TB	PRESS + WT + OBE 14220	18,000
—	THERMAL —	—
195TB	PRESS + WT + SSE 27352	32,500

CONCLUSIONS

THE PIPING AT AND AROUND VALVE CV0432B IS ADEQUATELY SUPPORTED AND STRESSES MEET CODE ALLOWABLES AND ACCELERATION LIMITS AS SPECIFIED IN FSAR APPENDIX A. SEE SHEETS 3 + 4 FOR MORE INFORMATION REGARDING INACCESSIBLE PIPING.



CALCULATION SUMMARY SHEET

12447

ORIGINATOR H. J. Valentin DATE 8/19/82 CALC NO. 26028100 REV NO. 0
 PROJECT PALISADES CHECKED CEH DATE 9/1/82
 SUBJECT ECCENTRIC PIPE LOADS IN SMALL BORE PIPING - VALVE CV0438B JOB NO. 124-7-243 SHEET NO. 3 OF 4

RESULTS AND CONCLUSIONS

D.P. 250-309

RESULTS

THE PIPING IN THIS INACCESSIBLE REGION IS HIGHLY OVER-STRESSED DUE TO THE FACT THAT THERE EXISTS NO SUPPORT INFORMATION FOR THIS AREA. AND WAS MODELLED AS IF NO SUPPORTS EXISTED. THIS IS A HIGHLY CONSERVATIVE ASSUMPTION CONSIDERING THE FACT THAT THE PIPING WAS FIELD SUPPORTED.

RESULTS SHOW, THOUGH, THAT THE PIPING AT THE VALVE CV0438B AND CONNECTING MEET CODE STRESS ALLOWABLES AND IS THEREFORE PROPERLY SUPPORTED IN THE AREA OF CONCERN -

SEE SHEET 4.

NODE POINT	STRESS COMBINATION (PSI)		ALLOWABLE STRESS (PSI)
295	PRESS + WT.	63,988	15,000
30A	PRESS + WT + OBE	109,712	18,000
—	THERMAL	—	—
30A	PRESS + WT + SSE	155,663	32,500

CONCLUSIONS

SEE METHODS USED PAGE 4



CALCULATION SUMMARY SHEET

12447

ORIGINATOR Heidi C. Valente DATE 8/19/82 CALC NO. 02-03370 REV NO. 0
 PROJECT PLUMBLET JOB NO. 12447-020 CHECKED CEH DATE 9/1/82
 SUBJECT SEISMIC PIPE LOADS IN SMALL SHEET NO. 4 of 4
SDRE PIPING - VALVE CV0432B

METHODS USED

DUE TO INSUFFICIENT FIELD INFORMATION BETWEEN SUPPORT H1.17 AT ELEVATION 624+10 AND TANK T-103 AT ELEVATION 650+1/2, AN ASSUMPTION WAS MADE AS TO THE FIELD PIPE ROUTING BETWEEN THESE TWO POINTS. THE RESULT WAS APPROXIMATELY 90' OF UNSUPPORTED PIPING IN THE Y, X, AND Z DIRECTIONS, WHICH IN TURN IMPOSED CONSIDERABLE MOMENT AND LOADING ON SUPPORTS H1.17, H1.14 AND H1.13 LOCATED JUST BELOW THE INACCESSIBLE REGION. THEREFORE STRESS RESULTS WERE SEGREGATED INTO TWO SECTIONS 1) PIPING FROM TANK T-103 TO THE LAST 3 SUPPORTS OF THE ACCESSIBLE REGION AND 2) ACCESSIBLE PIPING UP TO THE 3 SUPPORTS PRIOR TO THE INACCESSIBLE AREA. VALVE CV-0432B IS SUFFICIENTLY INSULATED FROM THE EFFECTS OF THE UNSUPPORTED, INACCESSIBLE PIPING. ACCELERATION OF VALVE CV-0432B IS LESS THAN $3g$ IN EACH DIRECTION AND SEISMIC STRESSES ARE BELOW THE ALLOWABLE AS SPECIFIED BY 821.1 '69.

MULTIPLE RESPONSE SPECTRA ANALYSIS WAS USED RATHER THAN ENVELOPED SEISMIC SPECTRA. THIS LESS CONSERVATIVE METHOD WAS USED IN AN EFFORT TO EASE THE CLING EFFECT FROM THE 90' OF UNSUPPORTED PIPING ON THE RIG OF THE SYSTEM.



CALCULATION SHEET (ATTACHMENT I)

ORIGINATOR HEIDI VALENTA DATE 8-11-82 CALC. NO. 0623370 REV. NO. _____
PROJECT PALISADES JOB NO. 12447-060 CHECKED CEH DATE 9/1/82
SUBJECT VALVES CV-0438B SHEET NO. 17 of 17

S/N 337, VALVE CU-0438B

ISOMETRIC: SP-HBC-31-1 REV. 6

THE FOLLOWING DRAWINGS WERE SUPPLIED:

HENRY VOGT MACHINE CO.

BODY: M-48500

OPERATOR: FISHER GOVERNOR DWG. AK5819
VOGT CRO #157907

THE FOLLOWING INFORMATION WAS OBTAINED FROM
MR. SAM RADERER, ENGINEERING MANAGER, HENRY
VOGT CO. ON 8-6-82.

VALVE BODY WT. 21.9#
OPERATOR WT. 149.6#

COMBINED C.G. (BODY + OPERATOR) 20.69" ON VERTICAL
¢ OF OPERATOR FROM
¢ OF VALVE.

C.G. VALVE 4.315" FROM ¢ OF VALVE



Telephone call

ROUTE _____

BY HEIDI VALENTA OF BECHTEL

TO SAM RADERER OF HENRY VOST CO.

DATE 8-6 1982 TIME _____

SUBJECT VALVE CU0438B S/N 337

JOB NO. 12447-060

CALC # 060237Q

502-634-1511

THE FOLLOWING INFORMATION WAS RECEIVED FROM MR. SAM RADERER REGARDING VALVE MO-3072 .

- BODY WT. 21.9#
- OPER. WT. 149.6#
- COMBINED C.G. 20.69" ON VERTICAL ϕ OF OPERATOR FROM ϕ OF VALVE .
- VALVE BODY C.G. 4.315" FROM ϕ OF VALVE .



CALCULATION SUMMARY COVER SHEET

12447

PROJECT PALISADES JOB NO. 12447-060 DISCIPLINE STPD
 SUBJECT SAFETY INJECTION FILL & DRAIN FILE NO. _____
ECCENTRIC LOAD VALVE CV3003 CALC NO. 0603209
 ORIGINATOR Heidi Valenta DATE 9-14-82
 CHECKER CURT HERRON DATE 9/15/82 NO. OF SHEETS 3

RECORD OF ISSUES

NO.	DESCRIPTION	BY	DATE	CHKD	DATE	APPD.	DATE
△	PRELIMINARY AS-BUILT ANALYSIS	HJV	9/14/82	CEH	9/15/82	PCP	9/15/82
△							
△							
△							
△							
△							

FINAL CALC COMMITTED PRELIMINARY DESIGN CALC

CALCULATION SUMMARY PREPARATION INSTRUCTIONS

1. ORIGINATOR RESPONSIBILITIES

- Complete all title blocks with the following information: project, job number (include subjob), discipline, calculation number, revision, originator (include full name of all originators), date originated, total number of sheets comprising the summary (enter on cover sheet only), and pagination of all sheets excluding cover sheet.
- Complete all summary sheets appropriately to include all assumptions, methods used (e.g., computer program and revision, etc), design input, results, and conclusions.
- Complete cover sheet revision block with revision, description, and originator's initials and date.

2. CHECKER RESPONSIBILITIES

- Check the summary against the calculation to verify completeness and adequacy. (Checker cannot be the originator.)
- Initial and date all pages including the cover sheet.
- Initial and date cover sheet revision block.

3. REVIEW AND APPROVAL

- The discipline group supervisor or designee reviews for completeness and initials and dates the cover sheet revision block to indicate concurrence.



CALCULATION SUMMARY SHEET

12447

CALC NO. 0603209 REV NO. 0

ORIGINATOR Heidi Valente DATE 9/14/82

CHECKED CEH DATE 9/15/82

PROJECT PALISADES

JOB NO. 12447-060

SUBJECT SAFETY INJECTION FILL + DRAIN
EXCENTRIC LOADS VALUE CV3003

SHEET NO. 1 OF 3

DESIGN INPUT AND ASSUMPTIONS

INPUT

- | | | |
|-----------------------------|-----------|------------------------|
| 1. PIPING CLASS | _____ | G.C. |
| 2. MATERIAL SPEC. | _____ | SA376-TP304 |
| 3. PIPE NOM. WALL THICKNESS | _____ | 2" 1"
154, 133 |
| 4. OPER. TEMP. | _____ | — |
| 5. OPER. PRESS. | _____ | 200 (PERF.) |
| 6. DESIGN TEMP. | _____ | — |
| 7. DESIGN PRESS. | _____ | 250 |
| 8. PIPE WEIGHT | _____ | 3.653, 1.679 |
| 9. CONTENT WEIGHT | _____ | 1.455, .374 |
| 10. INSULATION WEIGHT | _____ | — |
| 11. TOTAL WEIGHT | _____ | 5.108, 2.053 |
| 12. SC | _____ | 18700 |
| 13. SH | _____ | 15600 |
| 14. SY | _____ | 25000 |
| 15. PIPING CODE | B31.1, 73 | PER FSAR
APPENDIX A |
| 16. | _____ | |

ASSUMPTIONS

SEE ATTACHMENT I



CALCULATION SUMMARY SHEET

12447
 ORIGINATOR A. D. Valente DATE 9/14/82 CALC NO. 060320 Q REV NO. 0
 PROJECT PALISADES CHECKED CEH DATE 9/15/82
 SUBJECT SAFETY INJECTION FILL + DRAIN JOB NO. 12447-060
ECCENTRIC LOADS VALVE CV3003 SHEET NO. 2 OF 3

RESULTS AND CONCLUSIONS

RESULTS

AS INDICATED BELOW THIS SYSTEM IS HIGHLY OVERSTRESSED IN WEIGHT AND SEISMIC. THE HIGH STRESS IS DUE IN PART TO THE LACK OF FIELD INFORMATION ON PIPING BETWEEN FLOOR PENETRATION @ 649+0 AND TANK 82-D.

NODE POINT	STRESS COMBINATION (PSI)	ALLOWABLE STRESS (PSI)
391	PRESS ⁴³² + WT.	30,371 15,600 ✓
391	PRESS ⁴³² + WT + OBE	49,426 18,720 ✓
—	THERMAL	— —
391	PRESS + WT + SSE	68,481 27,500 ✓

CONCLUSIONS

IF THE INACCESSIBLE PORTION OF THE PIPING BETWEEN THE TANK AND VALVE CV-3003 IS FOUND TO BE ADEQUATELY SUPPORTED, THE STRESS LEVELS AND SUPPORT LOADS ARE EXPECTED TO DROP.

AS A RESULT THE CONTROL VALVE CV-3003 AS WELL AS PIPING AROUND IT MAY BE SEISMICALLY ACCEPTABLE WITHOUT THE NEED FOR ANY NEW SUPPORTS.



CALCULATION SUMMARY SHEET

12447

CALC NO. 0005709 REV NO. 0

ORIGINATOR Heidi Valer, Jr. DATE 9-14-82 CHECKED CEH DATE 9/15/82

PROJECT PALISADES JOB NO. 12447-060

SUBJECT SHEATH INJECTION (ILLUSTRATED) SHEET NO. 3 OF 3

ECCENTRIC LOADS VALVE CV3003

METHODS USED

ASSUMING PIPE TO BE UNSUPPORTED BETWEEN FLOOR @ 649+0 AND TANK 82-D GIVES VERY UNREALISTIC LOADS AND STRESSES IN THIS AREA. ALTHOUGH, ACTUAL LOCATION OF SUPPORTS IN THE AREA IS UNKNOWN.

THE ORIGINAL STRESS MODEL CONSISTED OF 10 ISOMETRICS. THE MODEL USED FOR THIS ANALYSIS IS ONLY A PORTION OF THE ORIGINAL. PIPING BEYOND THE LIMITS OF THIS MODEL WAS NOT INCLUDED DUE TO THE FACT THAT THE EFFECT BEYOND THIS POINT UPON THE VALVE CV3003 IN QUESTION WOULD NOT BE SIGNIFICANT ENOUGH TO WARRANT THE MODELING OF THE 10 ENTIRE ISOMETRICS.

AN ENVELOPE SPECTRA FOR ELEVATIONS 616+4 1/2 TO 712+10 WAS USED FOR THE ENTIRE PIPING (THE MAJORITY OF THE PIPING IS AT ELEV. 616+0)



(ATTACHMENT I)

S/N

8-19-82

CV-3003

~~CV-3003~~
PALISADES
12447

19 AUGUST 31 16
55
26


~97#
ALTOGETHER

55#
ACTUATOR

#11 REVERSE
#77-4

16#
FOSD
AIRSET

26#
BODY



ATTACHMENT #2
Consumers Power Company
PALISADES SEP TOPIC III-6
October 13, 1982

HENRY **Vogt** MACHINE CO.
 P.O. Box 1918 Louisville, Ky. 40201
 502-634-9411
ENGINEERING DEPARTMENT

CRO 157907
 JOB NO. 5935-M336-AC

COMPANY Bechtel Corporation
 ADDRESS P. O. Box 3965, San Francisco, California
 SUBJECT Seismic Analysis - Bechtel Item 15.1
 BY G. A. Jolly DATE Oct. 4, 1973 CHECKED BY E.P. Becker DATE 10-8-73

Valve per Vogt Dwg. M-48500
 Bechtel Item 15.1
 Job No. 5935-M336-AC

EQUIPMENT DESCRIPTION


Vogt valve per Dwg. M-48500 is a 2" - 600# gate valve made from carbon steel (A181-Gr.2) which utilizes a Fisher Control Type 473-1-5 spring return, size 40 side mounted cylinder handwheel and associated equipment for operation. The total weight of the Fisher cylinder operator is 79#. The approximate weight of the valve/operator combination is 110#.

ASSUMPTIONS AND PROCEDURES

1. Two seismic considerations are covered by the calculations as follows:
 - A. A complete seismic analysis of the valve operator when operating at a 3g horizontal and vertical acceleration. (Fisher analysis is attached - See Dave Howell's analysis.)
 - B. An analysis of the valve bonnet as a result of the increased load due to 3g acceleration forces of the valve actuator. (See Vogt calculation attached - G. A. Jolly)
2. A Natural Frequency Calculation was conducted on valve.
3. Calculations are based on valve installed in horizontal pipe run with valve stem vertical.

CONCLUSIONS

Calculations indicate that valve and operator should operate satisfactorily during and after a 3g seismic load.



5935-M336-SH107-2

FISHER CONTROLS COMPANY

MARSHALLTOWN, IOWA 50158

AUTOMATIC CONTROL EQUIPMENT
SINCE 1880

September 27, 1973

M336 SN107

Seismic Certification for:

Agent Order: 50-2088

Customer Order: C-40934

Serial No.	Tag No.
5655387	CV-0437A
5655388	CV-0437B
5655389	CV-0438A
5655390	CV-0438B

Enclosed is the seismic calculations for a Size 40 Type 473-1-5 piston actuator. The equipment is considered to be able to withstand the specific seismic disturbance if the calculated stress does not exceed 50% of the tensile stress of cast iron and does not exceed the stress at room temperature of the yoke locknut.

Yoke - Cast Iron, ASTM A48-Class 30
50% of the Tensile Stress = 15000 PSI

Yoke Locknut - Steel, ASTM A235 - Class A
Approximate Yield in Shear = 20000 PSI

Also enclosed is a seismic test of an Asco solenoid performed by the Research Department. This is in compliance with the specifications levied on accessories.

Dave Howells
Dave Howells
Project Engineer

DH:dn

encl.

11052705

HENRY VOGT
MACHINE CO.

SEISMIC ANALYSIS DAVE HOWELLS

AGENT ORDER: 50-2088
CUSTOMER ORDER: C-40934
SERIAL NUMBER: 5655387-390

SIZE 40 TYPE 473-1-5 PISTON ACTUATOR

I. DETERMINATION OF RESULTANT STRESSES

VALVE INSTALLED IN A HORIZONTAL PIPE RUN WITH THE
VALVE STEM VERTICAL





FIG 1



SECTION A-A

FIG 2

11052706

101145 092113

- TERMS

- C1 - DISTANCE FROM NEUTRAL AXIS 1-1 TO OUTERMOST FIBER (in)
 C2 - DISTANCE FROM NEUTRAL AXIS 2-2 TO OUTERMOST FIBER (in)
 F - ACTUATOR OUTPUT FORCE (lbs)
 F1 - FORCE DUE TO VERTICAL SEISMIC ACCELERATION (lbs)
 F2 - FORCE DUE TO HORIZONTAL SEISMIC ACCELERATION (lbs)
 G1 - VERTICAL SEISMIC ACCELERATION (gs)
 G2 - HORIZONTAL SEISMIC ACCELERATION (gs)
 I1 - MOMENT OF INERTIA ABOUT AXIS 1-1 (in⁴)
 I2 - MOMENT OF INERTIA ABOUT AXIS 2-2 (in⁴)
 L1 - DISTANCE FROM SECTION A-A TO CG OF ACTUATOR (in)
 M - MOMENT ABOUT SECTION A-A DUE TO LATERAL LOAD ON ACTUATOR (in-lb)
 S1 - YOKE LEG STRESS DUE TO VERTICAL LOADS (psi)
 S2 - TOTAL YOKE LEG STRESS

$$F1 = (G1)W = 3 \times 79 = 237^{\#} \quad W \rightarrow \text{wgt of actuator}$$

$$F2 = (G2)W = 3 \times 79 = 237^{\#}$$

STRESS DUE TO VERTICAL LOADS, the greater of

$$1) S1 = \frac{F + F1 - W}{A} \rightarrow \text{stress when valve plug is seated}$$

OR

$$2) S1 = \frac{F1 + W}{A} \rightarrow \text{stress when valve plug is open}$$

where A is the cross sectional area of yoke legs.

$$F = (\text{AIR TO CR}) (\text{PISTON AREA}) = 100 \times 28.25 = 2825^{\#}$$

$$1) S1 = \frac{2825 + 237 - 79}{2.4} = 1245 \text{ PSI}$$

$$2) S1 = \frac{2825 + 79}{2.4} = 1210 \text{ PSI}$$

\(\therefore\) STRESS DUE TO VERTICAL LOADS = 1245 PSI

BENDING STRESS DUE HORIZONTAL SEISMIC LOAD:

$$S = \frac{MC}{I}$$

101115 0960

11052707

11053708

$$M = (F_2)(L_1) = 237 \times 12.875 = 3055 \text{ in lbs}$$

$$\frac{C}{I} \text{ the greater of } * \frac{C_1}{I_1} \text{ OR } \frac{C_2}{I_2}$$

$$\frac{1.125}{1.19} \text{ OR } \frac{2.9375}{3.4}$$

$$* .95 \text{ OR } .86$$

$$S = \frac{M C}{I} = (3055)(.95) = 2910 \text{ PSI BENDING STRESS DUE TO HORIZONTAL SEISMIC LOAD}$$

TOTAL YOKE LEG STRESS:

$$S_2 = S_1 + \frac{(F_2)(L_1)C_1}{I_1} = 1245 + \frac{(237)(12.875)(1.125)}{1.19} = 4155 \text{ PSI}$$

SUMMARY OF STRESSES

- ✓ STRESS DUE TO VERTICAL LOADS... 1245 PSI
- ✓ BENDING STRESSES DUE TO HORIZONTAL SEISMIC LOADS 2910 PSI
- ✓ TOTAL YOKE LEG STRESS 4155 PSI

CALCULATIONS PERFORMED BY:

Dave Howells
DATE: 27 Sept 73

PROJ. ENGR.

11053708

FISHER CONTROLS COMPANY
MARSHALLTOWN, IOWA

Project 73AR23

PROB. 1529

REPORT 14

PAGE 1

DATE 5-9-73

LABORATORY REPORT

VIBRATION TEST OF ASCO SOLENOID VALVE

ITEM	Solenoid Valve	TYPE	3-Way Universal
MANUFACTURER	Automatic Switch Company	DESIGN	
SIZE	1/4" NPT	DWG	
SPECIAL IDENTIFICATION	Catalog No. HT 8320A107	- SN	95872S

an HTX 8320 is the same as the unit tested, the X designates an explosion proof housing and does not change the seismic parameters

PURPOSE: Vibration tests were conducted to generate data for customers who require seismic information.

TEST PROCEDURE: See attached copy of Test Procedure.

TYPE OF MOUNTING: The assembly was nipple mounted thru a bracket mounted to the shaker table.

ACCELEROMETER LOCATION: The accelerometer was mounted on the shaker table.

RESULTS: DIRECTION 1 - No Malfunction

DIRECTION 2 - No Malfunction

DIRECTION 3 - No Malfunction

NOTE: See Data Sheets 1 and 2 for illustration of directions.

CONCLUSIONS AND RECOMMENDATIONS: The ASCO Solenoid Valve performed satisfactorily and meets or exceeds the specification outlined in the Test Procedure.

J. M. Wilkinson

James M. Wilkinson
Research Department

11052709

M336 5107

HENRY VOGT MACHINE CO.
GUY A JOLLY

1 OF 2

VOGT CRO 157907
BECHTEL ORDER 5935-M336-AC

DETERMINATION OF RESULTANT STRESSES
IN VALVE BONNET BOLTING AS A RESULT
OF 3G SEISMIC ACCELERATION.

OPERATING PRESS. (MAX) = 1440 psig
FLANGE MATERIAL - A191 GR 2.
BOLTING MATERIAL - A193 B7

ALLOWABLE BOLT STRESS - 25000 PSIG

GASKET DETAILS - 2 3/16" I.D. X 2 15/16" O.D
SPIRAL WOUND

FACING DETAILS - GASKET RECESSED AND
BOLTED UP METAL TO METAL
WITH A CONTROLLED COM-
PRESSION OF .030 INCHES.

*GASKET FACTORS N = .3125, (CONTACT)
b = .15625
γ = 4500
m = 3.00

11052710

(* TAYLOR FORGE BULLETIN #502, MODERN FLANGE DESIGN)
MIN BOLT LOAD FOR GASKET SEAT - H_{Gy}
H_{Gy} = bπGγ = .15625 x π x 2.5625 x 4500 = 5660 #
TOTAL JOINT-CONTACT SURFACE COMPRESSION LOAD = H_{GP}
H_{GP} = 2bπGmP = 2 x .15625 x π x 2.5625 x 3 x 1440 = 10800 #
TOTAL HYDRO LOAD = H
H = $\frac{G^2 P^2}{2}$ = $\frac{2.5625^2 \times \pi^2 \times 1440}{2}$ = 7426 #

M336 107
H_{GP} + H = 18294 # REQ. BOLT LOAD (TOTAL) 2 OF 9

A_B = 4 x .202 = .808 sq inches A_B = AREA BOLTING

BONNET BOLTING STRESS DUE TO PRESSURE LOADING
THE GREATER OF:

$$S_p = \frac{H_{GP} + H}{A_B} \quad \text{OR} \quad S_p = \frac{H_{GY}}{A_B}$$

$$S_p = \frac{18294 \#}{.808} = 22,641 \text{ psi}$$

SEISMIC LOADS ON BOLTING

A. F_V = VERTICLE LOAD ON BOLTS DUE TO 3g
SEISMIC (VERTICLE) ACCELERATION.

$$F_V = (G_1) W_V = 3 \times (90) = 270 \#$$

W_V = WT OF CYLINDER & BONNET
OF VALVE PER M-48500

STRESS ON BOLTS DUE TO THIS LOAD
(VERTICLE SEISMIC)

$$S_V = \frac{270 \#}{.808} = 334 \text{ psi}$$

11052711

B. F_H = HORIZONTAL LOAD ON CYLINDER &
BONNET DUE TO 3g SEISMIC
(HORIZONTAL) ACCELERATION.
THIS FORCE ACTS THROUGH CENTER
OF GRAVITY OF CYLINDER &
BONNET

$$F_H = (G_2) W_V = 3 \times (90) = 270 \#$$

THIS FORCE (F_H) ACTS AS A MOMENT ON THE BONNET BOLTING. A MOMENT BALANCE EQUATION HAS TO BE SET UP TO DETERMINE THE ACTUAL FORCES IN THE BOLTING TO RESIST THIS MOMENT.

ASSUMPTIONS:

a. THE PIVOT POINT IS CONSIDERED TO BE THE OUTER EDGE OF THE BOLTED BONNET FLANGE. (SEE SKETCH #2)

b. THE BOLTING LOADS ARE PROPORTIONAL TO THE DISTANCES FROM THE PIVOT POINT. (SEE SKETCH #2) THE PIVOT PT IS AT OUTSIDE EDGE OF BONNET FLANGE (ASSUMED)

$$\therefore \frac{F_1}{F_2} = \frac{d_1}{d_2} \quad \text{WHERE } F_1 \text{ \& } F_2 \text{ ARE THE RESISTANT FORCES OF THE BOLTS TO ROTATION.}$$

F_1 ACTS AT DISTANCE OF d_1 FROM PIVOT POINT

F_2 ACTS AT DISTANCE OF d_2 FROM PIVOT POINT

SUMMING MOMENTS ABOUT THE PIVOT POINT

$$\Sigma M = 0 \quad (\text{THERE ARE 4 BOLTS RESISTING ROTATION.})$$

$$L \times F_H = 2F_1 d_1 + 2F_2 d_2 \quad \frac{F_1}{F_2} = \frac{d_1}{d_2}$$

$$L \times F_H = \frac{2F_2}{d_2} (d_1^2 + d_2^2)$$

L = DISTANCE FROM PIVOT PT TO CENTER OF GRAVITY

117052772

M336 517

M336-110

L = 16.375 INCHES

d₁ = 1.094
d₂ = 3.718

16.375 x 270 = $\frac{2F_2}{3.718} (3.718^2 + 1.094^2)$

∴ F₂ = 547# ∴ F₁ = $547 \times \frac{1.094}{3.718} = 160.9\#$

STRESS ON BOLTS DUE TO THIS LOAD
(HORIZONTAL SEISMIC)

MAXIMUM STRESS OCCURS ON 2 BOLTS
THE GREATEST DISTANCE FROM
THE PIVOT POINT.


S_H = $\frac{F_2}{\frac{AB}{2}} = \frac{547}{.404} = 1,354 \text{ PSI}$

SUMMARY OF BONNET JOINT STRESSES

- STRESS DUE TO PRESSURE LOAD = 22,641 PSI ✓
- STRESS DUE TO VERTICLE SEISMIC LOAD = 1,034 PSI ✓
- STRESS DUE TO HORIZONTAL SEISMIC LOAD = 1,354 PSI ✓
- MAXIMUM TOTAL BOLTING STRESS = 24,379 PSI ✓

12057713

STRESS IN BONNET* DUE TO SEISMIC ϵ PRESSURE LOADING



SEE SKETCH #1

DETERMINE MIN. AREA RESISTING PRESS & SEISMIC LOAD.

AREA AT RETAINING NUT THREAD = A_{AA} (SECT AA)

THD: (2 3/4 - 12NIC - 2A) \Rightarrow OD ROOT THD = 2.750

PACKING CHAMBER DIM. = 1.125 $\frac{.083}{2.667}$

AREA = $A_{AA} = \frac{\pi}{4} (2.667^2 - 1.125^2) - 2 \times \left(\frac{\pi}{4} (.375)^2 \right)$

$A_{AA} = 4.59 - .221$

$A_{AA} = 4.37$

PACKING STUDS AREA

1052714

(SECT BB) AREA = $\frac{\pi}{4} (D^2 - C^2) = \frac{\pi}{4} (2^2 - .75^2)$ A_{BB}

SEE SKETCH #1

$A_{BB} = 2.7 \text{ sq in}$

SINCE THE AREA IS SIGNIFICANTLY LESS AT SECT BB CALCULATE THE STRESS AT THIS POINT DUE TO PRESS & SEISMIC. SECT BB IS THE WEAKEST PT.

M3310 2/10

m336 ch 10

FORCE AT SECT BB DUE TO PRESSURE

$$F_{BB} = (A_{GEN PCKING} - A_{GEN STEM}) \times PRESS (MAX)$$

$$= \frac{\pi}{4} [1.125^2 - .625^2] \times 1440 \text{ PSIG}$$

$$F_{BB} = .989.6 \#$$

HOWEVER THIS FORCE IS NOT AS GREAT AS THE OPERATOR OUTPUT LOAD (F) - USE F = 2825#

$$S_{BBP} = \frac{F}{A_{BB}}$$

$$S_{BBP} = \frac{2825\#}{2.7 \text{ IN}^2} = 1046 \text{ PSI}$$

STRESS AT SECT BB DUE TO SEISMIC (VERT) CONDITION

$$S_{BBV} = \frac{(G_1) W_v}{A_{BB}} = \frac{3 \times 90}{2.7}$$

$$S_{BBV} = 100$$

STRESS AT SECT BB DUE TO SEISMIC (HORIZONTAL) CONDITION.

$$S_{BBH} = \frac{MC}{I}$$

$$M = G_2 W \times L_{cc}$$

where L_{cc} = Dist from Sect CC TO CG of Operator/Bracket.

$$(SECT BB) \frac{I_{AA}}{C} = \frac{\pi}{32} \left[\frac{D^4 - C^4}{D} \right]$$

where $L_{cc} = 12.875 + 3\frac{1}{2}$

11052715

M336 d10

$$\frac{D}{H} = \frac{\pi}{32} \left[\frac{(2)^4 - (75)^4}{2} \right]$$

$$\frac{I}{c} = .77$$

$$S_{BHH} = \frac{MC}{I_{AA}}$$

$$S_{BHH} = \frac{3 \times 90 \times 16}{.77}$$

$$S_{BHH} = 5610 \text{ PSI}$$

SUMMARY OF STRESSES IN BONNET

- S_{BBP} = STRESS AT SECT BB DUE TO PRESS LOAD = 1,046 PSI
- S_{BBV} = STRESS AT SECT BB DUE TO VERT SEISMIC = 100 PSI
- S_{BBH} = STRESS AT SECT BB DUE TO HORIZ SEISMIC = 5,610 PSI
- TOTAL STRESS AT SECT BB = 6,756 PSI

11052718

NATURAL FREQUENCY CALCULATION

$$F_n = 5.42 \sqrt{\frac{EI}{W(L_{cc})^3}}$$

ASSUME THE OPERATOR
& BONNET IS A
CANTILEVER BEAM
FIXED AT SECT
"BT".

$$E = 28 \times 10^6$$

$$I = .77$$

$$W = 90 \#$$

$$L_{cc} = 16$$

$$F_n = 5.42 \sqrt{\frac{28 \times 10^6 \times .77}{90 \times (16)^3}}$$



$$F_n = 41.4 \text{ cps}$$

11052717

M336 dn 157

REVISION RECORD


No.	DATE	FROM	TO	BY



SKETCH 1

Customer Order No. 5935-M336-AC
Voigt Order No. CRD 157907
Fisher Operator No. SIZE40-4 on

M336 dn107



11052719

BOLTING ARRANGEMENT FOR B48499

SKETCH #2

ATTACHMENT #3
Consumers Power Company
PALISADES SEP TOPIC III-6
October 13, 1982

233
M-311-212

CONTROLLED COPY



RBD

D. Control

750W222-M233 SH.20

DISTRIBUTION	
DESIGN	1
PROJECT	RT
FIELD	
QA	
TRN	
CLIENT	
MARKET	
REVENUE	
PROFIT	
SALES	
INSPECT	
TESTED	
START UP	
	A.A. 1 SC
	RT
A. QUILL CO.	

VENUE DRAWING REVIEW	
<input checked="" type="checkbox"/>	Approved for Manufacturing
<input type="checkbox"/>	Approved for final
<input type="checkbox"/>	Approved except as noted &
<input type="checkbox"/>	Revisions required
<input type="checkbox"/>	Approved for manufacturing
<input type="checkbox"/>	Approved for construction
<input type="checkbox"/>	Approved for
<i>AW</i> Date <i>11/20/74</i>	
CO.	JOB
	0936
PLANT	
CONSUMERS POWER CO.	

AW for H.T.

1850182

ENGINEERING
OCT 12 1982
CONSOLIDATED POWER
CO.
JACKSON, MISSISSIPPI

5935-004-M348B-2-1 JUL 15 1974
950Y281

MASCOLETTI INTERNATIONAL
SEISMIC CALCULATIONS PER ASME SECTION III
CLASS 2

WORK UNDER THE SAMPLE-DPI
SIZE 1.00 IN. TYPE 20561 RATING 600 LBS. ACTUATOR 9.0K DESIGN PRESSURE 1250. PSIG
INPUT DATA

BODY GSKT O.D.	2.250 IN.	BONNET	ACTUATOR WGT.	45.000 LBS.
I.D.	1.940 IN.		WIDTH DIM.	2.500 IN.
H FACTOR	1.750	ACTUATOR WGT.	OUTSIDE DIM.	4.600 IN.
Y FACTOR	7600.000	PRESS.	INSIDE DIM.	3.600 IN.
SEAT GSKT O.D.	0.0 IN.	DIAPHRAGM AREA	C.G. HEIGHT	10.700 IN.
I.D.	0.0 IN.	C.G. HEIGHT		
H FACTOR	0.0	HUB O.D.	DESIGN STRESS INTENSITY	
Y FACTOR	7600.000		POINT @ 60F	17500. PSI @ TEMP 17500. PSI
FLANGE O.D.	4.310 IN.	ACCELERATION	YOKI @ 60F	4000. PSI
I.D.	1.190 IN.	VERTICAL	BOLT @ 60F	25000. PSI @ TEMP 25000. PSI
C.G.	3.250 IN.	HORIZONTAL	NUT @ 60F	20000. PSI
THICKNESS	0.625 IN.			
BOLT SIZE	0.500 IN.	NUT SHR AREA/IN.	INTERNAL MOMENT	0.0 IN-LBS
QUANTITY	4.000	ENGAGEMENT	EOPCF	0.0 LBS.
VALVE BODY ID.	1.000 IN.	DIAMETER	PRESSURE FO	1250.000 PSIG
HAND WHEEL NO.	000	HANDWHEEL DIST.	TEMPERATURE	500. DEG. F


OUTPUT DATA

WMI	11576. LBS.	W	12666. LBS	VM2	5573. LBS.	MINIMUM WALL THICKNESS	0.250 IN.
MOI	7475. IN.-LBS	MO2	6904. IN.-LBS				
NORMAL FLANGE		ALLOWABLE		TOTAL FLANGE		ALLOWABLE	
STRESSES SH	12036. PSI	STRESSES	26250. PSI	STRESSES SH	13566. PSI	STRESSES	52500. PSI
OPERATING ST	10434. PSI		17500. PSI	ST	10055. PSI		52500. PSI
SR	14166. PSI		17500. PSI	SR	14101. PSI		52500. PSI
SHR AVG	13091. PSI		17500. PSI	SHR AVG	14833. PSI		52500. PSI
SHT AVG	10435. PSI		17500. PSI	SHT AVG	11810. PSI		52500. PSI
NORMAL FLANGE		ALLOWABLE		TOTAL FLANGE		ALLOWABLE	
STRESSES SH	11117. PSI	STRESSES	26250. PSI	STRESSES SH	12647. PSI	STRESSES	52500. PSI
GASKET ST	8159. PSI		17500. PSI	ST	9360. PSI		52500. PSI
SR	13066. PSI		17500. PSI	SR	15021. PSI		52500. PSI
SHR AVG	12091. PSI		17500. PSI	SHR AVG	13034. PSI		52500. PSI
SHT AVG	9438. PSI		17500. PSI	SHT AVG	11013. PSI		52500. PSI
NORMAL BOLT		ALLOWABLE		TOTAL BOLT		ALLOWABLE	
STRESS SP	21032. PSI	STRESS	25000. PSI	STRESS SH	22692. PSI	STRESS	75000. PSI
				TOTAL YOKI		ALLOWABLE	
				STRESS SYI	741. PSI	STRESS	4000. PSI
				TOTAL NUT		ALLOWABLE	
				STRESS MUTT	161. PSI	STRESS	20000. PSI


FO101701-1-22-73

11053057

CG OF ACTUATOR
BONNET ASSY





- A. BONNET AND ACTUATOR ASSY ARE CONSIDERED AS A CANTILEVER BEAM RIGIDLY ATTACHED WHEN COMPUTING BONNET STRESSES.
- B. YOKE AND YOKE BONNET CONNECTIONS ARE ANALYZED SEPARATELY.



P1858184

WHEN HANDWHEEL IS SUPPLIED ADDITIONAL STRESSES ARE ADDED SEPARATELY




YOKE CROSS SECTION "A"- "A"
(PLANE OF HIGHEST STRESS INTENSITY)


MOMENT OF INERTIA:

$$I_{yy} = \frac{(a - a_1) b^3}{12}$$

SECTION MODULUS:
I/C ABOUT YY AXIS
IS SMALLER AND WILL
BE USED FOR STRESS
CALCULATION



YOKE SIZE	a	a ₁	d	b
9	4.6	2.6	2.0	1.25
11	4.6	2.6	2.0	1.25
13	5.12	4	2.5	1.37
15 / 18	7.18	5.75	4.5	2.25
18L	7.27	6.12	4.5	2.25
24	8.0	7.5	5.0	2.5



MASON FILAN INTERNATIONAL
SEISMIC CALCULATIONS

WORK ORDER NO. H88068-002
 SIZE 1.00 INCH TYPE 20761 RATING 600 LBS. ACTUATOR 11.0R DESIGN PRESSURE 750. PSIG
 INPUT DATA

BODY GSKT O.D.	2.380 IN.	BONNET	ACTUATOR WGT.	55.000 LBS.	WIDTH DIM.	2.500 IN.
I.D.	1.940 IN.	ACTUATOR WGT.	63.000 LBS.	OUTSIDE DIM.	4.600 IN.	
M FACTOR	3.000	PRESS.	11.000 PSI	INSIDE DIM.	3.600 IN.	
Y FACTOR	4500.000	DIAPHRAGM AREA	86.000 SQ. IN.	C.G. HEIGHT	10.500 IN.	
SEAT GSKT O.D.	1.780 IN.	C.G. HEIGHT	11.120 IN.	DESIGN STRESS INTENSITY		
I.D.	1.410 IN.	HUR O.D.	2.000 IN.	BONNET @ 60F	17500. PSI @ TEMP	17500. PSI
M FACTOR	3.000	ACCELERATION		YUKE @ 60F	17500. PSI	
Y FACTOR	4500.000	VERTICAL	3.000 G.	BOLT @ 60F	25000. PSI @ TEMP	25000. PSI
FLANGE O.D.	5.250 IN.	HORIZONTAL	3.000 G.	NUT @ 60F	20000. PSI	
I.D.	0.940 IN.	NUT SHR AREA/IN.	4.985 SQ. IN./IN.	EXTERNAL MOMENT	0.0 IN-LBS	
P.C.	3.750 IN.	ENGAGEMENT	0.440 IN.	FORCE	0.0 LBS.	
THICKNESS	0.811 IN.	DIAMETER	2.250 IN.	PRESSURE FO.	750.000 PSIG	
BOLT SIZE	0.750 IN.	HANDWHEEL DIST.	0.0 IN.	TEMPERATURE	550. DEG. F.	
QUANTITY	4.000					
VALVE BODY ID.	1.000 IN.					
HAND WHEEL NO.	000					


OUTPUT DATA

WM1	6106. LBS.	WM2	5445. LBS.	MINIMUM WALL THICKNESS	0.250 IN.
MO1	5713. IN.-LBS	MO2	15409. IN.-LBS		
NORMAL FLANGE		ALLOWABLE		TOTAL FLANGE	
STRESSES	SH 3703. PSI	STRESSES	26250. PSI	STRESSES	SHT 7355. PSI
OPERATING	ST 3939. PSI		17500. PSI		SHT 6280. PSI
	SR 5908. PSI		17500. PSI		SPT 9420. PSI
	SHR AVG 4836. PSI		17500. PSI		SHT AVG 8388. PSI
	SHT AVG 3821. PSI		17500. PSI		SHTT AVG 6817. PSI
NORMAL FLANGE		ALLOWABLE		TOTAL FLANGE	
STRESSES	SH 9989. PSI	STRESSES	26250. PSI	STRESSES	SHT 13641. PSI
GASKET	ST 10624. PSI		17500. PSI		SHT 12965. PSI
	SR 15937. PSI		17500. PSI		SRT 19449. PSI
	SHR AVG 12963. PSI		17500. PSI		SHTT AVG 18545. PSI
	SHT AVG 10306. PSI		17500. PSI		SHTT AVG 13303. PSI
NORMAL BOLT		ALLOWABLE		TOTAL BOLT	
STRESS	SB 4674. PSI	STRESS	25000. PSI	STRESS	SRT 6687. PSI
					SYT 2107. PSI
					NUTT 682. PSI

ED101701-1-22-73

11053060

M348 B
52



MASONFILAN INTERNATIONAL
SEISMIC CALCULATIONS

WORK ORDER NO. H88368-003
SIZE 3.00 INCH TYPE 20761 RATING 600 LBS. ACTUATOR 15.0R DESIGN PRESSURE 750. PSIG
INPUT DATA


BODY GSKT O.D.	4.440	IN.	BONNET	ACTUATOR WGT.	140.000	LBS.	WIDTH DIM.	4.500	IN.
I.D.	3.750	IN.	C	ACTUATOR WGT.	165.000	LBS.	OUTSIDE DIM.	7.180	IN.
M FACTOR	3.000		ACTUATOR WGT.	15.000	PSI	INSIDE DIM.	5.750	IN.	
Y FACTOR	4500.000		DIAPHRAGM APFA	178.000	SQ. IN.	C.G. HEIGHT	19.000	IN.	
SEAT GSKT O.D.	3.620	IN.	C.G. HEIGHT	18.620	IN.	DESIGN STRESS INTENSITY			
I.D.	3.190	IN.	HUB O.D.	3.500	IN.	BONNET @ 60F	17500. PSI @ TEMP	17500. PSI	
M FACTOR	3.000		ACCELERATION			YOK @ 60F	17500. PSI		
Y FACTOR	4500.000		VERTICAL	3.000	G.	BOLT @ 60F	25000. PSI @ TEMP	25000. PSI	
FLANGE O.D.	7.750	IN.	HORIZONTAL	3.000	G.	NUT @ 60F	20000. PSI		
I.D.	1.750	IN.	NUT SHR AREA/IN.	4.985	SQ. IN./IN.	EXTERNAL MOMENT	0.0	IN.-LBS	
R.C.	6.000	IN.	ENGAGEMENT	0.440	IN.	FORCE	0.0	LBS.	
THICKNESS	1.281	IN.	DIAMETER	2.250	IN.	PRESSURE FD	750.000	PSIG	
BOLT SIZE	0.875	IN.	HANDWHEEL DIST.	0.0	IN.	TEMPERATURE	550.	DEG. F	
QUANTITY	8.000								
VALVE BODY ID.	3.000	IN.							
HAND WHEEL NO.	000								

OUTPUT DATA

WM1	19859.	LBS.	WM2	15161.	LBS.	MINIMUM WALL THICKNESS	0.313	IN.
MO1	24972.	IN.-LBS	MO2	52492.	IN.-LBS			
NORMAL FLANGE			ALLOWABLE			TOTAL FLANGE		
STRESSES SH	4302.	PSI	STRESSES	26250.	PSI	STRESSES SHT	7558.	PSI
OPERATING ST	4062.	PSI		17500.	PSI	SFT	6430.	PSI
SR	6779.	PSI		17500.	PSI	SFT	10731.	PSI
SHR AVG	5541.	PSI		17500.	PSI	SHRT AVG	9145.	PSI
SHT AVG	4182.	PSI		17500.	PSI	SHTT AVG	6994.	PSI
NORMAL FLANGE			ALLOWABLE			TOTAL FLANGE		
STRESSES SH	9044.	PSI	STRESSES	26250.	PSI	STRESSES SHT	12300.	PSI
GASKET ST	8539.	PSI		17500.	PSI	SFT	10907.	PSI
SR	14250.	PSI		17500.	PSI	SFT	18202.	PSI
SHR AVG	11647.	PSI		17500.	PSI	SHRT AVG	15251.	PSI
SHT AVG	8791.	PSI		17500.	PSI	SHTT AVG	11603.	PSI
NORMAL BOLT			ALLOWABLE			TOTAL BOLT		
STRESS SB	5454.	PSI	STRESS	25000.	PSI	STRESS SBT	7503.	PSI
						TOTAL YOK		
						STRESS SYT	2134.	PSI
						TOTAL NUT		
						STRESS NUTT	2217.	PSI

E0101701-1-22-73

M348 B
012



MASONIELAN INTERNATIONAL
SEISMIC CALCULATIONS

WCRK ORDER NO. F88068-001 TYPE 40311 RATING 600 LBS. ACTUATOR 18.5P DESIGN PRESSURE 750. PSIG
SIZE 4.00 INCH INPUT DATA

BODY GSKT O.D.	6.440	IN.	BONNET		ACTUATOR WGT.	260.000	LBS.
I.D.	5.650	IN.	E		WIDTH DIM.	4.500	IN.
M FACTOR	3.000		ACTUATOR WGT.	305.000	LBS.		
Y FACTOR	4500.000		PRESS.	13.000	PSI	OUTSIDE DIM.	7.870
SEAT GSKT O.D.	5.620	IN.	DIAPHRAGM AREA	276.000	SQ. IN.	INSIDE DIM.	6.120
I.D.	4.620	IN.	C.G. HEIGHT	17.380	IN.	C.G. HEIGHT	16.000
M FACTOR	3.000		HUB O.D.	3.000	IN.	DESIGN STRESS INTENSITY	
Y FACTOR	4500.000					BONNET @ 60F	17500. PSI @ TEMP 17500. PSI
FLANGE O.D.	9.620	IN.	ACCELERATION			YOKF @ 60F	17500. PSI
I.D.	1.250	IN.	VERTICAL	3.000	G.	BOLT @ 60F	25000. PSI @ TEMP 25000. PSI
B.C.	7.880	IN.	HORIZONTAL	3.000	G.	NUT @ 60F	20000. PSI
THICKNESS	1.593	IN.					
BOLT SIZE	0.875	IN.	NUT SHR AREA/IN.	7.302	SQ. IN./IN.	EXTERNAL MOMENT	0.0
QUANTITY	8.000		ENGAGEMENT	0.625	IN.	FORCE	0.0
VALVE BODY ID.	4.000	IN.	DIAMETER	3.312	IN.	PFSSURE PD	750.000
HAND WHEEL NO.	000		HANDWHEEL DIST.	0.0	IN.	TEMPERATURE	555. DEG. F

OUTPUT DATA

WMI	38392.	LBS.	W	64376.	LBS	WM2	34574.	LBS.	MINIMUM WALL THICKNESS	0.375	IN.		
MOI	61715.	IN.-LBS	MC2	59065.	IN.-LBS								
NORMAL FLANGE STRESSES	SH	5777.	PSI	ALLOWABLE STRESSES	26250.	PSI	TOTAL FLANGE STRESSES	SHT	13183.	PSI	ALLOWABLE STRESSES	52500.	PSI
OPERATING	ST	8208.	PSI		17500.	PSI		STT	12056.	PSI		52500.	PSI
	SR	8420.	PSI		17500.	PSI		SRT	12367.	PSI		52500.	PSI
	SHR AVG	7098.	PSI		17500.	PSI		SHRT AVG	12775.	PSI		52500.	PSI
	SHT AVG	6993.	PSI		17500.	PSI		SHTT AVG	12620.	PSI		52500.	PSI
NORMAL FLANGE STRESSES	SH	5529.	PSI	ALLOWABLE STRESSES	26250.	PSI	TOTAL FLANGE STRESSES	SHT	12935.	PSI	ALLOWABLE STRESSES	52500.	PSI
GASKET	ST	7856.	PSI		17500.	PSI		STT	11704.	PSI		52500.	PSI
	SR	8058.	PSI		17500.	PSI		SRT	12005.	PSI		52500.	PSI
	SHR AVG	6794.	PSI		17500.	PSI		SHRT AVG	12470.	PSI		52500.	PSI
	SHT AVG	6692.	PSI		17500.	PSI		SHTT AVG	12320.	PSI		52500.	PSI
NORMAL BOLT STRESS	SB	10622.	PSI	ALLOWABLE STRESS	25000.	PSI	TOTAL BOLT STRESS	SBT	13364.	PSI	ALLOWABLE STRESS	75000.	PSI
							TOTAL YOKF STRESS	SYT	2671.	PSI	ALLOWABLE STRESS	17500.	PSI
							TOTAL NUT STRESS	NUTT	1376.	PSI	ALLOWABLE STRESS	20000.	PSI

E0101701-1-22-73

11053062

M348 B
dia