



Bentley K. Jones  
Director, Organizational Effectiveness  
Harris Nuclear Plant  
5413 Shearon Harris Rd  
New Hill, NC 27562-9300

919.362.2305

FEB 19 2018  
Serial: HNP-18-021

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1  
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Technical Specification 6.9.1.2, Duke Energy Progress, LLC, is providing the following information regarding reactor coolant specific activity for 2017.

During 2017, specific activity of the HNP reactor coolant did not exceed 1 microCurie per gram dose equivalent I-131 or 100/E-bar microCuries per gram of gross radioactivity as set forth in Technical Specification 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to Jeff Robertson, Manager – Regulatory Affairs, at (919) 362-3137.

Sincerely,

A handwritten signature in black ink, appearing to read "Bentley K. Jones", written over a white background.

Bentley K. Jones

cc: J. Zeiler, NRC Sr. Resident Inspector, HNP  
M. Barillas, NRC Project Manager, HNP  
NRC Regional Administrator, Region II



**Bentley K. Jones**  
Director, Organizational Effectiveness  
Harris Nuclear Plant  
5413 Shearon Harris Rd  
New Hill, NC 27562-9300

919.362.2305

Serial: HNP-18-021

ATTN: Document Control Desk  
U.S. Nuclear Regulatory Commission  
Washington, DC 20555-0001

Shearon Harris Nuclear Power Plant, Unit 1  
Docket No. 50-400/Renewed License No. NPF-63

Subject: Annual Report in Accordance with Technical Specification 6.9.1.2

Ladies and Gentlemen:

In accordance with Shearon Harris Nuclear Power Plant, Unit 1 (HNP), Technical Specification 6.9.1.2, Duke Energy Progress, LLC, is providing the following information regarding reactor coolant specific activity for 2017.

During 2017, specific activity of the HNP reactor coolant did not exceed 1 microCurie per gram dose equivalent I-131 or 100/E-bar microCuries per gram of gross radioactivity as set forth in Technical Specification 3.4.8.

This submittal contains no regulatory commitments. Please refer any questions regarding this submittal to Jeff Robertson, Manager – Regulatory Affairs, at (919) 362-3137.

Sincerely,

Bentley K. Jones

cc: J. Zeiler, NRC Sr. Resident Inspector, HNP  
M. Barillas, NRC Project Manager, HNP  
NRC Regional Administrator, Region II